



OCT 2 7 2009

Patricia Hill Thomas Stanislaus County Honor Farm 1010 10<sup>th</sup> Street, Ste 6800 Modesto, CA 95354-0862

Notice of Final Action - Authority to Construct RE:

Project Number: N-1093316

Dear Ms. Thomas:

The Air Pollution Control Officer has issued Authority to Construct permits to Stanislaus County Honor Farm for a 755 hp Cummins Model QSX15-G9 diesel-fired emergency standby IC engine powering an electric generator, at 8224 W. Grayson Road in Modesto. CA.

Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on September 15, 2009. The District's analysis of the proposal was also sent to CARB on September 10, 2009. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill at (209) 557-6400.

Sincerely,

David Warner

Director of Permit Services

DW:KC/ry

**Enclosures** 

Seyed Sadredin

. Executive Director/Air Pollution Control Officer

Northern Ragion 4800 Enterprise Way Modesto, CA 95356-8718 Tel: (209) 557-6400 FAX: (209) 557-6475 Tel: (559) 230-6000 FAX: (559) 230-6061

Central Region (Main Office) 1990 E. Gettysburg Avenue Fresno, CA 93726-0244 Southern Region 34946 Flyover Court Bakersfield, CA 93308-9725 Tel: 661-392-5500 FAX: 661-392-5585





OCT 2 7 2009

Mike Tollstrup, Chief Project Assessment Branch Stationary Source Division California Air Resources Board PO Box 2815 Sacramento, CA 95812-2815

RE: Notice of Final Action - Authority to Construct

Project Number: N-1093316

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued Authority to Construct permits to Stanislaus County Honor Farm for a 755 hp Cummins Model QSX15-G9 diesel-fired emergency standby IC engine powering an electric generator, at 8224 W. Grayson Road in Modesto, CA.

Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on September 15, 2009. The District's analysis of the proposal was also sent to CARB on September 10, 2009. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill at (209) 557-6400.

Sincerely,

**David Warner** 

**Director of Permit Services** 

DW:KC/ry

**Enclosures** 

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Modesto Bee Modesto Bee

# NOTICE OF FINAL ACTION FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT PERMITS

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to Stanislaus County Honor Farm for a 755 hp Cummins Model QSX15-G9 diesel-fired emergency standby IC engine powering an electric generator, at 8224 W. Grayson Road in Modesto, CA.

No comments were received following the District's preliminary decision on this project.

The application review for Project #N-1093316 is available for public inspection at <a href="http://www.valleyair.org/notices/public notices idx.htm">http://www.valleyair.org/notices/public notices idx.htm</a> and the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.





## **AUTHORITY TO CONSTRUCT**

**PERMIT NO: N-36-2-0** 

**ISSUANCE DATE: 10/22/2009** 

**LEGAL OWNER OR OPERATOR: STANISLAUS COUNTY HONOR FARM** 

**MAILING ADDRESS:** 

250 E HACKETT RD MODESTO, CA 95358

LOCATION:

8224 W GRAYSON RD MODESTO, CA 95358

#### **EQUIPMENT DESCRIPTION:**

755 HP CUMMINS MODEL QSX15-G9 DIESEL FIRED EMERGENCY STANDBY I.C. ENGINE POWERING AN **ELECTRIC GENERATOR.** 

### **CONDITIONS**

- No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] 3.
- Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115]
- The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
- This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201]
- This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115]
- This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 4102 and 4702 and 17 CCR 93115]

#### CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a FERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

DAVID WARNER, Director of Permit Services

- 9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
- 10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]
- 11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
- 12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
- Emissions from this IC engine shall not exceed any of the following limits: 4.35 g-NOx/bhp-hr, 0.54 g-CO/bhp-hr, or 0.06 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115]
- 14. Emissions from this IC engine shall not exceed 0.05 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115]
- 15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115]
- 16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115]