

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
DETERMINATION OF COMPLIANCE**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of determination of compliance (DOC) to Northern California Power Agency for a 294 MW (nominal), natural gas-fired, combined-cycle, electric generation facility that will consist of a Siemens natural gas-fired STG6-5000F "Flex Plant™ 30" combustion turbine generator equipped with dry-low NOx combustors rated at a combined heat input rate of 2,142 MMBtu/hr, unfired heat recovery steam generator, a steam turbine generator, a seven-cell mechanical draft cooling tower system equipped with high efficiency drift eliminators, and a natural gas-fired 36.5 MMBtu/hr auxiliary boiler for Siemens "Flex Plant™ 30" fast start-up technology, at 12745 North Thornton Road, Lodi, California.

The analysis of the regulatory basis for this proposed action, Project #N-1083490, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and the District office at the address below. Written comments on this project must be submitted within 30 days of the publication date of this notice to **DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356-8718.**