



**NOV 23 2009**

Mike Tollstrup, Chief  
Project Assessment Branch  
Air Resources Board  
P O Box 2815  
Sacramento, CA 95812-2815

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # S-1119  
Project # S-1074335**

Dear Mr. Tollstrup:

The District has issued the Final Renewed Title V Permit for Double C Limited. The preliminary decision for this project was made on September 18, 2009. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner  
Director of Permit Services

Attachments

cc: Juscelino Siongco, Permit Services Engineer

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT



NOV 23 2009

Gerardo C. Rios, Chief  
Permits Office (AIR-3)  
U.S. EPA - Region IX  
75 Hawthorne St.  
San Francisco, CA 94105

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # S-1119  
Project # S-1074335**

Dear Mr. Rios:

The District has issued the Final Renewed Title V Permit for Double C Limited. The preliminary decision for this project was made on September 18, 2009. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. We appreciate your concurrence with this action. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

Attachments

cc: Juscelino Siongco, Permit Services Engineer

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT



**NOV 23 2009**

Raymond Rodriguez  
Double C Limited  
34759 Lencioni Avenue  
Bakersfield, CA 93308

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # S-1119  
Project # S-1074335**

Dear Mr. Rodriguez:

The District has issued the Final Renewed Title V Permit for Double C Limited. The preliminary decision for this project was made on September 18, 2009. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner  
Director of Permit Services

Attachments

cc: Juscelino Siongco, Permit Services Engineer

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

Bakersfield Californian

**SAN JOAQUIN VALLEY  
AIR POLLUTION CONTROL DISTRICT  
NOTICE OF FINAL DECISION TO ISSUE  
RENEWED FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue the renewed Federally Mandated Operating Permit to Double C Limited for its oil and natural gas production facility, 10245 Oilfield Road, Bakersfield, California.

The District's analysis of the legal and factual basis for this proposed action, project #S-1074335, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and the District office at the address below. For additional information regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900, or contact David Warner, Director of Permit Services, in writing at SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.

**SAN JOAQUIN VALLEY  
AIR POLLUTION CONTROL DISTRICT**

**Final Title V Permit Renewal Evaluation  
Double C Limited  
S-1119**

**TABLE OF CONTENTS**

---

I.	PROPOSAL.....	2
II.	FACILITY LOCATION .....	2
III.	EQUIPMENT LISTING .....	3
IV.	GENERAL PERMIT TEMPLATE USAGE .....	3
V.	SCOPE OF EPA AND PUBLIC REVIEW .....	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS .....	4
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE.....	6
VIII.	PERMIT REQUIREMENTS .....	6
IX.	PERMIT SHIELD.....	11
X.	PERMIT CONDITIONS .....	12
XI.	ATTACHMENTS.....	12
A.	RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY LIST	
D.	PUBLIC COMMENTS/DISTRICT RESPONSE	

**TITLE V PERMIT RENEWAL EVALUATION**  
**Oil and Natural Gas Production**

**Engineer:** Juscelino Siongco  
**Date:** August 20, 2009

**Facility Number:** S-1119  
**Facility Name:** Double C Limited  
**Mailing Address:** 34759 Lencioni Avenue  
Bakersfield, CA 93308

**Contact Name:** Raymond Rodriguez  
**Phone:** (661) 393-6885

**Responsible Official:** Daniel Consie  
**Title:** Plant Manager

**Project # :** S-1074335  
**Deemed Complete:** October 10, 2007

---

**I. PROPOSAL**

Double C Limited was issued a Title V permit on July 15, 1998. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the initial Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

**II. FACILITY LOCATION**

Double C Limited is located at 10245 Oilfield Road, Bakersfield, CA.

### III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

### IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit Template:

#### A. Template SJV-UM-0-2 Facility Wide Umbrella

The applicant has requested to utilize template No. SJV-UM-0-2, Facility Wide Umbrella. Based on the information submitted in the Template Qualification Form, the applicant qualifies for the use of this template.

Template SJV-UM-0-2 conditions have been added as conditions 1 through 40 for the renewed facility wide requirements (S-1119-0-3) and replace conditions 1 through 40 of the existing facility wide requirements (S-1119-0-2).

### V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the proposed Renewed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the proposed permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's proposed actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate from model general permit templates and are not subject to further EPA or public review.

- Conditions 1 through 40 of the facility-wide requirements, S-1119-0-3.

## VI. FEDERALLY ENFORCEABLE REQUIREMENTS

### A. Rules Updated

- District Rule 2020, Exemptions  
(amended July 21, 1994 ⇒ amended March 21, 2002)<sup>1</sup>
- District Rule 2201, New and Modified Stationary Source Review Rule  
(amended December 19, 2002)
- District Rule 8011, General Requirements  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8031, Bulk Materials  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8041, Carryout and Trackout  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8051, Open Areas  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas  
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- 40 CFR 60, Subpart GG - Standards for Performance of Stationary Gas Turbines  
(amended February 24, 2006)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos  
(amended September 18, 2003)

---

<sup>1</sup>Requirements of this Rule are addressed by Facility wide Umbrella Template SJV-UM-0-2



- 40 CFR Part 82, Subpart B, Stratospheric Ozone (amended November 9, 2007)
- 40 CFR Part 82, Subpart F, Stratospheric Ozone (amended June 8, 2008)

#### **B. Rules Added**

- 40 CFR 60 Subpart KKKK - Standards of Performance for Stationary Combustion Turbines

#### **C. Rules Not Updated**

- District Rule 1080, Source Sampling (amended December 16, 1993)
- District Rule 1081, Stack Monitoring (amended December 17, 1992)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)<sup>1</sup>
- District Rule 1160, Emission Statements (adopted November 18, 1992)<sup>1</sup>
- District Rule 2010, Permits Required (amended December 17, 1992)<sup>1</sup>
- District Rule 2031, Transfer of Permits (amended December 17, 1992)<sup>1</sup>
- District Rule 2040, Applications (amended December 17, 1992)<sup>1</sup>
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)<sup>1</sup>
- District Rule 2080, Conditional Approval (amended December 17, 1992)<sup>1</sup>
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)<sup>2</sup>
- District Rule 4101, Visible Emissions (amended November 15, 2001)<sup>1</sup>
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)

---

<sup>2</sup> Facility wide Umbrella Template SJV-UM-0-2 addresses requirements of Sections 5.2, 9.1.1, 9.4, 9.5, 9.7, 9.8, 9.9, 9.13.1, 9.13.2, 9.16, and 10.0.

- District Rule 4601, Architectural Coatings  
(amended December 17, 1992 ⇒ amended October 31, 2001)<sup>1</sup>
- District Rule 4663, Organic Solvent Cleaning, Storage, and Disposal  
(adopted December 20, 2001)
- District Rule 4703, Stationary Gas Turbines  
(amended April 25, 2002)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 68 - Chemical Accident Prevention Provisions

## VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit."

For this facility, the following are not federally enforceable and will not be discussed in further detail:

District Rule 4102, Nuisance (as amended December 17, 1992)

- Condition 42 of the facility-wide requirements, S-1119-0-3 is based on District Rule 4102.
- Conditions 36 and 38 of permit units S-1119-1-12 and S-1119-2-12 are based on District Rule 4102.

## VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit.

### A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which are specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any affect on current permit requirements and will therefore not be addressed in this evaluation.

**B. District Rule 2201 - New and Modified Stationary Source Review Rule**

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

**C. District Rule 4663, Organic Solvent Cleaning, Storage, and Disposal**

This rule was amended in September 20, 2007 to lower the solvent's VOC content limits. This amended version of the rule has not been approved for inclusion in the Air Quality State Implementation Plans (SIPs).

The amended version of Rule 4663 is more stringent than the SIP approved District Rule 4663 (December 20, 2001). Therefore, conditions 43 through 46 of the facility-wide requirement, S-1119-0-3, assure compliance with the SIP approved District Rule 4663.

**D. District Rule 8011 - General Requirements**

The purpose of Regulation VIII (Fugitive PM10 Prohibitions) is to reduce ambient concentrations of fine particulate matter (PM10) by requiring actions to prevent, reduce or mitigate anthropogenic fugitive dust emissions. The Rules contained in this Regulation have been developed pursuant to United States Environmental Protection Agency guidance for Serious PM10 Nonattainment Areas. The rules are applicable to specified anthropogenic fugitive dust sources. Fugitive dust

contains PM10 and particles larger than PM10. Controlling fugitive dust emissions when visible emissions are detected will not prevent all PM10 emissions, but will substantially reduce PM10 emissions.

The provisions of this rule are applicable to specified outdoor fugitive dust sources. The definitions, exemptions, requirements, administrative requirements, recordkeeping requirements, and test methods set forth in this rule are applicable to all Rules under Regulation VIII (Fugitive PM10 Prohibitions) of the Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District.

Conditions 29 through 34 of permit unit S-1119-0-3 ensure compliance.

**E. District Rule 8021 - Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities**

The purpose of this rule is to limit fugitive dust emissions from construction, demolition, excavation, extraction, and other earthmoving activities.

This rule applies to any construction, demolition, excavation, extraction, and other earthmoving activities, including, but not limited to, land clearing, grubbing, scraping, travel on site, and travel on access roads to and from the site. This rule also applies to the construction of new landfill disposal sites or modification to existing landfill disposal sites prior to commencement of landfilling activities.

Section 5.0 requires that no person shall perform any construction, demolition, excavation, extraction, or other earthmoving activities unless the appropriate requirements in sections 5.1 and 5.2 are sufficiently implemented to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 29 of permit unit S-1119-0-3 ensures compliance.

**F. District Rule 8031 - Bulk Materials**

The purpose of this rule is to limit fugitive dust emissions from the outdoor handling, storage, and transport of bulk materials.

This rule applies to the outdoor handling, storage, and transport of any bulk material.

Section 5.0 requires that no person shall perform any outdoor handling, storage, and transport of bulk materials unless the appropriate requirements in Table 8031-1 of this rule are sufficiently implemented to limit VDE to 20% opacity or to

comply with the conditions for a stabilized surface as defined in Rule 8011. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 30 of permit unit S-1119-0-3 ensures compliance.

#### **G. District Rule 8041 - Carryout and Trackout**

The purpose of this rule is to limit fugitive dust emissions from carryout and trackout.

This rule applies to all sites that are subject to Rules 8021 (Construction, Demolition, Excavation, Extraction, and other Earthmoving Activities), 8031 (Bulk Materials), and 8071 (Unpaved Vehicle and Equipment Traffic Areas) where carryout or trackout has occurred or may occur.

Section 5.0 requires that an owner/operator shall sufficiently prevent or cleanup carryout and trackout as specified in sections 5.1 through 5.8. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII. The use of blower devices, or dry rotary brushes or brooms, for removal of carryout and trackout on public roads is expressly prohibited. The removal of carryout and trackout from paved public roads does not exempt an owner/operator from obtaining state or local agency permits which may be required for the cleanup of mud and dirt on paved public roads.

Condition 31 of permit unit S-1119-0-3 ensures compliance.

#### **H. District Rule 8051 - Open Areas**

The purpose of this rule is to limit fugitive dust emissions from open areas.

This rule applies to any open area having 3.0 acres or more of disturbed surface area, that has remained undeveloped, unoccupied, unused, or vacant for more than seven days.

Section 5.0 requires that whenever open areas are disturbed or vehicles are used in open areas, the owner/operator shall implement one or a combination of control measures indicated in Table 8051-1 to comply with the conditions of a stabilized surface at all times and to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 32 of permit unit S-1119-0-3 ensures compliance.

**I. District Rule 8061 - Paved and Unpaved Roads**

The purpose of this rule is to limit fugitive dust emissions from paved and unpaved roads by implementing control measures and design criteria.

This rule applies to any new or existing public or private paved or unpaved road, road construction project, or road modification project.

Condition 33 of permit unit S-1119-0-3 ensures compliance.

**J. District Rule 8071 - Unpaved Vehicle/Equipment Traffic Area**

The purpose of this rule is to limit fugitive dust emissions from unpaved vehicle and equipment traffic areas by implementing control measures and design criteria.

This rule applies to any unpaved vehicle/equipment traffic area of 1.0 acre or larger.

Condition 34 of permit unit S-1119-0-3 ensures compliance.

**K. 40 CFR 60 Subpart GG**

The provisions of this subpart are applicable to all stationary gas turbines with a heat input at peak load equal to or greater than 10 million Btu per hour. Section 60.334 and 60.335 of this Subpart was amended February 24, 2006. The amended provisions, 40 CFR 60.334(c), (e), and (f) clarify the monitoring methods are options rather than requirements for turbines that do not use water or steam to control NO<sub>x</sub> emissions. In addition, the introductory text of 46 CFR 60.334(j), 60.334(j)(1)(iv), and 40 CFR 60.335(b)(8) were also revised to reflect the amended provisions of 40 CFR 60.334(c), (e), and (f).

Since the gas turbine permit units S-1119-1-12 and S-1119-2-12 use steam injection to control NO<sub>x</sub> emissions, the options of the amended provisions are not applicable.

**L. 40 CFR 60 Subpart KKKK**

The EPA promulgated this new NSPS that would apply to new stationary combustion turbines greater than or equal to 1 MW that commence construction, modification or reconstruction after February 18, 2005. The gas turbine permit units S-1119-1-12 and S-1119-2-12 were initially constructed before February 18, 2005 and not been modified or reconstructed since. Therefore requirements of this NSPS are not applicable.

**M. 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos**

These regulations apply to demolition or renovation activity, as defined in 40 CFR 61.141. 40 CFR Section 61.150 of this Subpart was amended September 18, 2003, and condition 35 of S-1119-0-3 assures compliance with the requirements.

**N. 40 CFR Part 82, Subparts B and F, Stratospheric Ozone**

These regulations apply to servicing motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC). Sections of this regulation were amended in 2004 and 2008, and conditions 27 and 28 of S-1119-0-3 assure compliance with the requirements.

**O. 40 CFR Part 64-CAM**

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

1. S-1119-1-12 and S-1119-2-12 – 25 MW General Electric LM-2500 Natural Gas-Fired Turbine Engine Cogeneration System

These two permit units had been previously determined to be subject to CAM for NO<sub>x</sub> and CO under Project #S-1020862, the first renewal of its Title V permit. However, units that have continuous emission monitors (CEMS) for the pollutants for which it is considered a Major Source are exempt from CAM requirements. These permit units are equipped with CEMs for NO<sub>x</sub>, and CO. Therefore these permit unit are exempt from CAM and all references to 40 CFR Part 64 have been removed from the permits.

**IX. PERMIT SHIELD**

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

**A. Requirements Addressed by Model General Permit Templates**

1. Model General Permit Template SJV-UM-0-2

By submitting Model General Permit Template SJV-UM-0-2 qualification form, the applicant has requested that a permit shield be granted for all the applicable requirements identified by the template. Therefore, the permit shields as granted in Model General Permit Template are included as conditions 39 and 40 of the facility-wide requirements (S-1119-0-3).

**X. PERMIT CONDITIONS**

See Attachment A – Renewed Title V Operating Permit.

**XI. ATTACHMENTS**

- A. Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List
- D. Public Comment/District Response



---

# ATTACHMENT A

Renewed Title V Operating Permit

---



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT



# Permit to Operate

**FACILITY:** S-1119

**EXPIRATION DATE:** 02/28/2013

**LEGAL OWNER OR OPERATOR:**  
**MAILING ADDRESS:**

DOUBLE C LIMITED  
34759 LENCIONI AVE, SUITE A  
BAKERSFIELD, CA 93308

**FACILITY LOCATION:**

HEAVY OIL CENTRAL  
KERN FRONT, CA

**FACILITY DESCRIPTION:**

OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

**Seyed Sadredin**  
Executive Director / APCO

**David Warner**  
Director of Permit Services

# San Joaquin Valley Air Pollution Control District

FACILITY: S-1119-0-3

EXPIRATION DATE: 02/28/2013

## FACILITY-WIDE REQUIREMENTS

---

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Kern County Rule 111] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: DOUBLE C LIMITED  
Location: HEAVY OIL CENTRAL, KERN FRONT, CA  
S-1119-0-3: Nov 13 2009 1:22PM - SIONGCOJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following outdated SIP requirement: Kern County Rule 111. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071- (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within 8 hours after detection of a breakdown in monitoring equipment and 24 hours prior to a planned shut down of monitoring equipment. [District Rule 2520, 9.6.2; Rule 1080, 9.0 and 10.0; and 40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. An owner or operator shall not use organic solvents for cleaning operations that exceed the VOC content limits specified as follows: A) Product cleaning during manufacturing process or surface preparation for adhesive application; 1) general, 25 g/l (0.21 lb/gal) and 2) electrical apparatus components and electronic components, 100 g/l (0.84 lb/gal); B) repair and maintenance cleaning, 1) 25 g/l (0.21 lb/gal) and 2) electrical apparatus components and electronic components 100 g/l (0.84 lb/gal); C) cleaning of coating or adhesive application equipment, 25 g/l (0.21 lb/gal). [District Rule 4663] Federally Enforceable Through Title V Permit
44. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall be performed by one or more of the following methods: 1) wipe cleaning; 2) application of solvent from hand-held spray bottles from which solvents are dispensed without a propellant-induced force; 3) non-atomized solvent flow method in which the cleaning solvent is collected in a container or a collection system which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container, or; 4) solvent flushing method in which the cleaning solvent is discharged into a container that is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the open air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 4663] Federally Enforceable Through Title V Permit
45. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall not atomize the solvent into the open air unless it is vented to a VOC emission control system. This provision shall not apply to the cleaning of nozzle tips of automated spray equipment systems, except for robotic systems, and cleaning with spray bottles or containers described elsewhere in this permit. [District Rule 4663] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

46. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall not use VOC-containing materials to clean spray equipment used for the application of coatings, adhesives, or ink, unless an enclosed system or equipment that is proven to be equally effective at controlling emissions is used for cleaning. If an enclosed system is used, it must totally enclose spray guns, cups, nozzles, bowls, and other parts during washing, rinsing and draining procedures, and it must be used according to the manufacturer's recommendations and must be closed when not in use. [District Rule 4663] Federally Enforceable Through Title V Permit
47. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts and thinners shall be stored in closed, non-absorbent and non-leaking containers. [District Rule 4663] Federally Enforceable Through Title V Permit
48. In lieu of complying with the requirements in District Rule 4663, Section 5.1, an owner or operator may comply with this rule by using a VOC emission collection and control system in association with the solvent cleaning operation as provided in District Rule 4663, Sections 5.5.4 and 5.5.5 and either Section 5.5.2 or Section 5.5.3, as applicable (amended September 20, 2007). [District Rule 4663] Federally Enforceable Through Title V Permit
49. An owner or operator shall maintain the records required by District Rule 4663, Sections 6.2.2 through 6.2.6 (amended September 20, 2007) at the stationary source for a period of five years. The records shall be made available to the APCO upon request. [District Rules 1070 and 4663] Federally Enforceable Through Title V Permit
50. The VOC content of solvents and organic materials shall be determined by using United States Environmental Protection Agency (EPA) Test Method 24 or 24A, or South Coast Air Quality Management District (SCAQMD) Method 304 (Determination of Volatile Organic compounds in Various Materials), or by using the manufacturer's product formulation data and the formula for "Grams of VOC per liter of Material" in Section 3.0. [District Rule 4663] Federally Enforceable Through Title V Permit
51. The content of exempt halogenated VOCs shall be determined by using the California Air Resources Board (ARB) Test Method 432 or SCAQMD Test Method 303 (Determination of Exempt Compounds). [District Rule 4663] Federally Enforceable Through Title V Permit
52. The facility shall comply with all applicable requirements regarding preparation and implementation of a Risk Management Plan and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR Part 68] Federally Enforceable Through Title V Permit
53. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1119-1-12

**EXPIRATION DATE:** 02/28/2013

**SECTION:** 11 **TOWNSHIP:** 28S **RANGE:** 27E

**EQUIPMENT DESCRIPTION:**

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE  
COGENERATION SYSTEM WITH STEAM INJECTION

## PERMIT UNIT REQUIREMENTS

---

1. Turbine washing operation shall take place only when the turbine is off-line. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60, Subpart A] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District NSR Rule, 4703, 40 CFR 60.334(a)] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a),(b); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h)] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NOx and CO concentrations and daily emission rates. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR 60.334(b)2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.



12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District NSR Rule] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District NSR Rule, 4201, 4703; 40 CFR 60.332(a) and 333(b)(2)] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rules 1080; 40 CFR 60.7(c)] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 (Oxy USA) and S-1342-7 (Stockdale Oil & Gas). [District NSR Rule] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District NSR Rule and 4703; 40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District NSR Rule, 1081 and 4703] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Nitrogen oxides (NO<sub>x</sub>) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O<sub>2</sub>) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081, 2520, 9.3.2, and 4703; 40 CFR 60.335(b), (c)] Federally Enforceable Through Title V Permit
25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NO<sub>x</sub>, CO, and O<sub>2</sub>. The continuous NO<sub>x</sub> monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District NSR Rule, 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080 and 4703] Federally Enforceable Through Title V Permit
28. Except for NO<sub>x</sub> and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NO<sub>x</sub> and CO shall be averaged over a three hour period. [District Rule 4703] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080, and 4703; 40 CFR 60.332(a), (b)] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District NSR Rule] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NO<sub>x</sub> and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District NSR Rule, 2520, 9.4.2 and 4703] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended September 20, 2007); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District NSR Rule] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District NSR Rule] Federally Enforceable Through Title V Permit
36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District NSR Rule] Federally Enforceable Through Title V Permit
38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District NSR Rule] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NOx concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation [District NSR Rule and 4703; 40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NOx and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District NSR Rule, 2520, 9.3.2 and 9.4.2] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a), (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.13(e)(2)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1119-2-12

**EXPIRATION DATE:** 02/28/2013

**SECTION:** 11 **TOWNSHIP:** 28S **RANGE:** 27E

**EQUIPMENT DESCRIPTION:**

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE  
COGENERATION SYSTEM WITH STEAM INJECTION

## PERMIT UNIT REQUIREMENTS

---

1. Turbine washing operation shall take place only when the turbine is off-line. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60, Subpart A] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District NSR Rule and 4703, 6.2.1; 40 CFR 60.334(a)] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a),(b); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h)] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NOx and CO concentrations and daily emission rates. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR 60.334(b)2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District NSR Rule] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District NSR Rule and 4201; 4703; 40 CFR 60.332(a) and 333(b)(2)] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rules 1080; 40 CFR 60.7(c)] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 (Oxy USA) and S-1342-7 (Stockdale Oil & Gas). [District NSR Rule] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District NSR Rule and 4703; 40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District NSR Rule, 1081, and 4703] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit
24. Nitrogen oxides (NOx) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O2) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081 and 4703; 40 CFR 60.335(b), (c)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NO<sub>x</sub>, CO, and O<sub>2</sub>. The continuous NO<sub>x</sub> monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District NSR Rule, 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080 and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080 and 4703] Federally Enforceable Through Title V Permit
28. Except for NO<sub>x</sub> and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NO<sub>x</sub> and CO shall be averaged over a three hour period. [District Rule 4703] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080 and 4703; 40 CFR 60.332(a), (b)] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District NSR Rule] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NO<sub>x</sub> and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District NSR Rule, 2520, 9.4.2 and 4703] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended September 20, 2007); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District NSR Rule] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District NSR Rule] Federally Enforceable Through Title V Permit
36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]
37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District NSR Rule] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NO<sub>x</sub> concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation [District NSR Rule and 4703; 40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NO<sub>x</sub> and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District NSR Rule, 2520, 9.3.2 and 9.4.2] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a), (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NO<sub>x</sub> emissions in ppmv (corrected to 15% O<sub>2</sub>) and O<sub>2</sub> concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.13(e)(2)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

---

# ATTACHMENT B

Previous Title V Operating Permit

---





**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT

# Permit to Operate

**FACILITY:** S-1119 **EXPIRATION DATE:** 02/29/2008

**LEGAL OWNER OR OPERATOR:** DOUBLE C LIMITED  
**MAILING ADDRESS:** 34759 LENCIONI AVE, SUITE A  
BAKERSFIELD, CA 93308

**FACILITY LOCATION:** HEAVY OIL CENTRAL  
KERN FRONT, CA

**FACILITY DESCRIPTION:** OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

**Seyed Sadredin**  
Executive Director / APCO

**David Warner**  
Director of Permit Services

# San Joaquin Valley Air Pollution Control District

FACILITY: S-1119-0-2

EXPIRATION DATE: 02/29/2008

## FACILITY-WIDE REQUIREMENTS

---

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0 and Kern County Rule 111] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (3/21/02). [District Rules 2010, 3.0 and 4.0; 2020 and Kern County Rule 201] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: DOUBLE C LIMITED  
Location: HEAVY OIL CENTRAL, KERN FRONT, CA  
S-1119-0-2 - Aug 20 2008 11:31AM - SIGNED

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and Kern County Rules 401] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (10/31/01) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials for architectural coatings subject to Rule 4601 (10/31/01) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (10/31/01). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (11/15/01) or Rule 8011 (11/15/01). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following outdated SIP requirements: Kern County Rule 401, Kern County Rule 111, Kern County Rules 201, 202, 203, 204, 208, and 209, Kern County Rule 410.1, and Kern County Rule 423. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (11/15/01); 4601, sections 5.1, 5.2, 5.3, 5.8 and 8.0 (10/31/01); 8021 (11/15/01); 8031 (11/15/01); 8041 (11/15/01); 8051 (11/15/01); 8061 (11/15/01); and 8071 (11/15/01). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within 8 hours after detection of a breakdown in monitoring equipment and 24 hours prior to a planned shut down of monitoring equipment. [District Rule 2520, 9.6.2; Rule 1080, 9.0 and 10.0; Kern County Rule 108; 40 CFR 60.334(c) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. An owner or operator shall not use organic solvents for cleaning operations that exceed the VOC content limits specified as follows: A) Product cleaning during manufacturing process or surface preparation for adhesive application; 1) general, 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components, 500 g/l (4.2 lb/gal); B) repair and maintenance cleaning, 1) 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components 900 g/l (7.5 lb/gal); C) cleaning of coating or adhesive application equipment, 550 g/l (4.6 lb/gal) [District Rule 4663, 5.1.2] Federally Enforceable Through Title V Permit
44. Cleaning activities that use solvents with a VOC content greater than 50 g/l (0.42 lb/gallon) shall be performed by one or more of the following methods: 1) wipe cleaning; 2) application of solvent from hand-held spray bottles from which solvents are dispensed without a propellant-induced force; 3) non-atomized solvent flow method in which the cleaning solvent is collected in a container or a collection system which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container, or; 4) solvent flushing method in which the cleaning solvent is discharged into a container that is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the open air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 4663, 5.2.1] Federally Enforceable Through Title V Permit
45. Solvent shall not be atomized into the open air unless it is vented to a VOC emission control system. This provision shall not apply to the cleaning of nozzle tips of automated spray equipment systems, except for robotic systems, and cleaning with spray bottles or containers described elsewhere in this permit. [District Rule 4663, 5.2.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

46. An owner or operator shall not use VOC-containing materials to clean spray equipment used for the application of coatings, adhesives, or ink, unless an enclosed system or equipment that is proven to be equally effective at controlling emissions is used for cleaning. If an enclosed system is used, it must totally enclose spray guns, cups, nozzles, bowls, and other parts during washing, rinsing and draining procedures, and it must be used according to the manufacturer's recommendations and must be closed when not in use. [District Rule 4663, 5.2.3] Federally Enforceable Through Title V Permit
47. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts and thinners shall be stored in closed, non-absorbent and non-leaking containers. [District Rule 4663, 5.3] Federally Enforceable Through Title V Permit
48. In lieu of complying with the requirements in Sections 5.1.2, an owner or operator may comply with this rule by using a VOC emission collection and control system in association with the solvent cleaning operation as provided in District Rule 4663, 5.4.1 and 5.4.2 (Adopted December 30, 2001). [District Rule 4663, 5.4] Federally Enforceable Through Title V Permit
49. An owner or operator shall maintain the records required by District Rule 4663, Sections 6.2.2 through 6.2.5 (Adopted December 20, 2001) at the stationary source for a period of five years. The records shall be made available to the APCO upon request. [District Rules 1070 and 4663, 6.2.1] Federally Enforceable Through Title V Permit
50. The VOC content of solvents and organic materials shall be determined by using United States Environmental Protection Agency (EPA) Test Method 24 or 24A, or South Coast Air Quality Management District (SCAQMD) Method 304 (Determination of Volatile Organic compounds in Various Materials), or by using the manufacturer's product formulation data and the formula for "Grams of VOC per liter of Material" in Section 3.0. [District Rule 4663, 6.3.1.1] Federally Enforceable Through Title V Permit
51. The content of exempt halogenated VOCs shall be determined by using the California Air Resources Board (ARB) Test Method 432 or SCAQMD Test Method 303 (Determination of Exempt Compounds). [District Rule 4663, 6.3.1.2] Federally Enforceable Through Title V Permit
52. The facility shall comply with all applicable requirements regarding preparation and implementation of a Risk Management Plan and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR Part 68] Federally Enforceable Through Title V Permit
53. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1119-1-11

**EXPIRATION DATE:** 02/29/2008

**SECTION:** 11 **TOWNSHIP:** 28S **RANGE:** 27E

**EQUIPMENT DESCRIPTION:**

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE  
COGENERATION SYSTEM WITH STEAM INJECTION

## PERMIT UNIT REQUIREMENTS

---

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703, 5.1] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District Rules 2201 and 4703, 5.2] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR Part 60, Subpart A and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District Rules 2201 and 4703, 6.2.1; 40 CFR 60.334(a) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2; 4801; 40 CFR 60.332(a) and 60.333(a) & (b); CFR 60.332(a); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NOx and CO concentrations and daily emission rates. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703, 3.19, 3.25, 5.1.2 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR Part 60.334(b)2] Federally Enforceable Through Title V Permit
12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District Rules 2201 and 4201; 4703, 5.1, 5.2; 40 CFR Part 60.332(a) and 333(b)2, and 40CFR Part 64] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rules 1080, 8.0; 2520, 9.6.1; Rule Kern County Rule 108; 40 CFR 60.7(c) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 (Oxy USA) and S-1342-7 (Stockdale Oil & Gas). [District Rule 2201] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.1 and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.2, and 40CFR Part 64] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201; Kern County Rule 404] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District Rules 2201 and 1081; 4703, 6.2.1 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081, 7.0; 4703, 6.3 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.



24. Nitrogen oxides (NOx) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O2) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081; 2520, 9.3; 4703, 5.1, 5.2 & 6.4 and 40 CFR Subpart GG, 60.335(b), (c)] Federally Enforceable Through Title V Permit
25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NOx, CO, and O2. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rules 2201 and 1080; 4703, 6.2.1, 6.2.3; Kern County Rule 108 and 40 CFR Part 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080; 4703, 6.2.3; 40 CFR Part 60 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080, 7.2; 4703, 6.2.3; Kern County Rule 108 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. Except for NOx and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NOx and CO shall be averaged over a three hour period. [District Rule 4703, 5.0, 6.2.3 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080; 4703, 6.2.6, 7.3; Kern County Rule 108; 40 CFR 60.332(a), (b); and 40 CFR Part 64] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NOx and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rules 2201 and 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended April 25, 2002); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c), and 40 CFR Part 64. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District Rule 2201] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]
37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NOx concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation [District Rules 2201 and 4703, 5.1, 5.2 & 6.3; 40 CFR 60.332(a) & (b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NOx and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District Rules 2201 and 2520, 9.3.2 and 9.4.2 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2; 4801; 40 CFR 60.332(a) and 60.333(a) & (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.486 paragraphs b, c and d and 40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1119-2-11

**EXPIRATION DATE:** 02/29/2008

**SECTION:** 11 **TOWNSHIP:** 28S **RANGE:** 27E

**EQUIPMENT DESCRIPTION:**

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE  
COGENERATION SYSTEM WITH STEAM INJECTION

## PERMIT UNIT REQUIREMENTS

---

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703, 5.1] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District Rules 2201 and 4703, 5.2] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR Part 60, Subpart A and 40 CFR Part 64] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District Rules 2201 and 4703, 6.2.1; 40 CFR 60.334(a) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2; 4801; 40 CFR 60.332(a) and 60.333(a) & (b); CFR 60.332(a); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NOx and CO concentrations and daily emission rates. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703, 3.19, 3.25, 5.1.2 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR Part 60.334(b)2] Federally Enforceable Through Title V Permit
12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District Rules 2201 and 4201; 4703, 5.1, 5.2; 40 CFR Part 60.332(a) and 333(b)2, and 40CFR Part 64] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rules 1080, 8.0; 2520, 9.6.1; Rule Kern County Rule 108; 40 CFR 60.7(c) and 40 CFR Part 64] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 (Oxy USA) and S-1342-7 (Stockdale Oil & Gas). [District Rule 2201] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.1 and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.2, and 40CFR Part 64] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201; Kern County Rule 404] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District Rules 2201 and 1081; 4703, 6.2.1 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081, 7.0; 4703, 6.3 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Nitrogen oxides (NO<sub>x</sub>) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O<sub>2</sub>) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081; 2520, 9.3; 4703, 5.1, 5.2 & 6.4 and 40 CFR Subpart GG, 60.335(b), (c)] Federally Enforceable Through Title V Permit
25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NO<sub>x</sub>, CO, and O<sub>2</sub>. The continuous NO<sub>x</sub> monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rules 2201 and 1080; 4703, 6.2.1, 6.2.3; Kern County Rule 108 and 40 CFR Part 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080; 4703, 6.2.3; 40 CFR Part 60 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080, 7.2; 4703, 6.2.3; Kern County Rule 108 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
28. Except for NO<sub>x</sub> and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NO<sub>x</sub> and CO shall be averaged over a three hour period. [District Rule 4703, 5.0, 6.2.3 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080; 4703, 6.2.6, 7.3; Kern County Rule 108; 40 CFR 60.332(a), (b); and 40 CFR Part 64] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NO<sub>x</sub> and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rules 2201 and 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended April 25, 2002); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c), and 40 CFR Part 64. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District Rule 2201] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]
37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District Rule 2201 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NOx concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation [District Rules 2201 and 4703, 5.1, 5.2 & 6.3; 40 CFR 60.332(a) & (b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NOx and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District Rules 2201 and 2520, 9.3.2 and 9.4.2 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2; 4801; 40 CFR 60.332(a) and 60.333(a) & (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.486 paragraphs b, c and d and 40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

---

# ATTACHMENT C

Detailed Facility List

---

**Detailed Facility Report**

For Facility=1119 and excluding Deleted Permits  
Sorted by Facility Name and Permit Number

DOUBLE C LIMITED  
HEAVY OIL CENTRAL  
KERN FRONT, CA

FAC # S 1119  
STATUS A  
TELEPHONE (805) 393-6885

TYPE TitleV  
TOXIC ID 50073

EXP. ON 02/28/2013  
AREA 5/  
INSP DATE 12/10

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	TOTAL	FEE PERMIT	STATUS	EQUIPMENT DESCRIPTION
S-1119-1-12	25 MW electrical generation	3020-08A F	1	8,171.00	8,171.00	A	A	NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE COGENERATION SYSTEM WITH STEAM INJECTION
S-1119-2-12	25 MW electrical generation	3020-08A F	1	8,171.00	8,171.00	A	A	NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE COGENERATION SYSTEM WITH STEAM INJECTION

Number of Facilities Reported: 1



---

# ATTACHMENT D

Public Comment/District Response

---

# **PUBLIC COMMENT/DISTRICT RESPONSE**

Double C Limited submitted public comments regarding the District's analysis and preliminary decision of their Title V Permit Renewal. A copy of the October 1, 2009 letter containing these comments is available at the District.

## **PUBLIC COMMENT**

Request that Facility-Wide Permit, Condition 41 be revised as follows: "Facility shall notify the APCO of a violation of any emission standard indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within ~~8 hours after detection of a breakdown in monitoring equipment and~~ 24 hours prior to a planned shutdown of monitoring equipment."

Reason: Facility-Wide Requirements, Condition 1, already states the following requirements: "The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but not later than one hour after its detection,..."

## **DISTRICT RESPONSE**

Any change to the condition must be approved through the Compliance management. Therefore no change to this condition are approved at this time.

## **PUBLIC COMMENT**

Request that Permit S-1119-1-12, Condition 43 be revised as follows: "Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of RATA testing. ~~the audits.~~ Audit reports shall be submitted along with quarterly compliance reports to the District"

Reason: The notification requirement is overly restrictive since the monitor audits are already required to be submitted with quarterly compliance reports and RATA testing notifications are already required.

## **DISTRICT RESPONSE**

Condition 43 requirements were determined during New Source Review (NSR) and will not be addressed during the Title V Renewal evaluation. The facility may submit an Authority to Construct application to address the requested change to the permit condition.