

## **NOTICE OF FINAL DETERMINATION OF COMPLIANCE**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District has issued a Final Determination of Compliance (FDOC) to Northern California Power Agency (Lodi Energy Center) for a 294 MW (nominal), natural gas-fired, combined-cycle, electric generation facility that will consist of a Siemens natural gas-fired STG6-500F "Flex Plant 30" combustion turbine generator equipped with dry-low NOx combustors, an unfired heat recovery steam generator, a steam turbine generator, a seven-cell mechanical draft cooling tower system equipped with high efficiency drift eliminators, and a natural gas-fired auxiliary boiler, all located at 12745 North Thornton Road in Lodi, CA.

All comments received following the District's preliminary decision on this project were considered. Changes were made to the determination of compliance evaluation in direct response to comments received from the oversight agencies, the applicant, and other interested parties. The changes made were minor and did not significantly increase permitted emission levels or trigger additional public notification requirements.

The application review for project N-1083490 is available for public inspection at the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4320 ENTERPRISE WAY, MODESTO, CA 95356-0244.**