

Modesto Bee

NOTICE OF FINAL DETERMINATION OF COMPLIANCE

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has issued a Final Determination of Compliance (FDOC) to Turlock Irrigation District for the installation of three identical 54.2 MW (each), nominal ISO rating, natural gas-fired, simple-cycle, peaking electric generation facility that will consist of General Electric's (GE) natural gas-fired aero-derivative LM6000 PG SPRINT combustion turbines equipped with GE's state-of-the-art single annular combustors rated at 523.2 MMBtu/hr (at ISO MW rating), located at 4500 Crows Landing Road, Modesto, California..

All comments received following the District's preliminary decision on this project were considered. Changes were made to the determination of compliance evaluation in direct response to comments received from the applicant. The changes made were minor and did not significantly increase permitted emission levels or trigger additional public notification requirements.

The application review for Project #N-1091384 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356-8718.**