



NOV 02 2010

Tim Hensleit
CCRC
451 E Almond Ave, Ste 103
Madera, CA 93637-5562

**RE: Notice of Final Action - Authority to Construct
Project Number: C-1102967**

Dear Mr. Hensleit:

The Air Pollution Control Officer has issued Authority to Construct permits to CCRC for installation of a 97.5 bhp natural gas-fired emergency standby internal combustion (IC) engine using LPG/Propane as a supplemental fuel powering an electrical generator, at 7121 N Whitney, Fresno.


Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary public notification and public notification of hazardous air emissions associated with the project as mandated by section §42301.6 of the California Health and Safety Code was completed on October 1, 2010. No comments were received following the Air District's noticing for this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Arnaud Marjollet at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

DW:JAH

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



HEALTHY AIR LIVING™

NOV 02 2010

Mike Tollstrup, Chief
Project Assessment Branch
Stationary Source Division
California Air Resources Board
PO Box 2815
Sacramento, CA 95812-2815

**RE: Notice of Final Action - Authority to Construct
Project Number: C-1102967**

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued Authority to Construct permits to CCRC for installation of a 97.5 bhp natural gas-fired emergency standby internal combustion (IC) engine using LPG/Propane as a supplemental fuel powering an electrical generator, at 7121 N Whitney, Fresno.

Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on October 1, 2010. The District's analysis of the proposal was also sent to CARB on September 28, 2010. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Arnaud Marjollet at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

DW:JAH

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Fresno Bee

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF AUTHORITY
TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to CCRC for installation of a 97.5 bhp natural gas-fired emergency standby internal combustion (IC) engine using LPG/Propane as a supplemental fuel powering an electrical generator, at 7121 N Whitney, Fresno.

No comments were received following the District's preliminary decision on this project.

The application review for Project #C-1102967 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726 .**



AUTHORITY TO CONSTRUCT

PERMIT NO: C-7991-2-0

ISSUANCE DATE: 11/01/2010

LEGAL OWNER OR OPERATOR: CCRC
MAILING ADDRESS: 451 E ALMOND AVE, STE 103
MADERA, CA 93637-5562

LOCATION: 7121 N WHITNEY
FRESNO, CA 93720

EQUIPMENT DESCRIPTION:
97.5 BHP FORD MODEL WSG-1068 RICH-BURN NATURAL GAS/LPG-FIRED EMERGENCY STANDBY IC ENGINE
POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. This Authority to Construct (ATC) cancels and supersedes (replaces) ATC C-7991-1-0. [District Rule 2201]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]
6. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]
8. Emissions from this IC engine shall not exceed any of the following limits: 6.1 g-NOx/bhp-hr, 0.175 g-PM10/bhp-hr, 74.6 g-CO/bhp-hr, or 1.2 g-VOC/bhp-hr. [District Rule 2201]
9. This IC engine shall be fired on Public Utility Commission (PUC) regulated natural gas with LPG/Propane as a supplemental fuel only. [District Rules 2201 and 4801]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

for 
DAVID WARNER, Director of Permit Services

C-7991-2-0, Nov 1 2010 8:43AM - HARTJ : Joint Inspection NOT Required

10. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201]
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
13. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
14. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702]
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702]
16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702]