



NOV 03 2010

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St.
San Francisco, CA 94105

**Re: Notice of Preliminary Decision – Title V Permit Renewal
District Facility # C-0014
Project # C-1053309**

Dear Mr. Rios:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Fresno Cogeneration Partners for its Cogeneration Plant located at 8105B S Lassen Avenue in San Joaquin, CA, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 45-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Attachments

C: Renald Harris, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



NOV 03 2010

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

**Re: Notice of Preliminary Decision - Title V Permit Renewal
District Facility # C-0014
Project # C-1053309**

Dear Mr. Tollstrup:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Fresno Cogeneration Partners for its Cogeneration Plant located at 8105B S Lassen Avenue in San Joaquin, CA, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Attachments
C: Renald Harris, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



NOV 03 2010

Jon Kimble
Fresno Cogeneration Partners
8105B S Lassen Avenue
Fresno, CA 93660

**Re: Notice of Preliminary Decision - Title V Permit Renewal
District Facility # C-0014
Project # C-1053309**


Dear Mr. Kimble:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Fresno Cogeneration Partners for its Cogeneration Plant located at 8105B S Lassen Avenue in San Joaquin, CA, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. Please submit your written comments on this project within the 30-day comment period which begins on the date of publication of the public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Attachments

C: Renald Harris, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Fresno Bee

**NOTICE OF PRELIMINARY DECISION
FOR THE PROPOSED RENEWAL OF
THE FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed renewal of the Federally Mandated Operating Permit to Fresno Cogeneration Partners for its cogeneration plant 8105B Lassen Avenue in San Joaquin, California.

The District's analysis of the legal and factual basis for this proposed action, project #C-1053309, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. There are no emission changes associated with this proposed action. This will be the public's only opportunity to comment on the specific conditions of the proposed renewal of the Federally Mandated Operating permit. If requested by the public, the District will hold a public hearing regarding issuance of this renewed permit. For additional information, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900. Written comments on the proposed renewed permit must be submitted within 30 days of the publication date of this notice to DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CALIFORNIA 93726-0244.

SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT

Proposed Title V Permit Renewal Evaluation Fresno Cogeneration Partners C-0014

TABLE OF CONTENTS

I.	PROPOSAL	2
II.	FACILITY LOCATION	2
III.	EQUIPMENT LISTING	3
IV.	GENERAL PERMIT TEMPLATE USAGE	3
V.	SCOPE OF EPA AND PUBLIC REVIEW.....	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS	3
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE.....	6
VIII.	PERMIT REQUIREMENTS	6
IX.	PERMIT SHIELD.....	42
X.	PERMIT CONDITIONS.....	42
XI.	ATTACHMENTS.....	42
A.	DRAFT RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY LIST	
D.	RULE 4601-ARCHITECTURAL COATINGS, VOC LIMIT TABLES	

TITLE V PERMIT RENEWAL EVALUATION

Cogeneration Operation

Engineer: Renald Harris
Date: September 1, 2010

Facility Number: C-0014
Facility Name: Fresno Cogeneration Partners
Mailing Address: 8105B S. Lassen Avenue
San Joaquin, CA 93660

Contact Name: Jon C. Kimble
Phone: (559)693-2494

Responsible Official: Jon C. Kimble
Title: Plant Manager

Project # : C-1053309
Deemed Complete: August 9, 2005

I. PROPOSAL

Fresno Cogeneration Partners was issued a Title V permit on December 20, 2000. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the initial Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Fresno Cogeneration Partners is located at 8105B S. Lassen Avenue, San Joaquin, CA.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment A.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant does not propose to use any model general permit templates.

V. SCOPE OF EPA AND PUBLIC REVIEW

The applicant is not requesting any model general permit templates. Therefore, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

Rules Updated

- District Rule 2020, Exemptions
(amended September 21, 1998 ⇒ amended December 20, 2007)
- District Rule 2201, New and Modified Stationary Source Review Rule
(amended December 18, 2008)
- District Rule 2520, Federally Mandated Operating Permits
(adopted June 15, 1995 ⇒ amended June 21, 2001)
- District Rule 4101, Visible Emissions
(amended December 17, 1992 ⇒ amended February 17, 2005)
- District Rule 4601, Architectural Coatings
(amended October 31, 2001 ⇒ amended December 17, 2009)
- District Rule 4703, Stationary Gas Turbines
(amended October 16, 1997 ⇒ amended September 20, 2007)
- 40 CFR Part 60, Subpart GG, New Source Performance Standards; Standard of Performance for Stationary Gas Turbines
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos

Rules Removed

- District Rule 4701, Internal Combustion Engines – Phase 1

As of June 1, 2006 District Rule 4701 is no longer applicable to diesel-fired emergency standby or emergency IC engines. Therefore, this diesel-fired emergency IC engine will comply with the requirements of District Rule 4702 and no further discussion is required.

- District Rule 8020, 8030, and 8060, Fugitive Dust (PM₁₀) Emissions (amended April 25, 1996)

These rules were removed on November 15, 2001 and were replaced with District Rules 8021, 8031, and 8061.

Rules Added

- District Rule 4702, Internal Combustion Engines – Phase 2 (adopted August 21, 2003)
- District Rule 8011, General Requirements (amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities (amended August 19, 2004)
- District Rule 8031, Bulk Materials (amended August 19, 2004)
- District Rule 8041, Carryout and Trackout (amended August 19, 2004)
- District Rule 8051, Open Areas (amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads (amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas (amended September 16, 2004)
- 40 CFR 60 Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
- 40 CFR 60 Subpart KKKK - Standards of Performance for Stationary Combustion Turbines

- 40 CFR 63 Subpart ZZZZ - National Emission Standard for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
- 40CFR Part 64, Compliance Assurance Monitoring (CAM)

Rules Not Updated

- District Rule 1070, Inspections (amended December 17, 1992)
- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4202, Particulate Matter - Emission Rate (amended December 17, 1992)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 82, Subpart F, Stratospheric Ozone

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

1) Rules Added

There are no new rules that are not federally enforceable being added at this time.

Rules Not Updated

- District Rule 4102, Nuisance (as amended December 17, 1992)

For this facility, condition #39 of the facility wide requirements C-14-0-2 is based on District Rule 4102 listed above and is not Federally Enforceable through Title V.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review the updated changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been updated amended or added and additional requirements placed on the permit per EPA request since the issuance of the initial Title V permit.

Dormant Emission Units:

Permit units C-14-1-14 and C-14-12-3 are currently out of operation and are designated as dormant emission units by District Permit conditions. Conditions # 1 through 4 for both permit units C-14-1-14 and C-14-12-3 have been added to these permit units, that these permit units can not be operated unless facility submits an application to comply with Title V requirements of District Rule 2520. Therefore these permit units will not be evaluated further in this permitting action.

1) District Rule 2020 - Exemptions

District Rule 2020 lists equipment which is specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any affect on current permit requirements and will therefore not be addressed in this evaluation. Condition 4 of permit unit -0-2 ensures compliance.

Table 1. Comparison of District Rule 2020 (9/17/98) to Rule 2020 (9/21/06)

REQUIREMENTS	District Rule 2020 (9/17/98)	District Rule 2020 (9/21/06)
An ATC or PTO is not required for listed exempt equipment.	X	X
Conditions are stated under which listed exempt equipment will require an ATC or PTO.	X	X
Record keeping is required to verify and maintain exemption, when the exemption is based on a maximum daily limitation.	X	X
A compliance schedule is stated for equipment which loses exemption from permitting, necessitating submission of a PTO application.	X	X

District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.

- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

- a. C-14-2-6: HAMMERMILL OPERATION, INCLUDING TWO 200-HP HAMMERMILLS WITH TWO FANS AND PRE-KNOCKOUT CYCLONES AND ONE BAGHOUSE
- The requirements of conditions 2 through 16 from the current PTO have been included as conditions 1 through 15 of the requirements for this permit unit.
- b. C-14-4-3: 136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A FIRE WATER PUMP
- The requirements of conditions 3 and 5 from the current PTO have been included as conditions 3 and 5 of the requirements for this permit unit.
- c. C-14-5-3: 534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
- The requirements of conditions 3 and 6 from the current PTO have been included as conditions 3 and 6 of the requirements for this permit unit.
- d. C-14-10-6: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS
- The requirements of conditions 3 through 12, 14, 15, 21, 22, 28, 40, and 43 from the current PTO have been included as conditions 3 through 12, 14, 15, 21, 22, 28, 40, and 43 of the requirements for this permit unit.

e. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

- The requirements of conditions 1, 7, 9 through 18, 20, 26 and 29 from the current PTO have been included as conditions 1, 7, 9 through 18, 20, 26 and 29 of the requirements for this permit unit.

District Rule 2520 - Federally Mandated Operating Permits

This rule was recently amended to incorporate several administrative corrections, clarify rule language, and add procedures for implementing compliance schedules. The only amendments to this rule that will have an effect on current permit requirements are the corrections to Section 9 rule references, as described in the following table:

Old Rule Section	Corrected Rule Section
9.3	9.2
9.4	9.3
9.5	9.4
9.6	9.5
9.7	9.6
9.8	9.7
9.9	9.8
9.10	9.9
9.11	9.10
9.12	9.11
9.13	9.12
9.14	9.13
9.15	9.14
9.16	9.15
9.17	9.16
9.18	9.17
9.19	9.18

Rule 2520, Section 6.4.4, "Other Changes Not Requiring Title V Permit Amendment," allowed the permittee to implement changes, including the addition of new emissions units, without triggering the permit modification or amendment requirements until the time of Title V permit renewal, provided the conditions described in Sections 6.4.4.1 through 6.4.4.2 were met.

b. C-14-4-3: 136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A FIRE WATER PUMP

- No changes were required to the permit for Rule 2520.

c. C-14-5-3: 534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

- No changes were required to the permit for Rule 2520.

d. C-14-10-6: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

- No changes were required to the permit for Rule 2520.

e. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

- No changes were required to the permit for Rule 2520.

District Rule 4101 - Visible Emissions

District Rule 4101 has been submitted to the EPA to replace SIP approved Rule 401 (all counties of the SJVUAPCD). EPA made a preliminary determination that District Rule 4101 is "more stringent" than the county versions previously referenced, per correspondence dated August 20, 1996.

Section 5.0 prohibits the discharge of any air contaminant for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker in shade as that designated as No. 1 on the Ringelmann Chart; or is of such opacity as to obscure an observer's view to a degree equal to or greater than the smoke described in Section 5.1 of Rule 4101. Condition 22 of permit unit -0-2 ensures compliance.

District Rule 4601 - Architectural Coatings

This rule limits the emissions of VOCs from architectural coatings. It requires limiting the application of any architectural coating to no more than what is listed in the Table of Standards (Section 5.0). The following analysis shows that the proposed requirement of the current District Rule 4601 is more stringent than SIP approved version of District Rule 4601. Streamlining procedures, as documented in the following steps is utilized to substitute the proposed set of requirements for the otherwise applicable requirements.

The following table has side-by-side comparison of applicable requirements:

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
2.0 Applicability	This rule is applicable to any person who supplies, sells, offers for sale, applies, or solicits the application of any architectural coating, or who manufactures any architectural coating for use within the District.	This rule is applicable to any person who supplies, sells, offers for sale, applies, or solicits the application of any architectural coating, or who manufactures, blends or repackages any architectural coating for use within the District.	No change in the applicability, therefore, non-SIP version of rule is as stringent as SIP version.
4.0 Exemptions	<p>The provisions of this rule shall not apply to:</p> <p>4.1 Any architectural coating that is sold or manufactured for use outside of the District or for shipment to other manufacturers for reformulation or repackaging.</p> <p>4.2 Any architectural coating that is sold in a containers with a volume of one liter (1.057 quarts) or less.</p> <p>4.3 Any aerosol coating product.</p>	<p>4.1 The provisions of this rule shall not apply to:</p> <p>4.1.1 Any architectural coating that is supplied, sold, offered for sale, or manufactured for use outside of the District or for shipment to other manufacturers for reformulation or repackaging.</p> <p>4.1.2 Any aerosol coating product.</p> <p>4.2 With the exception of Section 6.2, the provisions of this rule shall not apply to any architectural coating that is sold in a container with a volume of one liter (1.057 quarts) or less.</p>	The only change is to require reporting requirements as discussed in Section 6.2 of the non-SIP approved version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.
5.0 Requirements	Note: Section 5.0 requirements refer to Table of Standards, Table of Standards 1, and Table of Standards 2. These tables are included as Attachment D.		
	<p>5.1 VOC Content Limits: Except as provided in Sections 5.2, 5.3, 5.8 and 8.0, no person shall;</p> <p>5.1.1 manufacture, blend, or repackage for sale within the District;</p> <p>5.1.2 supply, sell, or offer for sale within the district;</p> <p>5.1.3 solicit for application or apply</p>	<p>5.1 VOC Content Limits: Except as provided in Sections 5.2 and 5.3, no person shall: manufacture, blend, or repackage for use within the District; or supply, sell, or offer for sale within the District; or solicit for application or apply within the District any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards</p>	Sections 5.8 and 8.0 of the SIP version are not included in the non-SIP version. As discussed in corresponding sections the non-SIP version is more stringent. The Table of Standards and Table of Standards 1

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>within the District any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards, after the specified effective date in the Table of Standards.</p>	<p>1 or the Table of Standards 2, after the specified effective date in the Table of Standards 1 or the Table of Standards 2. Limits are expressed as VOC Regulatory, thinned to the manufacturer's maximum thinning recommendation, excluding any colorant added to tint bases.</p>	<p>have the same VOC limits. Table of Standard 2 is more stringent as discussed below. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.</p>
	<p>5.2 Most Restrictive VOC Limit: If anywhere on the container of any architectural coating, or any label or sticker affixed to the container, or in any sales, advertising, or technical literature supplied by a manufacturer or anyone acting on their behalf, any representation is made that indicates that the coating meets the definition of or is recommended for use for more than one of the coating categories listed in the Table of Standards, then the most restrictive VOC content limit shall apply. This provision does not apply to the following coating categories:</p> <ul style="list-style-type: none"> 5.2.1 Lacquer coatings (including lacquer sanding sealers) 5.2.2 Metallic pigmented coatings 5.2.3 Shellacs 5.2.4 Fire-retardant coatings 5.2.5 Pretreatment wash primers 5.2.6 Industrial maintenance coatings 5.2.7 Low-solids coatings 5.2.8 Wood preservatives 5.2.9 High temperature coatings 5.2.10 Temperature-indicator safety coatings 5.2.11 Antenna coatings 5.2.12 Antifouling coatings 5.2.13 Flow coatings 5.2.14 Bituminous roof primers 5.2.15 Specialty primers, sealers and undercoaters 	<p>5.2 Most Restrictive VOC Limit: If a coating meets the definition in Section 3.0 for one or more specialty coating categories listed in the Table of Standards 1 or the Table of Standards 2, then that coating is not required to meet the VOC limits for Flat, Nonflat, or Nonflat – High Gloss coatings, but is required to meet the VOC limit for the applicable specialty coating listed in the Table of Standards 1 or the Table of Standards 2.</p> <p>5.2.1 Effective until December 31, 2010, with the exception of the specialty coating categories specified in Section 5.2.3.1 through 5.2.3.15, if a coating is recommended for use in more than one of the specialty coating categories listed in the Table of Standards 1, the most restrictive (or lowest) VOC content limit shall apply.</p> <p>5.2.2 Effective on and after January 1, 2011, with the exception of the specialty coating categories specified in Sections 5.2.3.2, 5.2.3.3, 5.2.3.5 through 5.2.3.9, and 5.2.3.14 through 5.2.3.18, if a coating is recommended for use in more than one of the specialty coating categories listed in the Table of Standards 2, the most restrictive (or lowest) VOC content limit shall apply.</p> <p>5.2.3 This requirement applies to: usage recommendations that appear anywhere on the coating container, anywhere on any label or sticker affixed to the container, or in any sales, advertising, or technical literature supplied by a manufacturer or anyone acting on their behalf.</p> <ul style="list-style-type: none"> 5.2.3.1 Lacquer coatings (including lacquer sanding sealers) 5.2.3.2 Metallic pigmented coatings 5.2.3.3 Shellacs 5.2.3.4 Fire-retardant coatings 5.2.3.5 Pretreatment wash primers 5.2.3.6 Industrial maintenance coatings 5.2.3.7 Low-solids coatings 	<p>The VOC limit of the non-SIP version is at least as stringent as the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.</p>

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		5.2.3.8 Wood preservatives 5.2.3.9 High temperature coatings 5.2.3.10 Temperature-indicator safety coatings 5.2.3.11 Antenna coatings 5.2.3.12 Antifouling coatings 5.2.3.13 Flow coatings 5.2.3.14 Bituminous roof primers 5.2.3.15 Specialty primers, sealers and undercoaters 5.2.3.16 Aluminum roof coatings 5.2.3.17 Zinc-rich primers 5.2.3.18 Wood Coatings	
	<p>5.3 Sell-Through of Coatings:</p> <p>5.3.1 A coating manufactured prior to the January 1, 2003 or January 1, 2004 effective date specified for that coating in the Table of Standards may be sold, supplied, or offered for sale for up to three years after the specified effective date. In addition, a coating manufactured before the effective date specified for that coating in the Table of Standards may be applied at any time, both before and after the specified effective date, so long as the coating complied with the standards in effect at the time the coating was manufactured. This Section 5.3 does not apply to any coating that does not display the date or date-code required by Section 6.1.1.</p> <p>5.3.2 A coating included in an approved Averaging Program that does not comply with the specified limit in the Table of Standards may be sold, supplied, or offered for sale for up to three years after the end of the compliance period specified in the approved Averaging Program. In addition, such a coating may be applied at any time, both during and after the compliance period. This Section 5.3.2 does not apply to any coating that does not display on the container either the statement: "This product is subject to architectural coatings averaging provisions in California" or a substitute symbol specified by the Executive Officer of the California Air Resources Board (ARB). This Section 5.3.2 shall remain in effect until January 1, 2008.</p>	<p>5.3 Sell-Through of Coatings:</p> <p>A coating manufactured prior to the effective date specified for that coating in the Table of Standards 1 or the Table of Standards 2, and that complied with the standards in effect at the time the coating was manufactured, may be sold, supplied, or offered for sale for up to three years after the specified effective date. In addition, a coating manufactured before the effective date specified for that coating in the Table of Standards 1 or the Table of Standards 2 may be applied at any time, both before and after the specified effective date, so long as the coating complied with the standards in effect at the time the coating was manufactured. This Section 5.3 does not apply to any coating that does not display the date or date-code required by Section 6.1.1.</p>	<p>The VOC limit of the non-SIP version is at least as stringent as the SIP version. Section 5.3.2 was removed it is no longer applicable in the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.</p>
	<p>5.4 Painting Practices: All architectural coating containers used to apply the contents therein to a surface directly from the container by pouring, siphoning, brushing, rolling, padding, ragging or other means, shall be closed when not in use. These architectural coating containers include, but are not limited to,</p>	<p>5.4 Painting Practices: All architectural coating containers used to apply the contents therein to a surface directly from the container by pouring, siphoning, brushing, rolling, padding, ragging or other means, shall be closed when not in use. These architectural coating containers include, but are not</p>	<p>No change in the requirements, therefore, non-SIP version of rule is as stringent as SIP version.</p>

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	drums, buckets, cans, pails, trays or other application containers. Containers of any VOC containing materials used for thinning and cleanup shall also be closed when not in use.	limited to, drums, buckets, cans, pails, trays or other application containers. Containers of any VOC-containing materials used for thinning and cleanup shall also be closed when not in use.	
	5.5 Thinning: No person who applies or solicits the application of any architectural coating shall apply a coating that is thinned to exceed the applicable VOC limit specified in the Table of Standards.	5.5 Thinning: No person who applies or solicits the application of any architectural coating shall apply a coating that is thinned to exceed the applicable VOC limit specified in the Table of Standards 1 or the Table of Standards 2.	The VOC limit of the non-SIP version is at least as stringent as the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.
	5.6 Rust Preventative Coatings: Effective January 1, 2004, no person shall apply or solicit the application of any rust preventative coating for industrial use, unless such a rust preventative coating complies with the industrial maintenance coating VOC limit specified in the Table of Standards.	5.6 Rust Preventative Coatings: Effective through December 31, 2010, no person shall apply or solicit the application of any rust preventative coating for industrial use, unless such a rust preventative coating complies with the industrial maintenance coating VOC limit specified in the Table of Standards 1.	The VOC limit of the non-SIP version is at least as stringent as the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.
	5.7 Coatings Not Listed in the Table of Standards: For any coating that does not meet any of the definitions for the specialty coatings categories listed in the Table of Standards, the VOC content limit shall be determined by classifying the coating as a flat coating or a nonflat coating, based on its gloss, as defined in Sections 3.21, 3.36 and 3.37 and the corresponding flat or nonflat VOC limit shall apply.	5.7 Coatings Not Listed in the Table of Standards 1 or the Table of Standards 2: For any coating that does not meet any of the definitions for the specialty coatings categories listed in the Table of Standards 1 or the Table of Standards 2, the VOC content limit shall be determined by classifying the coating as a Flat, Nonflat, or Nonflat – High Gloss coating, based on its gloss, and the corresponding Flat, Nonflat, or Nonflat – High Gloss VOC limit in the Table of Standards 1 or the Table of Standards 2 shall apply.	The VOC limit of the non-SIP version is at least as stringent as the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.
	5.8 Lacquers: Notwithstanding the provisions of Section 3.1, a person or facility may add up to 10 percent by volume of VOC to a lacquer to avoid blushing of the finish during days with relative humidity greater than 70 percent and temperature below 65°F, at the time of application, provided that the coating contains acetone and no more than 550 grams of VOC per liter of coating, less water and exempt compounds, prior to the addition of VOC.	---	This section has been removed. The operation is required to meet the lacquer VOC limit regardless of temperature and humidity. Therefore, non-SIP version of rule is as stringent as SIP version
	5.9 Averaging Compliance Option: On or after January 1, 2003, in lieu of compliance with the specified limits in The Table of Standards for floor coatings; industrial maintenance coatings; primers, sealers, and undercoaters; quick-dry primers, sealers, and undercoaters; quick-dry enamels; roof coatings; bituminous roof coatings; rust preventative coatings; stains; waterproofing sealers, as well as flats and non-flats (excluding recycled coatings), manufacturers may average designated coatings such that their actual cumulative emissions from the averaged coatings are less than or equal to the cumulative	---	This section is removed from the non-SIP version, it is no longer applicable. Therefore, non-SIP version of rule is as stringent as SIP version.

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>emissions that would have been allowed under those limits over a compliance period not to exceed one year. Such manufacturers must also comply with the averaging provisions contained in Section 8.0, as well as maintain and make available for inspection records for at least three years after the end of the compliance period. This Section 5.9 and Section 8.0 shall cease to be effective on January 1, 2005, after which averaging will no longer be allowed.</p>		
	---	<p>5.8 Prior to January 1, 2011, any coating that meets a definition in Section 3.0 for a coating category listed in the Table of Standards 2 and complies with the applicable VOC limit in the Table of Standards 2 and with Sections 5.2 and 6.1 (including those provision of Section 6.1 otherwise effective on January 1, 2011) shall be considered in compliance with this rule.</p>	<p>Table of Standards 2 is more stringent than the VOC limits of Table of Standards in the SIP-Approved version. Therefore, non-SIP version of rule is as stringent as SIP version.</p>
	<p>Table of Standards (See Attachment D for Table)</p>	<p>Table of Standards 1 (Effective through 12/31/10) (See Attachment D for Table)</p>	<p>The non-SIP rule requirements are the same as the Table of Standards in the SIP approved rule, except Table of Standards 1 expires at which time Table of Standards 2 is in effect. As discussed below these standards are more stringent. Therefore, non-SIP version of rule is as stringent as SIP version.</p>
		<p>Table of Standards 2 (Effective on and after 1/1/11) (See Attachment D for Table)</p>	<p>The requirements of Table of Standards 2 are more stringent than the Table of Standards in the SIP rule. Therefore, non-SIP version of rule is as stringent as SIP version.</p>
<p>6.0 Administrative Requirements</p>	<p>6.1 Labeling Requirements: Each manufacturer of any architectural coating subject to this rule shall display the information listed in Sections 6.1.1 through 6.1.9 on the coating container (or label) in which the coating is sold or distributed.</p> <p>6.1.1 Date Code: The date the coating was manufactured, or a date code representing the date, shall be indicated on the label, lid or bottom of the container. If the manufacturer uses a date code for any coating, the manufacturer shall file an explanation of each code with the Executive Officer of the ARB.</p> <p>6.1.2 Thinning Recommendations: A statement of the manufacturer's recommendation regarding thinning of the coating shall be indicated on the</p>	<p>6.1 Labeling Requirements: Each manufacturer of any architectural coating subject to this rule shall display the information listed in Sections 6.1.1 through 6.1.14 on the coating container (or label) in which the coating is sold or distributed.</p> <p>6.1.1 Date Code: The date the coating was manufactured, or a date code representing the date, shall be indicated on the label, lid or bottom of the container. If the manufacturer uses a date code for any coating, the manufacturer shall file an explanation of each code with the Executive Officer of the ARB.</p> <p>6.1.2 Thinning Recommendations: A statement of the manufacturer's recommendation regarding thinning</p>	<p>The non-SIP approved rule contain sections listed in the SIP rule plus additional requirements not found in the SIP version. Therefore, non-SIP version of rule is as stringent as SIP version.</p>

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>label or lid of the container. This requirement does not apply to the thinning of architectural coatings with water. If thinning of the coating prior to use is not necessary, the recommendation must specify that the coating is to be applied without thinning.</p> <p>6.1.3 VOC Content: Each container of any coating subject to this rule shall display either the maximum or actual VOC content of the coating, as supplied, including the maximum thinning as recommended by the manufacturer. VOC content shall be displayed in grams of VOC per liter of coating. VOC content displayed shall be calculated using product formulation data, or shall be determined using the test methods in Section</p> <p>6.3.1. The equations in Sections 3.25 or 3.26, as appropriate, shall be used to calculate VOC content.</p> <p>6.1.4 Industrial Maintenance Coatings: In addition to the information specified in Sections 6.1.1, 6.1.2 and 6.1.3, each manufacturer of any industrial maintenance coating subject to this rule shall display on the label or lid of the container in which the coating is sold or distributed one or more of the following descriptions listed in Section 6.1.4.1 through 6.1.4.3.</p> <p>6.1.4.1 "For industrial use only"</p> <p>6.1.4.2 "For professional use only"</p> <p>6.1.4.3 "Not for residential use" or "Not intended for residential use"</p> <p>6.1.5 Clear Brushing Lacquers: Effective January 1, 2003, the labels of all clear brushing lacquers shall prominently display the statements "For brush application only," and "This product must not be thinned or sprayed."</p> <p>6.1.6 Rust Preventative Coatings: Effective January 1, 2003, the labels of all rust preventative coatings shall prominently display the statement "For Metal Substrates Only"</p> <p>6.1.7 Specialty Primers, Sealers and Undercoaters: Effective January 1, 2003, the labels of all specialty primers, sealers and undercoaters shall prominently display one or more of the descriptions listed in Section</p> <p>6.1.7.1 through 6.1.7.5.</p> <p>6.1.7.1 For blocking stains.</p> <p>6.1.7.2 For fire-damaged substrates.</p> <p>6.1.7.3 For smoke-damaged substrates.</p> <p>6.1.7.4 For water-damaged substrates.</p> <p>6.1.7.5 For excessively chalky substrates.</p> <p>6.1.8 Quick Dry Enamels: Effective January 1, 2003, the labels of all quick dry enamels shall prominently display the words "Quick Dry" and the dry hard time.</p>	<p>of the coating shall be indicated on the label or lid of the container. This requirement does not apply to the thinning of architectural coatings with water. If thinning of the coating prior to use is not necessary, the recommendation must specify that the coating is to be applied without thinning.</p> <p>6.1.3 VOC Content: Each container of any coating subject to this rule shall display one of the following values, in grams of VOC per liter of coating:</p> <p>6.1.3.1 Maximum VOC Content, as determined from all potential product formulations; or</p> <p>6.1.3.2 VOC Content, as determined from actual formulation data; or</p> <p>6.1.3.3 VOC Content, as determined using the test methods in Section 6.3.2.</p> <p>If the manufacturer does not recommend thinning, the container must display the VOC Content, as supplied. If the manufacturer recommends thinning, the container must display the VOC Content, including the maximum amount of thinning solvent recommended by the manufacturer. If the coating is a multicomponent product, the container must display the VOC content as mixed or catalyzed. If the coating contains silanes, siloxanes, or other ingredients that generate ethanol or other VOCs during the curing process, the VOC content must include the VOCs emitted during curing.</p> <p>6.1.4 Faux Finishing Coatings: Effective January 1, 2011, the labels of all clear topcoat Faux Finishing coatings shall prominently display the statement "This product can only be sold or used as part of a Faux Finishing coating system".</p> <p>6.1.5 Industrial Maintenance Coatings: Each manufacturer of any industrial maintenance coating subject to this rule shall display on the label or lid of the container in which the coating is sold or distributed one or more of the following descriptions listed in Section 6.1.5.1 through 6.1.5.3.</p> <p>6.1.5.1 "For industrial use only"</p> <p>6.1.5.2 "For professional use only"</p> <p>6.1.5.3 "Not for residential use" or "Not intended for residential use"</p> <p>6.1.6 Clear Brushing Lacquers: The labels of all clear brushing lacquers shall prominently display the statements</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>6.1.9 Non-flat – High Gloss Coatings: Effective January 1, 2003, the labels of all non-flat – high gloss coatings shall prominently display the words “High Gloss”.</p>	<p>“For brush application only,” and “This product must not be thinned or sprayed.” (Category deleted effective January 1, 2011.)</p> <p>6.1.7 Rust Preventative Coatings: The labels of all rust preventative coatings shall prominently display the statement “For Metal Substrates Only”.</p> <p>6.1.8 Specialty Primers, Sealers and Undercoaters: Effective until December 31, 2010, the labels of all specialty primers, sealers and undercoaters shall prominently display one or more of the descriptions listed in Section 6.1.8.1 through 6.1.8.5. Effective on and after January 1, 2011, the labels of all specialty primers, sealers, and undercoaters shall prominently display one or more of the descriptions listed in Sections 6.1.8.1 through 6.1.8.3. On and after January 1, 2011, Sections 6.1.8.4 and 6.1.8.5 will be no longer effective.</p> <p>6.1.8.1 For fire-damaged substrates.</p> <p>6.1.8.2 For smoke-damaged substrates.</p> <p>6.1.8.3 For water-damaged substrates.</p> <p>6.1.8.4 For excessively chalky substrates.</p> <p>6.1.8.5 For blocking stains.</p> <p>6.1.9 Quick Dry Enamels: The labels of all quick dry enamels shall prominently display the words “Quick Dry” and the dry hard time. (Category deleted effective January 1, 2011.)</p> <p>6.1.10 Reactive Penetrating Sealers: Effective January 1, 2011, the labels of all Reactive Penetrating Sealers shall prominently display the statement “Reactive Penetrating Sealer.”</p> <p>6.1.11 Stone Consolidants: Effective January 1, 2011, the labels of all Stone Consolidants shall prominently display the statement “Stone Consolidant - For Professional Use Only.”</p> <p>6.1.12 Nonflat– High Gloss Coatings: The labels of all Nonflat – high gloss coatings shall prominently display the words “High Gloss.”</p> <p>6.1.13 Wood Coatings: Effective January 1, 2011, the labels of all Wood Coatings shall prominently display the statement “For Wood Substrates Only.”</p> <p>6.1.14 Zinc Rich Primers: Effective January 1, 2011, the labels of all Zinc Rich Primers shall prominently</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		display one or more of the following descriptions listed in Section 6.1.14.1 through 6.1.14.3. 6.1.14.1 "For industrial use only" 6.1.14.2 "For professional use only" 6.1.14.3 "Not for residential use" or "Not intended for residential use"	
	<p>6.2 Reporting Requirements</p> <p>6.2.1 Clear Brushing Lacquers: Each manufacturer of clear brushing lacquers shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of clear brushing lacquers sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.2 Rust Preventative Coatings: Each manufacturer of rust preventative coatings shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of rust preventative coatings sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.3 Specialty Primers, Sealers and Undercoaters: Each manufacturer of specialty primers, sealers and undercoaters shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of specialty primers, sealers and undercoaters sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.4 Toxic Exempt Compounds: For each architectural coating that contains perchloroethylene or methylene chloride, the manufacturer shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB the following information for products sold in the State during the preceding year:</p> <p>6.2.4.1 the product brand name and a copy of the product label with legible usage instructions;</p> <p>6.2.4.2 the product category listed in the Table of Standards to which the coating belongs;</p> <p>6.2.4.3 the total sales in California</p>	<p>6.2 Reporting Requirements</p> <p>The reporting requirements specified in Sections 6.2.1 through 6.2.6 shall apply until December 31, 2010.</p> <p>6.2.1 Clear Brushing Lacquers: Each manufacturer of clear brushing lacquers shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of clear brushing lacquers sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.2 Rust Preventative Coatings: Each manufacturer of rust preventative coatings shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of rust preventative coatings sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.3 Specialty Primers, Sealers and Undercoaters: Each manufacturer of specialty primers, sealers and undercoaters shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall specify the number of gallons of specialty primers, sealers and undercoaters sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p> <p>6.2.4 Toxic Exempt Compounds: For each architectural coating that contains perchloroethylene or methylene chloride, the manufacturer shall, on or before April 1 of each calendar year beginning in the year 2004, submit an annual report to the Executive Officer of the ARB the following information for products sold in the State during the preceding</p>	<p>Until December 31, 2010 both versions of the rule have the same reporting requirements. After that date the non-SIP approved rule includes very specific information to be kept and is required for all architectural coatings. Therefore, non-SIP version of rule is as stringent as SIP version.</p>

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>during the calendar year to the nearest gallon;</p> <p>6.2.4.4 the volume percent, to the nearest 0.10 percent, of perchloroethylene and methylene chloride in the coating.</p> <p>6.2.5 Recycled Coatings: Manufacturers of recycled coatings must submit a letter to the Executive Officer of the ARB certifying their status as a Recycled Paint Manufacturer. The manufacturer shall, on or before April 1 of each calendar year beginning with the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall include, for all recycled coatings, the total number of gallons distributed in the State during the preceding year, and shall describe the method used by the manufacturer to calculate State distribution.</p> <p>6.2.6 Bituminous Coatings: Each manufacturer of bituminous roof coatings or bituminous roof primers shall, on or before April 1 of each calendar year beginning with the year 2004, submit an annual report to the Executive Officer of ARB. The report shall specify the number of gallons of bituminous roof coatings or bituminous roof primers sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate State sales.</p>	<p>year:</p> <p>6.2.4.1 the product brand name and a copy of the product label with legible usage instructions;</p> <p>6.2.4.2 the product category listed in the Table of Standards 1 or the Table of Standards 2 to which the coating belongs;</p> <p>6.2.4.3 the total sales in California during the calendar year to the nearest gallon;</p> <p>6.2.4.4 the volume percent, to the nearest 0.10 percent, of perchloroethylene and methylene chloride in the coating.</p> <p>6.2.5 Recycled Coatings: Manufacturers of recycled coatings must submit a letter to the Executive Officer of the ARB certifying their status as a Recycled Paint Manufacturer. The manufacturer shall, on or before April 1 of each calendar year beginning with the year 2004, submit an annual report to the Executive Officer of the ARB. The report shall include, for all recycled coatings, the total number of gallons distributed in the State during the preceding year, and shall describe the method used by the manufacturer to calculate State distribution.</p> <p>6.2.6 Bituminous Coatings: Each manufacturer of bituminous roof coatings or bituminous roof primers shall, on or before April 1 of each calendar year beginning with the year 2004, submit an annual report to the Executive Officer of ARB. The report shall specify the number of gallons of bituminous roof coatings or bituminous roof primers sold in the State during the preceding calendar year, and shall describe the method used by the manufacturer to calculate state sales.</p> <p>6.2.7 Effective on and after January 1, 2011, Sales Data: All sales data listed in Sections 6.2.7.1 to 6.2.7.14 shall be maintained on-site by the responsible official for a minimum of three years. A responsible official from each manufacturer shall upon request of the Executive Officer of the ARB, or his or her delegate, provide data concerning the distribution and sales of architectural coatings. Sales data submitted by the responsible official to the Executive Officer of the ARB may be claimed as confidential, and such information shall be handled in accordance with</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		<p>the procedures specified in Title 17, California Code of Regulations Sections 91000-91022. The responsible official shall within 180 days provide information, including, but not limited to the data listed in Sections 6.2.7.1 through 6.2.7.14:</p> <ul style="list-style-type: none"> 6.2.7.1 the name and mailing address of the manufacturer; 6.2.7.2 the name, address and telephone number of a contact person; 6.2.7.3 the name of the coating product as it appears on the label and the applicable coating category; 6.2.7.4 whether the product is marketed for interior or exterior use or both; 6.2.7.5 the number of gallons sold in California in containers greater than one liter (1.057 quart) and equal to or less than one liter (1.057 quart); 6.2.7.6 the VOC Actual content and VOC Regulatory content in grams per liter. If thinning is recommended, list the VOC Actual content and VOC Regulatory content after maximum recommended thinning. If containers less than one liter have a different VOC content than containers greater than one liter, list separately. If the coating is a multi-component product, provide the VOC content as mixed or catalyzed; 6.2.7.7 the names and CAS numbers of the VOC constituents in the product; 6.2.7.8 the names and CAS numbers of any compounds in the product specifically exempted from the VOC definition; 6.2.7.9 whether the product is marketed as solvent-borne, waterborne, or 100% solids; 6.2.7.10 description of resin or binder in the product; 6.2.7.11 whether the coating is a single-component or multi-component product; 6.2.7.12 the density of the product in pounds per gallon; 6.2.7.13 the percent by weight of: solids, all volatile materials, water, and any compounds in the product specifically exempted from the VOC definition; and 	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		6.2.7.14 the percent by volume of solids, water, and any compounds in the product specifically exempted from the VOC definition.	
	<p>6.3 Test Methods</p> <p>6.3.1 VOC Content of Coatings: To determine the physical properties of a coating in order to perform the calculations in Section 3.26 and 3.27, the reference method for VOC content is U.S. EPA Method 24, except as provided in Sections 6.3.2 and 6.3.15. An alternative method to determine the VOC content of coatings is SCAQMD Method 304-91 (Revised February 1996), incorporated by reference in Section 6.3.14. The exempt compounds content shall be determined by SCAQMD Method 303-91 (Revised August 1996), incorporated by reference in Section 6.3.12. To determine the VOC content of a coating, the manufacturer may use U.S. EPA Method 24, or an alternative method as provided in Section 6.3.2, formulation data, or any other reasonable means for predicting that the coating has been formulated as intended (e.g., quality assurance checks, recordkeeping). However, if there are any inconsistencies between the results of a Method 24 test and any other means for determining VOC content, the Method 24 test results will govern, except when an alternative method is approved as specified in Section 6.3.2. The District Air Pollution Control Officer (APCO) may require the manufacturer to conduct a Method 24 analysis.</p> <p>6.3.2 Alternative Test Methods: Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with Section 6.3.1, after review and approved in writing by the staffs of the District, the ARB and the U.S. EPA, may also be used. 6.3.3 Methacrylate Traffic Marking Coatings: Analysis of methacrylate multicomponent coatings used as traffic marking coatings shall be conducted according to a modification of U.S. EPA Method 24 (40 CFR 59, subpart D, Appendix A), incorporated by reference in Section 6.3.15. This method has not been approved for methacrylate multicomponent coatings used for other purposes than as traffic marking coatings or for other classes of multicomponent coatings.</p>	<p>6.3 Test Methods</p> <p>The test methods listed below shall be used to demonstrate compliance with this rule. Alternate equivalent test methods may be used provided the test methods have been approved by the APCO and EPA.</p> <p>6.3.1 Calculation of VOC Content: For the purpose of determining compliance with the VOC content limits in the Table of Standards 1 or the Table of Standards 2, the VOC content of a coating shall be determined as defined in Section 3.77, 3.78, or 3.79 as appropriate. The VOC content of a tint base shall be determined without colorant that is added after the tint base is manufactured. If the manufacturer does not recommend thinning, the VOC Content must be calculated for the product as supplied. If the manufacturer recommends thinning, the VOC Content must be calculated including the maximum amount of thinning solvent recommended by the manufacturer. If the coating is a multi-component product, the VOC content must be calculated as mixed or catalyzed. If the coating contains silanes, siloxanes, or other ingredients that generate ethanol or other VOC during the curing process, the VOC content must include the VOCs emitted during curing.</p> <p>6.3.2 VOC Content of Coatings: To determine the physical properties of a coating in order to perform the calculations in Section 3.77 and 3.79, the reference method for VOC content is EPA Method 24, except as provided in Sections 6.3.3 and 6.3.16. An alternative method to determine the VOC content of coatings is SCAQMD Method 304-91 (Revised February 1996). The exempt compounds content shall be determined by SCAQMD Method 303-91 (Revised 1993), BAAQMD Method 43 (Revised 1996), or BAAQMD Method 41 (Revised 1995), as applicable. To determine the VOC content of a coating, the manufacturer may use EPA Method 24, or an alternative method as provided in Section 6.3.3, formulation</p>	<p>The non-SIP version includes all the requirements of the SIP version. Therefore, the non-SIP version of the rule is more stringent than the SIP version of the rule.</p>

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>6.3.4 Flame Spread Index: The flame spread index of a fire-retardant coating shall be determined by ASTM Designation E 84-99, "Standard Test Method for Surface Burning Characteristics of Building Materials"(see Section 3, Fire-Retardant Coating).</p> <p>6.3.5 Fire Resistance Rating: The fire resistance rating of a fire-resistive coating shall be determined by ASTM Designation E 119-98, "Standard Test Methods for Fire Tests of Building Construction Materials"(see Section 3, Fire-Resistive Coating).</p> <p>6.3.6 Gloss Determination: The gloss of a coating shall be determined by ASTM Designation D 523-89 (1999), "Standard Test Method for Specular Gloss"(see Section 3, Flat Coating, Nonflat Coating, Nonflat-High Gloss Coating and Quick-Dry Enamel).</p> <p>6.3.7 Metal Content of Coatings: The metallic content of a coating shall be determined by SCAQMD Method 318-95, Determination of Weight Percent Elemental Metal in Coatings by X-Ray Diffraction, <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i> (see Section 3, Metallic Pigmented Coating).</p> <p>6.3.8 Acid Content of Coatings: The acid content of a coating shall be determined by ASTM Designation D 1613-96, "Standard Test Method for Acidity in Volatile Solvents and Chemical Intermediates Used in Paint, Varnish, Lacquer and related products"(see Section 3, Pre-Treatment Wash Primer).</p> <p>6.3.9 Drying Times: The set-to-touch, dry-hard, dry-to-touch and dry-to-recoat times of a coating shall be determined by ASTM Designation D 1640-95, "Standard Test Methods for Drying, Curing, or Film Formation of Organic Coatings at Room Temperature" (see Section 3, Quick-Dry Enamel and Quick-Dry Primer, Sealer and Undercoater) The tack-free time of a quickdry enamel coating shall be determined by the Mechanical Test Method of ASTM Designation D 1640-95.</p> <p>6.3.10 Surface Chalkiness: The chalkiness of a surface shall be determined using ASTM Designation D4214-98, "Standard Test Methods for Evaluating the Degree of Chalking of Exterior Paint Films"(see Section 3, Specialty Primer, Sealer and Undercoater).</p> <p>6.3.11 Exempt Compounds—Siloxanes: Exempt compounds that are cyclic,</p>	<p>data, or any other reasonable means for predicting that the coating has been formulated as intended (e.g., quality assurance checks, recordkeeping). However, if there are any inconsistencies between the results of EPA Method 24 test and any other means for determining VOC content, the EPA Method 24 test results will govern, except when an alternative method is approved as specified in Section 6.3.3. The District Air Pollution Control Officer (APCO) may require the manufacturer to conduct an EPA Method 24 analysis.</p> <p>6.3.3 Alternative Test Methods: Other test methods demonstrated to provide results that are acceptable for purposes of determining compliance with Section 6.3.2 4, after review and approved in writing by the staffs of the District, ARB and EPA, may also be used.</p> <p>6.3.4 Methacrylate Traffic Marking Coatings: Analysis of methacrylate multicomponent coatings used as traffic marking coatings shall be conducted according to a modification of EPA Method 24 (40 CFR 59, subpart D, Appendix A). This method has not been approved for methacrylate multicomponent coatings used for other purposes than as traffic marking coatings or for other classes of multicomponent coatings.</p> <p>6.3.5 Flame Spread Index: The flame spread index of a fire-retardant coating shall be determined by ASTM E84-07, "Standard Test Method for Surface Burning Characteristics of Building Materials" (see Section 3.0, Fire-Retardant Coating).</p> <p>6.3.6 Fire Resistance Rating: The fire resistance rating of a fire-resistive coating shall be determined by ASTM E119-07, "Standard Test Methods for Fire Tests of Building Construction Materials" (see Section 3.0, Fire-Resistive Coating).</p> <p>6.3.7 Gloss Determination: The gloss of a coating shall be determined by ASTM D523-89 (1999), "Standard Test Method for Specular Gloss" (see Section 3.0, Flat Coating, Nonflat Coating, Nonflat-High Gloss Coating and Quick-Dry Enamel).</p> <p>6.3.8 Metal Content of Coatings: The metallic content of a coating shall be determined by SCAQMD Method 318-95, Determination of Weight Percent Elemental Metal in Coatings</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>branched, or linear completely methylated siloxanes, shall be analyzed as exempt compounds for compliance with Section 6 by BAAQMD Method 43, "Determination of Volatile Methylsiloxanes in Solvent-Based Coatings, Inks, and Related Materials," <i>BAAQMD Manual of Procedures</i>, Volume III, adopted 11/6/96 (see Section 3, Volatile Organic Compound, and Section 6.3.1).</p> <p>6.3.12 Exempt Compounds— Parachlorobenzotrifluoride (PCBTF): The exempt compound parachlorobenzotrifluoride, shall be analyzed as an exempt compound for compliance with Section 6 by BAAQMD Method 41, "Determination of Volatile Organic Compounds in Solvent Based Coatings and Related Materials Containing Parachlorobenzotrifluoride," <i>BAAQMD Manual of Procedures</i>, Volume III, adopted 12/20/95 (see Section 3, Volatile Organic Compound, and Section 6.3.1).</p> <p>6.3.13 Exempt Compounds: The content of compounds under U.S. EPA Method 24 shall be analyzed by SCAQMD Method 303-91 (Revised 1996), "Determination of Exempt Compounds," <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i> (see Section 3, Volatile Organic Compound, and Section 6.3.1).</p> <p>6.3.14 VOC Content of Coatings: The VOC content of a coating shall be determined by U.S. EPA Method 24 as it exists in appendix A of 40 <i>Code of Federal Regulations</i> (CFR) part 60, "Determination of Volatile Matter Content, Water Content, Density, Volume Solids and Weight Solids of Surface Coatings"(see Section 6.3.1).</p> <p>6.3.15 Alternative VOC Content of Coatings: The VOC content of coatings may be analyzed either by U.S. EPA Method 24 or SCAQMD Method 304-91 (Revised 1996), "Determination of Volatile Organic Compounds (VOC) in Various Materials," <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i> (see Section 6.3.1).</p> <p>6.3.16 Methacrylate Traffic Marking Coatings: The VOC content of methacrylate multicomponent coatings used as traffic marking coatings shall be analyzed by the procedures in 40 CFR part 59, subpart D, appendix A, "Determination of Volatile Matter</p>	<p>by X-Ray Diffraction, <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i> (see Section 3.0, Metallic Pigmented Coating, Aluminum Roof Coating and Faux Finish.</p> <p>6.3.9 Acid Content of Coatings: The acid content of a coating shall be determined by ASTM D1613-06, "Standard Test Method for Acidity in Volatile Solvents and Chemical Intermediates Used in Paint, Varnish, Lacquer and related products" (see Section 3.0, Pre-Treatment Wash Primer).</p> <p>6.3.10 Drying Times: The set-to-touch, dry-hard, dry-to-touch and dry-to-recoat times of a coating shall be determined by ASTM D1640-95, "Standard Test Methods for Drying, Curing, or Film Formation of Organic Coatings at Room Temperature" (see Section 3.0, Quick-Dry Enamel and Quick-Dry Primer, Sealer and Undercoater) The tack-free time of a quick-dry enamel coating shall be determined by the Mechanical Test Method of ASTM D1640-95. (Category deleted effective January 1, 2011.)</p> <p>6.3.11 Surface Chalkiness: The chalkiness of a surface shall be determined using ASTM D4214-98, "Standard Test Methods for Evaluating the Degree of Chalking of Exterior Paint Films"(see Section 3, Specialty Primer, Sealer and Undercoater). (Category deleted effective January 1, 2011.)</p> <p>6.3.12 Exempt Compounds—Siloxanes: Exempt compounds that are cyclic, branched, or linear completely methylated siloxanes, shall be analyzed as exempt compounds for compliance with Section 6 by BAAQMD Method 43, "Determination of Volatile Methylsiloxanes in Solvent-Based Coatings, Inks, and Related Materials," <i>BAAQMD Manual of Procedures</i>, Volume III, adopted 11/6/96 (see Section 3.0, Volatile Organic Compound, and Section 6.3.2).</p> <p>6.3.13 Exempt Compounds— Parachlorobenzotrifluoride (PCBTF): The exempt compound parachlorobenzotrifluoride, shall be analyzed as an exempt compound for compliance with Section 6 by BAAQMD Method 41, "Determination of Volatile Organic Compounds in Solvent Based Coatings and Related Materials Containing</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
	<p>Content of Methacrylate Multicomponent Coatings Used as Traffic Marking Coatings" (September 11, 1998) (see Section 6.3.3).</p>	<p>Parachlorobenzotrifluoride," <i>BAAQMD Manual of Procedures</i>, Volume III, adopted 12/20/95 (see Section 3.0, Volatile Organic Compound, and Section 6.3.2).</p> <p>6.3.14 Exempt Compounds: The content of compounds under U.S. EPA Method 24 shall be analyzed by SCAQMD Method 303-91 (Revised 1993), "Determination of Exempt Compounds," <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i> (see Section 3.0, Volatile Organic Compound, and Section 6.3.2).</p> <p>6.3.15 VOC Content of Coatings: The VOC content of a coating shall be determined by EPA Method 24 as it exists in appendix A of 40 <i>Code of Federal Regulations</i> (CFR) part 60, "Determination of Volatile Matter Content, Water Content, Density, Volume Solids and Weight Solids of Surface Coatings" (see Section 6.3.2).</p> <p>6.3.16 Alternative VOC Content of Coatings: The VOC content of coatings may be analyzed either by U.S. EPA Method 24 or SCAQMD Method 304-91 (Revised 1996), "Determination of Volatile Organic Compounds (VOC) in Various Materials," <i>SCAQMD Laboratory Methods of Analysis for Enforcement Samples</i>.</p> <p>6.3.17 Methacrylate Traffic Marking Coatings: The VOC content of methacrylate multicomponent coatings used as traffic marking coatings shall be analyzed by the procedures in 40 CFR part 59, subpart D, appendix A, "Determination of Volatile Matter Content of Methacrylate Multicomponent Coatings Used as Traffic Marking Coatings" (September 11, 1998).</p> <p>6.3.18 Hydrostatic Pressure for Basement Specialty Coatings: The hydrostatic pressure resistance for basement specialty coatings shall be analyzed using ASTM D7088-04, "Standard Practice for Resistance to Hydrostatic Pressure for Coatings Used in Below Grade Applications Applied to Masonry".</p> <p>6.3.19 Tub and Tile Refinish Coating Adhesion: The adhesion of tub and tile coating shall be determined by ASTM D4585-99, "Standard Practice for Testing Water Resistance of Coatings Using Controlled Condensation" and ASTM D3359-02,</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		<p>"Standard Test Methods for Measuring Adhesion by Tape Test".</p> <p>6.3.20 Tub and Tile Refinish Coating Hardness: The hardness of tub and tile refinish coating shall be determined by ASTM D3363-05, "Standard Test Method for Film Hardness by Pencil Test".</p> <p>6.3.21 Tub and Tile Refinish Coating Abrasion Resistance: Abrasion resistance of tub and tile refinish coating shall be analyzed by ASTM D4060-07, "Standard Test Methods for Abrasion Resistance of Organic Coatings by the Taber Abraser".</p> <p>6.3.22 Tub and Tile Refinish Coating Water Resistance: Water resistance of tub and tile refinish coatings shall be determined by ASTM D4585-99, "Standard Practice for Testing Water Resistance of Coatings Using Controlled Condensation" and ASTM D714-02e1, "Standard Test Method for Evaluating Degree of Blistering of Paints".</p> <p>6.3.23 Waterproofing Membrane: Waterproofing membrane shall be tested by ASTM C836-06, "Standard Specification for High Solids Content, Cold Liquid-Applied Elastomeric Waterproofing Membrane for Use with Separate Wearing Course".</p> <p>6.3.24 Mold and Mildew Growth for Basement Specialty Coatings: Mold and mildew growth resistance for basement specialty coatings shall be determined by ASTM D3273-00, "Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber" and ASTM D3274-95, "Standard Test Method for Evaluating Degree of Surface Disfigurement of Paint Films by Microbial (Fungal or Algal) Growth or Soil and Dirt Accumulation".</p> <p>6.3.25 Reactive Penetrating Sealer Water Repellency: Reactive penetrating sealer water repellency shall be analyzed by ASTM C67-07, "Standard Test Methods for Sampling and Testing Brick and Structural Clay Tile"; or ASTM C97-02, "Standard Test Methods for Absorption and Bulk Specific Gravity of Dimension Stone"; or ASTM C140-06, "Standard Test Methods for Sampling and Testing Concrete Masonry Units and Related Units".</p> <p>6.3.26 Reactive Penetrating Sealer Water Vapor Transmission: Reactive penetrating sealer water vapor transmission shall be analyzed ASTM</p>	

Requirement Category	SIP Version of Rule 4601 (10/31/01)	Non-SIP Version of Rule 4601 (12/17/09)	Conclusion
		<p>E96/E96M-05, "Standard Test Method for Water Vapor Transmission of Materials".</p> <p>6.3.27 Reactive Penetrating Sealer - Chloride Screening Applications: Reactive penetrating sealers shall be analyzed by National Cooperative Highway Research Report 244 (1981), "Concrete Sealers for the Protection of Bridge Structures".</p> <p>6.3.28 Stone Consolidants: Stone consolidants shall be tested using ASTM E2167-01, "Standard Guide for Selection and Use of Stone Consolidants".</p>	
7.0 Compliance Schedule	Persons subject to this rule shall be in compliance with this rule by October 31, 2001.	Persons subject to this rule shall be in compliance with this rule by the dates specified within the rule.	No change in the requirements, therefore, non-SIP version of rule is as stringent as SIP version.
8.0 Averaging Compliance Option	<p>8.1 On or after January 1, 2003, in lieu of compliance with the specified limits in the Table of Standards for floor coatings; industrial maintenance coatings; primers, sealers, and undercoaters; quick-dry primers, sealers, and undercoaters; quick-dry enamels; roof coatings; rust preventative coatings; stains; waterproofing sealers, as well as flats and non-flats (excluding recycled coatings), manufacturers may average designated coatings such that their actual cumulative emissions from the averaged coatings are less than or equal to the cumulative emissions that would have been allowed under those limits over a compliance period not to exceed one year. Such manufacturers must also comply with the averaging provisions contained in this Section, as well as maintain and make available for inspection records for at least three years after the end of the compliance period. This Section shall cease to be effective on January 1, 2005, after which averaging will no longer be allowed.</p> <p>Per Section 8.1, averaging is no longer applicable. Therefore, Section 8.2 through 8.14 are not listed.</p>		No change in the requirements, therefore, non-SIP version of rule is as stringent as SIP version.

District Rule 4601 was amended (12/17/2009). As analyzed, each amended section of the non-SIP version of the rule is at least as stringent as, or more stringent than the corresponding section of the SIP version of the rule. Therefore, it is concluded that overall the non-SIP version of the rule is more stringent than the SIP version of the rule.

The following permit requirements were added and/or revised to ensure compliance with the current rule:

a. C-14-0-2 – Facility-Wide Requirements

- Conditions 23, 24, and 25 ensure compliance with the revised requirements of this rule.

District Rule 4701 – Internal Combustion Engines – Phase 1

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. Except as provided in Section 4.0, the provisions of this rule apply to any internal combustion engine, rated greater than 50 bhp, which requires a Permit to Operate (PTO).

Pursuant to Section 7.5.2.3 of District Rule 4702, as of June 1, 2006 District Rule 4701 is no longer applicable to diesel-fired emergency standby or emergency IC engines. Therefore, the two diesel-fired emergency and emergency standby IC engines at this facility, permit units C-14-4-3 and C-14-5-3, will comply with the requirements of District Rule 4702 and no further discussion is required.

District Rule 4702 – Internal Combustion Engines – Phase 2

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. This rule applies to any internal combustion engine with a rated brake horsepower greater than 50.

Section 3.15 of the District Rule 4702 states an engine shall be considered to be an emergency standby engine if it is used only for the following purposes: (1) periodic maintenance, periodic readiness testing, or readiness testing during and after repair work; (2) unscheduled outages, or to supply power while maintenance is performed or repairs are made to the primary power supply; and (3) if it is limited to operate 100 hours or less per calendar year for non-emergency purposes. Therefore, pursuant to Section 4.2 the emergency standby IC engine, permit unit C-14-5-3 (engines powering an electrical generator) will only have to meet the requirements of Sections 5.7 and 6.2.3 of the District Rule 4702.

Pursuant to Section 4.3 of the District Rule 4702, engines operated exclusively to preserve or protect property, human life, or public health during a disaster or state of emergency, such as a fire or flood, and limited to operate no more than 100 hours per calendar year as determined by an operational non-resettable elapsed operating time meter, for periodic maintenance, periodic readiness testing, and readiness testing during and after repair work will only have to meet the requirements of Section 6.2.3 of this Rule. Therefore, pursuant to Section 4.3 the emergency IC engine, permit unit C-14-4-3 (engines powering firewater pumps) will only have to meet the requirements of Section 6.2.3 of this Rule.

Section 5.7 of the District Rule 4702 requires that the owner of an emergency standby engine shall comply with the requirements specified in Section 5.7.2 through Section 5.7.5 below:

- Properly operate and maintain each engine as recommended by the engine manufacturer or emission control system supplier.
- Monitor the operational characteristics of each engine as recommended by the engine manufacturer or emission control system supplier.
- Install and operate a non-resettable elapsed operating time meter. In lieu of installing a non-resettable time meter, the owner of an engine may use an alternative device, method, or technique, in determining operating time provided that the alternative is approved by the APCO and is allowed by Permit-to-Operate or Stationary Equipment Registration condition. The owner of the engine shall properly maintain and operate the time meter or alternative device in accordance with the manufacturer's instructions.

Section 6.2.3 requires that an owner claiming an exemption under Section 4.2 or Section 4.3 shall maintain annual operating records. This information shall be retained for at least five years, shall be readily available, and provided to the APCO upon request. The records shall include, but are not limited to, the following:

- 1) Total hours of operation,
- 2) The type of fuel used,
- 3) The purpose for operating the engine,
- 4) For emergency standby engines, all hours of non-emergency and emergency operation shall be reported, and
- 5) Other support documentation necessary to demonstrate claim to the exemption.

**Title 17 CCR, Section 93115 - Airborne Toxic Control Measure (ATCM)
for Stationary Compression-Ignition (CI) Engines State Only Requirement**

This ATCM requires that no owner or operator shall operate an in-use stationary emergency standby diesel-fueled CI engine (>50 bhp) that emits diesel PM at a rate greater than 0.40 g/bhp-hr more than 20 hours per year for maintenance and testing purposes (permit unit C-14-5-3). Engines powering a firewater pump (permit unit C-14-4-3) are exempt from the 20 hours per year limitation. Engines that are not diesel-fueled CI engines are exempt from the requirements of this ATCM.

The ATCM also requires that in-use emergency standby engines are required to use only diesel fuels that meet the definition of CARB diesel at the time of purchase.

The ATCM also requires that no owner or operator shall operate an in-use stationary emergency standby diesel-fueled CI engine for non-emergency use, including maintenance and testing, during the following periods: a) whenever there is a school sponsored activity, if the engine is located on school grounds, and b) between 7:30 a.m. and 3:30 p.m. on days when school is in session, if the engine is located within 500 feet of school grounds. This facility is not located near any schools so these requirements are not applicable.

The ATCM also requires that owner or operator of an emergency standby diesel-fueled CI engine shall keep a monthly log of usage that shall list and document the nature of use for each of the following:

- a. Emergency use hours of operation;
- b. Maintenance and testing hours of operation;
- c. Hours of operation for any emission testing;
- d. Initial start-up hours;
- e. If applicable, hours of operation to comply with the requirements of NFPA 25;
- f. Hours of operation for all uses other than those specified above; and
- g. The fuel used.

The owner or operator shall document fuel use through the retention of fuel purchase records that account for all fuel used in the engine and all fuel purchased for use in the engine, and, at a minimum, contain the following information for each individual fuel purchase transaction:

- I. Identification of the fuel purchased as either CARB Diesel;

- II. Amount of fuel purchased;
- III. Date when the fuel was purchased;
- IV. Signature of owner or operator or representative of owner or operator who received the fuel; and
- V. Signature of fuel provider indicating fuel was delivered.

c. C-14-4-3 – 136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A FIRE WATER PUMP

- Conditions 6, 7 and 9 from the current permit requirements have been revised to exclude District Rule 4701, which is no longer applicable.

b. C-14-5-3 – 534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

- Conditions 7, 10 and 11 from the current permit requirements have been revised to exclude District Rule 4701, which is no longer applicable.

District Rule 4703 – Stationary Gas Turbines

This rule applies to all stationary gas turbine systems, which are subject to District permitting requirements, and with ratings equal to or greater than 0.3 megawatt (MW) or a maximum heat input rating of more than 3,000,000 Btu per hour.

The rule was amended on September 20, 2007 to include Tier 3 compliance limit requirements. This amendment to the rule does not effect the permit requirement of units C-14-10 and C-14-11.

a. C-14-10-6: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

- Conditions 4, 23, 24, 28 and 42 from the PTO were included as conditions 4, 23, 24, 28 and 42 of the requirements for this permit unit.

- Condition 30 is being revised to remove erroneous phrase referring to using continuous emission monitor system if CEMS is not used.
- b. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

- Conditions 20 through 22, 29, 43, 47 and 48 from the PTO were included as conditions 20 through 22, 29, 43, 47 and 48 of the requirements for this permit unit.
- Condition 31 is being revised to remove the pollutant CO as one of emissions CEMS monitors, because the CEMS for this turbine only monitors for NO_x and O₂. Also, remove erroneous phrase referring to using continuous emission monitor system if CEMS is not used.

In addition to the Tier 3 compliance limits requirements the term “thermal stabilization period” was removed and replaced with the term “transitional operation period” to not only define start up and shutdown periods, but “bypass transition period”, primary re-ignition period”, and “reduced load period”, as well.

- a. C-14-10-6: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

- Conditions 14, 15 and 16 from the current permit requirements have been revised to reflect current Rule 4703 and rule definitions.

b. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

- Conditions 16, 17 and 19 from the current permit requirements have been revised to reflect current Rule 4703 definitions.

District Rule 8011 - General Requirements

The purpose of Regulation VIII (Fugitive PM10 Prohibitions) is to reduce ambient concentrations of fine particulate matter (PM10) by requiring actions to prevent, reduce or mitigate anthropogenic fugitive dust emissions. The Rules contained in this Regulation have been developed pursuant to United States Environmental Protection Agency guidance for Serious PM10 Nonattainment Areas. The rules are applicable to specified anthropogenic fugitive dust sources. Fugitive dust contains PM10 and particles larger than PM10. Controlling fugitive dust missions when visible emissions are detected will not prevent all PM10 emissions, but will substantially reduce PM10 emissions.

The provisions of this rule are applicable to specified outdoor fugitive dust sources. The definitions, exemptions, requirements, administrative requirements, recordkeeping requirements, and test methods set forth in this rule are applicable to all Rules under Regulation VIII (Fugitive PM10 Prohibitions) of the Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District.

Conditions 29 through 34 of permit unit -0-2 ensure compliance.

District Rule 8021 - Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities

The purpose of this rule is to limit fugitive dust emissions from construction, demolition, excavation, extraction, and other earthmoving activities.

This rule applies to any construction, demolition, excavation, extraction, and other earthmoving activities, including, but not limited to, land clearing, grubbing, scraping, travel on site, and travel on access roads to and from the site. This rule also applies to the construction of new landfill disposal sites or

modification to existing landfill disposal sites prior to commencement of landfilling activities.

Section 5.0 requires that no person shall perform any construction, demolition, excavation, extraction, or other earthmoving activities unless the appropriate requirements in sections 5.1 and 5.2 are sufficiently implemented to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 29 of permit unit -0-2 ensures compliance.

District Rule 8031 - Bulk Materials

The purpose of this rule is to limit fugitive dust emissions from the outdoor handling, storage, and transport of bulk materials.

This rule applies to the outdoor handling, storage, and transport of any bulk material.

Section 5.0 requires that no person shall perform any outdoor handling, storage, and transport of bulk materials unless the appropriate requirements in Table 8031-1 of this rule are sufficiently implemented to limit VDE to 20% opacity or to comply with the conditions for a stabilized surface as defined in Rule 8011. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 30 of permit unit -0-2 ensures compliance.

District Rule 8041 - Carryout and Trackout

The purpose of this rule is to limit fugitive dust emissions from carryout and trackout.

This rule applies to all sites that are subject to Rules 8021 (Construction, Demolition, Excavation, Extraction, and other Earthmoving Activities), 8031 (Bulk Materials), and 8071 (Unpaved Vehicle and Equipment Traffic Areas) where carryout or trackout has occurred or may occur.

Section 5.0 requires that an owner/operator shall sufficiently prevent or cleanup carryout and trackout as specified in sections 5.1 through 5.8. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII. The use of blower devices, or dry rotary brushes or brooms, for removal of carryout and trackout on public roads is expressly prohibited. The removal of carryout and trackout from

paved public roads does not exempt an owner/operator from obtaining state or local agency permits which may be required for the cleanup of mud and dirt on paved public roads.

Condition 31 of permit unit -0-2 ensures compliance.

District Rule 8051 - Open Areas

The purpose of this rule is to limit fugitive dust emissions from open areas.

This rule applies to any open area having 3.0 acres or more of disturbed surface area, which has remained undeveloped, unoccupied, unused, or vacant for more than seven days.

Section 5.0 requires that whenever open areas are disturbed or vehicles are used in open areas, the owner/operator shall implement one or a combination of control measures indicated in Table 8051-1 to comply with the conditions of a stabilized surface at all times and to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 32 of permit unit -0-2 ensures compliance.

District Rule 8061 - Paved and Unpaved Roads

The purpose of this rule is to limit fugitive dust emissions from paved and unpaved roads by implementing control measures and design criteria.

This rule applies to any new or existing public or private paved or unpaved road, road construction project, or road modification project.

Condition 33 of permit unit -0-2 ensures compliance.

District Rule 8071 - Unpaved Vehicle/Equipment Traffic Area

The purpose of this rule is to limit fugitive dust emissions from unpaved vehicle and equipment traffic areas by implementing control measures and design criteria.

This rule applies to any unpaved vehicle/equipment traffic area of 1.0 acre or larger.

Condition 34 of permit unit -0-2 ensures compliance.

40 CFR Part 60, Subpart GG, Standard of Performance for Stationary Gas Turbines

This requirement limits emissions of nitrogen oxides. Emissions shall not exceed a NO_x emission rate of 75 ppmv or 150 ppmv, depending on the unit size (at 15% O₂ with the ISO correction factor). The following analysis shows that the proposed requirement of District Rule 4703 is more stringent than 40 CFR requirements pertaining to NO_x emissions. Streamlining procedures, as documented in the following steps is utilized to substitute the proposed set of requirements for the otherwise applicable requirements.

The following table has side-by-side comparison of applicable requirements:

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Emissions Limit	Section 5.1.2 - for > 10 MW, 5 ppmv @ 15% O ₂ . (Tier II Standard Option)	60.332(a) (1) – 75 ppmv @ 15% O ₂ . (Lowest possible concentration) 60.333(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% oxygen and on a dry basis.	5 ppmv @ 15% O ₂ .
Work place standards	N/A	60.333(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel, which contains sulfur in excess of 0.8% by weigh (8000 ppmw).	This unit shall be fired exclusively on natural gas which has a total sulfur content of less than or equal to 1.0 gr/100 scf
Monitoring	(6.2.1) Except for units subject to Section 6.2.3, for turbines with exhaust gas NO _x control devices, the owner or operator shall either install, operate, and maintain continuous emissions monitoring equipment for NO _x and oxygen, as identified in Rule 1080 (Stack Monitoring), or install and maintain APCO-approved alternate monitoring	60.334(a) The owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water injection to control NO _x emissions shall install or operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. 60.334(b) Install, certify, maintain, operate, and quality-assure a continuous emissions monitoring system for NO _x and O ₂ . 60.334(h)(3) The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) demonstrated by representative fuel sampling data which shows that sulfur content of gas does not exceed 0.25 gr/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of Appendix D of 40 CFR part 75 is required	The owner or operator shall install, certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO _x and O ₂ concentrations. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show exceedance, weekly monitoring shall resume and exceedance shall be reported to APCO

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Reporting	As per District Rule 1080: Time intervals, data and magnitude of excess NOx emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred	60.334(J) the owner or operator shall submit reports of excess emissions and monitor downtime as required under §60.7(c), periods of excess emissions that shall be reported are defined as follows: 60.334(J)(1)(iii) - An hour of excess emissions shall be any operating hour in which 4-hour rolling average NOx concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx or diluent (or both). 60.334(J) (5): all reports required under §60.7(c) shall be post marked by 30 th day following the end of each calendar quarter.	The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NOx concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx or diluent (or both)
Testing	Annual Testing for nitrogen oxides (NOx) concentrations using EPA Method 20 or 7E and oxygen (O ₂) using Method 3, 3A, or 20.	Initial NOx performance testing using EPA method 20 or 7E and EPA method 3, 3A for O ₂ .	Annual Testing for nitrogen oxides (NOx) concentrations using EPA Method 20 or 7E and oxygen (O ₂) using Method 3, 3A, or 20.

The District Rule 4703 requirement to limit NOx concentration to 5 ppmv @ 15% O₂ is clearly more stringent than the Subpart GG emissions limit of 75 ppmv as discussed below.

a. C-14-10-6: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

- The requirements of conditions 2, 12 through 15, 22 through 24, 28, 29, 31, 36, 37 and 39 from the current PTO will ensure compliance when included as conditions 2, 12 through 15, 22 through 24, 28, 29, 31, 36, 37 and 39 of the requirements for this permit unit.

b. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

- The requirements of conditions 4, 7, 8, 16, 17, 20 through 23, 29, 30 and 38 from the current PTO will ensure compliance when included as conditions 4, 7, 8, 16, 17, 20 through 23, 29, 30 and 38 of the requirements for this permit unit.
- Condition 32 is being revised to remove the pollutant CO as one of emissions CEMS monitors, because the CEMS for this turbine only monitors for NO_x and O₂.

40 CFR 60 Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

§60.4200 - Applicability

This subpart is applicable to owners and operators of stationary compression ignited internal combustion engines that commence construction after July 11, 2005, where the engines are:

- 1) Manufactured after April 1, 2006, if not a fire pump engine.
- 2) Manufactured as a National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

Since the proposed stationary engine (C-14-5-3) was installed before April 1, 2006 and the fire pump engine (C-14-4-3) was installed before July 1, 2006, this subpart does not apply.

All of the applicable standards of this subpart are less restrictive than current District requirements. This engine will comply with all current District standards so no further discussion is required.

40 CFR Part 60 Subpart KKKK, Standards of Performance for Stationary Combustion Turbines

The EPA promulgated this new NSPS that would apply to new stationary combustion turbines greater than or equal to 1 MW that commence construction, modification or reconstruction after February 18, 2005. The gas turbine permit units C-14-10 and C-14-11 were initially constructed before February 18, 2005 and have not been modified or reconstructed since. Therefore requirements of this NSPS are not applicable.

40 CFR Part 61, Subpart M, National Emission Standard for Asbestos

These regulations apply to demolition or renovation activity, as defined in 40 CFR 61.141. 40 CFR Section 61.150 of this Subpart was amended September 18, 2003, and condition 35 of C-14-0-2 assures compliance with the requirements.

40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

§6585(b) states, "A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 mega grams) or more per year or any combination of HAP at a rate of 25 tons (22.68 mega grams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site."

§6585(c) states, "An area source of HAP emissions is a source that is not a major source."

The facility is a major source as defined in §6585(b). Therefore, this facility is a major source of HAP emissions.

§6590(a) states, "An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand."

§6590(a) (1) defines the criteria for an existing stationary RICE as follows:

- (i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.
- (ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE exists if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

This facility is a major source of HAP emissions. The engines at this facility have not commenced construction or reconstruction on or after June 12, 2006. Therefore, the engines at this facility meet the definition of an existing stationary RICE as defined in §6590(a) (1) (iii).

§6590(b) (3) states that the following engines do not have to meet the requirements of this subpart and of subpart A of this part:

- stationary RICE which is an existing spark ignition 4 stroke rich burn (4SRB) stationary RICE located at an area source,
- existing spark ignition 4SRB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source, an existing spark ignition 2 stroke lean burn (2SLB) stationary RICE,
- existing spark ignition 4 stroke lean burn (4SLB) stationary RICE,
- existing compression ignition (CI) stationary RICE,

- existing emergency stationary RICE,
- existing limited use stationary RICE, or
- existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis

The engines at this facility are existing emergency stationary RICE. Therefore, the engines do not have to meet the requirements of this subpart and of subpart A of this part. No further discussion is required.

40 CFR Part 64 Compliance Assurance Monitoring (CAM)

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouse, and catalytic oxidizer; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

- a. C-14-2-6: HAMMERMILL OPERATION, INCLUDING TWO HAMMERMILLS WITH TWO FANS, PREKNOCKOUT CYCLONES AND ONE BAGHOUSE

Given:

- 1) Annual Emission Limit (AEL) = 1,825 lb-PM₁₀/yr
- 2) Add-on Control Device Control Efficiency (Dust Collector) = 99%
- 3) Threshold Limit = 140,000 lb-PM₁₀/yr

Using the following Eqn:

$$\begin{aligned} PE_{\text{Uncontrolled}} &= \text{AEL} \div (1 - \text{CE}) \\ &= 1,825 \text{ lb-PM}_{10}/\text{yr} \div (1 - 0.99) \\ &= 182,500 \text{ lb-PM}_{10}/\text{yr} \end{aligned}$$

182,500 lb-PM₁₀/yr >>> 140,000 lb-PM₁₀/yr

Since uncontrolled emissions exceed the PM₁₀ major source threshold of 140,000 lb/year, and therefore, this unit is subject to CAM.

- Conditions 15 through 18 of the proposed permit assure compliance with this rule.

- b. C-14-4-3: 136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A FIRE WATER PUMP
- This unit is not subject to CAM since it does not have any add-on control device for this unit.
- c. C-14-5-3: 534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
- This unit is not subject to CAM since it does not have any add-on control device for this unit.
- d. C-14-10-4: 23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS
- For NO_x and CO, this permit unit is equipped with continuous emissions monitoring system (CEMS) for criteria air pollutants. Therefore, this permit unit is exempt from the CAM requirements. For SO_x, PM₁₀ and VOC, this unit is not subject to CAM since it does not have any add-on control device for this unit for those pollutants.
- e. C-14-11-6: 55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)
- For NO_x and CO, this permit unit is equipped with continuous emissions monitoring system (CEMS) for criteria air pollutants. Therefore, this permit unit is exempt from the CAM requirements. For SO_x, PM₁₀ and VOC, this unit is not subject to CAM since it does not have any add-on control device for this unit for those pollutants.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

The applicant is not requesting to use any model general permit templates for this Title V renewal project.

B. Requirements not Addressed by Model General Permit Templates

Fresno Cogeneration Partners is not requesting any new permit shields within this Title V renewal project. In addition, Fresno Cogeneration Partners is not requesting any changes to the existing permit shields already included in their Title V operating permits. Therefore, all of the existing permit shields will be maintained on the revised permits for this renewal project.

C. Obsolete Permit Shields From Existing Permit Requirements

There are no obsolete permit shield conditions to be removed from the permits.

X. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List
- D. Rule 4601-Architectural Coatings, VOC Limit Tables

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-14-0-2

EXPIRATION DATE: 08/31/2005

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: FRESNO COGENERATION PARTNERS
Location: 8105 S LASSEN AVE, SAN JOAQUIN, CA 93660
C-14-0-2, Sep 14 2010 9:35AM - HARRIS

9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. {4400} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/1709); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin December 20 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-1-11

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

DORMANT FEED DRYING OPERATION WITH ONE MEC AND ONE GUARANTEED PERFORMANCE ROTARY DRUM DRYER; TWO SCREW FEEDERS; TWO PRE-KNOCKOUT 144" DIAMETER CYCLONES; AND A MULTICLONE WITH TWO CHAMBERS

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The drying operation shall be rendered inoperable through disconnection of the electrical power and controls to this unit. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits on the multiclone outlet by an ARB or District approved contractor shall be performed within 60 days of recommencing operation of this unit. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to recommencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,359 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Upon recommencing operation, material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Particulate matter grain loading shall not exceed 0.04 grains/dscf. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Upon recommencing operation, particulate matter emission testing shall be performed on the multiclone outlet annually by an ARB or District approved contractor. [District Rule 1081] Federally Enforceable Through Title V Permit
13. Source testing for particulate matter shall be performed according to EPA Method 5. [District Rule 4201, 4.1] Federally Enforceable Through Title V Permit
14. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-2-6

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

HAMMERMILL OPERATION, INCLUDING TWO 200-HP HAMMERMILLS WITH TWO FANS AND PRE-KNOCKOUT CYCLONES AND ONE BAGHOUSE

PERMIT UNIT REQUIREMENTS

1. Visible emissions from the exhaust of the baghouse serving the hammermill shall not equal or exceed 5% opacity for a period or periods aggregating more than three minutes in any one hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter (PM10) emissions from this permit unit shall not exceed 0.012 lb/ton of throughput nor 5.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The baghouse shall be equipped with a pressure differential gauge to indicate the pressure drop across the bags. The gauge shall be maintained in good working condition at all times and shall be located in an easily accessible location. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. A spare set of bags shall be maintained on the premises at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The baghouse cleaning frequency and duration shall be adjusted to optimize the control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The baghouse shall be maintained as follows: 576, Needled polyester (16 oz.) filter bags; 10,000 SF filter area; 25,000 - 37,500 ACFM air flow; 3.47/5.1 : 1 air-to-cloth ratio; and 5" W.C. pressure drop. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The bags shall be replaced whenever the normal cleaning procedure does not result in a pressure drop across the bags of 6" water column or less. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Particulate matter concentrations shall not exceed 0.015 grains/dscf. [District Rule 4201 and District Rule 2201] Federally Enforceable Through Title V Permit
15. Baghouse filters shall be inspected at least once every two weeks while not in operation for any tears, holes, abrasions, and scuffs which might interfere with the PM collection efficiency and shall be replaced as needed. [District Rule 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit
16. Records of baghouse inspection, maintenance, and repair shall be maintained. These records shall include identification of the baghouse, date of inspection, any corrective action taken as a result of inspection, and initials of the personnel performing the inspection. [District Rule 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit
17. Baghouse shall be inspected weekly while in operation for visible emissions. If excessive visible emissions are observed, appropriate action shall be taken, such as baghouse maintenance, cleaning, or replacement of bags as needed. [District Rule 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit
18. The facility shall conduct weekly visual inspections to determine whether visible emissions are present. If visible emissions are present, the facility will conduct a USEPA Method 9 test within 72 hours to determine if visible emissions are in excess of Ringelmann #1 or 20% opacity. If visible emissions can not be eliminated, the facility will conduct a EPA Method 5 source test within 30 days of detection of visible emissions to demonstrate compliance with the particulate matter emission limit. [District Rules 1081 and 2520, 9.3.2 and 40 CFR 64] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Permittee shall keep a record of the daily hammermill throughput, in tons. [District Rule 2201] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-4-3

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING A FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 406 (Fresno)] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed in concentration at the point of discharge 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be operated with the timing retarded four degrees from the manufacturer's standard recommended timing. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, and the purpose of the operation (for example, load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
9. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-10-6

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

PERMIT UNIT REQUIREMENTS

1. {2256} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
2. {2257} Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine shall be equipped with a calibrated continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rules 2201, 2520 9.4.2, and 4703 6.2.1] Federally Enforceable Through Title V Permit
5. The gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The heat input to the turbine shall not exceed 1,320,000 MMBtu/year based on a 12-month rolling sum. Compliance with this limit shall be determined at the end of each month. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emissions rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
11. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. This unit shall be fired exclusively on PUC-quality natural gas and the PUC-quality natural gas shall have a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
13. The fuel sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, or tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or GAS Processors Association Standard 2377. If the fuel sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a fuel sulfur content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
14. Except during traditional operation period, emission rates from the gas turbine shall not exceed any of the following: PM10: 2.22 lb/hr, SOx (as SO2): 0.98 lb/hr, NOx (as NO2): 5.0 ppmvd @ 15% O2 and 6.20 lb/hr (based on a 3-hour average), VOC: 2.0 ppmvd @ 15% O2 and 0.88 lb/hr, CO: 12.0 ppmvd @ 15% O2 and 8.07 lb/hr (based on a 3-hour rolling average), or ammonia: 10 ppmvd @ 15% O2 (based on a 1-hour rolling average). [District Rules 2201, 4102, 4301, 4703 and 40 CFR Part 60 Subpart GG] Federally Enforceable Through Title V Permit
15. During traditional operation period, emission rates from the gas turbine shall not exceed any of the following: PM10: 2.22 lb/hr, SOx (as SO2): 0.98 lb/hr, NOx (as NO2): 20 lb/hr (based on a 3-hour rolling average), VOC: 0.88 lb/hr, CO: 8.07 lb/r (based on a 3-hour rolling average), or ammonia: 20 ppmvd @ 15% O2 (based on a 1-hour rolling average). [District Rules 2201, 4102, 4301, 4703 and 40 CFR Part 60 Subpart GG] Federally Enforceable Through Title V Permit
16. Traditional operation period shall be any of the following periods as they are define in Rule 4703: bypass transition period, primary re-ignition period, reduced load period start-up or shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
17. Permittee shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100] Federally Enforceable Through Title V Permit
18. In the event of a breakdown of monitoring equipment, the owner shall notify the APCO as soon as reasonably possible, but no later than eight (8) hours after its detection, unless the owner or operator demonstrates to the APCO's satisfaction that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the APCO of the intent to shut down any monitoring equipment at least 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. A violation of emissions standards indicated by the CEM system shall be reported to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
20. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100] Federally Enforceable Through Title V Permit
21. Compliance with the ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O2 = ((a-(bxc/1,000,000)) x 1,000,000/b), where a = ammonia injection rate (lb/hr)/17 lb/lb.mol, b = dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol), and c = change in measure NOx concentration ppmv @ 15% O2 across catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Compliance testing to measure the PM10, NOx (as NO2), VOC, CO, ammonia emissions, and fuel gas sulfur content of this permit unit shall be conducted at least once every twelve months. [District Rules 2201 and 4703, 6.3 and 40 CFR 60.332 (a), (b) and 40 CFR 60.333] Federally Enforceable Through Title V Permit
23. The following test methods shall be used. PM10: EPA Method 5 (front half and back half), NOx: EPA Method 7E or 20, CO: EPA Method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit [District Rules 1081, 4703, 6.4, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a),(b) and District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
25. Permittee shall comply with all applicable source sampling requirements of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Compliance demonstration (source testing) shall be District witnessed, or authorized and the samples shall be collected by a California Air Resources Board certified testing laboratory. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days of source testing. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The owner or operator shall install, certify, maintain, operate, and quality-assure a Continuous Emissions Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x (before and after the SCR catalyst), CO, and O₂ concentrations. The CEMS shall be capable of monitoring emissions during startups and shutdowns, as well as during normal operating conditions. [40 CFR 50.334(b) and District Rules 1080, 2201, and 4703] Federally Enforceable Through Title V Permit
29. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
30. Results of the CEM system shall be averaged over three hour periods using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703 5.1, 6.4] Federally Enforceable Through Title V Permit
31. The NO_x, CO, and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60 Appendix B Performance Specifications 2 and 3. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
32. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown, or malfunction, performance testing evaluations, calibration, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emissions measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
33. Audits of continuous emissions monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
34. The owner/operator shall perform a relative accuracy test (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
35. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. this summary shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventative measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period and used to determine compliance with an emissions standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit
37. The owner or operator shall report periods of excess emissions that are defined as follows: any one-hour period during which the average-water-to-fuel ratio (when the CEMS is not operational and Dry-Low NOx technology is not being used), as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the NOx emission limit. Each report shall include average water-to-fuel ratio, average fuel consumption, ambient conditions, and gas turbine load. [40 CFR 60.334(c)(1)] Federally Enforceable Through Title V Permit
38. Results of the CEM system shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3 or by other methods deemed equivalent by mutual agreement with the District, the California Air Resources Board, and the Environmental Protection Agency. [District Rule 1080, 6.0] Federally Enforceable Through Title V Permit
39. The continuous monitor of fuel, water, and water-to-fuel ratio system shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the NOx emissions limits at 30, 50, 75, and 100% of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. [40 CFR 60.335(c)(2)] Federally Enforceable Through Title V Permit
40. The minimum ammonia injection rate shall be reported to the District and the injection rate shall be monitored by the operator during CEM breakdowns to demonstrate NOx emission compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
41. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the required monitoring devices to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
42. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.4 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
43. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, and calculated NOx mass emission rates (lb/hr). [District Rules 2201 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-11-6

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK

PERMIT UNIT REQUIREMENTS

1. The HRSG bypass stack shall only be utilized when the main stack is not utilized (except during transition periods between the stacks) and the HRSG bypass stack shall be subject to all of the same requirements as the main stack at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The owner/operator shall perform an initial relative accuracy test as specified by 40 CFR Part 60 Appendix B to certify the new stack probe in the HRSG bypass stack, and every 720 stack operating hours per 40 CFR Part 75 Appendix B Section 2.3.3 thereafter. [District Rule 1080] Federally Enforceable Through Title V Permit
3. Calibration gas audit linearity checks shall be performed quarterly or every 168 stack operating hours per 40 CFR Part 75 Appendix B Section 2.2.4. [District Rule 1080] Federally Enforceable Through Title V Permit
4. {2257} Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
6. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
7. This unit shall be fired exclusively on PUC-quality natural gas and the PUC-quality natural gas shall have a total sulfur content less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
8. The fuel sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If the fuel sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a fuel sulfur content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
9. Gas turbine heat input shall not exceed 2,824,250 MMBtu/year based on a 12-month rolling sum. Compliance with this limit shall be determined at the end of each month. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
14. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, and 4) daily emissions measured by CEMS. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Except during traditional operation period, emission rates from the gas turbine shall not exceed any of the following: 2.0 ppmvd NOx @ 15% O2 (based on a 3-hour rolling average), 0.0029 lb-SOx/MMBtu, 0.0066 lb-PM10/MMBtu, 20 ppmv CO @ 15% O2, 2 ppmv VOC @ 15% O2, or 10 ppmv-ammonia @ 15% O2 (based on a 1-hour rolling average). [40 CFR 60.332, and District Rules 2201, 4703, 5.1 and 5.2 and 4102] Federally Enforceable Through Title V Permit
17. During traditional operation period, emissions rates from the gas turbine shall not exceed any of the following: 20 lb-NOx/hr (based on a 3-hour rolling average), 1.25 lb-SOx/hr, 2.85 lb-PM10/hr, 19.40 lb-CO/hr (based on a 3-hour rolling average), 1.12 lb-VOC/hr, or 20 ppmv-ammonia @ 15% O2 (based on a 1-hour rolling average). [40 CFR 60.332, and District Rules 2201, 4703, 5.1 and 5.2 and 4102] Federally Enforceable Through Title V Permit
18. Ammonia slip shall be calculated as follows: ammonia slip ppmv @ 15% O2 = $\{[a-(b \times c/1,000,000)] \times 1,000,000/b\}$, where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), and c = change in measured NOx concentration ppmv at 15% O2 across the catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Traditional operation period shall be any of the following periods as they are define in Rule 4703: bypass transition period, primary re-ignition period, reduced load period start-up or shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
20. Compliance testing to measure the PM10, NOx (as NO2), VOC, CO, ammonia emissions, and fuel gas sulfur of this permit unit shall be conducted at least once every twelve months. [District Rules 2201, 4703, 6.3, 40 CFR 60.332(a), (b), and 40 CFR 60.333] Federally Enforceable Through Title V Permit
21. The following test methods shall be used. PM10: EPA Method 5 (front half and back half), NOx: EPA Method 7E or 20, CO: EPA Method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rule 1081; District Rule 4703, 6.4; and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
22. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a)(b) and District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
23. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. For units equipped with CEM, CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

27. Permittee shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100] Federally Enforceable Through Title V Permit
28. The District shall be notified in writing within 10 days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100] Federally Enforceable Through Title V Permit
29. The owner or operator shall install, certify, maintain, operate, and quality-assure a Continuous Emissions Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x (before and after the SCR catalyst) and O₂ concentrations. The CEMS shall be capable of monitoring emissions during startups and shutdowns, as well as during normal operating conditions. [40 CFR 50.334(b) and District Rules 1080, 2201, and 4703] Federally Enforceable Through Title V Permit
30. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
31. Results of the CEM system shall be averaged over three hour periods using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
32. The NO_x and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60 Appendix B Performance Specifications 2, 3, and 4A. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown, or malfunction, performance testing evaluations, calibration, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emissions measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
34. Audits of continuous emissions monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Permittee shall comply with all applicable source sampling requirements of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The owner/operator shall perform a relative accuracy test (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
37. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. this summary shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
38. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and the cause of excess (if known), corrective actions taken and preventative measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period and used to determine compliance with an emissions standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the required monitoring devices to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
40. Results of the CEM system shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3 or by other methods deemed equivalent by mutual agreement with the District, the California Air Resources Board, and the Environmental Protection Agency. [District Rule 1080, 6.0] Federally Enforceable Through Title V Permit
41. In the event of a breakdown of monitoring equipment, the owner shall notify the APCO as soon as reasonably possible, but no later than eight (8) hours after its detection, unless the owner or operator demonstrates to the APCO's satisfaction that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the APCO of the intent to shut down any monitoring equipment at least 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of the following: 1) the occurrence and duration of any start-up, shutdown, or malfunction in the operation of the permit unit; 2) performance testing, evaluations, calibrations, checks, adjustments, and maintenance of CEMS; and 3) emission measurements. [District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of the following: 1) annual hours of operation, 2) daily and annual fuel consumption, 3) daily and annual continuous emission monitor measurements, 4) daily calculated ammonia slip, and 5) daily and annual emission rates. [District Rules 2201 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
44. Permittee shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: 1) time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; 2) averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; 3) applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and 4) the nature of system repairs and adjustments; 5) a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
45. Permittee shall maintain on file copies of natural gas bills. [District Rule 2201] Federally Enforceable Through Title V Permit
46. A violation of emission standards indicated by the CEM system shall be reported to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
47. The minimum ammonia injection rate shall be reported to the District and the injection rate shall be monitored during CEM breakdowns to demonstrate NOx emission compliance. [District Rule 4703, 6.2.5] Federally Enforceable Through Title V Permit
48. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.4 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
49. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, and calculated NOx mass emission rates (lb/hr). [District Rules 2201 and 2529, 9.4.2] Federally Enforceable Through Title V Permit
50. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 71] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

52. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
53. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
54. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
55. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
56. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
57. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
58. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
59. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
60. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
61. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
62. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
63. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
64. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

65. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
66. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-12-2

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

DORMANT FULL-TIME 329 BHP NATURAL GAS-FIRED INTERNAL COMBUSTION ENGINE SERVED BY A 3-WAY CATALYST AND AIR-FUEL RATIO CONTROLLER, POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to commencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
6. {2257} Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
7. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
8. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine annual fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
9. The engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 5 ppmvd NOx @ 15% O2 (equivalent to 0.071 g-NOx/bhp-hr); 0.00285 lb-SOx/MMBtu (equivalent to 0.01 g-SOx/bhp-hr); 0.0706 g-PM10/bhp-hr; 600 ppmvd CO @ 15% O2 (equivalent to 5.19 g-CO/bhp-hr); or 25 ppmvd VOC @ 15% O2 (equivalent to 0.12 g-VOC/bhp-hr). [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
11. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NO_x/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
14. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NO_x and CO. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Upon recommencing operation, the permittee shall monitor operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (e.g. oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit
17. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit
18. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4702] Federally Enforceable Through Title V Permit
20. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
21. Upon recommencing operation, source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
22. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Upon recommencing operation, the permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Upon recommencing operation, the permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: C-14-0-1

EXPIRATION DATE: 08/31/2005

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rule 110 (Fresno)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rule 110 (Fresno)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0 and 4.0; 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: FRESNO COGENERATION PARTNERS
Location: 8105 S LASSEN AVE, SAN JOAQUIN, CA 93660
C-14-0-1: Dec 29 2009 3:22PM - HARRISR

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.6.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520. [District Rules 2520, 9.6.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.8] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.9.1] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.9.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.9.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.9.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.10] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.14.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.14.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.14.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.14.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101, by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rule 401 (Fresno)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall supply, sell, solicit or apply any architectural coating, except specialty coatings, that contains more than 250 grams of VOC per liter of coating (less water and exempt compounds, and excluding any colorant added to tint bases), or manufacture, blend, or repackage such coating with more than 250 grams of VOC per liter (less water and exempt compounds, and excluding any colorant added to tint bases) for use within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. Special Coating Limitations: No person shall apply, sell, solicit, or offer for sale any architectural coating listed in the Table of Standards (District Rule 4601, Table 1 and Table 2), nor manufacture, blend, or repackage such coating for use within the District, which contains VOCs in excess of the specified limits listed in Table 1 (grams of VOC per liter of coating as applied less water and exempt compounds, excluding any colorant added to tint bases) and in Table 2 (grams of VOC per liter of material), except as provided in Section 5.3 of Rule 4601. [District Rule 4601, 5.2] Federally Enforceable Through Title V Permit
25. All VOC-containing materials shall be stored in closed containers when not in use. In use includes, but is not limited to: being accessed, filled, emptied, maintained or repaired. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. A person shall not use VOCs for the cleanup of spray equipment unless equipment for collection of the cleaning compounds and minimizing its evaporation to the atmosphere is used. [District Rule 4601, 5.5] Federally Enforceable Through Title V Permit
27. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.2). [District Rule 4601, 6.1 and 6.2] Federally Enforceable Through Title V Permit
28. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official [District Rule 2520, 9.14.1 and 10.0] Federally Enforceable Through Title V Permit
29. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
30. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart F. [40 CFR Part 82, Subpart F] Federally Enforceable Through Title V Permit
31. Disturbances of soil related to any construction, demolition, excavation, extraction, or water mining activities shall comply with the requirements for fugitive dust control in SJVUAPCD District Rule 8020 unless specifically exempted under section 4 of Rule 8020. [District Rule 8020] Federally Enforceable Through Title V Permit
32. Outdoor handling and storage of any bulk material which emits dust shall comply with the requirements of SJVUAPCD Rule 8030, unless specifically exempted under section 4 of Rule 8030. [District Rule 8030] Federally Enforceable Through Title V Permit
33. Any paved road over 3 miles in length, and any unpaved roads over half a mile in length, constructed after December 10, 1993 shall use the design criteria and dust control measures of, and comply with the administrative requirements of, SJVUAPCD Rule 8060 unless specifically exempted under section 4 of Rule 8060. [District Rule 8060] Federally Enforceable Through Title V Permit
34. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.17] Federally Enforceable Through Title V Permit
36. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
37. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permit shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
38. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
39. The owner and operator shall submit a single Risk Management Plan (RMP) that includes the information required by 40 CFR Subpart G, sections 68.155 through 68.185 for all covered processes. The RMP shall be submitted in a method and format to a central point as specified by EPA prior to June 21, 1999. [40 CFR 68] Federally Enforceable Through Title V Permit
40. On December 20, 2000, the initial Title V permit was issued, the reporting period of the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of reporting period. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-1-14

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

DORMANT FEED DRYING OPERATION WITH ONE MEC AND ONE GUARANTEED PERFORMANCE ROTARY DRUM DRYERS, TWO SCREE FEEDERS, TWO PRE-KNOCKOUT CYCLONES, AND A MULTICLONE WITH TWO CHAMBERS

PERMIT UNIT REQUIREMENTS

1. The drying operation shall be rendered inoperable through disconnection of the electrical power and controls to this unit. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
2. Permittee shall notify the District's Compliance Division days prior to recommencing operation of this unit, and; within 60 days of recommencing operation, shall conduct particulate matter emission testing on the multiclone outlet by an ARB or District approved contractor. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
3. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,359 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Particulate matter grain loading shall not exceed 0.04 grains/dscf. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
10. Upon recommencing operation, particulate matter emission testing shall be performed on the multiclone outlet annually by an ARB or District approved contractor. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Source testing for particulate matter shall be performed according to EPA Method 5. [District Rule 4201, 4.1] Federally Enforceable Through Title V Permit
12. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-2-8

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

HAMMERMILL OPERATION, INCLUDING TWO HAMMERMILLS WITH TWO FANS, PREKNOCKOUT CYCLONES AND ONE BAGHOUSE

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Visible emissions from the exhaust of the baghouse serving the hammermill shall not equal or exceed 5% opacity for a period or periods aggregating more than three minutes in any one hour. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Particulate matter (PM10) emissions from this permit unit shall not exceed 0.012 lb/ton of throughput nor 5.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The baghouse shall be equipped with a pressure differential gauge to indicate the pressure drop across the bags. The gauge shall be maintained in good working condition at all times and shall be located in an easily accessible location. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
11. A spare set of bags shall be maintained on the premises at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The baghouse cleaning frequency and duration shall be adjusted to optimize the control efficiency. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The baghouse shall be maintained as follows: 576, Needled polyester (16 oz.) filter bags; 10,000 SF filter area; 25,000 - 37,500 ACFM air flow; 3.47/5.1 : 1 air-to-cloth ratio; and 5" W.C. pressure drop. [District Rule 2201] Federally Enforceable Through Title V Permit
14. The bags shall be replaced whenever the normal cleaning procedure does not result in a pressure drop across the bags of 6" water column or less. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Particulate matter concentrations shall not exceed 0.015 grains/dscf. [District Rule 4201 and District Rule 2201] Federally Enforceable Through Title V Permit
16. Permittee shall keep a record of the daily hammermill throughput, in tons. [District Rule 2201] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-4-4

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED IC ENGINE POWERING AN EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 406 (Fresno)] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed in concentration at the point of discharge 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be operated with the timing retarded four degrees from the manufacturer's standard recommended timing. [District NSR Rule] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, and the purpose of the operation (for example, load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
9. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-5-4

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 406 (Fresno)] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed in concentration at the point of discharge 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The engine shall be operated with the timing retarded four degrees from the manufacturer's standard recommended timing. [District NSR Rule] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. During periods of maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example, oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit
9. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of hours of emergency and non-emergency operation. Records shall include the date, the initial start-up hours, the number of hours of operation, the purpose of the operation (for example, load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701, 4702, 17 CCR 93115, and 2520 9.4.2] Federally Enforceable Through Title V Permit
11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-10-9

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Gas turbine shall be equipped with a calibrated continuous monitoring system to measure and record hours of operation and fuel consumption. [District Rules 2201, 2520 9.4.2, and 4703 6.2.1] Federally Enforceable Through Title V Permit
5. The gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The heat input to the turbine shall not exceed 1,320,000 MMBtu/year based on a 12-month rolling sum. Compliance with this limit shall be determined at the end of each month. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NOx/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emissions rate, or Permit to Operate is surrendered or sold. [District Rule 2201] Federally Enforceable Through Title V Permit
11. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NOx and CO. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. This unit shall be fired exclusively on PUC-quality natural gas and the PUC-quality natural gas shall have a total sulfur content of less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
13. The fuel sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, or tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or GAS Processors Association Standard 2377. If the fuel sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a fuel sulfur content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
14. Except during thermal stabilization, emission rates from the gas turbine shall not exceed any of the following: PM10: 2.22 lb/hr, SOx (as SO2): 0.98 lb/hr, NOx (as NO2): 5.0 ppmvd @ 15% O2 and 6.20 lb/hr (based on a 3-hour average), VOC: 2.0 ppmvd @ 15% O2 and 0.88 lb/hr, CO: 12.0 ppmvd @ 15% O2 and 8.07 lb/hr (based on a 3-hour rolling average), or ammonia: 10 ppmvd @ 15% O2 (based on a 1-hour rolling average). [District Rules 2201, 4301, 4102 and 40 CFR Part 60 Subpart GG] Federally Enforceable Through Title V Permit
15. During thermal stabilization, emission rates from the gas turbine shall not exceed any of the following: PM10: 2.22 lb/hr, SOx (as SO2): 0.98 lb/hr, NOx (as NO2): 20 lb/hr (based on a 3-hour rolling average), VOC: 0.88 lb/hr, CO: 8.07 lb/r (based on a 3-hour rolling average), or ammonia: 20 ppmvd @ 15% O2 (based on a 1-hour rolling average). [District Rules 2201, 4301, 4102 and 40 CFR Part 60 Subpart GG] Federally Enforceable Through Title V Permit
16. The thermal stabilization period shall be defined as the startup or shutdown time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
17. Permittee shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100] Federally Enforceable Through Title V Permit
18. In the event of a breakdown of monitoring equipment, the owner shall notify the APCO as soon as reasonably possible, but no later than eight (8) hours after its detection, unless the owner or operator demonstrates to the APCO's satisfaction that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the APCO of the intent to shut down any monitoring equipment at least 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. A violation of emissions standards indicated by the CEM system shall be reported to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
20. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100] Federally Enforceable Through Title V Permit
21. Compliance with the ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O2 = $((a-(b \times c/1,000,000)) \times 1,000,000/b)$, where a = ammonia injection rate (lb/hr)/17 lb/lb.mol, b = dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol), and c = change in measure NOx concentration ppmv @ 15% O2 across catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Compliance testing to measure the PM10, NOx (as NO2), VOC, CO, ammonia emissions, and fuel gas sulfur content of this permit unit shall be conducted at least once every twelve months. [District Rules 2201 and 4703, 6.3 and 40 CFR 60.332 (a), (b) and 40 CFR 60.333] Federally Enforceable Through Title V Permit
23. The following test methods shall be used. PM10: EPA Method 5 (front half and back half), NOx: EPA Method 7E or 20, CO: EPA Method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4703, 6.4, and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a),(b) and District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
25. Permittee shall comply with all applicable source sampling requirements of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Compliance demonstration (source testing) shall be District witnessed, or authorized and the samples shall be collected by a California Air Resources Board certified testing laboratory. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days of source testing. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The owner or operator shall install, certify, maintain, operate, and quality-assure a Continuous Emissions Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x (before and after the SCR catalyst), CO, and O₂ concentrations. The CEMS shall be capable of monitoring emissions during startups and shutdowns, as well as during normal operating conditions. [40 CFR 50.334(b) and District Rules 1080, 2201, and 4703] Federally Enforceable Through Title V Permit
29. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
30. Results of the CEM system shall be averaged over three hour periods using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703 5.1, 6.4] Federally Enforceable Through Title V Permit
31. The NO_x, CO, and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60 Appendix B Performance Specifications 2 and 3. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
32. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown, or malfunction, performance testing evaluations, calibration, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emissions measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
33. Audits of continuous emissions monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
34. The owner/operator shall perform a relative accuracy test (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
35. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. this summary shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventative measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period and used to determine compliance with an emissions standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit
37. The owner or operator shall report periods of excess emissions that are defined as follows: any one-hour period during which the average-water-to-fuel ratio (when the CEMS is not operational and Dry-Low NOx technology is not being used), as measured by the continuous monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance with the NOx emission limit. Each report shall include average water-to-fuel ratio, average fuel consumption, ambient conditions, and gas turbine load. [40 CFR 60.334(c)(1)] Federally Enforceable Through Title V Permit
38. Results of the CEM system shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3 or by other methods deemed equivalent by mutual agreement with the District, the California Air Resources Board, and the Environmental Protection Agency. [District Rule 1080, 6.0] Federally Enforceable Through Title V Permit
39. The continuous monitor of fuel, water, and water-to-fuel ratio system shall be used to determine the fuel consumption and the water-to-fuel ratio necessary to comply with the NOx emissions limits at 30, 50, 75, and 100% of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. [40 CFR 60.335(c)(2)] Federally Enforceable Through Title V Permit
40. The minimum ammonia injection rate shall be reported to the District and the injection rate shall be monitored by the operator during CEM breakdowns to demonstrate NOx emission compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
41. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the required monitoring devices to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
42. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.4 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
43. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, and calculated NOx mass emission rates (lb/hr). [District Rules 2201 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-11-5

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)

PERMIT UNIT REQUIREMENTS

1. The HRSG bypass stack shall only be utilized when the main stack is not utilized (except during transition periods between the stacks) and the HRSG bypass stack shall be subject to all of the same requirements as the main stack at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The owner/operator shall perform an initial relative accuracy test as specified by 40 CFR Part 60 Appendix B to certify the new stack probe in the HRSG bypass stack, and every 720 stack operating hours per 40 CFR Part 75 Appendix B Section 2.3.3 thereafter. [District Rule 1080] Federally Enforceable Through Title V Permit
3. Calibration gas audit linearity checks shall be performed quarterly or every 168 stack operating hours per 40 CFR Part 75 Appendix B Section 2.2.4. [District Rule 1080] Federally Enforceable Through Title V Permit
4. Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
7. This unit shall be fired exclusively on PUC-quality natural gas and the PUC-quality natural gas shall have a total sulfur content less than or equal to 1.0 gr/100 scf. [40 CFR 60.333(b) and District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
8. The fuel sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If the fuel sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a fuel sulfur content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
9. Gas turbine heat input shall not exceed 2,824,250 MMBtu/year based on a 12-month rolling sum. Compliance with this limit shall be determined at the end of each month. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NO_x/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
14. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, and 4) daily emissions measured by CEMS. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Except during thermal stabilization, emission rates from the gas turbine shall not exceed any of the following: 2.0 ppmvd NO_x @ 15% O₂ (based on a 3-hour rolling average), 0.0029 lb-SO_x/MMBtu, 0.0066 lb-PM₁₀/MMBtu, 20 ppmv CO @ 15% O₂, 2 ppmv VOC @ 15% O₂, or 10 ppmv-ammonia @ 15% O₂ (based on a 1-hour rolling average). [40 CFR 60.332, District NSR and District Rules 4703, 5.1 and 5.2 and 4102] Federally Enforceable Through Title V Permit
17. During thermal stabilization, emissions rates from the gas turbine shall not exceed any of the following: 20 lb-NO_x/hr (based on a 3-hour rolling average), 1.25 lb-SO_x/hr, 2.85 lb-PM₁₀/hr, 19.40 lb-CO/hr (based on a 3-hour rolling average), 1.12 lb-VOC/hr, or 20 ppmv-ammonia @ 15% O₂ (based on a 1-hour rolling average). [40 CFR 60.332, District NSR Rule and District Rules 4703, 5.1 and 5.2 and 4102] Federally Enforceable Through Title V Permit
18. Ammonia slip shall be calculated as follows: ammonia slip ppmv @ 15% O₂ = {[a-(b x c/1,000,000)] x 1,000,000/b}, where a = ammonia injection rate (lb/hr)/17 (lb/lb mol), b = dry exhaust gas flow rate (lb/hr)/29 (lb/lb mol), and c = change in measured NO_x concentration ppmv at 15% O₂ across the catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
19. The thermal stabilization period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
20. Compliance testing to measure the PM₁₀, NO_x (as NO₂), VOC, CO, ammonia emissions, and fuel gas sulfur of this permit unit shall be conducted at least once every twelve months. [District Rules 2201, 4703, 6.3, 40 CFR 60.332(a), (b), and 40 CFR 60.333] Federally Enforceable Through Title V Permit
21. The following test methods shall be used. PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E or 20, CO: EPA Method 10 or 10B, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rule 1081; District Rule 4703, 6.4; and 40 CFR 60.335(b)] Federally Enforceable Through Title V Permit
22. HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a)(b) and District Rule 4703, 6.4.5] Federally Enforceable Through Title V Permit
23. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. For units equipped with CEM, CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

27. Permittee shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100] Federally Enforceable Through Title V Permit
28. The District shall be notified in writing within 10 days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100] Federally Enforceable Through Title V Permit
29. The owner or operator shall install, certify, maintain, operate, and quality-assure a Continuous Emissions Monitoring System (CEMS) which continuously measures and records the exhaust gas NO_x (before and after the SCR catalyst) and O₂ concentrations. The CEMS shall be capable of monitoring emissions during startups and shutdowns, as well as during normal operating conditions. [40 CFR 50.334(b) and District Rules 1080, 2201, and 4703] Federally Enforceable Through Title V Permit
30. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period. [40 CFR 60.334(b)(2) and District Rule 1080] Federally Enforceable Through Title V Permit
31. Results of the CEM system shall be averaged over three hour periods using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NO_x, EPA Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for SO₂, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
32. The NO_x, CO, and O₂ CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60 Appendix B Performance Specifications 2, 3, and 4A. [40 CFR 60.334(b)(1) and District Rule 1080] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown, or malfunction, performance testing evaluations, calibration, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emissions measurements. [40 CFR 60.7(b) and District Rule 1080] Federally Enforceable Through Title V Permit
34. Audits of continuous emissions monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Permittee shall comply with all applicable source sampling requirements of District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The owner/operator shall perform a relative accuracy test (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
37. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
38. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO_x emissions, nature and the cause of excess (if known), corrective actions taken and preventative measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period and used to determine compliance with an emissions standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the required monitoring devices to ensure that such devices are functioning properly. [District Rule 1080] Federally Enforceable Through Title V Permit
40. Results of the CEM system shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3 or by other methods deemed equivalent by mutual agreement with the District, the California Air Resources Board, and the Environmental Protection Agency. [District Rule 1080, 6.0] Federally Enforceable Through Title V Permit
41. In the event of a breakdown of monitoring equipment, the owner shall notify the APCO as soon as reasonably possible, but no later than eight (8) hours after its detection, unless the owner or operator demonstrates to the APCO's satisfaction that a longer reporting period was necessary, and shall initiate repairs. The owner shall inform the APCO of the intent to shut down any monitoring equipment at last 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of the following: 1) the occurrence and duration of any start-up, shutdown, or malfunction in the operation of the permit unit; 2) performance testing, evaluations, calibrations, checks, adjustments, and maintenance of CEMS; and 3) emission measurements. [District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of the following: 1) annual hours of operation, 2) daily and annual fuel consumption, 3) daily and annual continuous emission monitor measurements, 4) daily calculated ammonia slip, and 5) daily and annual emission rates. [District Rules 2201 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
44. Permittee shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: 1) time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; 2) averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; 3) applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and 4) the nature of system repairs and adjustments; 5) a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
45. Permittee shall maintain on file copies of natural gas bills. [District Rule 2201] Federally Enforceable Through Title V Permit
46. A violation of emission standards indicated by the CEM system shall be reported to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
47. The minimum ammonia injection rate shall be reported to the District and the injection rate shall be monitored during CEM breakdowns to demonstrate NOx emission compliance. [District Rule 4703, 6.2.5] Federally Enforceable Through Title V Permit
48. The permittee shall maintain the following records: date and time, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, and maintenance of any continuous emission monitor. [District Rule 4703, 6.2.4 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
49. The permittee shall maintain the following records: hours of operation, fuel consumption (scf/hr and scf/rolling twelve month period), continuous emission monitor measurements, and calculated NOx mass emission rates (lb/hr). [District Rules 2201 and 2529, 9.4.2] Federally Enforceable Through Title V Permit
50. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

52. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
53. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
54. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
55. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
56. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
57. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
58. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
59. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
60. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
61. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
62. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
63. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
64. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

65. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
66. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-14-12-3

EXPIRATION DATE: 08/31/2005

EQUIPMENT DESCRIPTION:

DORMANT FULL-TIME 329 BHP NATURAL GAS-FIRED INTERNAL COMBUSTION ENGINE SERVED BY A 3-WAY CATALYST AND AIR-FUEL RATIO CONTROLLER, POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
3. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Operators shall notify the District at least seven (7) calendar days prior to commencing operation of this dormant emissions unit, at which time this permit will be administratively modified to remove DEU references. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
6. Sulfur compound emissions shall not exceed 0.2% by volume, 2,000 ppmv, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
8. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine annual fuel usage. [District Rule 4702] Federally Enforceable Through Title V Permit
9. The engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 5 ppmvd NOx @ 15% O2 (equivalent to 0.071 g-NOx/bhp-hr); 0.00285 lb-SOx/MMBtu (equivalent to 0.01 g-SOx/bhp-hr); 0.0706 g-PM10/bhp-hr; 600 ppmvd CO @ 15% O2 (equivalent to 5.19 g-CO/bhp-hr); or 25 ppmvd VOC @ 15% O2 (equivalent to 0.12 g-VOC/bhp-hr). [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
11. Units subject to the Specific Limiting Condition (SLC) plan are C-14-1, '-2, '-10, '-11, and '-12. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Combined emission rate for all units subject to the SLC plan shall not exceed any of the following: 120.9 lb-PM10/day, 50.9 lb-SOx/day, 209.2 lb-NOx/day, 562.7 lb-CO/day, or 45.7 lb-VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The combined annual emissions rates for all units subject to the SLC plan shall not exceed either of the following: 48,539 lb-NO_x/year or 199,889 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
14. For each unit subject to the SLC, the permittee shall maintain all necessary records in order to show compliance with the daily and annual SLC limits, including (but not limited to) the following: 1) amount of fuel used, 2) HHV of fuel, 3) calculated daily emissions for each air contaminant emitted, 4) daily emissions measured by CEMS, 5) and calculated combined annual emissions for NO_x and CO. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The permittee shall apply to revise each Permit to Operate subject to the SLC when any unit subject to the SLC has a District-authorized change in daily emission rate, or Permit to Operate is surrendered or sold. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Upon recommencing operation, the permittee shall monitor operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (e.g. oil pressure, exhaust gas temperature, etc.). [District Rule 4702] Federally Enforceable Through Title V Permit
17. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit
18. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4702] Federally Enforceable Through Title V Permit
20. Upon recommencing operation, the permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
21. Upon recommencing operation, source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
22. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Upon recommencing operation, the permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
28. Upon recommencing operation, the permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

Detailed Facility Report
For Facility=14 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

FRESNO COGENERATION PARTNERS 8105 S LASSEN AVE SAN JOAQUIN, CA 93660	FAC # STATUS: TELEPHONE:	C 14 A (209) 693-2494	TYPE: TOXIC ID:	TitleV 40000	EXPIRE ON: AREA: INSP. DATE:	08/31/2005 9/ 05/10
---	--------------------------------	-----------------------------	--------------------	-----------------	------------------------------------	---------------------------

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
C-14-1-14	1,336 HP ELECTRIC MOTOR RATING	3020-01 G	1	815.00	815.00	A	DORMANT FEED DRYING OPERATION WITH ONE MEC AND ONE GUARANTEED PERFORMANCE ROTARY DRUM DRYERS, TWO SCREE FEEDERS, TWO PRE-KNOCKOUT CYCLONES, AND A MULTICLONE WITH TWO CHAMBERS
C-14-2-8	710.7 total electric HP	3020-01 F	1	607.00	607.00	A	HAMMERMILL OPERATION, INCLUDING TWO HAMMERMILLS WITH TWO FANS, PREKNOCKOUT CYCLONES AND ONE BAGHOUSE
C-14-4-4	136 bhp IC engine	3020-10 B	1	117.00	117.00	A	136 BHP CUMMINS MODEL #V378F2 DIESEL-FIRED IC ENGINE POWERING AN EMERGENCY FIRE WATER PUMP
C-14-5-4	534 bhp IC engine	3020-10 D	1	479.00	479.00	A	534 HP CATERPILLAR MODEL #3406B DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
C-14-10-9	23,000 kW	3020-08A F	1	8,171.00	8,171.00	A	23 MW ELECTRICAL GENERATOR POWERED BY A PRATT AND WHITNEY MODEL FT4A9 GAS-FIRED, SIMPLE CYCLE TURBINE ENGINE WITH DRY LOW NOX (DLN) TECHNOLOGY OR WATER INJECTION, A SELECTIVE CATALYTIC REDUCTIONS (SCR) SYSTEM, AN OXIDATION CATALYST, AN INLET AIR EVAPORATIVE COOLER, AND LUBE OIL VENT MIST ELIMINATORS
C-14-11-5	55,000 kW	3020-08B G	1	10,215.00	10,215.00	A	55 MW COGENERATION UNIT INCLUDING 45 MW GENERAL ELECTRIC LM-6000PC GAS TURBINE WITH SELECTIVE CATALYTIC REDUCTION AND CO OXIDATION CATALYST, 10 MW STEAM TURBINE, AND HEAT RECOVERY STEAM GENERATOR WITH A HRSG BYPASS STACK (REPLACES C-14-3)
C-14-12-3	329 BHP NATURAL GAS-FIRED IC ENGINE	3020-10 C	1	240.00	240.00	A	DORMANT FULL-TIME 329 BHP NATURAL GAS-FIRED INTERNAL COMBUSTION ENGINE SERVED BY A 3-WAY CATALYST AND AIR-FUEL RATIO CONTROLLER, POWERING AN ELECTRICAL GENERATOR

Number of Facilities Reported: 1

ATTACHMENT D

Rule 4601-Architectural Coatings
VOC Limit Tables

TABLE OF STANDARDS

Limits are expressed in grams of VOC per liter^a of coating thinned to the manufacturer's maximum recommendation, excluding the volume of any water, exempt compounds, or colorant added to tint bases. Manufacturer's maximum recommendation means the maximum recommendation for thinning that is indicated on the label or lid of the coating container.

COATING CATEGORY	EFFECTIVE DATES	
	10/31/01	1/1/2003
Flat Coatings	250	100
Nonflat Coatings	250	150
Nonflat - High Gloss Coatings	250	250
Specialty Coatings		
Antenna Coatings	530	530
Antifouling Coatings	400	400
Bituminous Roof Coatings	300	300
Bituminous Roof Primers	350	350
Bond Breakers	350	350
Clear Wood Coatings:		
Clear Brushing Lacquers	680	680
Lacquers (including lacquer sanding sealers)	680	550
Sanding Sealers (other than lacquer sanding sealers)	350	350
Varnishes	350	350
Concrete Curing Compounds	350	350
Dry Fog Coatings	400	400
Faux Finishing Coatings	350	350
Fire Resistive Coatings	350	350
Fire-Retardant Coatings:		
Clear	650	650
Opaque	350	350
Floor Coatings	250	250
Flow Coatings	420	420
Form-Release Compounds	250	250
Graphic Arts Coatings (Sign Paints)	500	500
High Temperature Coatings	420	420
Industrial Maintenance Coatings	340	250 (Effective 1/1/04)
Low Solids Coatings	120 ^b	120 ^b
Magnesite Cement Coatings	450	450
Mastic Texture Coatings	300	300
Metallic Pigmented Coatings	500	500
Multi-Color Coatings	420	250
Pre-Treatment Wash Primers	420	420
Primers, Sealers, and Undercoaters	350	200
Quick-Dry Enamels	400	250
Quick-Dry Primers, Sealers and Undercoaters	450	200
Recycled Coatings	250	250

TABLE OF STANDARDS, continued

EFFECTIVE DATES

	10/31/01	1/1/2003
Roof Coatings	250	250
Rust Preventative Coatings	400	400
Shellacs:		
Clear	730	730
Opaque	550	550
Specialty Primers, Sealers, and Undercoaters	350	350
Stains	350	250
Swimming Pool Coatings	340	340
Swimming Pool Repair and Maintenance Coatings	340	340
Temperature-Indicator Safety Coatings	550	550
Traffic Marking Coatings	150	150
Waterproofing Sealers	400	250
Waterproofing Concrete/Masonry Sealers	400	400
Wood Preservatives	350	350

a Conversion factor: one pound VOC per gallon (U.S.) = 119.95 grams VOC per liter.

b Units are grams of VOC per liter of coating, including water and exempt compounds in accordance with Section 3.27.

6.0 Administrative Requirements

6.1 Labeling Requirements: Each manufacturer of any architectural coating subject to this rule shall display the information listed in Sections 6.1.1 through 6.1.9 on the coating container (or label) in which the coating is sold or distributed.

6.1.1 Date Code: The date the coating was manufactured, or a date code representing the date, shall be indicated on the label, lid or bottom of the container. If the manufacturer uses a date code for any coating, the manufacturer shall file an explanation of each code with the Executive Officer of the ARB.

6.1.2 Thinning Recommendations: A statement of the manufacturer's recommendation regarding thinning of the coating shall be indicated on the label or lid of the container. This requirement does not apply to the thinning of architectural coatings with water. If thinning of the coating prior to use is not necessary, the recommendation must specify that the coating is to be applied without thinning.

6.1.3 VOC Content: Each container of any coating subject to this rule shall display either the maximum or actual VOC content of the coating, as supplied, including the maximum thinning as recommended by the manufacturer. VOC content shall be displayed in grams of VOC per liter of coating. VOC content displayed shall be calculated using product formulation data, or shall be determined using the test methods in Section 6.3.1. The equations in Sections 3.25 or 3.26, as appropriate, shall be used to calculate VOC content.

TABLE OF STANDARDS 1 (Effective through 12/31/10)

Limits are expressed in grams of VOC per liter^a of coating thinned to the manufacturer's maximum recommendation, excluding the volume of any water, exempt compounds, or colorant added to tint bases. Manufacturer's maximum recommendation means the maximum recommendation for thinning that is indicated on the label or lid of the coating container.

COATING CATEGORY	Effective Date: 1/1/2003
Flat Coatings	100
Nonflat Coatings	150
Nonflat - High Gloss Coatings	250
Specialty Coatings	
Antenna Coatings	530
Antifouling Coatings	400
Bituminous Roof Coatings	300
Bituminous Roof Primers	350
Bond Breakers	350
Clear Wood Coatings:	
Clear Brushing Lacquers	680
Lacquers (including lacquer sanding sealers)	550
Sanding Sealers (other than lacquer sanding sealers)	350
Varnishes	350
Concrete Curing Compounds	350
Dry Fog Coatings	400
Faux Finishing Coatings	350
Fire Resistive Coatings	350
Fire-Retardant Coatings:	
Clear	650
Opaque	350
Floor Coatings	250
Flow Coatings	420
Form-Release Compounds	250
Graphic Arts Coatings (Sign Paints)	500
High Temperature Coatings	420
Industrial Maintenance Coatings	250
Low Solids Coatings	120 ^b
Magnesite Cement Coatings	450
Mastic Texture Coatings	300
Metallic Pigmented Coatings	500
Multi-Color Coatings	250

TABLE OF STANDARDS 1, continued (Effective through 12/31/10)

COATING CATEGORY	Effective Date: 1/1/2003
Pre-Treatment Wash Primers	420
Primers, Sealers, and Undercoaters	200
Quick-Dry Enamels	250
Quick-Dry Primers, Sealers and Undercoaters	200
Recycled Coatings	250
Roof Coatings	250
Rust Preventative Coatings	400
Shellacs:	
Clear	730
Opaque	550
Specialty Primers, Sealers, and Undercoaters	350
Stains	250
Swimming Pool Coatings	340
Swimming Pool Repair and Maintenance Coatings	340
Temperature-Indicator Safety Coatings	550
Traffic Marking Coatings	150
Waterproofing Sealers	250
Waterproofing Concrete/Masonry Sealers	400
Wood Preservatives	350

a Conversion factor: one pound VOC per gallon (U.S.) = 119.95 grams VOC per liter.

b Units are grams of VOC per liter of coating, including water and exempt compounds in accordance with Section 3.27.

TABLE OF STANDARDS 2 (Effective on and after 1/1/11)

Limits are expressed as VOC Regulatory, thinned to the manufacturer's maximum thinning recommendation, excluding any colorant added to tint bases.

COATING CATEGORY	VOC Limit (g/l) Effective 1/1/2011 through 12/31/2011 ²	VOC Limit (g/l) Effective on and after 1/1/2012 ²
Flat Coatings	50	50
Nonflat Coatings	100	100
Nonflat - High Gloss Coatings	150	150
Specialty Coatings		
Aluminum Roof Coatings	400	400
Basement Specialty Coatings *	400	400
Bituminous Roof Coatings	50	50
Bituminous Roof Primers	350	350
Bond Breakers	350	350
Concrete Curing Compounds	350	350
Concrete/Masonry Sealers #	100	100
Driveway Sealers †	50	50
Dry Fog Coatings	150	150
Faux Finishing Coatings	350	350
Fire Resistive Coatings	350	350
Floor Coatings	100	100
Form-Release Compounds	250	250
Graphic Arts Coatings (Sign Paints)	500	500
High Temperature Coatings	420	420
Industrial Maintenance Coatings	250	250
Low Solids Coatings ¹	120 ¹	120 ¹
Magnesite Cement Coatings	450	450
Mastic Texture Coatings	100	100
Metallic Pigmented Coatings	500	500
Multi-Color Coatings	250	250
Pre-Treatment Wash Primers	420	420
Primers, Sealers, and Undercoaters	100	100
Reactive Penetrating Sealers ‡	350	350
Recycled Coatings	250	250
Roof Coatings	50	50
Rust Preventative Coatings	400	250

TABLE OF STANDARDS 2 (continued) (Effective on and after 1/1/11)

Limits are expressed as VOC Regulatory, thinned to the manufacturer's maximum thinning recommendation, excluding any colorant added to tint bases.

COATING CATEGORY	VOC Limit (g/l) Effective 1/1/2011 through 12/31/2011 ²	VOC Limit (g/l) Effective on and after 1/1/2012 ²
Shellacs:		
Clear	730	730
Opaque	550	550
Specialty Primers, Sealers, and Undercoaters	350	100
Stains	250	250
Stone Consolidants ✎	450	450
Swimming Pool Coatings	340	340
Traffic Marking Coatings	100	100
Tub and Tile Refinish Coatings ↗	420	420
Waterproofing Membranes ✎	250	250
Wood Coatings ✎	275	275
Wood Preservatives	350	350
Zinc-Rich Primers ✎	340	340

1 Units are grams of VOC per liter of coating, including water and exempt compounds in accordance with Section 3.77.

2 The dates listed do not preclude voluntary compliance with the applicable limit prior to those dates.

6.0 Administrative Requirements

6.1 Labeling Requirements: Each manufacturer of any architectural coating subject to this rule shall display the information listed in Sections 6.1.1 through 6.1.14 on the coating container (or label) in which the coating is sold or distributed.

6.1.1 Date Code: The date the coating was manufactured, or a date code representing the date, shall be indicated on the label, lid or bottom of the container. If the manufacturer uses a date code for any coating, the manufacturer shall file an explanation of each code with the Executive Officer of the ARB.