



# San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



HEALTHY AIR LIVING™

JUN 14 2011

Mike Tollstrup, Chief  
Project Assessment Branch  
Stationary Source Division  
California Air Resources Board  
PO Box 2815  
Sacramento, CA 95812-2815

**RE: Notice of Final Action - Authority to Construct  
Project Number: N-1110516**

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued Authority to Construct permits to City of Stockton for the installation of a 954 bhp diesel-fired emergency engine powering an electrical generator, at 1001 Correia Road, Stockton.

Enclosed is a copy of the Authority to Construct permit and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on May 13, 2011. The District's analysis of the proposal was also sent to CARB on May 11, 2011. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill at (209) 557-6400.

Sincerely,

David Warner  
Director of Permit Services

DW:fjc/st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bekersfield, CA 93308-8725  
Tel: 861-392-5500 FAX: 661-392-5585

Stockton Record

**NOTICE OF FINAL ACTION  
FOR THE ISSUANCE OF AUTHORITY  
TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to City of Stockton for the installation of a 954 bhp diesel-fired emergency engine powering an electrical generator, at 1001 Correia Road, Stockton.

No comments were received following the District's preliminary decision on this project.

The application review for Project #N-1110516 is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.**



## AUTHORITY TO CONSTRUCT

**PERMIT NO:** N-8543-1-0

**ISSUANCE DATE:** 06/13/2011

**LEGAL OWNER OR OPERATOR:** CITY OF STOCKTON  
**MAILING ADDRESS:** ATTN: MICHAEL CALLAHAN  
2500 NAVY DRIVE  
STOCKTON, CA 95206

**LOCATION:** 1001 CORREIA RD  
STOCKTON, CA 95219

**EQUIPMENT DESCRIPTION:**  
954 BHP DOOSAN MODEL 22L DIESEL-FIRED (TIER 2 CERTIFIED) EMERGENCY ENGINE POWERING AN ELECTRIC GENERATOR.

### CONDITIONS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. The exhaust stack release height shall be at least 12 feet. [District Rule 4102]
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115, and 40 CFR 60 Subpart III]
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart III]
8. Emissions from this IC engine shall not exceed any of the following limits: 3.75 g-NOx/bhp-hr, 0.70 g-CO/bhp-hr, or 0.25 g-VOC/bhp-hr. [District Rule 2201, 17 CCR 93115, and 40 CFR Part 60 Subpart III]
9. Emissions from this IC engine shall not exceed 0.10 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115, and 40 CFR Part 60 Subpart III]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

  
DAVID WARNER, Director of Permit Services

N-8543-1-0 Jun 13 2011 9:07AM - CRUZ : Joint Inspection NOT Required

10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart IIII]
11. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
12. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
13. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]
14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115]
15. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
16. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115]
17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115]