



# San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

JUL 08 2011

Mike Tollstrup, Chief  
Project Assessment Branch  
Air Resources Board  
P O Box 2815  
Sacramento, CA 95812-2815

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # N-770  
Project # N-1094359**

Dear Mr. Tollstrup:

The District has issued the Final Renewed Title V Permit for Ripon Cogeneration, LLC. The preliminary decision for this project was made on May 12, 2010. No comments were received subsequent to the District preliminary decision.

Enclosed are the Renewed Title V Permit and a public notice that will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. Should you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,

David Warner  
Director of Permit Services

DW:JK/st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061  
[www.valleyair.org](http://www.valleyair.org)

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: (661) 392-5500 FAX: (661) 392-5585



JUL 08 2011

Gerardo C. Rios, Chief  
Permits Office (AIR-3)  
U.S. EPA - Region IX  
75 Hawthorne St.  
San Francisco, CA 94105

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # N-770  
Project # N-1094359**

Dear Mr. Rios:

The District has issued the Final Renewed Title V Permit for Ripon Cogeneration, LLC. The preliminary decision for this project was made on May 12, 2010. No comments were received subsequent to the District preliminary decision.

Enclosed are the Renewed Title V Permit and a public notice that will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. We appreciate your concurrence with this action. Should you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,



David Warner  
Director of Permit Services

DW:JK/st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



# San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT

JUL 08 2011

Jim Groff  
Ripon Cogeneration, LLC  
944 S Stockton Ave  
Ripon, CA 95366

**Re: Notice of Final Action - Title V Permit Renewal  
District Facility # N-770  
Project # N-1094359**

Dear Mr. Groff:

The District has issued the Final Renewed Title V Permit for Ripon Cogeneration, LLC. The preliminary decision for this project was made on May 12, 2010. No comments were received subsequent to the District preliminary decision.

Enclosed are the Renewed Title V Permit and a public notice that will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. Should you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,

David Warner  
Director of Permit Services

DW:JK/st

Enclosures

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061  
[www.valleyair.org](http://www.valleyair.org)

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: (661) 392-5500 FAX: (661) 392-5585

**SAN JOAQUIN VALLEY  
AIR POLLUTION CONTROL DISTRICT  
NOTICE OF FINAL DECISION TO ISSUE  
RENEWED FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue the renewed Federally Mandated Operating Permit to Ripon Cogeneration, LLC for its cogeneration facility 944 S Stockton Ave, Ripon, California.

The District's analysis of the legal and factual basis for this proposed action, project #N-1094359, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and the District office at the address below. For additional information regarding this matter, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400, or contact David Warner, Director of Permit Services, in writing at SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356-8718.



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT

  
**HEALTHY AIR LIVING™**

# Permit to Operate

**FACILITY:** N-770

**EXPIRATION DATE:** 04/30/2016

**LEGAL OWNER OR OPERATOR:**  
**MAILING ADDRESS:**

RIPON COGENERATION LLC  
944 S STOCKTON AVE  
RIPON, CA 95366

**FACILITY LOCATION:**

944 S STOCKTON AVE  
RIPON, CA 95366

**FACILITY DESCRIPTION:**

COGENERATION FACILITY

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

**Seyed Sadredin**  
Executive Director / APCO

**David Warner**  
Director of Permit Services

# San Joaquin Valley Air Pollution Control District

FACILITY: N-770-0-3

EXPIRATION DATE: 04/30/2016

## FACILITY-WIDE REQUIREMENTS

---

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rules 2010, 3.0 & 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 5) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: RIPON COGENERATION LLC  
Location: 944 S STOCKTON AVE, RIPON, CA 95386  
N-770-0-3 - JUL 7 2011 11:10AM - KANLON

11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520. [District Rules 2520, 9.5.2; and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.1] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.8] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit
23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

24. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.



37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1100, Section 6.1 (12/17/92); 2010 section 3.0 (12/17/92); 2070 section 7.0 (12/17/92); 4101 (02/17/05); 4601 Sections 5.1, 5.4, 6.1 and 6.3 (12/17/09). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. The facility shall comply with all applicable requirements regarding preparation and implementation of a risk management plan by June 21, 1999 and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR 68] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of each year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-770-3-8

EXPIRATION DATE: 04/30/2016

## EQUIPMENT DESCRIPTION:

470 MMBTU/HR GENERAL ELECTRIC LM-5000 NATURAL GAS FIRED TURBINE WITH STEAM INJECTION AND SELECTIVE CATALYTIC REDUCTION WITH AMMONIA INJECTION SERVING A 49.9 MW COGENERATION PLANT

## PERMIT UNIT REQUIREMENTS

---

1. The turbine shall be designed and operated at STIG (trademark GE). [District NSR Rule] Federally Enforceable Through Title V Permit
2. A minimum of 45,000 lb/hr of steam at 650 PSIG and 550 degrees F shall be available for injection into the combustion section of the turbine for NOx control, except during start-up and shut-down. [District NSR Rule] Federally Enforceable Through Title V Permit
3. A selective catalytic reduction (SCR) system shall be installed in the path of the heat recovery boiler where the temperature range is 575 degrees F to 750 degrees F. [District NSR Rule] Federally Enforceable Through Title V Permit
4. The permittee shall provide a continuous temperature monitoring and recording system to indicate the flue gas temperature through the SCR system. [District NSR Rule] Federally Enforceable Through Title V Permit
5. There shall be no visible emissions (except for uncombined water) from the entire system. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Ammonia shall be injected into the combustion gases at a ratio determined by source testing to reduce the NOx emission concentration to 5 ppm, dry at 15% oxygen, except for start-up periods of one hour duration and shutdown periods of one-half hour. [District NSR Rule] Federally Enforceable Through Title V Permit
7. The ammonia slip shall not exceed 20 ppmv, dry at 15% oxygen. [District Rule 4102]
8. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding 0.1 gr/dscf in concentration at the point of discharge. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
9. The NOx emissions shall not exceed 5 ppmv dry @ 15% O2 over a one hour averaging period except for start-up periods of one hour duration and shutdown periods of one-half hour duration. [40 CFR60.332(a)(1) and District Rule 4703, 5.1.2] Federally Enforceable Through Title V Permit
10. The CO emissions shall not exceed 200 ppmv dry @ 15% O2 over a one hour averaging period except for start-up periods of one hour duration and shutdown periods of one-half hour duration [District Rule 4703, 5.2] Federally Enforceable Through Title V Permit
11. The NOx emission rate shall not exceed 250 pounds during any one day. [District NSR Rule] Federally Enforceable Through Title V Permit
12. The CO emission rate shall not exceed 1,302 pounds during any one day. [District NSR Rule] Federally Enforceable Through Title V Permit
13. The VOC emission concentration shall not exceed 0.0133 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

14. The SO<sub>x</sub> emission concentration shall not exceed 0.0029 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The PM<sub>10</sub> emission concentration shall not exceed 0.0088 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
16. The daily emission rate shall be calculated by multiplying the hourly emission rate by the number of operating hours. [District NSR Rule] Federally Enforceable Through Title V Permit
17. Performance testing for NO<sub>x</sub> and CO emissions shall be conducted annually using EPA Methods 7E or 20, or ASTM D6522 for NO<sub>x</sub> and EPA Methods 10 or 10B for CO. Oxygen content of the exhaust gas shall be measured by EPA Methods 3, 3A, or 20. [District Rules 4703, 6.3.1, 6.4.1, 6.4.2, 6.4.3 and 2520, 9.3.2; 40 CFR 60.335(a)] Federally Enforceable Through Title V Permit
18. The stack height shall be a minimum of 71 feet and shall be adequate for stack sampling pursuant to EPA reference methods for source testing and shall meet all the requirements of District Rule 1081. [District Rule 1081, 3.2] Federally Enforceable Through Title V Permit
19. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
20. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 day of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
21. If the turbine is fired on PUC-regulated natural gas, the operator shall maintain on file copies of natural gas bills. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Any emissions in excess of the limits imposed by conditions in this permit, as measured by the continuous monitoring equipment constitutes a violation of District Rules and Regulations and shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
23. Operator shall notify the District no later than eight hours after the detection of a breakdown of the CEMS. The operator shall inform the District of the intent to shut down the CEMS at least 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
24. Operator shall maintain a daily log indicating the hourly ammonia injection rate. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rules 4703, 6.2.6; and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080 Sections 4.0, 6.3, 6.4, 6.5, 6.6, 7.1, 7.3, 8.0, 9.0, 10.0, 11.0 (12/17/92); 1081 Sections 3.0, 6.0, 7.1 and 7.2 (12/16/93); 4201, Section 3.0 (12/17/92); 4703 Sections 5.1, 5.1.2, 5.2, 6.2.3, 6.2.4, 6.2.6, 6.2.8, 6.4.1, 6.4.2, and 6.4.3 (9/20/07); 4801 (12/17/92); 40 CFR 60.332(a)(1) (7/8/04), 60.333(b) (7/8/04), 60.334(b) (2/24/06), 60.334(j)(1)(iii) (2/24/06), 60.334(j)(5) (2/24/06), and 60.335(a) (2/24/06). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: San Joaquin County Rules 108, 404, and 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NO<sub>x</sub>, CO, O<sub>2</sub> or CO<sub>2</sub> concentrations. [40 CFR 64; 40 CFR 60.334(b); District Rules 4703, 6.2.1, 6.2.3, and 1080, 4.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

29. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO<sub>x</sub>, CO, and O<sub>2</sub> analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Source Emission Monitoring and Testing. [District Rule 1081] Federally Enforceable Through Title V Permit
30. Results of the CEMS shall be averaged in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1 and 6.2.3] Federally Enforceable Through Title V Permit
31. Audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
32. The owner/operator shall perform a relative accuracy test audit (RATA) as specified by 40 CFR Part 60, Appendix F, 5.1.1, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit
33. During each full unit operating hour, the CEMS must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour. [40 CFR 64; 40 CFR 60.334(b)(2); District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
34. The NO<sub>x</sub>, CO, and O<sub>2</sub> CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specifications 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64; 40 CFR 60.334(b)(1); District Rules 1080, 6.3, 6.5, and 6.6, and 4703, 6.2.3] Federally Enforceable Through Title V Permit
35. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEMS is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
36. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 64; 40 CFR 60.7(b); District Rules 1080, 7.3, and 4703, 6.2.8] Federally Enforceable Through Title V Permit
37. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO<sub>x</sub> and CO emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEMS was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
38. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NO<sub>x</sub> or CO concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO<sub>x</sub>, CO or O<sub>2</sub>. [40 CFR 64 and 40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
40. This unit shall be fired exclusively on natural gas with sulfur content of less than to 0.00398% by weight. [District NSR Rule and District Rule 4201] Federally Enforceable Through Title V Permit
41. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D1072, D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
42. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
43. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [40 CFR 64, District Rule 2520, 9.3.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
44. The owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c) on a semi annual basis. Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined in 40 CFR 60.334(j). All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.334(j); 40 CFR 60.334 (j)(5); District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
45. The unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of 20.0 gr/100 scf or less (equivalent to 0.068% by weight). [40 CFR 60.333(b)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.