

Fresno Bee

**NOTICE OF PRELIMINARY DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
THE PROPOSED SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District solicits public comment on the proposed modification of Fresno/Clovis Regional WWTP for its wastewater treatment facility located at 5607 W. Jensen Avenue in Fresno, California. This ATC authorizes the installation of a digester gas treatment system consisting of a chiller, a compressor, a hydrogen sulfide removal unit, a membrane processing unit, activated carbon adsorption beds and a 7.46 MMBtu/hr waste gas/digester gas fired combustion device.

The District's analysis of the legal and factual basis for this proposed action, project #1110245, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. This will be the public's only opportunity to comment on the specific conditions of the modification. If requested by the public, the District will hold a public hearing regarding issuance of this modification. For additional information, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900. Written comments on the proposed initial permit must be submitted within 30 days of the publication date of this notice to DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.