



AUG 30 2011

Glenn Mount
Modesto Irrigation District
PO Box 4060
Modesto, CA 95352-5060

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # N-3233
Project # N-1091426**

Dear Mr. Mount:

The District has issued the Final Title V Permit for Modesto Irrigation District. The preliminary decision for this project was made on September 9, 2010. No comments were received subsequent to the District preliminary decision. Enclosed are the Renewed Final Title V Permit and public notice to be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Attachments

cc: Juscellino Siongco, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-6718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-8000 FAX: (559) 230-8061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 861-392-5500 FAX: 861-392-5585



AUG 30 2011

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # N-3233
Project # N-1091426**

Dear Mr. Rios:

The District has issued the Final Title V Permit Renewal for Modesto Irrigation District. The preliminary decision for this project was made on September 9, 2010. No comments were received subsequent to the District preliminary decision. Enclosed are the Renewed Final Title V Permit and public notice to be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. We appreciate your concurrence with this action. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Attachments

cc: Juscélino Siongco, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-8000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUG 30 2011

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # N-3233
Project # N-1091426**

Dear Mr. Tollstrup:

The District has issued the Final Title V Permit for Modesto Irrigation District. The preliminary decision for this project was made on September 9, 2010. No comments were received subsequent to the District preliminary decision. Enclosed are the Renewed Final Title V Permit and public notice to be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Attachments

cc: Juscélino Sióngco, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95358-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6081

Southern Region
34948 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Modesto Bee

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT
NOTICE OF FINAL DECISION TO ISSUE
RENEWED FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue the renewed Federally Mandated Operating Permit to Modesto Irrigation District for its electrical generating facility, 920 Woodland Ave, Modesto, California.

The District's analysis of the legal and factual basis for this proposed action, project #N-1091426, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. For additional information regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900, or contact David Warner, Director of Permit Services, in writing at SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.



Permit to Operate

FACILITY: N-3233

EXPIRATION DATE: 11/30/2015

LEGAL OWNER OR OPERATOR:
MAILING ADDRESS:

MODESTO IRRIGATION DISTRICT
GENERATION DEPT ADMIN OFFICES
P O BOX 4060
MODESTO, CA 95352

FACILITY LOCATION:

920 WOODLAND AVENUE
MODESTO, CA 95351

FACILITY DESCRIPTION:

POWER GENERATION FACILITY

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

David Warner
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: N-3233-0-3

EXPIRATION DATE: 11/30/2015

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: MODESTO IRRIGATION DISTRICT
Location: 820 WOODLAND AVENUE, MODESTO, CA 95351
N-3233-0-3: Aug 25 2011 2:07PM - SIONGCOJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1st every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-3233-1-6

EXPIRATION DATE: 11/30/2015

EQUIPMENT DESCRIPTION:

ONE (1) GENERAL ELECTRIC LM5000 PD AERO-DERIVATIVE 460 MMBTU/HR (HHV) GAS TURBINE ENGINE WITH STEAM INJECTION, OXIDIZATION CATALYST, AMMONIA INJECTION, AND SELECTIVE CATALYTIC REDUCTION SERVING A 49.9 MW ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
2. When operating on natural gas, the unit shall be fired exclusively on PUC-regulated natural gas which has a sulfur content of less than or equal to 0.017% by weight. When operating on liquid fuel, the unit shall be fired on low sulfur light distillate fuel with less than or equal to 0.05% sulfur by weight. [District NSR Rule; 40 CFR 60.333(b); Stanislaus County Rule 407] Federally Enforceable Through Title V Permit
3. The sulfur content of each fuel source shall be documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
5. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
6. Operator shall notify the APCO no later than eight hours after the detection of a breakdown of the CEM. Operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
7. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report shall be received by the District within 30 days of the end of the quarter and shall include the following: time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess emissions (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which a CEM was inoperative (monitor downtime), except for zero and span checks and the nature of system repairs and adjustments; a negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
8. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device was inoperative and emission measurements. [40 CFR 60.7 (b) and District Rules 1080, 7.3 and District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year from the date the facility is notified of the problem by the District, provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
10. The Turbine and associated ancillary equipment must be properly maintained and kept in good operating condition at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
11. The Turbine and associated ancillary equipment shall only be operated by personnel properly trained in its operation. [District NSR Rule] Federally Enforceable Through Title V Permit
12. Natural gas; OGT; JP4; Jet A; Jet B; No. 1d; No 1; 1GT; No. 2d; No. 2; and 2GT are the only fuels permitted for combustion in the Turbine. [District NSR Rule] Federally Enforceable Through Title V Permit
13. The Turbine shall be equipped and operated with an Automatic Combustion Control System. [District NSR Rule] Federally Enforceable Through Title V Permit
14. The Turbine shall not be operated unless the exhaust gas is subjected to the Oxidation (CO) Catalyst System and the Selective Catalytic Reduction (SCR) System prior to discharge to the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The CO Catalyst System and the SCR Systems must be in full use whenever the Turbine is in operation, except during start-up and shutdown periods. [District NSR Rule] Federally Enforceable Through Title V Permit
16. The facility-wide CO emissions shall not exceed 199,999 pounds during any one calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
17. The facility-wide SOx emissions shall not exceed 54,750 pounds per year. [District NSR Rule] Federally Enforceable Through Title V Permit
18. The Ammonia Injection System must be utilized whenever the flue gas temperature at the inlet of the SCR System exceeds 550 degrees F, except during start up and shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
19. The NOx emission concentration, measured as NO2, shall not exceed 3.5 ppmv, dry, corrected to 15% O2 when operating on natural gas; and 6.2 ppmv, dry, corrected to 15% O2 when operating on fuel oil, except for start-up or shut-down periods. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
20. A visible emissions inspection shall be conducted after every 400 cumulative hours of operation on fuel oil. If a visible emissions inspection documents opacity, a EPA Method 9 evaluation shall be completed within three working days, or during the next period of operation if the unit ceases firing on fuel oil within the three working day period. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. The CO emission concentration, at maximum heat input capacity shall not exceed 16.0 ppmv, dry, corrected to 15% O2, when operating on Natural Gas, and 20.0 ppmv, dry, corrected to 15% O2, when operating on Fuel Oil, except for start-up and shut-down periods. [District NSR Rule] Federally Enforceable Through Title V Permit
22. The NMHC emission concentration, at maximum heat input capacity shall not exceed 0.000475% by weight, wet, while operating on Natural Gas and 0.000713% by weight, wet, while operating on Fuel Oil, except for start-up and shut-down periods. [District NSR Rule] Federally Enforceable Through Title V Permit
23. The NH3 emission concentration shall not exceed 25.0 ppmv, dry, corrected to 15% O2. [District NSR Rule] Federally Enforceable Through Title V Permit
24. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081, 3.0, and 6.0 (as amended 12/16/93). [District Rule 1081 , 3.0, and 6.0] Federally Enforceable Through Title V Permit
25. All concentrations of gaseous emissions must be expressed in parts per million, by volume, dry basis, corrected to 15% O2. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

26. A complete laboratory analysis of Fuel Oil combusted during any source test shall be provided along with the source test results. Testing shall include, but not be limited to, an ultimate analysis of Fuel Oil & a full set of metals pursuant to AB2588. [District NSR Rule] Federally Enforceable Through Title V Permit
27. Annual performance testing shall include, but not be limited to, an analysis of the exhaust stream directly after the HRSG for: A. Flow rate; B. Oxides of Nitrogen; C. Carbon Monoxide; D. Hydrocarbons: Methane & Non-Methane, including saturated and unsaturated; E. Ammonia; F. Particulates (Fuel Oil only); G. Oxides of Sulfur (Fuel Oil only). [District NSR Rule] Federally Enforceable Through Title V Permit
28. Performance testing shall be conducted annually to measure NO_x and CO emission concentrations using the following test methods: EPA Methods 7E or 20 for NO_x emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A, or 20 for Oxygen content of the exhaust gas. The 9-run tests for NO_x RATA purposes, shall be performed at highest physically achievable load of the gas turbine. [40 CFR 60.335(a), (b)(7) and District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3] Federally Enforceable Through Title V Permit
29. Annual performance testing shall be performed at representative performance as specified by the APCO or between 90 and 100 percent of peak (or the highest physically achievable) load. Annual performance testing is required for Natural Gas only, unless Fuel Oil usage exceeds 200 hours per year. [District NSR Rule and 40 CFR 60.335(b)(7) and 60.8(c)] Federally Enforceable Through Title V Permit
30. The District shall be notified at least 30 days prior to any performance testing and a test plan shall be submitted for District approval at least 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
31. Performance testing shall be witnessed or authorized by District personnel. Test results shall be submitted to the District within 60 days of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
32. A Continuous Monitoring System shall be installed and operated to measure and record the fuel consumption, the mass ratio of steam-to-fuel injected, the mass ratio of water-to-fuel injected into the Combustor, the flue gas temperature at the inlet of the SCR System, NO_x, SO_x (when firing on fuel oil), O₂ or CO₂ and CO emission concentration in the exhaust gas after the HRSG. [District NSR Rule] Federally Enforceable Through Title V Permit
33. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) for NO_x, CO, and O₂. The CEMS shall continuously measure and record the exhaust gas NO_x and O₂ concentrations, hours of operation and fuel consumption. The CEMS shall be capable of monitoring emissions during startups and shutdowns as well as during normal operating conditions. [40 CFR 60.334 (b)(2) and District NSR Rule and 4703, 6.2.1] Federally Enforceable Through Title V Permit
34. The Continuous Monitoring System shall convert the actual NO_x, SO_x (when firing on fuel oil), and CO concentrations to corrected concentrations at 15% O₂, dry basis. The System shall also record the total lb/day emissions of NO_x, SO_x (when firing on fuel oil), and CO. [District NSR Rule] Federally Enforceable Through Title V Permit
35. Results of the CEM system shall be averaged over a three hour time period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
36. The NO_x emission rate shall not exceed 150.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
37. The CO emission rate shall not exceed 550.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
38. The NMHC emission rate shall not exceed 143.0 lb/day while operating on Natural Gas and 143.4 lb/day when operating on Fuel Oil. [District NSR Rule] Federally Enforceable Through Title V Permit
39. The SO_x emission rate shall not exceed 12.9 lb/day while operating on Natural Gas and 150.0 lb/day when operating on Fuel Oil. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. The PM10 emission rate shall not exceed 10.0 lb/hr while operating on either Natural Gas or Fuel Oil. The PM10 emission rate shall not exceed 74.4 lb/day while operating on Natural Gas and 80.0 lb/day when operating on Fuel Oil. [District NSR Rule] Federally Enforceable Through Title V Permit
41. The cold start-up period must not exceed two (2) hours in any one day, commencing at midnight. The shut-down period must not exceed two (2) hours in any one day, commencing at midnight. [District NSR Rule] Federally Enforceable Through Title V Permit
42. The emissions during the start-up and shut-down periods must be counted towards the applicable daily emission limitations. [District NSR Rule] Federally Enforceable Through Title V Permit
43. There shall be no visible emissions from the turbine, except for uncombined water and except during periods of start-up and shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
44. The owner or operator shall maintain a stationary gas turbine system operating log that includes on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, the quantity and type of fuel used, steam-to-fuel ratios, water-to-fuel ratios and ammonia usage. [40 CFR 60.334 (j) and District Rule 4703; 6.2.6] Federally Enforceable Through Title V Permit
45. The permittee shall retain records of the cumulative annual facility-wide CO and SOx emissions. The record shall be updated daily. [District NSR Rule] Federally Enforceable Through Title V Permit
46. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
47. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
49. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
50. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
51. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
52. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
53. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
54. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
55. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

56. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
57. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
58. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
59. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
60. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
61. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-3233-4-5

EXPIRATION DATE: 11/30/2015

EQUIPMENT DESCRIPTION:

87 MW LOAD FOLLOWING POWER PLANT SERVED BY A 466 MMBTU/HR GENERAL ELECTRIC LM6000 SPRINT MODEL NATURAL GAS FIRED TURBINE WITH WATER INJECTION, A 234 MMBTU/HR JOHN ZINK LDRW-LE OR EQUIVALENT DUCT BURNER, A HEAT RECOVERY STEAM GENERATOR, A CONDENSING STEAM TURBINE, AN INLET AIR COOLING/FILTERING SYSTEM, A SELECTIVE CATALYTIC REDUCTION SYSTEM, AN OXIDATION CATALYST AND A LUBE OIL COALESCER

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The exhaust stack exit shall be at least 90 feet in height, the exhaust shall be vertical and the stack exhaust flow shall not be impeded. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The gas turbine engine and generator lube oil vents shall be equipped with mist eliminators. Visible emissions from lube oil vents shall not exhibit opacity of 5% or greater except for up to three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in proper operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) for NO_x, CO, and O₂. The CEMS shall continuously measure and record the exhaust gas NO_x and O₂ concentrations, hours of operation and fuel consumption. The CEMS shall be capable of monitoring emissions during startups and shutdowns as well as during normal operating conditions. [40 CFR 60.334 (b)(2) and District NSR Rule and 4703, 6.2.1] Federally Enforceable Through Title V Permit
6. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
7. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
8. The permittee shall monitor and record the NO_x emission rate, the ammonia injection rate, the water injection rate, the exhaust temperature and the calculated exhaust flow rate. [District Rule 4703 and 4001] Federally Enforceable Through Title V Permit
9. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081, 3.0, and 6.0 (as amended 12/16/93). [District Rule 1081, 3.0, and 6.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Start-up and shutdown durations shall not exceed 2 hours per day and 365 hours per calendar year. Start-up is defined as the period beginning with the initial firing of the turbine and ending when the turbine meets the NOx and CO limits for steady state operation. Shutdown is defined as the period beginning with initiation of the turbine shutdown sequence and ending with cessation of firing of the gas turbine. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
11. The facility-wide CO emissions shall not exceed 199,999 pounds during any one calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
12. The facility-wide SOx emissions shall not exceed 54,750 pounds during any one calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
13. The NOx emissions from this unit shall not exceed 58,340 pounds during any one calendar year. [District NSR Rule] Federally Enforceable Through Title V Permit
14. The NOx emissions during start-up and shutdown periods shall not exceed 24.6 pounds during any one hour. [District NSR Rule] Federally Enforceable Through Title V Permit
15. The NOx emissions, except during start-up and shutdown periods, shall not exceed 2.5 ppmvd @ 15% O2 over a 1 hour rolling average. [District NSR Rule and 4703] Federally Enforceable Through Title V Permit
16. The CO emissions during start-up and shutdown periods shall not exceed 40.8 pounds during any one hour. [District NSR Rule] Federally Enforceable Through Title V Permit
17. The CO emissions, except during start-up and shutdown periods, shall not exceed 6.0 ppmvd @ 15% O2 over a 3 hour rolling average. [District NSR Rule] Federally Enforceable Through Title V Permit
18. The VOC emissions shall not exceed 2.0 ppmvd, as methane, @ 15% O2 over a 3 hour rolling average. [District NSR Rule] Federally Enforceable Through Title V Permit
19. The PM10 emissions shall not exceed 2.5 pounds during any one hour while only the turbine is operating. [District NSR Rule] Federally Enforceable Through Title V Permit
20. The PM10 emission shall not exceed 3.0 pounds during any one hour while both the turbine and duct burner are operating. [District NSR Rule] Federally Enforceable Through Title V Permit
21. This unit shall be fired exclusively on natural gas as defined in 40 CFR 60.331(u) which has a total sulfur content of no greater than 1.0 grain of sulfur compounds (as S) per 100 scf. [40 CFR 60.333(b), Stanislaus County Rule 407, and District NSR Rule] Federally Enforceable Through Title V Permit
22. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. The ammonia (NH3) emissions shall not exceed 10 ppmvd @ 15% O2 over a 24 hour rolling average. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated utilizing the following procedure: ammonia slip ppmvd @ 15% O2 = ((a - (b x c/1,000,000)) x (1,000,000 / b) x d, where a = ammonia injection rate (lb/hr) / (17 lb/lb mol), b = dry exhaust flow rate (lb/hr) / (29 lb/lb mol), c = change in measured NOx concentration ppmvd @ 15% O2 across the catalyst and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Should the calculated ammonia slip value indicate a violation of the emission limit, source testing for ammonia slip shall be conducted with the turbine system operating under conditions similar to those it was operating at during the calculated violation. Source testing shall be conducted within 60 days of the calculated violation. Alternatively, the permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District to monitor compliance. At least 60 days prior to using a NH3 CEM, the permittee shall submit a monitoring plan for District review and approval. [District Rule 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

25. Performance testing shall be conducted annually to measure NO_x and CO emission concentrations using the following test methods: EPA Methods 7E or 20 for NO_x emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A, or 20 for Oxygen content of the exhaust gas. The 9-run tests for NO_x RATA purposes, shall be performed at highest physically achievable load of the gas turbine. [40 CFR 60.335(a), (b)(7) and District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3] Federally Enforceable Through Title V Permit
26. Performance testing to demonstrate compliance with the VOC, PM₁₀ and NH₃ requirements of this permit shall be conducted at least once every twelve months. [District NSR Rule and 4001] Federally Enforceable Through Title V Permit
27. The District shall be notified at least 30 days prior to any performance testing and a test plan shall be submitted for District approval at least 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
28. Performance testing shall be witnessed or authorized by District personnel. Test results shall be submitted to the District within 60 days of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
29. Performance testing for VOC shall be conducted utilizing EPA method 18 or EPA method 25. Alternative source testing methods will be allowed provided prior written approval is received from both the District and the EPA. [District NSR Rule] Federally Enforceable Through Title V Permit
30. Performance testing to measure concentrations of PM₁₀ shall be conducted using EPA methods 201 and 202, or EPA methods 201A and 202, or CARB method 501 in conjunction with CARB method 5. Alternative source testing methods will be allowed provided prior written approval is received from both the District and the EPA. [District NSR Rule] Federally Enforceable Through Title V Permit
31. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device was inoperative and emission measurements. [40 CFR 60.7 (b) and District Rule 1080, 7.3 and District NSR Rule] Federally Enforceable Through Title V Permit
32. The owner or operator shall maintain a stationary gas turbine system operating log that includes on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, and the quantity and type of fuel used. [District Rule 4703; 6.2.6] Federally Enforceable Through Title V Permit
33. The permittee shall retain records of the cumulative annual facility-wide CO and SO_x emissions. The record shall be updated daily. [District NSR Rule] Federally Enforceable Through Title V Permit
34. The annual facility SO_x emissions for natural gas shall be calculated utilizing the annual quantity of natural gas burned and the permitted natural gas sulfur content limit. The annual facility SO_x emissions for liquid fuels shall be calculated utilizing the annual quantity of liquid fuels burned and either the permitted fuel sulfur content limit or the actual measured sulfur content of the liquid fuels burned. [District NSR Rule] Federally Enforceable Through Title V Permit
35. The annual CO emissions from the turbines shall be determined utilizing CEMS data. [District NSR Rule] Federally Enforceable Through Title V Permit
36. The permittee shall maintain hourly records of the NO_x, CO and ammonia concentrations (ppmv @ 15% O₂). [District NSR Rule and 4201] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of the cumulative annual NO_x emissions from this unit. The record shall be updated daily. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

38. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report shall be received by the District within 30 days of the end of the quarter and shall include the following: time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess emissions (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which a CEM was inoperative (monitor downtime), except for zero and span checks and the nature of system repairs and adjustments; a negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
39. Results of the CEM system shall be averaged over the time period applicable to each emission limit listed on this permit, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
40. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
41. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) Have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
42. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
43. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
44. The owners and operators of each source and each affected unit at the source shall: (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
45. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
46. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
47. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
48. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
49. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
50. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
51. The owners and operators of each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) Pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-3233-5-3

EXPIRATION DATE: 11/30/2015

EQUIPMENT DESCRIPTION:

27,000 GALLON PER MINUTE COOLING TOWER WITH A HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. No hexavalent chromium containing compounds shall be added to the water that is circulating through the cooling tower or will circulate through the cooling tower. [District Rule 7012]
2. The drift rate shall not exceed 0.0005%. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The PM10 emission rate shall not exceed 0.17 pounds during any one hour. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Compliance with the PM10 daily emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{circulating water recirculation rate} * \text{total dissolved solids concentration in the blowdown water} * \text{design drift rate}$. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. Total Dissolved Solids (TDS) in the blowdown water shall be sampled and analyzed using a conductivity analyzer at least quarterly. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. Water recirculation rate shall be measured and recorded quarterly. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of all circulating water tests performed. Records shall be maintained for at least 5 years and shall be made available to the District upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.