



JAN 20 2012

Martin Lundy
Chevron USA, Inc
P O Box 1392
Bakersfield, CA 93302

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # S-1127
Project # S-1054422**

Dear Mr. Lundy:

The District has issued the Final Renewed Title V Permit for Chevron USA, Inc. This renewed Title V permit becomes effective on January 31, 2012. The preliminary decision for this project was made on November 3, 2011. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Attachments

cc: Sajjad Ahmad, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



JAN 20 2012

Gerardo C. Rios, Chief
Permits Office (AIR-3)
U.S. EPA - Region IX
75 Hawthorne St.
San Francisco, CA 94105

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # S-1127
Project # S-1054422**

Dear Mr. Rios:

The District has issued the Final Renewed Title V Permit for Chevron USA, Inc. This renewed Title V permit becomes effective on January 31, 2012. The preliminary decision for this project was made on November 3, 2011. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. We appreciate your concurrence with this action. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Attachments

cc: Sajjad Ahmad, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



JAN 20 2012

Mike Tollstrup, Chief
Project Assessment Branch
Air Resources Board
P O Box 2815
Sacramento, CA 95812-2815

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # S-1127
Project # S-1054422**

Dear Mr. Tollstrup:

The District has issued the Final Renewed Title V Permit for Chevron USA, Inc. This renewed Title V permit becomes effective on January 31, 2012. The preliminary decision for this project was made on November 3, 2011. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation.

The public notice for issuance of the Final Renewed Title V Permit will be published approximately three days from the date of this letter.

I would like to thank you and your staff for working with us. Should you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,

David Warner
Director of Permit Services

Attachments

cc: Sajjad Ahmad, Permit Services Engineer

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT
NOTICE OF FINAL DECISION TO ISSUE
RENEWED FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue the renewed Federally Mandated Operating Permit to Chevron USA, Inc. for its oil and natural gas production site at Heavy Oil Western Stationary Source in Kern County, California.

The District's analysis of the legal and factual basis for this proposed action, project #S-1054422, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. For additional information regarding this matter, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900, or contact David Warner, Director of Permit Services, in writing at SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 E. GETTYSBURG AVE, FRESNO, CA 93726-0244.

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Title V Permit Renewal Evaluation
Chevron USA, Inc.
S-1127**

TABLE OF CONTENTS

I.	PROPOSAL.....	2
II.	FACILITY LOCATION.....	2
III.	EQUIPMENT LISTING.....	3
IV.	GENERAL PERMIT TEMPLATE USAGE.....	3
V.	SCOPE OF EPA AND PUBLIC REVIEW.....	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS.....	3
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE.....	6
VIII.	PERMIT REQUIREMENTS.....	6
IX.	PERMIT SHIELD.....	68
X.	PERMIT CONDITIONS.....	68
XI.	ATTACHMENTS.....	68

- A. RENEWED TITLE V OPERATING PERMIT
- B. PREVIOUS TITLE V OPERATING PERMIT
- C. DETAILED FACILITY LIST
- D. RULE 4320 EMISSION CONTROL PLAN
- E. COMMENTS AND DISTRICT RESPONSES

TITLE V PERMIT RENEWAL EVALUATION
Heavy Oil Production Operation

Engineer: Sajjad Ahmad
Date: January 18, 2012

Facility Number: S-1127
Facility Name: Chevron USA, Inc.
Mailing Address: P.O. Box 1392
Bakersfield, CA 93302

Contact Name: Martin Lundy
Phone: (661) 654-7142

Responsible Official: Michael Jennings
Title: Manager, Health, Environment and Safety

Project #: S-1054422
Deemed Complete: September 9, 2005

I. PROPOSAL

Chevron USA, Inc. (Chevron) was issued a Title V permit on March 30, 2001. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the initial Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Chevron USA, Inc. is located at Chevron's Heavy Oil Western Source in Kern County.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is not proposing to use any model general permit templates as a part of this Title V renewal project.

V. SCOPE OF EPA AND PUBLIC REVIEW

The applicant is not requesting any model general permit templates. Therefore, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions
(amended December 20, 2007 – SIP approved ⇒ amended August 18, 2011 – not SIP approved)
- District Rule 2201, New and Modified Stationary Source Review Rule
(amended December 18, 2008 – SIP approved ⇒ amended April 21, 2011 – not SIP approved)
- District Rule 4101, Visible Emissions
(amended November 15, 2001 ⇒ amended February 17, 2005)
- District Rule 4305, Boilers, Steam Generators, Process Heaters – Phase 2
(amended December 19, 2002 ⇒ amended August 21, 2003)
- District Rule 4306, Boilers, Steam Generators and Process Heaters – Phase 3
(amended March 17, 2005 ⇒ amended October 16, 2008)
- District Rule 4351, Boilers, Steam Generators, Process Heaters – Phase 1
(amended October 19, 1995 ⇒ amended August 21, 2003)

- District Rule 4401, Steam-Enhanced Crude Oil Production Wells
(amended December 14, 2006 – SIP approved ⇒ amended June 16, 2011 – not SIP approved)
- District Rule 4601, Architectural Coatings
(Amended October 31, 2001 ⇒ Amended December 17, 2009)
- District Rule 4623, Storage of Organic Liquids
(amended December 20, 2001 ⇒ amended May 19, 2005)
- District Rule 4703, Stationary Gas Turbines
(amended August 17, 2006 ⇒ amended September 20, 2007)
- 40 CFR Part 60, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Industrial Steam Generators
- 40 CFR Part 60, Subpart GG, Standards of Performance for Stationary Gas Turbines

B. Rules Removed

- District Rule 8020, 8030, and 8060, Fugitive Dust (PM₁₀) Emissions (amended April 25, 1996)

These rules were removed on November 15, 2001 and were replaced with District Rules 8021, 8031, and 8061.

C. Rules Added

- District rule 4320, Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr
(Adopted October 16, 2008)
- District Rule 8011, General Requirements
(adopted November 15, 2001; amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities
(adopted November 15, 2001; amended August 19, 2004)
- District Rule 8031, Bulk Materials
(adopted November 15, 2001 ⇒ amended August 19, 2004)

- District Rule 8041, Carryout and Trackout
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8051, Open Areas
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads
(adopted November 15, 2001 ⇒ amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas
(adopted November 15, 2001 ⇒ amended September 16, 2004)

D. Rules Not Updated

- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2520, Federally Mandated Operating Permits (adopted June 15, 1995 ⇒ amended June 21, 2001)
- District Rule 4201, Particulate Matter Concentration
(amended December 17, 1992)
- District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 61, Subpart M, National Emissions Standards for Asbestos
- 40 CFR Part 64, Compliance Assurance Monitoring (CAM)
- 40 CFR Part 82, Subpart B, Servicing Motor Vehicle Air Conditioners
- 40 CFR Part 82, Subpart F, Stratospheric Ozone

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. District Rule 4102, Nuisance (as amended December 17, 1992)

For this facility, condition 42 of the facility-wide requirements S-1127-0-1 is based on the rule listed above and is not Federally Enforceable through Title V.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit.

Dormant Emission Units:

Permit units S-1127-25-27, -39-26, -42-25, -55-25, -71-23, -73-25, and -112-22 are currently out of operation and are designated as dormant emission units by District Permit conditions. Conditions have been added to these permit units, that these permit units can not be operated unless facility submits an application to comply with Title V requirements of District Rule 2520. Therefore these permit units will not be evaluated further in this permitting action.

A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which is specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any affect on current permit requirements and will therefore not be addressed in this evaluation.

B. District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable to the permits being renewed as a part of this project.

C. District Rule 2520 - Federally Mandated Operating Permits

This rule was amended to incorporate several administrative corrections, clarify rule language, and add procedures for implementing compliance schedules. The only amendments to this rule that will have an effect on current permit requirements are the corrections to Section 9 rule references, as described in the following table:

Old Rule Section	Corrected Rule Section
9.3	9.2
9.4	9.3
9.5	9.4
9.6	9.5
9.7	9.6
9.8	9.7
9.9	9.8
9.10	9.9
9.11	9.10
9.12	9.11
9.13	9.12
9.14	9.13
9.15	9.14
9.16	9.15
9.17	9.16
9.18	9.17
9.19	9.18

Rule 2520, Section 6.4.4, "Other Changes Not Requiring Title V Permit Amendment," allowed the permittee to implement changes, including the addition of new emissions units, without triggering the permit modification or amendment requirements until the time of Title V permit renewal, provided the conditions described in Sections 6.4.4.1 through 6.4.4.2 were met.

1. All Permits:

- Mapping or identification of specific permit conditions that have been updated due to the change in the reference sections of this Rule is not necessary. Every District Rule 2520 section reference on each permit has been updated according to the table above.

Mandatory Greenhouse Gas Reporting

There are no federally applicable Greenhouse Gas (GHG) requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

D. District Rule 4101 - Visible Emissions

District Rule 4101 has been submitted to the EPA to replace SIP approved Rule 401 (all counties of the SJVUAPCD). EPA made a preliminary determination that District Rule 4101 is "more stringent" than the county versions previously referenced, per correspondence dated August 20, 1996.

Section 5.0 prohibits the discharge of any air contaminant for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker in shade as that designated as No. 1 on the Ringelmann Chart; or is of such opacity as to obscure an observer's view to a degree equal to or greater than the smoke described in Section 5.1 of Rule 4101.

Condition 22 of the facility-wide requirements of S-1127-0-1 ensures compliance.

E. District Rule 4305 – Boilers, Steam Generators and Process Heaters – Phase 2

The purpose of this rule is to limit emissions oxides of nitrogen (NO_x) and carbon monoxide (CO) from the operation of boilers, steam generators, and process heaters.

Section 5.0, Requirements

Section 5.1.1 requires that except for units subject to Sections 5.2, NO_x emissions shall not exceed the limits specified in the following table. All ppmv emission limits specified in this section are referenced at dry stack gas conditions and 3.00 percent by volume stack gas oxygen. Emission concentrations shall be corrected to 3.00 percent oxygen in accordance with Section 8.1.

<i>Rule 4305 Emissions Limits</i>		
	Operated on gaseous fuel	Operated on liquid fuel
	NO_x Limit	NO_x Limit
For all units, except box or cabin type units and vertical cylindrical process heaters.	30 ppmv or 0.036 lb/MMBtu	40 ppmv or 0.052 lb/MMBtu
For box or cabin type units, and vertical cylindrical process heaters.	147 ppmv or 0.18 lb/MMBtu	155 ppmv or 0.2 lb/MMBtu

Compliance is assured with the following conditions:

Steam Generators	
Permit Unit	Condition
S-1127-22-27	10
S-1127-28-28	11
S-1127-29-24	11
S-1127-30-25	12
S-1127-31-25	11
S-1127-34-21	13
S-1127-35-22	12
S-1127-36-24	11
S-1127-38-26	12
S-1127-57-25	13
S-1127-66-29	13
S-1127-69-27	13
S-1127-70-28	9

Section 5.1.2 applies to units operated on combinations of gaseous fuel and liquid fuel. No units at this facility are permitted to operate on combinations of gaseous and liquid fuels. Therefore, this section is not applicable.

Section 5.2, Low Use

Section 5.2 states that each unit that is operated with an annual heat input less than 30 billion Btu per calendar year, as made enforceable by permit to operate, shall comply with one of the following:

- 5.2.1 tune the unit at least once each calendar year in which it operates by a qualified technician in accordance with the procedure described in Rule 4304; or
- 5.2.2 operate the unit in a manner that maintains exhaust oxygen concentrations at less than or equal to 3.00 percent by volume on a dry basis; or
- 5.2.3 operate the unit in compliance with the applicable emission requirements of Section 5.1 and 5.3.

No units at this facility are permitted to operate with an annual heat input less than 30 billion Btu per calendar year. Therefore, this section is not applicable.

Section 5.3, CO Emissions Limits

Section 5.3 states that for units subject to section 5.1, carbon monoxide emissions shall not exceed 400 ppmv. Compliance is assured with the following conditions:

Steam Generators	
Permit Unit	Condition
S-1127-22-27	10
S-1127-28-28	11
S-1127-29-24	11
S-1127-30-25	12
S-1127-31-25	11
S-1127-34-21	13
S-1127-35-22	12
S-1127-36-24	11
S-1127-38-26	12
S-1127-57-25	13
S-1127-66-29	13
S-1127-69-27	13
S-1127-70-28	9

Section 5.4, Monitoring Provisions

Section 5.4.1 applies to any unit which simultaneously fires gaseous and liquid fuels, and is subject to the requirements of Section 5.1. No units fire simultaneously on gaseous and liquid fuels. Therefore, this section is not applicable.

Section 5.4.2 requires the operator of any unit subject to the emissions limits specified in Section 5.1 to install and maintain Continuous Emissions Monitoring (CEMS) for NO_x, CO and O₂, or implements an APCO-approved Alternate Monitoring System.

In order to satisfy the requirements of District Rule 4306, all steam generators at this facility are subject to pre-approved alternate monitoring scheme A (pursuant to District Policy SSP-1105), which requires that monitoring of NO_x, CO, and O₂ exhaust concentrations be conducted at least once per month (in which a source test is not performed) using a portable analyzer.

Compliance with these requirements is assured with the following conditions:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	16 thru 19
S-1127-28-28	18 thru 21
S-1127-29-24	17 thru 20
S-1127-30-25	18 thru 21
S-1127-31-25	17 thru 20
S-1127-34-21	19 thru 22
S-1127-35-22	18 thru 21
S-1127-36-24	17 thru 20
S-1127-38-26	18 thru 21
S-1127-57-25	19 thru 22
S-1127-66-29	19 thru 22
S-1127-69-27	19 thru 22
S-1127-70-28	15 thru 18

Section 5.4.3 states that for units subject to the requirements of Section 5.2.1 or 5.2.2, monitor operational characteristics recommended by the manufacturer and approved by the APCO. Units operated at this facility are not subject to Sections 5.2.1 or 5.2.2. Therefore, this section is not applicable.

Section 5.4.4 states that the operator of any unit subject to Section 5.2.1 or 5.2.2 shall install and maintain an operational non-resettable, totalizing mass or volumetric flow meter in each fuel line to each unit. Volumetric flow measurements shall be periodically compensated for temperature and pressure. A master meter, which measures fuel to all units in a group of similar units, may satisfy these requirements if approved by the APCO in writing. The cumulative annual fuel usage may be verified from utility service meters, purchase or tank fill records, or other acceptable methods, as approved by the APCO. Units operated at this facility are not subject to Sections 5.2.1 or 5.2.2. Therefore, this section is not applicable.

Section 5.5, Compliance Determination

Section 5.5.1 requires that the operator of any unit shall have the option of complying with either the applicable heat input (lb/MMBtu) emission limits or the concentration (ppmv) emission limits specified in Section 5.1. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling).

Section 5.5.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or

conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0.

Section 5.5.3 pertains to units equipped with Continuous Emissions Monitoring Systems (CEMS). No units at this facility are equipped with CEMS. Therefore this section is not applicable.

Section 5.5.4 requires that for emissions monitoring pursuant to Sections 5.4.2, 5.4.2.1, and 6.3.1 using a portable NO_x analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period.

Section 5.5.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit.

Compliance with these requirements is assured with the following conditions:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	24 thru 27
S-1127-28-28	26 thru 29
S-1127-29-24	25 thru 28
S-1127-30-25	26 thru 29
S-1127-31-25	25 thru 28
S-1127-34-21	27 thru 30
S-1127-35-22	26 thru 29
S-1127-36-24	25 thru 28
S-1127-38-26	26 thru 29
S-1127-57-25	27 thru 30
S-1127-66-29	27 thru 30
S-1127-69-27	27 thru 30
S-1127-70-28	23 thru 26

Section 5.5.6 establishes the requirements for units subject to startup and shutdown requirements. Section 5.5.6 states that the applicable emission limits of Sections 5.1 shall not apply during start-up or shutdown provided an operator complies with the requirements specified in below.

- 5.5.6.1 The duration of each start-up or each shutdown shall not exceed two hours.
- 5.5.6.2 The emission control system shall be in operation and emissions shall be minimized insofar as technologically feasible during start-up or shutdown.

Compliance with these requirements is assured with the following conditions:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	13 and 14
S-1127-28-28	15 and 16
S-1127-29-24	14 and 15
S-1127-30-25	15 and 16
S-1127-31-25	14 and 15
S-1127-34-21	16 and 17
S-1127-35-22	15 and 16
S-1127-36-24	14 and 15
S-1127-38-26	15 and 16
S-1127-57-25	16 and 17
S-1127-66-29	16 and 17
S-1127-69-27	16 and 17
S-1127-70-28	12 and 13

Section 6.1, Recordkeeping

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.5 shall be maintained for five calendar years and shall be made available to the APCO upon request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule.

Section 6.1.1 applies to units operated under the exemption of Section 4.2. No units operate under the exemption in Section 4.2. Therefore the requirements in this section are not applicable.

Section 6.1.2 applies to units operated under the exemption of Section 4.3. No units operate under the exemption in Section 4.3. Therefore the requirements in this section are not applicable.

Section 6.1.3 requires that the operator of any unit subject to Section 5.2.1 or 5.2.2 shall record the amount of fuel use on a monthly basis for each unit. The units operated at this facility are not subject to the requirements of Sections 5.2.1 or 5.2.2. Therefore, the requirements in this section are not applicable.

Section 6.1.4 requires that the operator of a unit subject to Section 5.2.1 or 6.3.1 shall maintain records to verify that the required tune-up and the required monitoring of the operational characteristics have been performed. The units operated at this facility are not subject to the requirements of Sections 5.2.1 or 6.3.1. Therefore, the requirements in this section are not applicable.

Section 6.1.4 requires that the operator performing start-up or shutdown of a unit shall keep records of the duration of start-up or shutdown.

Compliance with the recordkeeping requirements of this rule is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	13 and 41
S-1127-28-28	15 and 44
S-1127-29-24	14 and 42
S-1127-30-25	15 and 43
S-1127-31-25	14 and 42
S-1127-34-21	16 and 44
S-1127-35-22	15 and 43
S-1127-36-24	14 and 42
S-1127-38-26	15 and 42
S-1127-57-25	16 and 43
S-1127-66-29	16 and 44
S-1127-69-27	16 and 43
S-1127-70-28	12 and 40

Section 6.2, Test Methods

Section 6.2 identifies the following test methods as District-approved source testing methods for the pollutants listed:

Pollutant	Units	Test Method Required
NO _x	ppmv	EPA Method 7E or ARB Method 100
NO _x	lb/MMBtu	EPA Method 19
CO	ppmv	EPA Method 10 or ARB Method 100
Stack Gas O ₂	%	EPA Method 3 or 3A, or ARB Method 100
Stack Gas Velocities	ft/min	EPA Method 2
Stack Gas Moisture Content	%	EPA Method 4

Compliance with the test method requirements of this rule is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	28
S-1127-28-28	30
S-1127-29-24	29
S-1127-30-25	30
S-1127-31-25	29
S-1127-34-21	31
S-1127-35-22	30
S-1127-36-24	29
S-1127-38-26	30
S-1127-57-25	31
S-1127-66-29	31
S-1127-69-27	31
S-1127-70-28	27

Section 6.3, Compliance Testing

Section 6.3.1 requires that each unit subject to the requirements of Sections 5.1 or 5.2.3 shall be source tested to determine compliance with the applicable emission limits at least once every 12 months. Units that demonstrate compliance on two consecutive 12-month source tests may defer the following 12-month source test up to 36 months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits specified in Sections 5.1 or 5.2.3, the source testing frequency shall revert to at least once every 12 months.

Section 6.3.2 states that in lieu of compliance with Section 6.3.1, compliance with the applicable limits in Sections 5.1 or 5.2.3 shall be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units.

Compliance with the compliance testing requirements of this rule is demonstrated with the permit conditions listed in the following table:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	24, 29 thru 33
S-1127-28-28	26, 31 thru 35
S-1127-29-24	25, 30 thru 34
S-1127-30-25	26, 31 thru 35
S-1127-31-25	25, 30 thru 34
S-1127-34-21	27, 32 thru 36
S-1127-35-22	26, 31 thru 35
S-1127-36-24	25, 30 thru 34
S-1127-38-26	26, 31 thru 35
S-1127-57-25	27, 32 thru 36
S-1127-66-29	27, 32 thru 36
S-1127-69-27	27, 32 thru 36
S-1127-70-28	23, 28 thru 32

F. District Rule 4306 – Boilers, Steam Generators, and Process Heaters – Phase 3

The purpose of this rule is to limit emissions oxides of nitrogen (NO_x) and carbon monoxide (CO) from the operation of boilers, steam generators, and process heaters.

Section 5.1, NO_x and CO Emissions Limits

Section 5.1.1 requires that except for units subject to Sections 5.2, NO_x and carbon monoxide (CO) emissions shall not exceed the limits specified in the following table. All ppmv emission limits specified in this section are referenced at dry stack gas conditions and 3.00 percent by volume stack gas oxygen. Emission concentrations shall be corrected to 3.00 percent oxygen in accordance with Section 8.1.

The steam generators at this facility fall into the following category:

Rule 4306 Emissions Limits				
Category	Operated on gaseous fuel		Operated on liquid fuel	
	NO_x Limit	CO Limit	NO_x Limit	CO Limit
C. Oilfield Steam Generators	15 ppmv or 0.018 lb/MMBtu	400 ppmv	40 ppmv or 0.052 lb/MMBtu	400 ppmv

The requirements of this section are met by each unit with the condition listed in the tables below.

Steam Generators	
Permit Unit	Condition
S-1127-22-27	10
S-1127-28-28	11
S-1127-29-24	11
S-1127-30-25	12
S-1127-31-25	11
S-1127-34-21	13
S-1127-35-22	12
S-1127-36-24	11
S-1127-38-26	12
S-1127-57-25	13
S-1127-66-29	13
S-1127-69-27	13
S-1127-70-28	9

Section 5.2, Low Use

The units at this facility annual heat input will exceed the 9 billion Btu heat input per calendar year criteria limit addressed by this section. Since the units are not subject to Section 5.2, the requirements of this section will not be discussed.

Section 5.3, Startup and Shutdown Provisions

Section 5.3 states that on and after the full compliance schedule specified in Section 7.1, the applicable emission limits of Sections 5.1, 5.2.2 and 5.2.3 shall not apply during start-up or shutdown provided an operator complies with the requirements specified in Sections 5.3.1 through 5.3.4.

Compliance with these requirements is assured with the following conditions:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	13 and 14
S-1127-28-28	15 and 16
S-1127-29-24	14 and 15
S-1127-30-25	15 and 16
S-1127-31-25	14 and 15
S-1127-34-21	16 and 17
S-1127-35-22	15 and 16
S-1127-36-24	14 and 15
S-1127-38-26	15 and 16
S-1127-57-25	16 and 17
S-1127-66-29	16 and 17
S-1127-69-27	16 and 17
S-1127-70-28	12 and 13

Section 5.4, Monitoring Provisions

Section 5.4.2 requires that permit units subject to District Rule 4306, Section 5.1 emissions limits shall either install and maintain Continuous Emission Monitoring (CEM) equipment for NO_x, CO and O₂, or install and maintain APCO-approved alternate monitoring.

In order to satisfy the requirements of District Rule 4306, the facility is subject to pre-approved alternate monitoring scheme A (pursuant to District Policy SSP-1105), which requires that monitoring of NO_x, CO, and O₂ exhaust concentrations shall be conducted at least once per month (in which a source test is not performed) using a portable analyzer.

Compliance with the monitoring provisions of this rule is demonstrated with the permit conditions listed in the following table:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	16 thru 19
S-1127-28-28	18 thru 21
S-1127-29-24	17 thru 20
S-1127-30-25	18 thru 21
S-1127-31-25	17 thru 20
S-1127-34-21	19 thru 22
S-1127-35-22	18 thru 21
S-1127-36-24	17 thru 20
S-1127-38-26	18 thru 21
S-1127-57-25	19 thru 22
S-1127-66-29	19 thru 22
S-1127-69-27	19 thru 22
S-1127-70-28	15 thru 18

Section 5.5, Compliance Determination

Section 5.5.1 requires that the operator of any unit shall have the option of complying with either the applicable heat input (lb/MMBtu) emission limits or the concentration (ppmv) emission limits specified in Section 5.1. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling).

Section 5.5.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0.

Section 5.5.4 requires that for emissions monitoring pursuant to Sections 5.4.2, 5.4.2.1, and 6.3.1 using a portable NO_x analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period.

Section 5.5.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit.

Compliance with these requirements is assured with the following conditions:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	24 thru 27
S-1127-28-28	26 thru 29
S-1127-29-24	25 thru 28
S-1127-30-25	26 thru 29
S-1127-31-25	25 thru 28
S-1127-34-21	27 thru 30
S-1127-35-22	26 thru 29
S-1127-36-24	25 thru 28
S-1127-38-26	26 thru 29
S-1127-57-25	27 thru 30
S-1127-66-29	27 thru 30
S-1127-69-27	27 thru 30
S-1127-70-28	23 thru 26

Section 6.1, Recordkeeping

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.4 shall be maintained for five calendar years and shall be made available to the APCO upon request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule.

Section 6.1.1 applies to units seeking exemption under Section 4.2. None of the units at this facility are subject to the exemption.

Section 6.1.2 requires that the operator of a unit subject to Category H unit listed in Section 5.1.1 Table 1 or to Section 5.2 shall record the amount of fuel use at least on a monthly basis. No units at the facility are subject to this section.

Section 6.1.3 requires that the operator of a unit subject to Section 5.2.1 or 6.3.1 shall maintain records to verify that the required tune-up and the required monitoring of the operational characteristics have been performed. Section 6.3.1 states that tune-ups required by Sections 5.2.1 and 6.3.1 do not need to be performed for units that operate and maintain an APCO approved CEMS or an APCO approved Alternate Monitoring System where the applicable emission limits are periodically monitored. All the units in this project maintain an APCO approved Alternate Monitoring System where the applicable emission limits are periodically monitored; therefore the requirements of this section are not applicable to the units in this project.

Section 6.1.4 requires the operator performing start-up or shutdown of a unit shall keep records of the duration of start-up or shutdown.

Compliance with the recordkeeping requirements of this rule is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	13 and 41
S-1127-28-28	15 and 44
S-1127-29-24	14 and 42
S-1127-30-25	15 and 43
S-1127-31-25	14 and 42
S-1127-34-21	16 and 44
S-1127-35-22	15 and 43
S-1127-36-24	14 and 42
S-1127-38-26	15 and 42
S-1127-57-25	16 and 43
S-1127-66-29	16 and 44
S-1127-69-27	16 and 43
S-1127-70-28	12 and 40

Section 6.2, Test Methods

Section 6.2 identifies the following test methods as District-approved source testing methods for the pollutants listed:

Pollutant	Units	Test Method Required
NO _x	ppmv	EPA Method 7E or ARB Method 100
NO _x	lb/MMBtu	EPA Method 19
CO	ppmv	EPA Method 10 or ARB Method 100
Stack Gas O ₂	%	EPA Method 3 or 3A, or ARB Method 100
Stack Gas Velocities	ft/min	EPA Method 2
Stack Gas Moisture Content	%	EPA Method 4

Compliance with the test method requirements of this rule is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	28
S-1127-28-28	30
S-1127-29-24	29
S-1127-30-25	30
S-1127-31-25	29
S-1127-34-21	31
S-1127-35-22	30
S-1127-36-24	29
S-1127-38-26	30
S-1127-57-25	31
S-1127-66-29	31
S-1127-69-27	31
S-1127-70-28	27

Section 6.3, Compliance Testing

Section 6.3.1 requires that this unit be tested to determine compliance with the applicable requirements of section 5.1 and 5.2.3 not less than once every 12 months.

In addition, since the applicant has proposed to use pre-approved Alternate Monitoring Scheme "A" using a portable analyzer, the tune-up requirements listed in Section 6.3.1 are not applicable to the boilers/steam generators.

Section 6.3.1 also requires that, during the 36-month source testing interval, the owner/operator shall monthly monitor the operational characteristics recommended by the unit manufacturer. Since the pre-approved Alternate Monitoring Scheme "A" using a portable analyzer requires monthly monitoring of NO_x, CO, and O₂ exhaust emissions concentrations, operational characteristics monitoring requirement is satisfied, and no further discussion is required.

Section 6.3.2 states that in lieu of compliance with Section 6.3.1, compliance with the applicable emission limits in Sections 5.1 or 5.2.3 shall be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided:

- All units in the group are initially source tested. The emissions from all test runs from units within the group are less than 90% of the permitted value, and the emissions do not vary greater than 25% from the average of all test runs; and
- All units in a group are similar in terms of rated heat input, make and series, operational conditions, fuel used, and control method. No unit with a rated heat input greater than 100 MMBtu shall be considered as part of the group; and
- The group is owned by a single owner and is located at a single stationary source; and
- Selection of the representative unit(s) is approved by the APCO prior to testing; and
- The number of representative units source tested shall be at least 30% of the total number of units in the group. The representative tests shall rotate each year so that within three years all units in the group have been tested at least once.
- All units in the group shall have received the similar maintenance and tune-up procedures as the representative unit(s) as listed in the Permit to Operate. The operator shall submit to the APCO the specific maintenance procedures to be performed on each unit that will be included in the group for representative testing. Such maintenance procedures shall be specified in the Permit to Operate for units that are included in the group for representative testing. Any maintenance work on a unit which has no effect on emissions standards and which is not specified in the maintenance procedures shall be submitted to the APCO for approval before such unit can be included as part of the group for representative testing. Any unit that necessitates any maintenance work which has an effect on emission standards and is beyond the maintenance procedures identified in the Permit to Operate, shall not be

- included as part of the group for representative testing. The unit shall be source tested in accordance with the provisions of Section 6.3.1; and
- Should any of the representative units exceed the required emission limits, each of the units in the group shall demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. After compliance with the requirements of Section 6.3.2.7 has been demonstrated, subsequent source testing shall be performed pursuant to Sections 6.3.1 or 6.3.2.

Compliance with the compliance testing requirements of this rule is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	24, 29 thru 33
S-1127-28-28	26, 31 thru 35
S-1127-29-24	25, 30 thru 34
S-1127-30-25	26, 31 thru 35
S-1127-31-25	25, 30 thru 34
S-1127-34-21	27, 32 thru 36
S-1127-35-22	26, 31 thru 35
S-1127-36-24	25, 30 thru 34
S-1127-38-26	26, 31 thru 35
S-1127-57-25	27, 32 thru 36
S-1127-66-29	27, 32 thru 36
S-1127-69-27	27, 32 thru 36
S-1127-70-28	23, 28 thru 32

G. District Rule 4320 – Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr

The purpose of this rule is to limit the emissions of oxides of nitrogen (NO_x), carbon monoxide (CO), oxides of sulfur (SO₂), and particulate matter 10 microns or less (PM₁₀) from boilers, steam generators, and process heaters.

Section 5.1 states that operators of a unit(s) shall comply with all applicable requirements of the rule and one of the following, on a unit-by-unit basis:

- Section 5.1.1 requires the unit comply with the emission limits specified in Sections 5.2 and 5.4; or
- Section 5.1.2, Pay an annual emissions fee to the District as specified in Section 5.3 and comply with the control requirements specified in Section 5.4.

Per Section 5.4.1.2, on and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall limit fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet.

Per Section 6.4.1, the operator submitted to the District an Emissions Control Plan containing the compliance schedule required by Section 7.0 of the rule (see Attachment D). For the steam generators, the facility proposes to comply with Section 5.1.2 and pay an annual emissions fee and comply with the control requirements in Section 5.4.1.2 by limiting fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet. Compliance with these requirements is demonstrated with the permit conditions listed in the table below.

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	15, 42 and 43
S-1127-28-28	17, 45 and 46
S-1127-29-24	16, 43 and 44
S-1127-30-25	17, 44 and 45
S-1127-31-25	16, 43 and 44
S-1127-34-21	18, 45 and 46
S-1127-35-22	17, 44 and 45
S-1127-36-24	16, 43 and 44
S-1127-38-26	17, 43 and 44
S-1127-57-25	18, 44 and 45
S-1127-66-29	18, 45 and 46
S-1127-69-27	18, 44 and 45
S-1127-70-28	14, 41 and 42

H. District Rule 4351 – Boilers, Steam Generators, and Process Heaters – Phase 1

The purpose of this rule is to limit emissions of oxides of nitrogen (NO_x) from boilers, steam generators, and process heaters to levels consistent with reasonably available control technology (RACT). This rule applies to any boiler, steam generator or process heater, with a rated heat input greater than 5 million Btu per hour that is fired with gaseous and/or liquid fuels, and is included in a major NO_x source.

The following permit conditions ensure compliance with this rule:

Steam Generators	
Permit Unit	Conditions
S-1127-22-27	28 thru 33
S-1127-28-28	6, 30 thru 35, 44
S-1127-29-24	29 thru 34
S-1127-30-25	30 thru 35
S-1127-31-25	29 thru 34
S-1127-34-21	6, 31 thru 36, 44
S-1127-35-22	6, 30 thru 35, 43
S-1127-36-24	29 thru 34
S-1127-38-26	6, 30 thru 35, 42
S-1127-57-25	6, 31 thru 36, 42
S-1127-66-29	6, 31 thru 36, 44
S-1127-69-27	6, 31 thru 36, 43
S-1127-70-28	27 thru 32

I. District Rule 4401 – Steam-Enhanced Crude Oil Production Well Vents (Amended 12/14/06 – SIP Approved, and Amended 6/16/11 – Not SIP Approved)

The following discussion addresses both SIP and Non SIP versions of this rule.

Section 1.0, Purpose

The purpose of this rule is to limit the VOC emissions from steam-enhanced crude oil production well vents.

Section 2.0, Applicability

This rule is applicable to all steam-enhanced crude oil production wells and any associated vapor collection and control systems.

Section 3.0, Definitions

Section 3.20 defines leak as: the dripping of VOC-containing liquid or the detection of a concentration of total organic compound, above background, determined according to the test method specified in Section 6.3.3 that exceeds the values specified in Table 1, Section 3.20.1 and Section 3.20.2 of this rule. Any liquid or gas coming from a component undergoing repair or replacement, or during sampling of process fluid from a component into a container is not considered a leak provided such activities are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere.

Table 1 - Gas Leak in ppmv as Methane		
Type of Components	Major Gas Leak	Minor Gas Leak
1. PRDs	Greater than 10,000	400 to 10,000
2. Components other than PRDs	Greater than 10,000	2,000 to 10,000

Section 3.20.1 defines Major Liquid Leak as: a visible mist or a continuous flow of liquid that is not seal lubricant.

Section 3.20.2 defines Minor Liquid Leak as: a liquid leak, except seal lubricant, that is not a major liquid leak and drips liquid at a rate of more than three drops per minute.

Section 3.50 defines the VOC collection and control system as "An APCO-approved system that is not open to the atmosphere and that is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to an APCO-approved control device that has a VOC destruction or removal efficiency of at least 99%, or that transports gases or vapors back to a process system." Definitions of the terms discussed above are listed as permit conditions as show in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	6
S-1127-160-12	11
S-1127-161-18	10
S-1127-162-14	9
S-1127-164-17	11
S-1127-165-12	9
S-1127-166-15	9
S-1127-167-17	11
S-1127-168-16	11
S-1127-169-14	9
S-1127-171-19	7
S-1127-173-15	9

Permit Units	Permit Conditions
S-1127-174-18	7
S-1127-176-15	10
S-1127-177-14	9
S-1127-178-13	11
S-1127-179-18	9
S-1127-180-15	7
S-1127-185-15	7
S-1127-187-13	9
S-1127-201-9	7
S-1127-420-6	6
S-1127-427-6	4

Section 4.0, Exemptions

Section 4.1 states that any steam-enhanced crude oil production well undergoing service or repair during the time the well is not producing is exempt from the requirements of this rule.

This exemption is listed as a permit condition as show in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	7
S-1127-160-12	12
S-1127-161-18	11
S-1127-162-14	10
S-1127-164-17	12
S-1127-165-12	10
S-1127-166-15	10
S-1127-167-17	12
S-1127-168-16	12
S-1127-169-14	10
S-1127-171-19	8
S-1127-173-15	10

Permit Units	Permit Conditions
S-1127-174-18	8
S-1127-176-15	11
S-1127-177-14	10
S-1127-178-13	12
S-1127-179-18	10
S-1127-180-15	8
S-1127-185-15	8
S-1127-187-13	10
S-1127-201-9	8
S-1127-420-6	7
S-1127-427-6	5

Section 5.0, Requirements

Section 5.1 states that an operator shall not operate a steam-enhanced crude oil production well unless the operator complies with the requirements of either Section 5.1.1 or Section 5.1.2.

Section 5.1.1 requires that the steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0. The well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere.

Section 5.1.2 requires that the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0.

Compliance with these sections is demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	8
S-1127-160-12	13
S-1127-161-18	12
S-1127-162-14	11
S-1127-164-17	13
S-1127-165-12	11
S-1127-166-15	11
S-1127-167-17	13
S-1127-168-16	13
S-1127-169-14	11
S-1127-171-19	9
S-1127-173-15	11

Permit Units	Permit Conditions
S-1127-174-18	9
S-1127-176-15	12
S-1127-177-14	11
S-1127-178-13	13
S-1127-179-18	11
S-1127-180-15	9
S-1127-185-15	9
S-1127-187-13	11
S-1127-201-9	9
S-1127-420-6	8
S-1127-427-6	6

Section 5.2.1 requires that an operator shall be in violation of this rule if any District inspection demonstrates that one or more of the conditions in Section 5.2.2 exist at the facility or if any operator inspection conducted pursuant to Section 5.4 demonstrates that one or more of the conditions in Section 5.2.2 exist at the facility.

Section 5.2.2 requires that the following conditions shall be used for determination of violation during an inspection pursuant to the provisions of Section 5.2.1:

5.2.2.1 Existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended lines. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere.

5.2.2.2 Existence of a component with a major liquid leak as defined in Section 3.0.

5.2.2.3 Existence of a component with a gas leak greater than 50,000 ppmv.

5.2.2.4 Existence of a component leak described in Section 5.2.2.4.1 through Section 5.2.2.4.3 in excess of the allowable number of leaks specified in Table 3.

5.2.2.4.1 A minor liquid leak, or

5.2.2.4.2 A minor gas leak, or

5.2.2.4.3 A gas leak greater than 10,000 ppmv up to 50,000 ppmv.

Table 2 - Number of Allowable Leaks	
Number of Steam-Enhanced Crude Oil Production Wells Connected to a VOC Collection and Control System	Number of Allowable Leaks
1 to 25	3
26 to 50	6
51 to 100	8
101 to 250	10
251 to 500	15
More than 500	One (1) for each 20 wells tested with a minimum of 50 wells tested.

Compliance with the leak standards pursuant to Section 5.2 are demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions	Permit Units	Permit Conditions
S-1127-159-11	9, 10	S-1127-174-18	10, 11
S-1127-160-12	14, 15	S-1127-176-15	13, 14
S-1127-161-18	13, 14	S-1127-177-14	12, 13
S-1127-162-14	12, 13	S-1127-178-13	14, 15
S-1127-164-17	14, 15	S-1127-179-18	12, 13
S-1127-165-12	12, 13	S-1127-180-15	10, 11
S-1127-166-15	12, 13	S-1127-185-15	10, 11
S-1127-167-17	14, 15	S-1127-187-13	12, 13
S-1127-168-16	14, 15	S-1127-201-9	10, 11
S-1127-169-14	12, 13	S-1127-420-6	9, 10
S-1127-171-19	10, 11	S-1127-427-6	7, 8
S-1127-173-15	12, 13		

Section 5.3.1 requires that an operator shall not use any component with a leak as defined in Section 3.0, or that is found to be in violation of the provisions of Section 5.2.2. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of this rule.

Section 5.3.2 requires that each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere.

Section 5.3.3 requires that an operator shall comply with the requirements of Section 6.7, if there is any change in the description of major components or critical components. Section 6.7 requires that by January 30 of each year an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan.

Compliance with the operating requirements in Sections 5.3 is demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	11 thru 13
S-1127-160-12	16 thru 18
S-1127-161-18	15 thru 17
S-1127-162-14	14 thru 16
S-1127-164-17	16 thru 18
S-1127-165-12	14 thru 16
S-1127-166-15	14 thru 16
S-1127-167-17	16 thru 18
S-1127-168-16	16 thru 18
S-1127-169-14	14 thru 16
S-1127-171-19	12 thru 14
S-1127-173-15	14 thru 16

Permit Units	Permit Conditions
S-1127-174-18	12 thru 14
S-1127-176-15	15 thru 17
S-1127-177-14	14 thru 16
S-1127-178-13	16 thru 18
S-1127-179-18	14 thru 16
S-1127-180-15	12 thru 14
S-1127-185-15	12 thru 14
S-1127-187-13	14 thru 16
S-1127-201-9	12 thru 14
S-1127-420-6	11 thru 13
S-1127-427-6	9 thru 11

Section 5.4.1 requires that except for pipes and unsafe-to-monitor components, as operator shall inspect all other components pursuant to the requirements of Section 6.3.3 at least once every year.

Section 5.4.2 requires that an operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of this rule.

Section 5.4.3 requires that in addition to the inspections required by Section 5.4.1, an operator shall inspect for leaks all accessible operating pumps, compressors, and pressure relief devices (PRDs) in service as follows:

- 5.4.3.1 An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week.
- 5.4.3.2 Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of this rule.

Section 5.4.4 requires that in addition to the inspections required by Section 5.4.1, Section 5.4.2 and Section 5.4.3, an operator shall perform the following inspections:

- 5.4.4.1 An operator shall initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release. An operator shall re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection.
- 5.4.4.2 An operator shall inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service.
- 5.4.4.3 Except for PRDs subject to the requirements of Section 5.4.4.1, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced.

Section 5.4.5 requires that an operator shall inspect all unsafe-to-monitor components during each turnaround.

Section 5.4.6 requires that a District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.

Compliance with the inspection and re-inspection requirements of Section 5.4 are demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	14 thru 19
S-1127-160-12	19 thru 24
S-1127-161-18	18 thru 23
S-1127-162-14	17 thru 22
S-1127-164-17	19 thru 24
S-1127-165-12	17 thru 22
S-1127-166-15	17 thru 22
S-1127-167-17	19 thru 24
S-1127-168-16	19 thru 24
S-1127-169-14	17 thru 22
S-1127-171-19	15 thru 20
S-1127-173-15	17 thru 22

Permit Units	Permit Conditions
S-1127-174-18	15 thru 20
S-1127-176-15	18 thru 23
S-1127-177-14	17 thru 22
S-1127-178-13	19 thru 24
S-1127-179-18	17 thru 22
S-1127-180-15	15 thru 20
S-1127-185-15	15 thru 20
S-1127-187-13	17 thru 22
S-1127-201-9	15 thru 20
S-1127-420-6	14 thru 19
S-1127-427-6	12 thru 17

Section 5.5.1 requires that an operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak. An operator shall include the following information on the tag:

- 1) The date and time of leak detection.
- 2) The date and time of leak measurement.
- 3) For a gaseous leak, the leak concentration in ppmv.
- 4) For a liquid leak, whether it is a major liquid leak or a minor liquid leak.
- 5) Whether the component is an essential component, an unsafe-to-monitor component, or a critical component.

Section 5.5.2 requires that an operator shall keep the tag affixed to the component until an operator has met all of the following conditions:

- 1) Repaired or replaced the leaking component, and
- 2) Re-inspected the component using the test method in Section 6.3.3, and
- 3) The component is found to be in compliance with the requirements of this rule.

Section 5.5.3 requires that an operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak.

Section 5.5.4 requires that except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0, an operator shall comply with at least one of the requirements of Section 5.5.4.1, Section 5.5.4.2, or Section 5.5.4.3 as soon as practicable but not later than the time period specified in Table 3.

- 5.5.4.1 Repair or replace the leaking component; or
- 5.5.4.2 Vent the leaking component to a VOC collection and control system as defined in Section 3.0, or
- 5.5.4.3 Remove the leaking component from operation.

Type of Leak	Repair Period in Calendar Days
Minor Gas Leak	14
Major Gas Leak less than or equal to 50,000 ppmv	5
Gas Leak Greater than 50,000 ppmv	2
Minor Liquid Leak	3
Major Liquid Leak	2

Section 5.5.5 requires that the leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3.

Section 5.5.6 requires that the time of the initial leak detection shall be the start of the repair period specified in Table 3.

Section 5.5.7 requires that if the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier.

Compliance with the leak repair requirements of Section 5.5 are demonstrated with the permit conditions listed in the following table (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	20 thru 27
S-1127-160-12	25 thru 32
S-1127-161-18	24 thru 31
S-1127-162-14	23 thru 30
S-1127-164-17	25 thru 32
S-1127-165-12	23 thru 30
S-1127-166-15	23 thru 30
S-1127-167-17	25 thru 32
S-1127-168-16	25 thru 32
S-1127-169-14	23 thru 30
S-1127-171-19	21 thru 28
S-1127-173-15	23 thru 30

Permit Units	Permit Conditions
S-1127-174-18	21 thru 28
S-1127-176-15	24 thru 31
S-1127-177-14	23 thru 30
S-1127-178-13	25 thru 32
S-1127-179-18	23 thru 30
S-1127-180-15	21 thru 28
S-1127-185-15	21 thru 28
S-1127-187-13	23 thru 30
S-1127-201-9	21 thru 28
S-1127-420-6	20 thru 27
S-1127-427-6	18 thru 25

Section 6.1, Recordkeeping and Submissions

Section 6.1 requires that an operator shall maintain the records required by Sections 6.1 and 6.2 for a period of five (5) years. These records shall be made available to the APCO upon request.

Section 6.1.1 requires that the operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs.

Section 6.1.2 states that a small producer shall maintain monthly records of county-specific crude oil production. The facility is not a small producer. Therefore this section is not applicable.

Section 6.1.3 states that the operator of any steam enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0.

Section 6.1.4 requires that the inspection log maintained pursuant to Section 6.4.

Section 6.1.5 states that records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration.

Section 6.1.6 states that an operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5.

Section 6.1.7 states that an operator shall keep a copy of the APCO-approved Operator Management Plan at the facility.

Sections 6.1.8 and 6.1.9 specify recordkeeping and submission requirements for gauge tanks. This permit covers thermally enhanced oil recovery wells and does not include any gauge tanks. Therefore, the requirements of these sections are not applicable to this operation and no further discussion is required.

Section 6.1.10 states that an operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year.

Compliance with the recordkeeping requirements of Section 6.1 are demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	28 thru 34
S-1127-160-12	33 thru 39
S-1127-161-18	32 thru 38
S-1127-162-14	31 thru 37
S-1127-164-17	33 thru 39
S-1127-165-12	31 thru 37
S-1127-166-15	31 thru 37
S-1127-167-17	33 thru 39
S-1127-168-16	33 thru 39
S-1127-169-14	31 thru 37
S-1127-171-19	29 thru 34
S-1127-173-15	31 thru 37

Permit Units	Permit Conditions
S-1127-174-18	29 thru 35
S-1127-176-15	32 thru 38
S-1127-177-14	31 thru 37
S-1127-178-13	33 thru 39
S-1127-179-18	31 thru 37
S-1127-180-15	29 thru 35
S-1127-185-15	29 thru 35
S-1127-187-13	31 thru 37
S-1127-201-9	29 thru 35
S-1127-420-6	28 thru 34
S-1127-427-6	26 thru 32

Section 6.2, Compliance Source Testing

Section 6.2.1 requires that an operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature.

Section 6.2.2 states that if approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the requirements in Sections 6.2.2.1 through 6.2.2.3 as described below:

- 6.2.2.1 An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines – Phase 2); or
- 6.2.2.2 A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters – 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters – 0.075 MMBtu/hr to 2.0 MMBtu/hr); or
- 6.2.2.3 A unit subject to District Rule 4311 (Flares). Section 6.2.3 states that the APCO may waive the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device.

Section 6.2.3 states that an operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0:

- 6.2.3.1 An operator shall conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July – September), and whenever there is a change in the source or type of produced fluid in the gauge tank.
- 6.2.3.2 The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9.

Section 6.2.3 specifies compliance testing requirements for gauge tanks. Since the facility does not operate any gauge tanks, the requirements of this section are not applicable.

Compliance with the source testing requirements of Section 6.2 is demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	35, 36
S-1127-160-12	40, 42
S-1127-161-18	39, 40
S-1127-162-14	38, 38
S-1127-164-17	40, 41
S-1127-165-12	38, 39
S-1127-166-15	38, 39
S-1127-167-17	40, 41
S-1127-168-16	40, 41
S-1127-169-14	38, 39
S-1127-171-19	36, 37
S-1127-173-15	38, 39

Permit Units	Permit Conditions
S-1127-174-18	36, 37
S-1127-176-15	39, 40
S-1127-177-14	38, 39
S-1127-178-13	40, 41
S-1127-179-18	38, 39
S-1127-180-15	36, 37
S-1127-185-15	36, 37
S-1127-187-13	38, 39
S-1127-201-9	36, 37
S-1127-420-6	35, 36
S-1127-427-6	33, 34

Section 6.3, Test Methods

Section 6.3.1 specifies that the control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported.

Section 6.3.2 requires that the VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be analyzed by CARB Method 432.

Section 6.3.3 specifies that leak detection shall be performed with a portable hydrocarbon detection instrument in accordance with EPA Method 21. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface.

Section 6.3.4 requires that the VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids.

Compliance with the test method requirements of Section 6.3 are demonstrated with the permit conditions listed in the following table (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions	Permit Units	Permit Conditions
S-1127-159-11	37 thru 40	S-1127-174-18	38 thru 41
S-1127-160-12	42 thru 45	S-1127-176-15	41 thru 44
S-1127-161-18	41 thru 44	S-1127-177-14	40 thru 43
S-1127-162-14	40 thru 43	S-1127-178-13	42 thru 45
S-1127-164-17	42 thru 45	S-1127-179-18	40 thru 43
S-1127-165-12	40 thru 43	S-1127-180-15	38 thru 41
S-1127-166-15	40 thru 43	S-1127-185-15	38 thru 41
S-1127-167-17	42 thru 45	S-1127-187-13	40 thru 43
S-1127-168-16	42 thru 45	S-1127-201-9	38 thru 41
S-1127-169-14	40 thru 43	S-1127-420-6	37 thru 40
S-1127-171-19	38 thru 41	S-1127-427-6	35 thru 38
S-1127-173-15	40 thru 43		

Section 6.4, Inspection Log

Section 6.4 states that an operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed:

- 6.4.1 The total number of components inspected, and the total number and percentage of leaking components found by component type.
- 6.4.2 The location, type, and name or description of each leaking component and description of any unit where the leaking component is found.
- 6.4.3 The date of leak detection and the method of leak detection.
- 6.4.4 For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak.
- 6.4.5 The date of repair, replacement, or removal from operation of leaking components.

- 6.4.6 The identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier.
- 6.4.7 The methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier.
- 6.4.8 The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced.
- 6.4.9 The inspector's name, business mailing address, and business telephone number.
- 6.4.10 The date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log.

Compliance with the inspection log requirements of Section 6.4 are demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	41
S-1127-160-12	46
S-1127-161-18	45
S-1127-162-14	44
S-1127-164-17	46
S-1127-165-12	44
S-1127-166-15	44
S-1127-167-17	46
S-1127-168-16	46
S-1127-169-14	44
S-1127-171-19	42
S-1127-173-15	44

Permit Units	Permit Conditions
S-1127-174-18	42
S-1127-176-15	45
S-1127-177-14	44
S-1127-178-13	46
S-1127-179-18	44
S-1127-180-15	42
S-1127-185-15	42
S-1127-187-13	44
S-1127-201-9	42
S-1127-420-6	41
S-1127-427-6	39

Section 6.5, Employee Training Program

Section 6.5 states that an operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary.

Compliance with the employee training requirements of Section 6.5 are demonstrated with the permit conditions listed in the following table (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions	Permit Units	Permit Conditions
S-1127-159-11	42	S-1127-174-18	43
S-1127-160-12	47	S-1127-176-15	46
S-1127-161-18	46	S-1127-177-14	45
S-1127-162-14	45	S-1127-178-13	47
S-1127-164-17	47	S-1127-179-18	45
S-1127-165-12	45	S-1127-180-15	43
S-1127-166-15	45	S-1127-185-15	43
S-1127-167-17	47	S-1127-187-13	45
S-1127-168-16	47	S-1127-201-9	43
S-1127-169-14	45	S-1127-420-6	42
S-1127-171-19	43	S-1127-427-6	40
S-1127-173-15	45		

Section 6.6, Operator Management Plan

Section 6.6 states that by June 30, 2008, an operator whose existing wells are subject to this rule or whose existing wells are exempt pursuant to Section 4.0 of this rule on or before December 14, 2006 shall prepare and submit an Operator Management Plan for approval by the APCO. An operator may use diagrams, charts, spreadsheets, or other methods approved by the APCO to describe the information required by Section 6.6.4 through Section 6.6.7 below. The Operator Management Plan shall include, at a minimum, all of the following information:

- 6.6.1 A description of all wells and all associated VOC collection and control systems subject to this rule, and all wells and all associated VOC collection and control systems that are exempt pursuant to Section 4.0 of this rule.
- 6.6.2 Identification and description of any known hazard that might affect the safety of an inspector.

- 6.6.3 Except for pipes, the number of components that are subject to this rule by component type.
- 6.6.4 Except for pipes, the number and types of major components, inaccessible components, unsafe-to-monitor components, critical components, and essential components that are subject to this rule and the reason(s) for such designation.
- 6.6.5 Except for pipes, the location of components subject to the rule (components may be grouped together functionally by process unit or facility description).
- 6.6.6 Except for pipes, components exempt pursuant to Section 4.6 (except for components buried below ground) may be described in the Operator Management Plan by grouping them functionally by process unit or facility description. The results of any laboratory testing or other pertinent information to demonstrate compliance with the applicable exemption criteria for components for which an exemption is being claimed pursuant to Sections 4.6 shall be submitted with the Operator Management Plan.
- 6.6.7 A detailed schedule of an operator's inspections of components to be conducted as required by this rule and whether the operator inspections of components required by this rule will be performed by a qualified contractor or by an in-house team.
- 6.6.8 A description of the training standards for personnel that inspect and repair components.
- 6.6.9 A description of the leak detection training for conducting the test method specified in Section 6.3.3 for new operators, and for experienced operators, as necessary.

Section 6.7 states that by January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan.

Section 6.8 states that the APCO shall provide written notice to the operator of the approval or incompleteness of a new or revised Operator Management Plan within 60 days of receiving such Operator Management Plan. If the APCO fails to respond in writing within 60 days after the date of receiving the Operator Management Plan, it shall be deemed approved. No provision of the Operator Management Plan, approved or not, shall conflict with or take precedence over any provision of this rule.

Compliance with the operator management plan requirements of Section 6.6, 6.7 and 6.8 are demonstrated with the permit conditions listed in the table below (both SIP and non-SIP version of the rule):

Permit Units	Permit Conditions
S-1127-159-11	13, 43, 44
S-1127-160-12	18, 48, 49
S-1127-161-18	17, 47, 48
S-1127-162-14	16, 46, 47
S-1127-164-17	18, 48, 49
S-1127-165-12	16, 46, 47
S-1127-166-15	16, 46, 47
S-1127-167-17	18, 48, 49
S-1127-168-16	18, 48, 49
S-1127-169-14	16, 46, 47
S-1127-171-19	14, 44, 45
S-1127-173-15	16, 46, 47

Permit Units	Permit Conditions
S-1127-174-18	14, 44, 45
S-1127-176-15	17, 47, 48
S-1127-177-14	16, 46, 47
S-1127-178-13	18, 48, 49
S-1127-179-18	16, 46, 47
S-1127-180-15	14, 44, 45
S-1127-185-15	14, 44, 45
S-1127-187-13	16, 46, 47
S-1127-201-9	14, 44, 45
S-1127-420-6	13, 43, 44
S-1127-427-6	11, 41, 42

Section 7.0, Compliance Schedule

Section 7.0 establishes a compliance schedule for existing and new steam-enhanced crude oil production wells. The wells at this facility are expected to operate in compliance with the requirements of this rule. Therefore, no further discussion is required.

J. District Rule 4601 - Architectural Coatings

This rule limits the emissions of VOCs from architectural coatings. It requires limiting the application of any architectural coating to no more than what is listed in the Table of Standards (Section 5.0). This rule further specifies labeling requirements, coatings thinning recommendations, and storage requirements.

The following changes were included in the latest rule amendment that resulted in adding new permit requirements and/or revising current permit requirements:

- The tables outlining the VOC content of different specialty coatings has been largely replaced with the Table of Standards in Section 5.0.
- New labeling, reporting, test methodology and other requirements have been incorporated into the rule in order to allow ARB to administer the Averaging Program as detailed in Section 8.0.

Conditions 23, 24 and 25 of the requirements for this revised facility wide permit S-1127-0-1 will assure compliance with the requirements of this rule.

K. District Rule 4623 - Storage of Organic Liquids

The purpose of this rule is to limit volatile organic compound (VOC) emissions from the storage of organic liquids.

All of the permits for the tanks at this facility are identical and therefore will be discussed together when demonstrating compliance with rule requirements.

The following tank permits are discussed below: S-1127-285-4, '-286-4, '-290-4, '-292-4, '-293-4, '-294-4, '-295-4, '-325-5, '-329-4, '-330-4, '-358-2, '-360-4, '-365-4, '-366-4, '-432-4, '-433-4, '-434-4, '-435-4, and '-436-4.

Section 4.0, Exemptions

Section 4.4 states that the tanks exclusively receiving and/or storing an organic liquid with a TVP less than 0.5 psia are exempt from all other requirements of the rule except for complying with the following provisions:

- TVP and API Gravity Testing provisions pursuant to Section 6.2,
- Recordkeeping provisions pursuant to Section 6.3.6,
- Test Methods provisions pursuant to Section 6.4, and
- Compliance schedules pursuant to Section 7.2.

All the tank permits at this facility meet this exemption and therefore they will only be subject to the sections of the rule listed above. Compliance with this exemption is demonstrated with the permit condition #1 on all tank permits.

Section 6.2, TVP and API Gravity Testing of Stored Organic Liquid in Uncontrolled Fixed Roof Tanks

Section 6.2.1.1 states that an operator shall conduct an initial TVP testing of each uncontrolled fixed roof tank. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. The operator shall submit the records of TVP and/or API gravity testing to the APCO as specified in Section 6.3.6. The operator shall be in full compliance with the rule by the deadline specified in Section 7.1

- 6.2.1.1.1 The selection of representative, uncontrolled fixed roof tanks is submitted in writing to the APCO, and written approval is granted by the APCO prior to conducting the test.
- 6.2.1.1.2 One uncontrolled fixed roof tank represents some or all of the tanks in a tank battery (defined in Section 3.31).

- 6.2.1.1.3 For crude oil production facilities, the representative uncontrolled fixed roof tank shall be the first line tank (or tanks) in a tank battery that is first receiving the produced fluids (mixture of oil, water, and gases) from the crude oil production wells.
- 6.2.1.1.4 The stored organic liquid in each of the represented tanks is the same and came from the same source.
- 6.2.1.1.5 The TVP and storage temperature of the stored organic liquid of the representative tank to be tested are the same or higher than those of the tanks it is to represent.

Since all the tanks at this facility are existing tanks, no initial testing is necessary.

Section 6.2.1.2 states the TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. If the tank stores crude oil or petroleum distillates, the operator shall also conduct an API gravity testing.

Section 6.2.1.3 states that in lieu of complying with Sections 6.2.1.1 and 6.2.1.2, an operator shall submit a complete application for an Authority to Construct to install and operate on each uncontrolled fixed roof tank the appropriate VOC control system specified in Section 5.1. The operator shall be in full compliance with the rule by the deadline specified in Section 7.1.

Section 6.2.2 states that an operator shall conduct a TVP testing of each uncontrolled fixed roof tank at least once every 24 months during summer (July – September), and/or whenever there is a change in the source or type of organic liquid stored in each tank. In lieu of testing each uncontrolled fixed roof tank, an operator may conduct a TVP testing of a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 are met. The operator shall also comply with Section 6.2.1.2. The operator shall submit the records of TVP and/or API gravity testing to the APCO as specified in Section 6.3.6.

Compliance with the TVP and API Gravity Testing provisions pursuant to Section 6.2 are demonstrated with the permit conditions 2, 3, and 7 listed on each of the tank permits.

Section 6.3, Recordkeeping

An operator shall retain accurate records required by this rule for a period of five years. Records shall be made available to the APCO upon request, except for certain records that need to be submitted as specified in the respective sections below.

Section 6.3.6 states that an operator shall submit the records of TVP and API gravity testing conducted in accordance with the requirements of Section 6.2 to the APCO within 45 days after the date of testing. The record shall include the tank identification number, PTO number, type of stored organic liquid, TVP and API gravity of the stored organic liquid, test methods used, and a copy of the test results. An operator who uses the information in Appendix A to demonstrate the TVP and/or API gravity of the stored organic liquid shall submit information to the APCO within 45 days after the date that the type of organic liquid stored in the tank has been determined.

Compliance with the recordkeeping provisions pursuant to Section 6.3.6 are demonstrated with the permit conditions 8, 9, and 10 listed on each of the tank permits.

Section 6.4, Test Methods

The following test methods shall be used unless otherwise approved by the APCO and the United States Environmental Protection Agency (US EPA).

- 6.4.1 Analysis of halogenated exempt compounds shall be conducted using California Air Resources Board (ARB) Method 432.
- 6.4.2 The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287-92 (2000) e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057-95 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products".
- 6.4.3 Except for crude oil subject to Section 6.4.4, the TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323-94 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "ARB Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative to using ASTM D 323-94, the TVP of crude oil with an API gravity range of greater than 26° up to 30° may be

determined by using other equivalent test methods approved by APCO, ARB and US EPA.

- 6.4.4 The latest version of the Lawrence Berkeley National Laboratory "Test Method for Vapor Pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and US EPA, shall be used to determine the TVP of crude oil with an API gravity of 26 or less, or for any API gravity that is specified in this test method.
- 6.4.5 An operator may use the information in Appendix A to determine the TVP of the stored organic liquid in a tank provided the storage temperature listed in Appendix A is not exceeded at any time.
- 6.4.6 The control efficiency of any VOC destruction device, measured and calculated as carbon, shall be determined by US EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case US EPA Method 25a may be used. US EPA Method 18 may be used in lieu of US EPA Method 25 or US EPA Method 25A provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of the known analytes/compounds to ensure that the VOC concentrations are neither under- or over-reported.
- 6.4.7 Analysis of halogenated exempt compounds shall be analyzed by ARB Method 422 "Exempt Halogenated VOCs in Gases September 12, 1990".
- 6.4.8 Measurements of a gas-leak concentration shall be determined by US EPA Method 21.

Compliance with the test methods provisions pursuant to Section 6.4 are demonstrated with the permit conditions 5 and 6 listed on each of the tank permits.

Section 7.0, Compliance Schedule

Section 7.2 states that any tank that is exempted under Section 4.0 that becomes subject to the VOC control system requirements of this rule through the loss of exemption status, shall be in full compliance with this rule on the date the exemption status is lost.

District inspections of the facility assures compliance with the requirements above.

Continued compliance with the requirements of this rule is expected.

L. District Rule 4703 – Stationary Gas Turbines

Permit Units S-1127-148-17 and -149-17:

Section 2.0 of this rule states that the provisions of this rule apply to all stationary gas turbine systems, which are subject to District permitting requirements, and with ratings equal to or greater than 0.3 megawatt (MW) or a maximum heat input rating of more than 3,000,000 Btu per hour, except as provided in Section 4.0.

Each of the two gas turbines (permit units S-1127-148 and -149) is rated at 22.3 MW. Therefore, each turbine is subject to the requirements of this rule.

Since both gas turbines are identical, the permit conditions on both permits are also identical.

Section 5.1 – NO_x Emission Requirements

Section 5.1.2, Table 5-2, Tier 2 NO_x Compliance Limits, requires the owner or operator to achieve less than or equal to 5 ppmvd NO_x @ 15% O₂ to meet Tier-2 compliance schedule listed in Section 7.2.

Tier 2 NO _x Compliance Limits			
Turbine Classification Rating	Compliance Option (see Section 7.2)	NO _x Compliance Limit, ppmvd at 15% O ₂	
		Gas Fuel	Liquid Fuel
d) Greater than 10 MW, Combined cycle	Standard	5	25

Each of the two turbines in this project is rated at 22.3 MW combined cycle; therefore they are subject to limit d) Greater than 10 MW, combined cycle. Compliance with these requirements is demonstrated with the permit condition 30 listed on each gas turbine permit.

Section 5.2 – CO Emission Requirements

Section 5.2, Table 5-4, CO Compliance Limits, requires the owner or operator to operate and maintain the gas turbine such that CO emissions must be less than 200 ppmvd @ 15% O₂. Rule 4703 does not include a specific averaging period requirement for demonstrating compliance with the CO emission limit. The District practice is to require CO emissions compliance demonstration on 3-hour rolling average period.

Each turbine is currently restricted to emit less than or equal to 13.5 ppmvd CO @ 15% O₂ on 3-hour rolling average period. Thus, compliance is expected with this section.

Compliance with these requirements is demonstrated with the permit condition 30 listed on each gas turbine permit.

Section 6.2 - Monitoring and Recordkeeping

Section 6.2.3 requires the units 10 MW and greater, and that have operated an average of more than 4,000 hours per year over the last three years before August 18, 1994, to monitor the exhaust gas NO_x emissions. The NO_x monitoring system shall meet EPA requirements as specified in 40 CFR Part 60 App. B, Spec. 2, 40 CFR Part 60 App. F, and 40 CFR Part 60.7 (c), 60.7 (d), and 60.13, or other systems that are acceptable to the EPA. The owner or operator shall submit to the APCO information demonstrating that the emission monitoring system has data gathering and retrieval capability. Each gas turbine is equipped with Continuous Emissions Monitoring System (CEMs) and; therefore, is currently in compliance with these requirement. Compliance with these requirements is demonstrated with the permit condition 34 listed on each gas turbine permit.

Section 6.2.4 requires the facility to maintain all records for a period of five years from the date of data entry and shall make such records available to the APCO upon request. Compliance with these requirements is demonstrated with the permit condition 45 listed on each gas turbine permit.

Section 6.2.5 requires that the owner or operator submit to the APCO, before issuance of the Permit to Operate, information correlating the control system operating to the associated measure NO_x output. Since these units are currently permitted, this information has previously been collected and no further information is needed.

Section 6.2.6 requires the facility to maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local startup and stop time, length and reason for reduced load periods, total hours of operation, and the type and quantity of fuel used (liquid/gas). The facility will be required to maintain a log in accordance with the requirements of this section. Compliance with this requirement is demonstrated with the permit condition 14 listed on each gas turbine permit.

Section 6.2.7 establishes recordkeeping requirements for units that are exempt pursuant to the requirements of Section 4.2. Each of the two turbines is subject

to the requirements of this rule. Therefore, the requirements of this section are not applicable and no further discussion is required.

Section 6.2.8 requires owners or operators performing startups or shutdowns to keep records of the duration of each startup and shutdown. As discussed in the Section 6.2.6 discussion above for this rule, the facility will maintain an operating log that will satisfy the requirements of this section. Compliance with this requirement is demonstrated with the permit condition 14 listed on each gas turbine permit.

Section 6.2.11 requires the operator of a unit to keep records of the date, time and duration of each bypass transition period and each primary re-ignition period. As discussed in the Section 6.2.6 discussion above for this rule, the facility will maintain an operating log that will satisfy the requirements of this section. Compliance with this requirement is demonstrated with the permit condition 14 listed on each gas turbine permit.

Sections 6.3 and 6.4 - Compliance Testing

Section 6.3.1 states that the owner or operator of any stationary gas turbine system subject to the provisions of Section 5.0 of this rule shall provide source test information annually regarding the exhaust gas NO_x and CO concentrations. Each gas turbine is currently required to be tested annually to ensure compliance with NO_x, CO and O₂ concentrations. Compliance with this requirement is demonstrated with the permit condition 37 listed on each gas turbine permit.

Section 6.3.2 specifies source testing requirements for units operating less than 877 hours per year. The turbines at this facility will be allowed to operate in excess of 877 hours per year. Therefore, the requirements of this section are not applicable and no further discussion is required.

Section 6.3.3 states that units with intermittently operated auxiliary burners shall demonstrate compliance with the auxiliary burner in both "on" and "off" configurations. Compliance with these requirements is demonstrated with the permit conditions 9 listed on each gas turbine permit.

Section 6.4 states that the facility must demonstrate compliance annually with the NO_x and CO emission limits using the following test methods, unless otherwise approved by the APCO and EPA:

- Oxides of nitrogen emissions for compliance tests shall be determined by using EPA Method 7E or EPA Method 20.

- Carbon monoxide emissions for compliance tests shall be determined by using EPA Test Methods 10 or 10B.
- Oxygen content of the exhaust gas shall be determined by using EPA Methods 3, 3A, or 20.
- HHV and LHV of gaseous fuels shall be determined by using ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81.

Compliance with these requirements is demonstrated with the permit conditions 7 and 41 listed on each gas turbine permit.

The District has determined that these gas turbines have been operating in compliance with the requirements of this rule. Therefore, continued compliance is expected and no further discussion is required.

M. District Rule 8011 - General Requirements

The purpose of Regulation VIII (Fugitive PM10 Prohibitions) is to reduce ambient concentrations of fine particulate matter (PM10) by requiring actions to prevent, reduce or mitigate anthropogenic fugitive dust emissions. The Rules contained in this Regulation have been developed pursuant to United States Environmental Protection Agency guidance for Serious PM10 Nonattainment Areas. The rules are applicable to specified anthropogenic fugitive dust sources. Fugitive dust contains PM10 and particles larger than PM10. Controlling fugitive dust emissions when visible emissions are detected will not prevent all PM10 emissions, but will substantially reduce PM10 emissions.

The provisions of this rule are applicable to specified outdoor fugitive dust sources. The definitions, exemptions, requirements, administrative requirements, recordkeeping requirements, and test methods set forth in this rule are applicable to all Rules under Regulation VIII (Fugitive PM10 Prohibitions) of the Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District.

Conditions 29 through 34 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

N. District Rule 8021 - Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities

The purpose of this rule is to limit fugitive dust emissions from construction, demolition, excavation, extraction, and other earthmoving activities.

This rule applies to any construction, demolition, excavation, extraction, and other earthmoving activities, including, but not limited to, land clearing, grubbing, scraping, travel on site, and travel on access roads to and from the site. This rule also applies to the construction of new landfill disposal sites or modification to existing landfill disposal sites prior to commencement of landfilling activities.

Section 5.0 requires that no person shall perform any construction, demolition, excavation, extraction, or other earthmoving activities unless the appropriate requirements in sections 5.1 and 5.2 are sufficiently implemented to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII. Condition 29 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

O. District Rule 8031 - Bulk Materials

The purpose of this rule is to limit fugitive dust emissions from the outdoor handling, storage, and transport of bulk materials.

This rule applies to the outdoor handling, storage, and transport of any bulk material.

Section 5.0 requires that no person shall perform any outdoor handling, storage, and transport of bulk materials unless the appropriate requirements in Table 8031-1 of this rule are sufficiently implemented to limit VDE to 20% opacity or to comply with the conditions for a stabilized surface as defined in Rule 8011. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 30 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

P. District Rule 8041 - Carryout and Trackout

The purpose of this rule is to limit fugitive dust emissions from carryout and trackout.

This rule applies to all sites that are subject to Rules 8021 (Construction, Demolition, Excavation, Extraction, and other Earthmoving Activities), 8031 (Bulk Materials), and 8071 (Unpaved Vehicle and Equipment Traffic Areas) where carryout or trackout has occurred or may occur.

Section 5.0 requires that an owner/operator shall sufficiently prevent or cleanup carryout and trackout as specified in sections 5.1 through 5.8. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII. The use of blower devices, or dry rotary brushes or brooms, for removal of carryout and trackout on public roads is expressly prohibited. The removal of carryout and trackout from paved public roads does not exempt an owner/operator from obtaining state or local agency permits which may be required for the cleanup of mud and dirt on paved public roads.

Condition 31 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

Q. District Rule 8051 - Open Areas

The purpose of this rule is to limit fugitive dust emissions from open areas.

This rule applies to any open area having 3.0 acres or more of disturbed surface area, that has remained undeveloped, unoccupied, unused, or vacant for more than seven days.

Section 5.0 requires that whenever open areas are disturbed or vehicles are used in open areas, the owner/operator shall implement one or a combination of control measures indicated in Table 8051-1 to comply with the conditions of a stabilized surface at all times and to limit VDE to 20% opacity. In addition to the requirements of this rule, a person shall comply with all other applicable requirements of Regulation VIII.

Condition 32 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

R. District Rule 8061 - Paved and Unpaved Roads

The purpose of this rule is to limit fugitive dust emissions from paved and unpaved roads by implementing control measures and design criteria.

This rule applies to any new or existing public or private paved or unpaved road, road construction project, or road modification project.

Condition 33 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

S. District Rule 8071 - Unpaved Vehicle/Equipment Traffic Area

The purpose of this rule is to limit fugitive dust emissions from unpaved vehicle and equipment traffic areas by implementing control measures and design criteria.

This rule applies to any unpaved vehicle/equipment traffic area of 1.0 acre or larger.

Condition 34 of the facility-wide requirements S-1127-0-1 will ensure compliance with these requirements.

T. 40 CFR Part 60, Subpart Dc – Standards of Performance for Small Industrial-Commercial-Industrial Steam Generators

Permit units: S-1127-22, -25, -28, -29, -30, -31, -34, -35, -36, -38, -39, -42, -55, -57, -66, -69, -70, -71, -73, -112: ----- 62.5 MMBtu/hr-Each Natural Gas/Vapor Recovery Gas-Fired Steam Generators

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. 40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Industrial Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction). Subpart Dc has standards for SO_x and PM₁₀.

Since all steam generators at this facility are rated at 62.5 MMBtu/hr, they are all subject to Subpart Dc requirements.

§60.332 Standard for Sulfur Dioxide:

Since coal is not combusted by the steam generators at this facility, the requirements of this section are not applicable.

§ 60.43c Standards for Particulate Matter

The steam generators at this facility are not fired on coal, combust mixtures of coal with other fuels, combust wood, combust mixture of wood with other fuels, or oil; therefore none of the steam generators will be subject to the requirements of this section.

§60.44c Compliance and Performance Tests Methods and Procedures for Sulfur Dioxide.

Since none of the steam generators at this facility is subject to the sulfur dioxide requirements of this subpart, no testing to show compliance is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

§60.45c Compliance and Performance Test Methods and Procedures for Particulate Matter

Since the steam generators at this facility are not subject to the particulate matter requirements of this subpart, no testing to show compliance is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

§60.46c Emission Monitoring for Sulfur Dioxide

Since the steam generators at this facility are not subject to the sulfur dioxide requirements of this subpart, no monitoring is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

§60.47c Emission Monitoring for Particulate Matter

Since the steam generators at this facility are not subject to the particulate matter requirements of this subpart, no monitoring is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

§60.48c Reporting and Recordingkeeping Requirements

Section 60.48c (a) states that the owner or operator of each affected facility shall submit notification of the date of construction or reconstruction, anticipated startup, and actual startup, as provided by §60.7 of this part. This notification shall include:

- (1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

The design heat input capacity and type of fuel combusted at the facility will be listed on the unit's equipment description. No conditions are required to show compliance with this requirement.

- (2) If applicable, a copy of any Federally enforceable requirement that limits the annual capacity factor for any fuel mixture of fuels under §60.42c or §40.43c.

This requirement is not applicable since the units are not subject to §60.42c or §40.43c.

- (3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

The facility has not proposed an annual capacity factor; therefore one will not be required.

- (4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of §60.42c(a) or (b)(1), unless and until this determination is made by the Administrator

This requirement is not applicable since the unit will not be equipped with an emerging technology used to control SO₂ emissions.

Section 60.48 c (g) states that the owner or operator of each affected facility shall record and maintain records of the amounts of each fuel combusted during each day.

Section 60.48 c (i) states that all records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record. District Rule 4320 requires that records be kept for five years. Therefore, no conditions are required to show compliance with this requirement.

U. 40 CFR Part 60, Subpart GG – Standards of Performance for Stationary Gas Turbines

Permit Units S-1127-148-17 and -149-17:

All of the 40 CFR Part 60, Subpart GG requirements on the existing permits have been updated in accordance with the latest rule amendments and have been included as discussed below. Since both gas turbines are identical, the permit conditions on both permits are also identical.

Based on the conditions in Permits to Operate, each gas turbine engine is subject to the requirements of this subpart. These requirements and their compliance determination are briefly discussed in the following sections.

§60.332 Standard for NO_x:

§60.332(a)(2) requires that no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0150 \frac{(14.4)}{Y} + F; \text{ where}$$

STD = allowable ISO corrected NO_x emission concentration in % by volume @ 15% O₂ on dry basis

Y = Manufacturer's rated heat rate at manufacturer's rated load (kJ/w-hr) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The Y shall not exceed 14.4 kJ/w-hr.

F = NO_x emission allowance for fuel-bound nitrogen.

For each gas turbine unit,

Heat input rate = 240 x 10⁶ Btu/hr
Power Rating = 22.3 MW

$$Y = \left(240 \times 10^6 \frac{\text{Btu}}{\text{hr}} \right) \times \left(\frac{1 \text{ kJ}}{0.9478 \text{ Btu}} \right) \times \left(\frac{1}{22.3 \times 10^6 \text{ w}} \right) = 11.4 \frac{\text{kJ}}{\text{w-hr}}$$

Since Y exceeds 14.4 kJ/w-hr, Y is set equal to 14.4 kJ/w-hr.

F = 0; for conservative calculations

$$\text{STD} = 0.0150 \frac{(14.4)}{11.4} + 0 = 0.0189 \text{ \% by volume @ 15\% O}_2 \text{ (189 ppmv @ 15\% O}_2\text{)}$$

The units at this facility are required to demonstrate compliance with 5 ppmv @ 15% O₂ on 3-hour rolling average basis for each gas turbine engine. In addition, the current permits list the maximum NO_x emission limit of 105 ppmvd @ 15% O₂. Therefore, each unit is in compliance with the NO_x standards.

Compliance with these requirements is demonstrated with the permit conditions 28 and 29 listed on each gas turbine permit.

§60.333 Standard for SO_x:

§60.333(b) requires that no owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

The turbines are currently permitted to fire only on PUC-quality natural gas with a sulfur content of less than or equal to 0.017% by weight. Therefore, the requirements of this section are met and compliance is demonstrated with the permit condition 2 listed on each turbine permit.

§60.334 Monitoring of Operations

§60.334(b) states that the owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and using water or steam injection to control NO_x emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

(1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:

- (i) On a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
- (ii) On a ppm at 15 percent O₂ basis; or
- (iii) On a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).

(2) As specified in §60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

These turbines were constructed between October 3, 1977 and July 8, 2004, do not use steam or water injection for NOx control, and currently use approved CEMS. Therefore, the units are in compliance with these requirements.

§60.334 (h) requires that the owner or operator of any stationary gas turbine subject to the provisions of this subpart:

- (1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in §60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084–82, 94, D5504–01, D6228–98, or Gas Processors Association Standard 2377–86 (all of which are incorporated by reference-see §60.17), which measure the major sulfur compounds may be used; and
- (2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (*i.e.* , if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in §60.332). The nitrogen content of the fuel shall be determined using methods described in §60.335(b)(9) or an approved alternative.
- (3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in §60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:

- (i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
- (ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

§60.334(j) states that for each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction.

§60.334(j)(1)(iii) states that for turbines using NO_x and diluent CEMS, an hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO_x concentration exceeds the applicable emission limit in §60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NO_x concentration" is the arithmetic average of the average NO_x concentration measured by the CEMS for a given hour (corrected to 15 percent O₂ and, if required under §60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO_x concentrations immediately preceding that unit operating hour. A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO_x concentration or diluent (or both).

Compliance with these requirements are demonstrated with the permit condition 19 listed on each turbine permit.

§60.334(j)(5) requires the owner or operator to postmark the reports required under §60.7(c) by the 30th day following the end of each 6-month period. The permittee is required to submit semi-annual reports. Thus, compliance is expected with this section.

Compliance with these requirements are demonstrated with the permit conditions 16 and 19 listed on each turbine permit.

§60.335 Test Methods and Procedure

§60.335(a) states that the owner or operator shall conduct the performance tests required in §60.8 using EPA Method 20, ASTM D6522-00 or EPA Method 7E and either EPA Method 3 or 3A to determine NO_x and diluent concentration. Sampling traverse points are to be selected following Method 20 or Method 1.

Compliance with these requirements are demonstrated with the permit condition 41 listed on each turbine permit.

§60.335(b)(2) states that the 3-run performance test must be performed within +/-5% at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice.

§60.335(b)(3) states that for a combined cycle turbine system with duct burner, the owner may elect to measure turbine NO_x emissions after the duct burner rather than directly after turbine. Rule 4703 requires the facility to test the turbine system with duct burner "on" and "off" configurations.

Compliance with these requirements is demonstrated with the permit condition 9 listed on each gas turbine permit.

§60.335(b)(7) states that if the owner or operator elects to install and certify a NO_x CEMS under §60.334(e), then the initial performance test required under §60.8 may be done in the following alternative manner:

- (i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.
- (ii) Use the test data both to demonstrate compliance with the applicable NO_x emission limit under §60.332 and to provide the required reference method data for the RATA of the CEMS described under §60.334(b).
- (iii) The requirement to test at three additional load levels is waived.

Compliance with these requirements are demonstrated with the permit condition 41 listed on each turbine permit.

Compliance is expected with this Subpart

V. 40 CFR Part 64-CAM

Applicability

This section requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

Major Source Thresholds (4/21/11 Revision of Rule 2201)

Pollutant	lb/year	ton/year
NOx	20,000	10
SOx	140,000	70
PM10	140,000	70
CO	200,000	100
VOC	20,000	10

Steam Generators:

Permit units: S-1127-22, -25, -28, -29, -30, -31, -34, -35, -36, -38, -39, -42, -55, -57, -66, -69, -70, -71, -73, -112: ----- 62.5 MMBtu/hr-Each Natural Gas/Vapor Recovery Gas-Fired Steam Generators

These steam generators contain emission limits for NO_x, SO_x, PM₁₀, CO, and VOC emissions. However, these steam generators are not equipped with any ad-on controls (external control devices) for SO_x, PM₁₀, CO, and VOC emissions. Therefore, these permit units are not subject to CAM requirements of 40 CFR 64 for SO_x, PM₁₀, CO, and VOC emissions.

These steam generators may be subject to CAM for NO_x, as there is a NO_x limit on each permit, and each unit does have add-on control in the form of Flue Gas Recirculation (FGR). However, as shown below, the pre-control annual potential to emit is not greater than the major source threshold of 20,000 pounds NO_x/year. Therefore, these permit units are not subject to CAM.

Pre-control Annual PE:

All steam generators at this facility have identical heat input rating of 62.5 MMBtu/hr, therefore, pre-control annual PE calculations are identical and shown only once.

These steam generators are equipped with FGR and are currently operating in compliance with Rule 4306 and therefore are required to meet the NO_x emissions limit of 0.0182 lb/MMBtu (or 15 ppmvd NO_x @ 3% O₂). To assess whether CAM is triggered the emissions factor corresponding to pre add-on (FGR) is calculated as follows:

AP-42 Table 1.4-1 (7/98) lists the following emissions factors for small boilers (< 100 MMBtu/hr):

	Emissions Factor (lb/10 ⁶ scf)
Uncontrolled	100
Controlled – low NO _x burners	50
Controlled – Low NO _x burners/Flue gas recirculation	32

The control efficiency of FGR and corresponding emissions factor are:

$$100 \times (50 - 32)/50 = 36\%$$

$$0.0182/(1 - 0.36) = 0.028 \text{ lb/MMbtu}$$

And the pre add-on control emissions are:

$$62.5 \text{ MMBtu/hr} \times 0.028 \text{ lb/MMbtu} \times 8760 \text{ hr/yr} = \underline{15,330 \text{ lb/yr}}$$

Since 15,330 lb-NO_x/yr < 20,000 lb-NO_x/yr (Major Source threshold for NO_x), these units are not subject to CAM for NO_x emissions.

Gas Turbines:

Permit units: S-1127-148 and -149: 22.3 MW Combined Cycle Cogeneration Units Including Gas-Fired Turbines

Units S-1127-148 and -149 are not subject to CAM for SO_x, PM₁₀, CO, and VOC since these units are not equipped with any add-on controls for these pollutants. Additionally, these units are not subject to CAM for NO_x emissions since they are equipped with Continuous Emissions Monitors (CEMs) for this pollutant.

Tanks:

Permit units: S-1127-285, -286, -290, -292, -293, -294, -295, -325, -329, -330, -358, -360, -365, -366, -432, -433, -434, -435, and -436.

All of these tank permits are identical with none of them containing any emission limits for NO_x, SO_x, PM₁₀, CO, and VOC. Therefore, none of these units is subject to CAM.

Wells:

Permit units: S-1127-159, -160, -161, -162, -164, -165, -166, -167, -168, -169, -171, -173, -174, -176, -177, -178, -179, -180, -185, -187, -201, -420, and -427.

- 1) All of these permit units contain a fugitive emission limit for VOC.
- 2) The vapor control system on each of these permit units is a collection system and not a control device. Therefore, none of these units is subject to CAM.

W. 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos

These regulations apply to demolition or renovation activity, as defined in 40 CFR 61.141. 40 CFR Section 61.150 of this Subpart was amended September 18, 2003, and condition 35 of S-1127-0-1 assures compliance with the requirements.

X. 40 CFR Part 82, Subparts B and F, Stratospheric Ozone

These regulations apply to servicing motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC). Sections of this regulation were amended in 2004 and 2008, and conditions 27 and 28 of S-1127-0-1 assure compliance with the requirements.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

The applicant is not requesting to use any model general permit templates for this Title V renewal project.

B. Requirements not Addressed by Model General Permit Templates

Chevron USA Inc. is not requesting any new permit shields within this Title V renewal project. In addition, Chevron USA Inc. is not requesting any changes to the existing permit shields already included in their Title V operating permit. Therefore, all of the existing permit shields will be maintained on the revised permit for this renewal project.

X. PERMIT CONDITIONS

See Attachment A - Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List
- D. Rule 4320 Emission Control Plan
- E. Comments and District Responses

ATTACHMENT A

Renewed Title V Operating Permit



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT



HEALTHY AIR LIVING™

Permit to Operate

FACILITY: S-1127

EXPIRATION DATE: 02/29/2016

LEGAL OWNER OR OPERATOR:

CHEVRON USA INC

MAILING ADDRESS:

PO BOX 1392
BAKERSFIELD, CA 93302

FACILITY LOCATION:

HEAVY OIL CENTRAL

FACILITY DESCRIPTION:

OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin

Executive Director / APCO

David Warner

Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-1127-0-1

EXPIRATION DATE: 02/29/2016

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
 These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin April 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due on the last day of the month following the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. All permits for facilities #S-88, S-511, S-1127, S-1131, and S-1551 are included in ChevronTexaco Inc.'s Heavy Oil Central stationary source. [District NSR Rule]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-22-27

EXPIRATION DATE: 02/29/2016

SECTION: SW3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3, DIS #43006-74) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
7. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
8. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Emissions shall not exceed any of the following limits: PM₁₀: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NO_x as NO₂: 15 ppmvd @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, or CO: 29 ppmvd @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
11. During start-up and shutdown periods, emissions shall not exceed: NO_x as NO₂: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NO_x as NO₂: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
29. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
33. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-25-25

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 40-32, DIS# 43001-75)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. NO_x and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
24. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

32. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
33. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
34. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
36. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
37. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
38. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
40. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
41. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
42. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-28-28

EXPIRATION DATE: 02/29/2016

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306 and 4320] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rules 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
38. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
42. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
44. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit
45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-29-24

EXPIRATION DATE: 02/29/2016

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR 44-9, DIS #43007-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule]
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-30-25

EXPIRATION DATE: 02/29/2016

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9, DIS #43008-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
4. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit
43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-31-25

EXPIRATION DATE: 02/29/2016

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9, DIS #43009-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-34-21

EXPIRATION DATE: 02/29/2016

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5, DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
43. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
44. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-35-22

EXPIRATION DATE: 02/29/2016

SECTION: 5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5, DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4320, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
8. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
42. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-36-24

EXPIRATION DATE: 02/29/2016

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5, DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-38-26

EXPIRATION DATE: 02/29/2016

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3, DIS# 43007-74) A NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

5.3 The APCO makes a determination that a permit shall be required because the source may not operate in compliance with all District rules and regulations; or

5.4 The owner specifically requests a Permit to Operate.

6.0 District Exempt Source Categories

Except as required by Section 5.0, no Authority to Construct or Permit to Operate shall be required for an emission unit specified below. All other equipment within that source category shall require an ATC or PTO.

6.1 Combustion and Heat Transfer Systems

6.1.1 Steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with:

6.1.1.1 Natural gas containing no more than five (5) percent by weight hydrocarbons heavier than butane and no more than 1.0 grain of total sulfur per 100 standard cubic feet of gas; or

6.1.1.2 Liquefied petroleum gas containing no more than two (2) percent by volume hydrocarbons heavier than butane and no more than 15 grains of total sulfur per 100 standard cubic feet of gas; or

6.1.1.3 Any combination of gases specified in Sections 6.1.1.1 and 6.1.1.2.

6.1.1.4 The percent by weight hydrocarbons content heavier than butane shall be determined by using the latest version of ASTM E-260 (Standard Practice for Packed Column Gas Chromatography).

6.1.1.5 The gas sulfur content shall be determined by using the latest version of ASTM D-1072 (Standard Test Method for Total Sulfur in Fuel Gases by Combustion and Barium Chloride Titration), ASTM D-3246 (Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry), or ASTM D-6228 (Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection).

5.3 The APCO makes a determination that a permit shall be required because the source may not operate in compliance with all District rules and regulations; or

5.4 The owner specifically requests a Permit to Operate.

6.0 District Exempt Source Categories

Except as required by Section 5.0, no Authority to Construct or Permit to Operate shall be required for an emission unit specified below. All other equipment within that source category shall require an ATC or PTO.

6.1 Combustion and Heat Transfer Systems

6.1.1 Steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with:

6.1.1.1 Natural gas containing no more than five (5) percent by weight hydrocarbons heavier than butane and no more than 1.0 grain of total sulfur per 100 standard cubic feet of gas; or

6.1.1.2 Liquefied petroleum gas containing no more than two (2) percent by volume hydrocarbons heavier than butane and no more than 15 grains of total sulfur per 100 standard cubic feet of gas; or

6.1.1.3 Any combination of gases specified in Sections 6.1.1.1 and 6.1.1.2.

6.1.1.4 The percent by weight hydrocarbons content heavier than butane shall be determined by using the latest version of ASTM E-260 (Standard Practice for Packed Column Gas Chromatography).

6.1.1.5 The gas sulfur content shall be determined by using the latest version of ASTM D-1072 (Standard Test Method for Total Sulfur in Fuel Gases by Combustion and Barium Chloride Titration), ASTM D-3246 (Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry), or ASTM D-6228 (Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection).

5.3 The APCO makes a determination that a permit shall be required because the source may not operate in compliance with all District rules and regulations; or

5.4 The owner specifically requests a Permit to Operate.

6.0 District Exempt Source Categories

Except as required by Section 5.0, no Authority to Construct or Permit to Operate shall be required for an emission unit specified below. All other equipment within that source category shall require an ATC or PTO.

6.1 Combustion and Heat Transfer Systems

6.1.1 Steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with:

6.1.1.1 Natural gas containing no more than five (5) percent by weight hydrocarbons heavier than butane and no more than 1.0 grain of total sulfur per 100 standard cubic feet of gas; or

6.1.1.2 Liquefied petroleum gas containing no more than two (2) percent by volume hydrocarbons heavier than butane and no more than 15 grains of total sulfur per 100 standard cubic feet of gas; or

6.1.1.3 Any combination of gases specified in Sections 6.1.1.1 and 6.1.1.2.

6.1.1.4 The percent by weight hydrocarbons content heavier than butane shall be determined by using the latest version of ASTM E-260 (Standard Practice for Packed Column Gas Chromatography).

6.1.1.5 The gas sulfur content shall be determined by using the latest version of ASTM D-1072 (Standard Test Method for Total Sulfur in Fuel Gases by Combustion and Barium Chloride Titration), ASTM D-3246 (Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry), or ASTM D-6228 (Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection).

5.3 The APCO makes a determination that a permit shall be required because the source may not operate in compliance with all District rules and regulations; or

5.4 The owner specifically requests a Permit to Operate.

6.0 District Exempt Source Categories

Except as required by Section 5.0, no Authority to Construct or Permit to Operate shall be required for an emission unit specified below. All other equipment within that source category shall require an ATC or PTO.

6.1 Combustion and Heat Transfer Systems

6.1.1 Steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with:

6.1.1.1 Natural gas containing no more than five (5) percent by weight hydrocarbons heavier than butane and no more than 1.0 grain of total sulfur per 100 standard cubic feet of gas; or

6.1.1.2 Liquefied petroleum gas containing no more than two (2) percent by volume hydrocarbons heavier than butane and no more than 15 grains of total sulfur per 100 standard cubic feet of gas; or

6.1.1.3 Any combination of gases specified in Sections 6.1.1.1 and 6.1.1.2.

6.1.1.4 The percent by weight hydrocarbons content heavier than butane shall be determined by using the latest version of ASTM E-260 (Standard Practice for Packed Column Gas Chromatography).

6.1.1.5 The gas sulfur content shall be determined by using the latest version of ASTM D-1072 (Standard Test Method for Total Sulfur in Fuel Gases by Combustion and Barium Chloride Titration), ASTM D-3246 (Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry), or ASTM D-6228 (Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection).

- 5.3 The APCO makes a determination that a permit shall be required because the source may not operate in compliance with all District rules and regulations; or
- 5.4 The owner specifically requests a Permit to Operate.

6.0 District Exempt Source Categories

Except as required by Section 5.0, no Authority to Construct or Permit to Operate shall be required for an emission unit specified below. All other equipment within that source category shall require an ATC or PTO.

6.1 Combustion and Heat Transfer Systems

6.1.1 Steam generators, steam superheaters, water boilers, water heaters, steam cleaners, and closed indirect heat transfer systems that have a maximum input heat rating of 5,000,000 Btu per hour (gross) or less and is equipped to be fired exclusively with:

6.1.1.1 Natural gas containing no more than five (5) percent by weight hydrocarbons heavier than butane and no more than 1.0 grain of total sulfur per 100 standard cubic feet of gas; or

6.1.1.2 Liquefied petroleum gas containing no more than two (2) percent by volume hydrocarbons heavier than butane and no more than 15 grains of total sulfur per 100 standard cubic feet of gas; or

6.1.1.3 Any combination of gases specified in Sections 6.1.1.1 and 6.1.1.2.

6.1.1.4 The percent by weight hydrocarbons content heavier than butane shall be determined by using the latest version of ASTM E-260 (Standard Practice for Packed Column Gas Chromatography).

6.1.1.5 The gas sulfur content shall be determined by using the latest version of ASTM D-1072 (Standard Test Method for Total Sulfur in Fuel Gases by Combustion and Barium Chloride Titration), ASTM D-3246 (Standard Test Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry), or ASTM D-6228 (Standard Test Method for Determination of Sulfur Compounds in Natural Gas and Gaseous Fuels by Gas Chromatography and Flame Photometric Detection).

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-39-24

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID #36-3, DIS# 43008-74)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. NO_x, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
24. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
33. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
34. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
36. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
37. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
38. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
40. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
41. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
42. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-42-23

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 42-3, DIS# 43003-75)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rule 4305] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
23. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
24. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall keep daily records of the sulfur content of the natural gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted and shall make records available for inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
37. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
38. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
40. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
42. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
44. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
46. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
47. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-55-23

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 65-3, DIS# 43006-80)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. NO_x, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O₂, NO_x concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
26. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
35. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
38. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
40. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
41. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
42. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-57-25

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67-3, DIS# 43008-80) WITH NORTH AMERICAN GLE 1 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320]
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, and Rule 4306] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-66-29

EXPIRATION DATE: 02/29/2016

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9, DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCO performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081 and 2520] Federally Enforceable Through Title V Permit
8. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O₂, NO_x concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
43. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
44. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit
45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-69-27

EXPIRATION DATE: 02/29/2016

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4, DIS# 43013-82) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCO performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by a District-approved independent laboratory on an annual basis. Sample collection for such determination shall be District-witnessed or approved. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Permittee shall keep weekly records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-70-28

EXPIRATION DATE: 02/29/2016

SECTION: NW 3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4, DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District RuleS 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
7. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
8. Emissions shall not exceed any of the following limits: PM₁₀: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NO_x as NO₂: 15 ppmvd @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, or CO: 29 ppmvd @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201 and 4306] Federally Enforceable Through Title V Permit
10. During start-up and shutdown periods, emissions shall not exceed: NO_x as NO₂: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
13. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
14. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
28. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
29. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
32. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
41. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-71-24

EXPIRATION DATE: 02/29/2016

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR
(CUSA ID# 79-4, DIS# 43009-82)

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
13. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
14. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
15. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
16. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4305. [District Rule 4305] Federally Enforceable Through Title V Permit
20. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 25 below. [District NSR Rule] Federally Enforceable Through Title V Permit
21. The fuel supply line shall be physically disconnected or prevented from entering this unit. [District NSR Rule and District Rule 2080] Federally Enforceable Through Title V Permit
22. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District NSR Rule and District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
23. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
25. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
26. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
27. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
28. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
29. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
41. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
42. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
43. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

44. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351]
45. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-73-23

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 53-32, DIS# 43012-78)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
21. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
22. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
23. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
24. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
37. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
38. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
40. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
41. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
42. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-112-20

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 77-32, DIS# 43011-82)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
15. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
16. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
17. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
18. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Last Amended December 17, 1992) and 4301 (Last Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
21. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
22. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
23. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. NO_x and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
31. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
33. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
34. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
38. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520 section 6.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-148-17

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Unit shall demonstrate compliance annually with NOx and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
11. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
15. Operator shall operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
16. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
17. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
18. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Ammonia injection rate shall be regulated to maintain ammonia emissions (slip) below 21 ppmv. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated as: $\text{slip} = (\text{a-bxc}/1,000,000) \times 1,000,000/\text{b}$, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
26. Thermal stabilization period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
27. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
29. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
31. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
32. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
33. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit
35. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. Permittee shall keep accurate records of turbine daily NO_x (as NO₂) and oxygen (O₂) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
37. Compliance source testing for NO_x, CO, and O₂ shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
38. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit
40. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
41. The following test methods shall be used: NO_x - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM₁₀ - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O₂ - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
42. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
45. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-149-17

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Unit shall demonstrate compliance annually with NO_x and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
11. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
15. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
16. The continuous NO_x monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
17. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
18. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Ammonia injection rate shall be regulated to maintain ammonia emissions (slip) below 21 ppmv. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated as: $\text{slip} = (\text{a-bxc}/1,000,000) \times 1,000,000/\text{b}$, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
26. Thermal stabilization period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
27. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
29. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
31. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
32. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
33. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
34. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit
35. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. Permittee shall keep accurate records of turbine daily NO_x (as NO₂) and oxygen (O₂) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
37. Compliance source testing for NO_x, CO, and O₂ shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
38. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit
40. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
41. The following test methods shall be used: NO_x - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM₁₀ - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O₂ - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit
42. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit
43. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit
44. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
45. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-159-11

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 56 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-5-32)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 96.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. Permittee shall maintain a current roster of all wells connected to this system, and shall make such roster available for District inspection upon request. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
7. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
8. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
9. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
12. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
13. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
14. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
15. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
16. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
18. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
19. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
20. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
22. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
23. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
24. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
26. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
27. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
28. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
29. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
30. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
31. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
32. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
33. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
34. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
36. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
37. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
38. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
39. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
40. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
41. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
43. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
44. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-160-12

EXPIRATION DATE: 02/29/2016

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 50 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 109.6 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401; 5.3.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
42. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
43. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
44. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
46. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
47. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
48. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
49. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-161-18

EXPIRATION DATE: 02/29/2016

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 210.5 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
11. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
16. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
17. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
18. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
19. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
20. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
22. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
23. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
24. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
25. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
26. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
27. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
30. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
31. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
32. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
34. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
35. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
36. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
37. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
38. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
39. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
40. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
41. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
42. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
43. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

44. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
45. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
46. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
47. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
48. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-162-14

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 89.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-164-17

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 49 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 114.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
10. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
42. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
43. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
44. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
46. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
47. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
48. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
49. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-165-12

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 39 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 91.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-166-15

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 92 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 215.5 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-167-17

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 150 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 351.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
10. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
42. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
43. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
44. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
46. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
47. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
48. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
49. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-168-16

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 89.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
10. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
42. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
43. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
44. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
46. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
47. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
48. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
49. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-169-14

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 73 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 171.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-171-19

EXPIRATION DATE: 02/29/2016

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 220 STEAM ENHANCED WELLS- PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-1-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 378.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
8. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
9. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
12. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
13. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
14. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
15. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
16. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
18. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
19. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
21. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
22. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
23. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
24. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
26. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
27. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
28. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
29. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
30. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
31. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
32. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
34. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
35. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
36. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
37. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
39. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
40. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
41. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
43. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
44. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
45. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-173-15

EXPIRATION DATE: 02/29/2016

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-3-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. VOC emission rate shall not exceed 44.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of wells connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-174-18

EXPIRATION DATE: 02/29/2016

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 91 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-2-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed well casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 156.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
8. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
9. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
12. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
13. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
14. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
15. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
16. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
18. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
19. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
21. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
22. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
23. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
24. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
26. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
27. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
28. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
29. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
30. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
31. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
32. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
34. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
35. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
36. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
37. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
39. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
40. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
41. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
43. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
44. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
45. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-176-15

EXPIRATION DATE: 02/29/2016

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. Volatile organic compound (VOC) emission rate shall not exceed 224.9 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
12. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
16. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
17. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
18. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
19. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
20. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
22. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
23. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
24. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
25. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
26. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
27. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
30. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
31. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
32. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
34. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
35. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
36. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
37. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
38. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
39. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
40. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
41. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
42. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
43. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

44. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
45. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
46. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
47. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
48. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-177-14

EXPIRATION DATE: 02/29/2016

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 160 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. Volatile organic compound (VOC) emission rate shall not exceed 336.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-178-13

EXPIRATION DATE: 02/29/2016

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 26 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 57.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
42. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
43. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
44. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
46. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
47. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
48. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
49. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-179-18

EXPIRATION DATE: 02/29/2016

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 130 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPTHA CC-3-31)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. VOC emission rate shall not exceed 223.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of wells connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-180-15

EXPIRATION DATE: 02/29/2016

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPTHA CC-2-31)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 44.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
8. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
9. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
12. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
13. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
14. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
15. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
16. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
18. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
19. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
21. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
22. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
23. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
24. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
26. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
27. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
28. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
29. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
30. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
31. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
32. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
34. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
35. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
36. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
37. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
39. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
40. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
41. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
43. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
44. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
45. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-185-15

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 49 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-4-32)

PERMIT UNIT REQUIREMENTS

1. Fluids from these steam-enhanced wells with closed well casing vents and cyclic wells with closed well casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 84.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. A listing of all steam enhanced wells connected to this system shall be submitted to the District at least 60 days prior to the permit anniversary date. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
8. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
9. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
12. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
13. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
14. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
15. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
16. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
18. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
19. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
21. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
22. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
23. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
24. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
26. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
27. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
28. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
29. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
30. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
31. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
32. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
34. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
35. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
36. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
37. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
39. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
40. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
41. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
43. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
44. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
45. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-187-13

EXPIRATION DATE: 02/29/2016

SECTION: 03 **TOWNSHIP:** 09S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-1-3, WITH 44 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401]
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020. [District NSR Rule and 4401]
3. Volatile organic compound (VOC) emission rate shall not exceed 103.1 lb/day. [District NSR Rule]
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201]
5. All records of required monitoring data and support information required by this permit shall be retained for a period of at least five years and shall be made available for District inspection upon request. [District Rules 2520, 9.4.2, and 4401, 6.1] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
33. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
34. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
35. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
36. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
38. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
39. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
40. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
41. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
42. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

43. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
44. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
45. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
46. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
47. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-201-9

EXPIRATION DATE: 02/29/2016

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH UP TO 66 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS (MONTE CRISTO 2)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020. [District NSR Rule] Federally Enforceable Through Title V Permit
2. VOC emission rate shall not exceed 113.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
5. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
6. A listing of all steam enhanced wells connected to this system shall be submitted to the District at least 60 days prior to the permit anniversary date. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
8. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
9. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
12. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
13. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
14. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
15. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
16. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
18. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
19. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
21. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
22. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
23. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
24. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
26. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
27. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
28. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
29. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
30. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
31. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
32. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
34. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
35. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
36. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
37. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
39. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
40. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
41. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
43. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
44. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
45. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-290-4

EXPIRATION DATE: 02/29/2016

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

84,546 GAL FIXED ROOF STORAGE TANK (TANK ID FOAM TK 1-3)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-292-4

EXPIRATION DATE: 02/29/2016

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

45,486 GAL FIXED ROOF STORAGE TANK (TANK ID DRAIN T-4)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-293-4

EXPIRATION DATE: 02/29/2016

SECTION: NW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID DRAIN T-5)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1. "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-294-4

EXPIRATION DATE: 02/29/2016

SECTION: NW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 10-3)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-295-4

EXPIRATION DATE: 02/29/2016

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

34,230 GALLON FIXED ROOF STORAGE TANK (TANK ID SALVAGE TK P-7)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-325-5

EXPIRATION DATE: 02/29/2016

SECTION: SW39 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-329-4

EXPIRATION DATE: 02/29/2016

SECTION: NW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-330-4

EXPIRATION DATE: 02/29/2016

SECTION: SW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

21,714 GALLON FIXED ROOF STORAGE TANK (TANK ID 34-9)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-358-2

EXPIRATION DATE: 02/29/2016

SECTION: SW32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

420,000 GALLON FIXED ROOF STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-360-4

EXPIRATION DATE: 02/29/2016

SECTION: SE07 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

63,546 GALLON FIXED ROOF STORAGE TANK (TANK ID T-9)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-420-6

EXPIRATION DATE: 02/29/2016

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

1 THERMALLY ENHANCED STEAM DRIVE OIL WELL WITH CLOSED CASING VENT

PERMIT UNIT REQUIREMENTS

1. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
2. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
3. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
4. Permittee shall maintain a current listing of all steam enhanced wells with closed-casing vents, and shall make such records available for District inspection upon request. [District Rules 4401 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. VOC emission rate shall not exceed 2.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
7. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
8. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
9. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
11. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
12. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
13. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
14. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
15. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
16. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
17. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
18. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
19. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
20. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit
22. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
23. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
24. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
25. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
26. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
27. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
28. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
29. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
30. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
31. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
32. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
33. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
34. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
36. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
37. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
38. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
39. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
40. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
41. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
43. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
44. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-427-6

EXPIRATION DATE: 02/29/2016

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH UP TO 248 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
2. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended June 16, 2011), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
3. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
4. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: 1) The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1.1 and 5.1.2] Federally Enforceable Through Title V Permit
7. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit
8. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3.2] Federally Enforceable Through Title V Permit
11. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3.3] Federally Enforceable Through Title V Permit
12. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4.1] Federally Enforceable Through Title V Permit
13. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.2] Federally Enforceable Through Title V Permit
14. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4.3] Federally Enforceable Through Title V Permit
15. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4.4] Federally Enforceable Through Title V Permit
16. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4.5] Federally Enforceable Through Title V Permit
17. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4.6] Federally Enforceable Through Title V Permit
18. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5.1] Federally Enforceable Through Title V Permit
19. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401, 5.5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5.3] Federally Enforceable Through Title V Permit
21. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
22. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5.4] Federally Enforceable Through Title V Permit
23. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.5] Federally Enforceable Through Title V Permit
24. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5.6] Federally Enforceable Through Title V Permit
25. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5.7] Federally Enforceable Through Title V Permit
26. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
27. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1.3] Federally Enforceable Through Title V Permit
28. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1.4] Federally Enforceable Through Title V Permit
29. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1.5] Federally Enforceable Through Title V Permit
30. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
31. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
32. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
34. If approved by the APCO, a VOC collection and control system is not subject to Section 6.2.1 if all uncondensed VOC emissions collected by the system are controlled by a device meeting one of the following requirements: 1) An internal combustion engine subject to District Rule 4702 (Internal Combustion Engines - Phase 2); 2) A combustion device subject to District Rule 4320 (Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr); District Rule 4307 (Boilers, Steam Generators, and Process Heaters - 2.0 MMBtu/hr to 5.0 MMBtu/hr); or District Rule 4308 (Boilers, Steam Generators, and Process Heaters - 0.075 MMBtu/hr to 2.0 MMBtu/hr); or 3) A unit subject to District Rule 4311 (Flares). [District Rule 4401, 6.2.2] Federally Enforceable Through Title V Permit
35. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
36. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
37. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
38. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.4] Federally Enforceable Through Title V Permit
39. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

40. Operator shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. [District Rule 4401, 6.5] Federally Enforceable Through Title V Permit
41. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
42. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-432-4

EXPIRATION DATE: 02/29/2016

SECTION: NW9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

4,200 BBL OPEN-TOP PETROLEUM STORAGE TANK (TANK ID T-8A, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-433-4

EXPIRATION DATE: 02/29/2016

SECTION: NW9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

21,000 GALLON OPEN TOP CRUDE OIL OVERFLOW TANK (TANK ID T-8B, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-434-4

EXPIRATION DATE: 02/29/2016

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14A, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-435-4

EXPIRATION DATE: 02/29/2016

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14B, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-436-4

EXPIRATION DATE: 02/29/2016

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

210,000 GALLON OPEN TOP CRUDE OIL STORAGE TANK (TANK ID T-1C, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-1127-0-0

EXPIRATION DATE: 02/28/2006

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (Amended September 17, 1998). [District Rules 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CHEVRON USA INC
Location: HEAVY OIL CENTRAL
S-1127-0-0: Jun 14 2011 4:40PM - AHMADS

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.6.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520(6/15/95) [District Rules 2520, 9.6.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.8] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.9.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.9.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.9.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.9.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.10] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.14.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.14.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.14.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.14.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (12/17/92), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall supply, sell, solicit or apply any architectural coating, except specialty coatings, that contains more than 250 grams of VOC per liter of coating (less water and exempt compounds, and excluding any colorant added to tint bases), or manufacture, blend, or repackage such coating with more than 250 grams of VOC per liter (less water and exempt compounds, and excluding any colorant added to tint bases) for use within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. Specialty Coating Limitations: No person shall apply, sell, solicit, or offer for sale any architectural coating listed in the Tables of Standards (District Rule 4601, Table 1 and Table 2), nor manufacture, blend, or repackage such coating for use within the District, which contains VOCs in excess of the specified limits after the corresponding date listed in Table 1 (grams of VOC per liter of coating as applied less water and exempt compounds, excluding any colorant added to tint bases) and in Table 2 (grams of VOC per liter of material), except as provided in Section 5.3 of Rule 4601. [District Rule 4601, 5.2] Federally Enforceable Through Title V Permit
25. All VOC-containing materials shall be stored in closed containers when not in use. In use includes, but is not limited to: being accessed, filled, emptied, maintained or repaired. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. A person shall not use VOCs for the cleanup of spray equipment unless equipment for collection of the cleaning compounds and minimizing its evaporation to the atmosphere is used. [District Rule 4601, 5.5] Federally Enforceable Through Title V Permit
27. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.2 (12/17/92). [District Rule 4601, 6.1 and 6.2] Federally Enforceable Through Title V Permit
28. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.14.1 and 10.0] Federally Enforceable Through Title V Permit
29. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
30. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
31. Disturbances of soil related to any construction, demolition, excavation, extraction, or water mining activities shall comply with the requirements for fugitive dust control in SJVUAPCD District Rule 8020 (4/25/96) unless specifically exempted under section 4 of Rule 8020 (4/25/96). [District Rule 8020] Federally Enforceable Through Title V Permit
32. Outdoor handling and storage of any bulk material which emits dust shall comply with the requirements of SJVUAPCD Rule 8030 (4/25/96), unless specifically exempted under section 4 of Rule 8030 (4/25/96). [District Rule 8030] Federally Enforceable Through Title V Permit
33. Any paved road over 3 miles in length, and any unpaved roads over half a mile in length, constructed after December 10, 1993 shall use the design criteria and dust control measures of, and comply with the administrative requirements of, SJVUAPCD Rule 8060 (4/25/96) unless specifically exempted under section 4 of Rule 8060 (4/25/96). [District Rule 8060] Federally Enforceable Through Title V Permit
34. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.17] Federally Enforceable Through Title V Permit
36. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
37. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permit shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
38. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (12/17/92); 4601, sections 5.1, 5.2, 5.4, 5.5, 6.1, and 6.2 (9/17/97); 8020 (4/25/96); 8030 (4/25/96); 8060 (4/25/96); A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
41. On March 31, 2001, the initial Title V permit was issued, the reporting period of the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of reporting period. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
42. All permits for facilities #S-88, S-511, S-1127, S-1131, and S-1551 are included in ChevronTexaco Inc.'s Heavy Oil Central stationary source. [District Rule 2201]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-22-29

EXPIRATION DATE: 02/28/2006

SECTION: SW3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

82.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3, DIS #43006-74) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6 , 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
12. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2, 4320, and 4351] Federally Enforceable Through Title V Permit
19. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4320] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2520, 9.3.2, 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
35. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-25-27

EXPIRATION DATE: 02/28/2006

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 40-32, DIS# 43001-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. The requirements of 40 CFR 72.6(b) and 40-CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
25. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
33. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
34. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
36. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
37. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
38. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
41. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
42. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
46. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-28-30

EXPIRATION DATE: 02/28/2006

SECTION: NE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2.1; 4351, 6.2.1, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM₁₀: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NO_x as NO₂: 15 ppmvd @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, or CO: 29 ppmvd @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NO_x as NO₂: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NO_x as NO₂: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rule 4320] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4320] Federally Enforceable Through Title V Permit
19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 5.4.2.1, 4306, 5.4.2.1, 4320 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rule 4320] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

25. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rules 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit
26. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081, 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
27. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis and when the mode of operation of the FGR system (open or closed) is changed, using District approved portable analyzers, in any calendar month in which the unit operates. [District Rules 2520, 9.3.2, 4305 and 4306] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 5.4.2.1, 4306, 5.4.2.1, 4320, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. This unit shall be tested for compliance with the NO_x and CO emissions limits at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4320 and 4351] Federally Enforceable Through Title V Permit
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4. [District Rules 1081, 4305, 6.2, 4306, 6.2, 4320 and 4351] Federally Enforceable Through Title V Permit
38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-29-26

EXPIRATION DATE: 02/28/2006

SECTION: NE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR 44-9, DIS #43007-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule]
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3, and 4320] Federally Enforceable Through Title V Permit
13. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22, and 4320] Federally Enforceable Through Title V Permit
14. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2, 4320 and 4351] Federally Enforceable Through Title V Permit
20. Whenever the flue gas recirculation (FGR) system on this unit is switched from the open to the closed position, or from the closed to the open position, compliance source testing for NOx and CO emissions shall be conducted within 60 days of change of FGR operation date unless source testing with FGR system in both the open and closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2520, 9.3.2, 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
26. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
36. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
37. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
38. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-30-27

EXPIRATION DATE: 02/28/2006

SECTION: 9 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9, DIS #43008-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. *If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value.* [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
9. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3, and 4320] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
15. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
17. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2, 4320, and 4351] Federally Enforceable Through Title V Permit
21. Whenever the flue gas recirculation (FGR) system on this unit is switched from the open to the closed position, or from the closed to the open position, compliance source testing for NOx and CO emissions shall be conducted within 60 days of change of FGR operation date unless source testing with FGR system in both the open and closed position has occurred within the previous 12 months. [District Rule 1070] Federally Enforceable Through Title V Permit
22. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2520, 9.3.2, 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
27. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
37. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-31-27

EXPIRATION DATE: 02/28/2006

SECTION: 9 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9, DIS #43009-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rules 404 (Madera), 406 (Fresno), and 407 (Kings, Merced, San Joaquin, Tulare, Kern, and Stanislaus)] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
6. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
9. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
10. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3, and 4320] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22, and 4320] Federally Enforceable Through Title V Permit
15. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
17. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2, 4320 and 4351] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rule 4320] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2520, 9.3.2, 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
27. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4320 and 4320] Federally Enforceable Through Title V Permit
35. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
37. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
38. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
39. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-34-25

EXPIRATION DATE: 02/28/2006

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5, DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. Emissions shall not exceed any of the following limits: PM₁₀: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NO_x as NO₂: 15 ppmvd @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, or CO: 29 ppmvd @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
4. During start-up and shutdown periods, emissions shall not exceed: NO_x as NO₂: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NO_x as NO₂: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
10. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
12. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by an ARB certified testing laboratory. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and SO_x (lb/MMBtu) - ARB Method 100. [District Rules 1081, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
23. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
31. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
32. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-35-26

EXPIRATION DATE: 02/28/2006

SECTION: 5 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5, DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. Emissions shall not exceed any of the following limits: PM₁₀: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NO_x as NO₂: 15 ppmvd @ 3% O₂ or 0.0182 lb-NO_x/MMBtu, or CO: 29 ppmvd @ 3% O₂ or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
4. During start-up and shutdown periods, emissions shall not exceed: NO_x as NO₂: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NO_x as NO₂: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
10. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
12. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4320; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
14. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by an ARB certified testing laboratory. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and SO_x (lb/MMBtu) - ARB Method 100. [District Rules 1081, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
23. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
28. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
30. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of five years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
31. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-36-26

EXPIRATION DATE: 02/28/2006

SECTION: 05 TOWNSHIP: 29S RANGE: 28

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5, DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
9. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
13. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
14. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
16. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2., 4320 and 4351] Federally Enforceable Through Title V Permit
20. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5.2, 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2520, 9.3.2, 4305, 5.5.5, 4306, 5.5.5 and 4320] Federally Enforceable Through Title V Permit
25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
35. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
36. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-38-28

EXPIRATION DATE: 02/28/2006

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3, DIS# 43007-74) A
NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4351, 6.2.1; Rule 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
21. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
24. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
25. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
33. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
35. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4. [District Rules 1081, 4305, 6.2, 4306, 6.2, 4320 and 4351] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-39-26

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #36-3, DIS# 43008-74) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

20. NO_x, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
24. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
33. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
34. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
36. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
37. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
38. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
40. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
41. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
42. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-42-25

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 42-3, DIS# 43003-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method I-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rule 4305] Federally Enforceable Through Title V Permit
21. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
23. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
24. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
25. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The permittee shall keep daily records of the sulfur content of the natural gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted and shall make records available for inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
38. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
39. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
40. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
41. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
42. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
43. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

44. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
45. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
46. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
47. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
48. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-55-25

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 65-3, DIS# 43006-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3:2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
23. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
24. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
29. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

31. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
37. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
38. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
40. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
41. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
42. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
44. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
46. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
47. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-57-27

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67-3, DIS# 43008-80) WITH NORTH AMERICAN GLE 1 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or *grab sample analysis by GC-FPD/TCD performed in the laboratory.* [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320]
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; 4351, 6.2.1 and Rule 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320, and 4351, 6.3.1] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4306] Federally Enforceable Through Title V Permit
25. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4306] Federally Enforceable Through Title V Permit
32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOX and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306]
35. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
36. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
38. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-66-31

EXPIRATION DATE: 02/28/2006

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9, DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
8. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2.1; 4351, 6.2.1, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4306] Federally Enforceable Through Title V Permit
24. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

25. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. If either the NOX or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305 and 4306]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOX and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306]
35. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4320]
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and stack gas moisture content - EPA Method 4 [District Rules 1081, 4305, 4306, 4320 and 4351] Federally Enforceable Through Title V Permit
38. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
39. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-69-29

EXPIRATION DATE: 02/28/2006

SECTION: 04 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4, DIS# 43013-82) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
4. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
6. *When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks.* [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
8. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3 and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4306, 3.25 and 3.22 and 4320] Federally Enforceable Through Title V Permit
18. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by a District-approved independent laboratory on an annual basis. Sample collection for such determination shall be District-witnessed or approved. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
19. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
20. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Permittee shall keep weekly records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
25. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
30. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
32. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. If either the NOX or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. The permittee shall maintain records of: (1) the date and time of NOX, CO, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NOX and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306]
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, and stack gas moisture content - EPA Method 4. [District Rules 1081, 4305, 4320 and 4351] Federally Enforceable Through Title V Permit
38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-70-30

EXPIRATION DATE: 02/28/2006

SECTION: NW 3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4, DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
3. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H₂S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520, 9.3.2 AND 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
7. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
8. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 5.5.6, 4306, 5.3, and 4320] Federally Enforceable Through Title V Permit
9. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 5.1 and 4306, 5.1] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, 6.2, 4320 and 4351] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3.1, 4306, 6.3.1, 4320 and 4351, 6.3.1] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 5.5.2; 4306, 5.5.2 and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2520, 9.3.2; 4305, 5.5.5; 4306, 5.5.5; and 4320] Federally Enforceable Through Title V Permit
21. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
22. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
24. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
25. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
26. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-71-23

EXPIRATION DATE: 02/28/2006

SECTION: 04 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 79-4, DIS# 43009-82)

PERMIT UNIT REQUIREMENTS

1. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
2. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
6. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
10. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
11. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
13. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
14. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
15. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
16. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4305. [District Rule 4305] Federally Enforceable Through Title V Permit
21. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 25 below. [District NSR Rule] Federally Enforceable Through Title V Permit
22. The fuel supply line shall be physically disconnected or prevented from entering this unit. [District NSR Rule and District Rule 2080] Federally Enforceable Through Title V Permit
23. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District NSR Rule and District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
24. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule] Federally Enforceable Through Title V Permit
25. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
26. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
27. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
28. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
29. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
30. NO_x and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O₂, NO_x concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.3.2] Federally Enforceable Through Title V Permit
34. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
42. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
44. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
45. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351]
46. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-73-25

EXPIRATION DATE: 02/28/2006

SECTION: 32 TOWNSHIP: 28S RANGE: 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 53-32, DIS# 43012-78) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Emission rates shall not exceed any of the following PM₁₀: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
20. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
22. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
23. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
24. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
25. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
31. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
33. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
34. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
35. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
36. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
38. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
39. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
40. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
41. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
43. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
44. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
45. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-112-22

EXPIRATION DATE: 02/28/2008

SECTION: 32 TOWNSHIP: 28S RANGE: 28E

EQUIPMENT DESCRIPTION:

NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 77-32, DIS# 43011-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2210, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
5. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
6. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
8. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO₂. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
9. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method I-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit
13. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit
14. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
15. The following conditions must be met for representative unit(s) to be used to test for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
16. All units in a group for which representative units are source tested for NO_x and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
17. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit
18. The number of representative units source tested for NO_x and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.5.1, 5.5.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended December 17, 1992), and 4351, sections 4.2, 5.2.2, 6.1.1, 6.2, and 8.1 (Last Amended October 19, 1995). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
21. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
22. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SO_x (as SO₂): 0.094 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu or 30 ppmv @ 3% O₂, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
23. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
24. If the NO_x and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. NO_x and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
27. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NO_x and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
30. The stack concentration of NO_x (as NO₂), CO, and O₂ shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of the date and time of NO_x, CO, and O₂ measurements, the measured NO₂ and CO concentrations corrected to 3% O₂, and the O₂ concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
33. Source testing to demonstrate compliance with NO_x and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
34. If permittee fails any compliance demonstration for NO_x and/or CO emission limits when testing not less than once every 36 months, compliance with NO_x and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
35. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NO_x and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit
39. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520 section 6.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-148-16

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4] Federally Enforceable Through Title V Permit
9. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Unit shall demonstrate compliance annually with NO_x and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
11. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
12. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
13. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
15. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
16. Operator shall operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
17. The continuous NO_x monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
18. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
19. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
20. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
22. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
23. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SO_x (as SO₂): 29.8 lb/day, NO_x (as NO₂): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia injection rate shall be regulated to maintain ammonia emissions (slip) below 21 ppmv. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Ammonia slip shall be calculated as: $\text{slip} = (a - b \times c / 1,000,000) \times 1,000,000 / b$, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate.(lb/hr)/29(lb/lb.mol); and c=change in measured NO_x concentration in ppmvd at the actual stack oxygen (O₂) concentration. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
26. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
27. Thermal stabilization period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
28. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SO_x (as SO₂): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Maximum NO_x emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O₂. [District Rule 4001] Federally Enforceable Through Title V Permit
30. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (based on three-hour rolling average) shall not exceed either of the following: NO_x (as NO₂): 5 ppmv dry @ 15% oxygen (O₂); or CO: 13.5 ppmv @ 15% oxygen (O₂). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
31. Permittee shall report the following emission exceedences to the District: NO_x emission rate on a three-hour average, NSPS NO_x emission rate on one hour average, and DEL of NO_x during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NO_x daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit
36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. Permittee shall keep accurate records of turbine daily NO_x (as NO₂) and oxygen (O₂) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
38. Compliance source testing for NO_x, CO, and O₂ shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit
41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
42. Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20. [District Rules 2520, 9.4.1 and 4703, 6.4.1] Federally Enforceable Through Title V Permit
43. Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B. [District Rules 2520, 9.4.1 and 4703, 6.4.2] Federally Enforceable Through Title V Permit
44. Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20. [District Rules 2520, 9.4.1 and 4703, 6.4.3] Federally Enforceable Through Title V Permit
45. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit
47. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
48. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-149-16

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4] Federally Enforceable Through Title V Permit
9. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Unit shall demonstrate compliance annually with NO_x and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
11. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
12. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
13. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
14. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
15. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
16. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NO_x and O₂ concentration. [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
17. The continuous NO_x monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
18. A violation of NO_x emission standards indicated by the NO_x CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
19. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
20. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
22. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
23. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia injection rate shall be regulated to maintain ammonia emissions (slip) below 21 ppmv. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Ammonia slip shall be calculated as: $slip = (a-bxc/1,000,000) \times 1,000,000/b$, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
26. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
27. Thermal stabilization period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
28. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
30. Except during periods of gas turbine engine startup/shutdown, and thermal stabilization, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
31. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit
36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. Permittee shall keep accurate records of turbine daily NO_x (as NO₂) and oxygen (O₂) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit
38. Compliance source testing for NO_x, CO, and O₂ shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit
39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit
41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
42. Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20. [District Rules 2520, 9.4.1 and 4703, 6.4.1] Federally Enforceable Through Title V Permit
43. Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B. [District Rules 2520, 9.4.1 and 4703, 6.4.2] Federally Enforceable Through Title V Permit
44. Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20. [District Rules 2520, 9.4.1 and 4703, 6.4.3] Federally Enforceable Through Title V Permit
45. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit
47. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit
48. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-159-10

EXPIRATION DATE: 02/28/2006

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 56 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-5-32)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times, except during periods of actual service or repair [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Permittee shall maintain a current roster of all wells connected to this system, and shall make such roster available for District inspection upon request. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. VOC emission rate shall not exceed 96.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-160-16

EXPIRATION DATE: 02/28/2006

SECTION: 09 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 50 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 109.6 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.5.1 and 5.5.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.6.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 3 of Rule 4401. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.6.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.9 of Rule 4401. [District Rule 4401 5.7.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401 5.7.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401 5.7.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401 5.8.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.8.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.8.1, 5.8.2 and 5.8.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.8.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401 5.8.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401 5.8.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401 5.8.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401 5.9.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and 5.9.2.3 of Rule 4401, or the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.9.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401 5.9.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.9.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
29. *The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks.* [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401 5.9.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401 6.1.3] Federally Enforceable Through Title V Permit
35. The results of source tests conducted pursuant to Section 4.6.2 of Rule 4401 shall be submitted to the APCO within 60 days after the completion of the source test. [District Rule 4401 6.1.4] Federally Enforceable Through Title V Permit
36. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401 6.1.5] Federally Enforceable Through Title V Permit
37. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401 6.1.6] Federally Enforceable Through Title V Permit
38. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.8] Federally Enforceable Through Title V Permit
40. The results of gauge tank TVP testing conducted pursuant to Section 6.2.5 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
41. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.11] Federally Enforceable Through Title V Permit
42. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
43. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless flare. [District Rule 4401 6.2.2] Federally Enforceable Through Title V Permit
44. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device. [District Rule 4401 6.2.3] Federally Enforceable Through Title V Permit
45. An operator seeking approval pursuant to Section 6.2.2 or Section 6.2.3 shall submit a written request and supporting information to the APCO. The District shall evaluate the request and if approved by the APCO, the District shall provide EPA and ARB with a copy of the evaluation and shall request EPA and ARB approval. The District evaluation and the APCO request shall be deemed approved unless EPA or ARB objects to such approval in writing within 45 days of the receipt of the APCO request. [District Rule 4401 6.2.4] Federally Enforceable Through Title V Permit
46. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.17 of Rule 4401: conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.10 of Rule 4401. [District Rule 4401 6.2.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

47. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
48. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
49. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
50. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.5] Federally Enforceable Through Title V Permit
51. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
52. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
53. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
54. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3 and 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-161-22

EXPIRATION DATE: 02/28/2006

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 210.5 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
10. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
11. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.5.1 and 5.5.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.6.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 3 of Rule 4401. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
15. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.6.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.9 of Rule 4401. [District Rule 4401 5.7.1] Federally Enforceable Through Title V Permit
16. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401 5.7.2] Federally Enforceable Through Title V Permit
17. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401 5.7.3] Federally Enforceable Through Title V Permit
18. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401 5.8.1] Federally Enforceable Through Title V Permit
19. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.2] Federally Enforceable Through Title V Permit
20. In addition to the inspections required by Section 5.8.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. In addition to the inspections required by Sections 5.8.1, 5.8.2 and 5.8.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.8.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401 5.8.4] Federally Enforceable Through Title V Permit
22. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401 5.8.5] Federally Enforceable Through Title V Permit
23. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401 5.8.6] Federally Enforceable Through Title V Permit
24. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401 5.9.1] Federally Enforceable Through Title V Permit
25. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and 5.9.2.3 of Rule 4401, or the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.9.2] Federally Enforceable Through Title V Permit
26. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401 5.9.3] Federally Enforceable Through Title V Permit
27. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.9.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
28. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
29. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.5] Federally Enforceable Through Title V Permit
30. The time of the initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.6] Federally Enforceable Through Title V Permit
31. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401 5.9.7] Federally Enforceable Through Title V Permit
32. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401 6.1.3] Federally Enforceable Through Title V Permit
34. The results of source tests conducted pursuant to Section 4.6.2 of Rule 4401 shall be submitted to the APCO within 60 days after the completion of the source test. [District Rule 4401 6.1.4] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401 6.1.5] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401 6.1.6] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.8] Federally Enforceable Through Title V Permit
39. The results of gauge tank TVP testing conducted pursuant to Section 6.2.5 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.11] Federally Enforceable Through Title V Permit
41. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
42. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless flare. [District Rule 4401 6.2.2] Federally Enforceable Through Title V Permit
43. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device. [District Rule 4401 6.2.3] Federally Enforceable Through Title V Permit
44. An operator seeking approval pursuant to Section 6.2.2 or Section 6.2.3 shall submit a written request and supporting information to the APCO. The District shall evaluate the request and if approved by the APCO, the District shall provide EPA and ARB with a copy of the evaluation and shall request EPA and ARB approval. The District evaluation and the APCO request shall be deemed approved unless EPA or ARB objects to such approval in writing within 45 days of the receipt of the APCO request. [District Rule 4401 6.2.4] Federally Enforceable Through Title V Permit
45. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.17 of Rule 4401: conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.10 of Rule 4401. [District Rule 4401 6.2.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

46. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
47. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
48. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
49. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.5] Federally Enforceable Through Title V Permit
50. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
51. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
52. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
53. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3 and 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-162-13

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 89.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-164-16

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 49 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 114.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-165-11

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 39 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 91.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-166-14

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 92 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 215.5 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-167-16

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 150 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 351.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-168-15

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 89.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-169-13

EXPIRATION DATE: 02/28/2006

SECTION: 03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 73 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '629, '630, '638, '641, '650, '651 and '-1097 that are vented to an approved vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District NSR Rule] Federally Enforceable Through Title V Permit
3. Volatile organic compound (VOC) emission rate shall not exceed 171.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
5. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
6. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
13. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-171-18

EXPIRATION DATE: 02/28/2006

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 220 STEAM ENHANCED WELLS- PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-1-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times, except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. VOC emission rate shall not exceed 378.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-173-14

EXPIRATION DATE: 02/28/2006

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-3-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times, except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Permittee shall maintain a current roster of wells connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
17. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
18. VOC emission rate shall not exceed 44.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-174-17

EXPIRATION DATE: 02/28/2006

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 91 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-2-5)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed well casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time, [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times, except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
16. VOC emission rate shall not exceed 156.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-176-17

EXPIRATION DATE: 02/28/2006

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. Volatile organic compound (VOC) emission rate shall not exceed 224.9 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
12. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.5.1 and 5.5.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.6.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 3 of Rule 4401. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
15. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.6.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.9 of Rule 4401. [District Rule 4401 5.7.1] Federally Enforceable Through Title V Permit
16. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401 5.7.2] Federally Enforceable Through Title V Permit
17. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401 5.7.3] Federally Enforceable Through Title V Permit
18. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401 5.8.1] Federally Enforceable Through Title V Permit
19. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.2] Federally Enforceable Through Title V Permit
20. In addition to the inspections required by Section 5.8.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

21. In addition to the inspections required by Sections 5.8.1, 5.8.2 and 5.8.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.8.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401 5.8.4] Federally Enforceable Through Title V Permit
22. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401 5.8.5] Federally Enforceable Through Title V Permit
23. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401 5.8.6] Federally Enforceable Through Title V Permit
24. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401 5.9.1] Federally Enforceable Through Title V Permit
25. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and 5.9.2.3 of Rule 4401, or the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.9.2] Federally Enforceable Through Title V Permit
26. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401 5.9.3] Federally Enforceable Through Title V Permit
27. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.9.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
28. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
29. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.5] Federally Enforceable Through Title V Permit
30. The time of the initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.6] Federally Enforceable Through Title V Permit
31. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401 5.9.7] Federally Enforceable Through Title V Permit
32. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401 6.1.3] Federally Enforceable Through Title V Permit
34. The results of source tests conducted pursuant to Section 4.6.2 of Rule 4401 shall be submitted to the APCO within 60 days after the completion of the source test. [District Rule 4401 6.1.4] Federally Enforceable Through Title V Permit
35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401 6.1.5] Federally Enforceable Through Title V Permit
36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401 6.1.6] Federally Enforceable Through Title V Permit
37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
38. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.8] Federally Enforceable Through Title V Permit
39. The results of gauge tank TVP testing conducted pursuant to Section 6.2.5 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
40. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.11] Federally Enforceable Through Title V Permit
41. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
42. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless flare. [District Rule 4401 6.2.2] Federally Enforceable Through Title V Permit
43. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device. [District Rule 4401 6.2.3] Federally Enforceable Through Title V Permit
44. An operator seeking approval pursuant to Section 6.2.2 or Section 6.2.3 shall submit a written request and supporting information to the APCO. The District shall evaluate the request and if approved by the APCO, the District shall provide EPA and ARB with a copy of the evaluation and shall request EPA and ARB approval. The District evaluation and the APCO request shall be deemed approved unless EPA or ARB objects to such approval in writing within 45 days of the receipt of the APCO request. [District Rule 4401 6.2.4] Federally Enforceable Through Title V Permit
45. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.17 of Rule 4401: conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.10 of Rule 4401. [District Rule 4401 6.2.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

46. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
47. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
48. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
49. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.5] Federally Enforceable Through Title V Permit
50. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
51. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
52. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
53. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3 and 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-177-16

EXPIRATION DATE: 02/28/2006

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 160 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. Volatile organic compound (VOC) emission rate shall not exceed 336.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.5.1 and 5.5.2] Federally Enforceable Through Title V Permit
12. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.6.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
13. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 3 of Rule 4401. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
14. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.6.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.9 of Rule 4401. [District Rule 4401 5.7.1] Federally Enforceable Through Title V Permit
15. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401 5.7.2] Federally Enforceable Through Title V Permit
16. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401 5.7.3] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401 5.8.1] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.2] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.8.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

20. In addition to the inspections required by Sections 5.8.1, 5.8.2 and 5.8.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.8.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401 5.8.4] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401 5.8.5] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401 5.8.6] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401 5.9.1] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and 5.9.2.3 of Rule 4401, or the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.9.2] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401 5.9.3] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.9.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.5] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.6] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401 5.9.7] Federally Enforceable Through Title V Permit
31. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

32. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401 6.1.3] Federally Enforceable Through Title V Permit
33. The results of source tests conducted pursuant to Section 4.6.2 of Rule 4401 shall be submitted to the APCO within 60 days after the completion of the source test. [District Rule 4401 6.1.4] Federally Enforceable Through Title V Permit
34. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401 6.1.5] Federally Enforceable Through Title V Permit
35. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401 6.1.6] Federally Enforceable Through Title V Permit
36. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
37. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.8] Federally Enforceable Through Title V Permit
38. The results of gauge tank TVP testing conducted pursuant to Section 6.2.5 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.11] Federally Enforceable Through Title V Permit
40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
41. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless flare. [District Rule 4401 6.2.2] Federally Enforceable Through Title V Permit
42. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device. [District Rule 4401 6.2.3] Federally Enforceable Through Title V Permit
43. An operator seeking approval pursuant to Section 6.2.2 or Section 6.2.3 shall submit a written request and supporting information to the APCO. The District shall evaluate the request and if approved by the APCO, the District shall provide EPA and ARB with a copy of the evaluation and shall request EPA and ARB approval. The District evaluation and the APCO request shall be deemed approved unless EPA or ARB objects to such approval in writing within 45 days of the receipt of the APCO request. [District Rule 4401 6.2.4] Federally Enforceable Through Title V Permit
44. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.17 of Rule 4401: conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.10 of Rule 4401. [District Rule 4401 6.2.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

45. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
46. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
47. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
48. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.5] Federally Enforceable Through Title V Permit
49. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
50. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
51. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
52. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3 and 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-178-17

EXPIRATION DATE: 02/28/2006

SECTION: 09 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 26 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District NSR Rule and 4401] Federally Enforceable Through Title V Permit
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to front line production equipment vented to a District-approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to gauge tanks as defined by Rule 4401 Section 3.17. [District Rule 4401] Federally Enforceable Through Title V Permit
3. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Any increase to the maximum number of steam enhanced oil production wells with closed casing vents shall require prior authorization by Authority to Construct or APCO approval of application for transfer of ownership of Permit to Operate. [District NSR Rule] Federally Enforceable Through Title V Permit
5. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
6. VOC emission rate shall not exceed 57.1 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. Permittee shall maintain a current roster of wells connected to this system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
11. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.5.1 and 5.5.2] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.6.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.8 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 3 of Rule 4401. [District Rule 4401 5.6.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.6.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.9 of Rule 4401. [District Rule 4401 5.7.1] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401 5.7.2] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401 5.7.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401 5.8.1] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.2] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.8.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401 5.8.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. In addition to the inspections required by Sections 5.8.1, 5.8.2 and 5.8.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.8.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401 5.8.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401 5.8.5] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401 5.8.6] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401 5.9.1] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and 5.9.2.3 of Rule 4401, or the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.9.2] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401 5.9.3] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.9.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401 5.9.4] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401 5.9.6] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401 5.9.7] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401 6.1.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401 6.1.3] Federally Enforceable Through Title V Permit
35. The results of source tests conducted pursuant to Section 4.6.2 of Rule 4401 shall be submitted to the APCO within 60 days after the completion of the source test. [District Rule 4401 6.1.4] Federally Enforceable Through Title V Permit
36. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401 6.1.5] Federally Enforceable Through Title V Permit
37. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401 6.1.6] Federally Enforceable Through Title V Permit
38. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1.7] Federally Enforceable Through Title V Permit
39. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401 6.1.8] Federally Enforceable Through Title V Permit
40. The results of gauge tank TVP testing conducted pursuant to Section 6.2.5 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401 6.1.10] Federally Enforceable Through Title V Permit
41. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401 6.1.11] Federally Enforceable Through Title V Permit
42. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. [District Rule 4401 6.2.1] Federally Enforceable Through Title V Permit
43. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless flare. [District Rule 4401 6.2.2] Federally Enforceable Through Title V Permit
44. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 for a vapor control system which does not have a VOC destruction device. [District Rule 4401 6.2.3] Federally Enforceable Through Title V Permit
45. An operator seeking approval pursuant to Section 6.2.2 or Section 6.2.3 shall submit a written request and supporting information to the APCO. The District shall evaluate the request and if approved by the APCO, the District shall provide EPA and ARB with a copy of the evaluation and shall request EPA and ARB approval. The District evaluation and the APCO request shall be deemed approved unless EPA or ARB objects to such approval in writing within 45 days of the receipt of the APCO request. [District Rule 4401 6.2.4] Federally Enforceable Through Title V Permit
46. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.17 of Rule 4401: conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.10 of Rule 4401. [District Rule 4401 6.2.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

47. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401 6.3.1] Federally Enforceable Through Title V Permit
48. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401 6.3.2] Federally Enforceable Through Title V Permit
49. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401 6.3.3] Federally Enforceable Through Title V Permit
50. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401 6.3.5] Federally Enforceable Through Title V Permit
51. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401 6.4] Federally Enforceable Through Title V Permit
52. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
53. In accordance with the approved Operator Management Plan (OMP), permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
54. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3 and 6.7] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-179-17

EXPIRATION DATE: 02/28/2006

SECTION: 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 130 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPTHA CC-3-31)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. Permittee shall maintain a current roster of wells connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
17. Collected vapor shall be piped to authorized continuously operating disposal/incineration devices. [District NSR Rule and District Rule 4401] Federally Enforceable Through Title V Permit
18. Permittee shall maintain with the Permit to Operate a current roster of disposal/incineration device(s) connected to the casing collection system, and such roster shall be made readily available for District inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
19. VOC emission rate shall not exceed 223.8 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-180-14

EXPIRATION DATE: 02/28/2006

SECTION: 31 TOWNSHIP: 28S RANGE: 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPHTHA CC-2-31)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Well casing vents shall remain closed at all times except during actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit
12. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
13. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
16. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
17. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit
18. VOC emission rate shall not exceed 44.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-185-14

EXPIRATION DATE: 02/28/2006

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 49 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-4-32)

PERMIT UNIT REQUIREMENTS

1. Fluids from these steam-enhanced wells with closed well casing vents and cyclic wells with closed well casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. A listing of all steam enhanced wells connected to this system shall be submitted to the District at least 60 days prior to the permit anniversary date. [District NSR Rule] Federally Enforceable Through Title V Permit
16. VOC emission rate shall not exceed 84.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-187-15

EXPIRATION DATE: 02/28/2006

SECTION: 03 **TOWNSHIP:** 09S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-1-3, WITH 44 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES

PERMIT UNIT REQUIREMENTS

1. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District NSR Rule and 4401]
2. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks or vessels vented to a District approved vapor collection and control system that has a VOC destruction or removal efficiency of at least 99%, or to permit exempt storage equipment as defined by District rule 2020, Section 6.6. [District NSR Rule and 4401]
3. Volatile organic compound (VOC) emission rate shall not exceed 103.1 lb/day. [District NSR Rule]
4. Permittee shall maintain with the permit accurate fugitive component counts and resulting emissions according to Table 2-4 (Oil and Gas Production Operations Average Emission Factors) of USEPA's protocol for Equipment Emission Estimates - EPA -453/R-95-017. [District Rule 2201]
5. A gas leak is defined as the detection of a concentration of total organic compounds, above background (measured in accordance with EPA Method 21) that exceeds the following values: 1) A major gas leak is a detection of greater than 10,000 ppmv as methane; and 2) A minor gas leak is a detection of 400 to 10,000 ppmv as methane for pressure relief devices (PRDs) and 2,000 to 10,000 for components other than PRDs. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit
6. A liquid leak is defined as the dripping of VOC-containing liquid. A major liquid leak is a visible mist or a continuous flow of liquid that is not seal lubricant. A minor liquid leak is a liquid leak that is not a major liquid leak and drips liquid at a rate of more than three drops per minute, except for seal lubricant. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit
7. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Permittee shall not operate a steam-enhanced crude oil production well unless they comply with one of the following requirements: 1) Permittee shall keep the steam-enhanced crude oil production well vents closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) shall be connected to a VOC collection and control system. The well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere; or 2) Permittee shall install and maintain an APCO-approved VOC collection and control system that is not open to the atmosphere and that is composed of hard-piping, ductwork connections and, if necessary, flow inducing devices that transport gas or vapor from a piece or pieces of equipment to an APCO-approved control device that has a VOC destruction or removal efficiency of at least 99%, or that transports gases or vapors back to a process system. [District Rules 2201 and 4401, 5.5.1, and 5.5.2] Federally Enforceable Through Title V Permit
9. During District compliance inspection, the following conditions shall be used to determination of a violation: 1) Existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations requiring process fluid flow through the open-ended lines. Attended operations include draining or degassing operations, connection of temporary process equipment, sampling of process streams, emergency venting, and other normal operational needs, provided such operations are done as expeditiously as possible and with minimal spillage of material and VOC emissions to the atmosphere; 2) Existence of a component with a major liquid leak; 3) Existence of a component with a gas leak greater than 50,000 ppmv; or 4) Existence of a component leak consisting of a minor liquid or gas leak, or a gas leak greater than 10,000 ppmv up to 50,000 ppmv, in excess of the allowable number of leaks specified in Table 3 of Rule 4401. [District Rule 4401, 5.6.2] Federally Enforceable Through Title V Permit
10. The permittee shall not use any components that leak in excess of the applicable leak standards as specified in this permit. Components that have been found leaking in excess of the applicable leak standards of this rule may be used provided such leaking components have been identified with a tag for repair, are repaired, or are awaiting re-inspection after being repaired, within the applicable time period specified in this permit. [District Rule 4401, 5.7.1] Federally Enforceable Through Title V Permit
11. Permittee shall keep all hatches closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.7.2] Federally Enforceable Through Title V Permit
12. Except for pipes and unsafe-to-monitor components, permittee shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of Rule 4401 shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401, 5.8.1 & 5.8.2] Federally Enforceable Through Title V Permit
13. Permittee shall inspect audio-visually (by hearing and by sight) for leaks all accessible operating pumps, compressors, and pressure relief devices (PRDs) in service at least once each calendar week. [District Rule 4401, 5.8.3] Federally Enforceable Through Title V Permit
14. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of Rule 4401 shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 4 of Rule 4401. [District Rule 4401, 5.8.3] Federally Enforceable Through Title V Permit
15. Permittee shall initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release. Permittee shall re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection. [District Rule 4401, 5.8.4] Federally Enforceable Through Title V Permit
16. Permittee shall inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. [District Rule 4401, 5.8.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

17. Except for PRDs, permittee shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.8.5] Federally Enforceable Through Title V Permit
18. Permittee shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.8.5] Federally Enforceable Through Title V Permit
19. Permittee shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak. The following information shall be included on the tag: 1) the date and time of leak detection; 2) the date and time of leak measurement; 3) leak concentration in ppmv for a gaseous leak; 4) description of whether it is a major liquid leak or a minor liquid leak; and 5) whether the component is an essential component, an unsafe-to-monitor component, or a critical component. [District Rule 4401, 5.9.1] Federally Enforceable Through Title V Permit
20. Permittee shall keep the tag affixed to the component until all of the following conditions have been met: 1) the leaking component has been repaired or replaced, and 2) the component has been re-inspected using the test methods described in this permit; and 3) the component is found to be in compliance with the requirements of Rule 4401. [District Rule 4401, 5.9.2] Federally Enforceable Through Title V Permit
21. Permittee shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.9.3] Federally Enforceable Through Title V Permit
22. Except for leaking critical components or leaking essential components, if the operator has minimized a leak but the leak still exceeds the applicable leak limits, the operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 4 of Rule 4401: 1) repair or replace the leaking component; 2) vent the leaking component to a VOC collection and control system; or 3) remove the leaking component from operation. [District Rule 4401, 5.9.4] Federally Enforceable Through Title V Permit
23. The leak rate, measured after leak minimization has been performed, shall be used to determine the applicable repair period specified in Table 4 of Rule 4401 and the time of initial leak detection shall be the start of the repair period specified in Table 4 of Rule 4401. [District Rule 4401, 5.9.5, and 5.9.6] Federally Enforceable Through Title V Permit
24. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.9.7] Federally Enforceable Through Title V Permit
25. All records of required monitoring data and support information required by this permit shall be retained for a period of at least five years and shall be made available for District inspection upon request. [District Rules 2520, 9.4.2, and 4401, 6.1] Federally Enforceable Through Title V Permit
26. Permittee shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1] Federally Enforceable Through Title V Permit
27. Unless waived by the District, permittee shall maintain source test records which show that the control efficiency requirements of the VOC collection and control system have been satisfied. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
28. Records shall be maintained of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components. The records shall include a copy of the current calibration gas certification from the vendor of the calibration gas cylinder, the date of calibration, the concentration of calibration gas, the instrument reading of calibration gas before adjustment, the instrument reading of calibration gas after adjustment, the calibration gas expiration date, and the calibration gas cylinder pressure at the time of calibration. [District Rule 4401, 6.1.6] Federally Enforceable Through Title V Permit
29. Permittee shall maintain a copy of the latest APCO-approved Operator Management Plan (OMP) at the facility and make it available to the APCO, ARB, and US EPA upon request. [District Rule 4401, 6.1.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

30. Annual control efficiency compliance tests shall be performed by source testers certified by the California Air Resource Board (CARB) on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive these source testing requirements if the vapor control system does not exhaust to atmosphere, or if all uncondensed VOC emissions collected by the vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine, or in a smokeless flare. [District Rule 4401, 6.2.1 & 6.2.2] Federally Enforceable Through Title V Permit
31. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3.1] Federally Enforceable Through Title V Permit
32. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by ARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
33. Permittee shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one centimeter or less from the surface of the component interface. [District Rule 4401, 6.3.3] Federally Enforceable Through Title V Permit
34. VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3.5] Federally Enforceable Through Title V Permit
35. Permittee shall maintain an inspection log in which, at a minimum, all of the following information shall be recorded for each inspection performed: 1) The total number of components inspected, and the total number and percentage of leaking components found by component type; 2) The location, type, and name or description of each leaking component and description of any unit where the leaking component is found; 3) The date of leak detection and the method of leak detection; 4) For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of leaking components; 6) The identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 7) The methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number; and 10) The date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.1.5 & 6.4] Federally Enforceable Through Title V Permit
36. Permittee shall establish and implement an employee training program for inspecting and repairing components and recordkeeping procedures, as necessary. Permittee shall maintain at the facility the copies of the training records of the training program. [District Rule 4401, 6.1.7 & 6.5] Federally Enforceable Through Title V Permit
37. In accordance with the approved OMP, permittee shall meet all applicable operating, leak standards, inspection and re-inspection, leak repair, record keeping, and notification requirements of Rule 4401. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit
38. By January 30 of each year, permittee shall submit to the APCO for approval, in writing, an annual report indicating any changes to the existing, approved OMP. [District Rule 4401, 5.7.3, and 6.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. Permittee shall maintain a current roster of all wells connected to this system and shall make such roster available for District inspection upon request. [District NSR Rule and 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-201-8

EXPIRATION DATE: 02/28/2006

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 66 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-2-32)

PERMIT UNIT REQUIREMENTS

1. Fluids produced from these steam-enhanced wells with closed well casing vents and cyclic wells with closed casing vents shall be introduced only to tanks S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097 that are vented to an approved operational vapor collection and control system achieving 99% control, or to permit exempt storage equipment as defined by District Rule 2020, Section 6.6 (Amended March 21, 2002). [District NSR Rule] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. The operator shall maintain monitoring records of the date and well identification where steam injection or well steam stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
4. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
6. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
7. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
8. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
9. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
10. Well casing vents shall remain closed at all times except during periods of actual service or repair. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
12. The source shall perform annual leak inspections on at least 20% of the system components. A different sample of system components shall be tested each year such that all system components are tested over a five year period. Testing shall be accomplished using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.3.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
13. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
14. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
15. A listing of all steam enhanced wells connected to this system shall be submitted to the District at least 60 days prior to the permit anniversary date. [District NSR Rule] Federally Enforceable Through Title V Permit
16. VOC emission rate shall not exceed 113.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-290-3

EXPIRATION DATE: 02/28/2006

SECTION: SW03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

84,546 GAL FIXED ROOF STORAGE TANK (TANK ID FOAM TK 1-3)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-292-3

EXPIRATION DATE: 02/28/2006

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

45,486 GAL FIXED ROOF STORAGE TANK (TANK ID DRAIN T-4)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-293-3

EXPIRATION DATE: 02/28/2006

SECTION: NW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID DRAIN T-5)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-294-3

EXPIRATION DATE: 02/28/2006

SECTION: NW03 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 10-3)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-295-3

EXPIRATION DATE: 02/28/2006

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

34,230 GALLON FIXED ROOF STORAGE TANK (TANK ID SALVAGE TK P-7)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-325-4

EXPIRATION DATE: 02/28/2006

SECTION: SW39 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-329-3

EXPIRATION DATE: 02/28/2006

SECTION: NW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-330-3

EXPIRATION DATE: 02/28/2006

SECTION: SW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

21,714 GALLON FIXED ROOF STORAGE TANK (TANK ID 34-9)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-358-1

EXPIRATION DATE: 02/28/2006

SECTION: SW32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

420,000 GALLON FIXED ROOF STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rules 4623, 2.0 and 2010] Federally Enforceable Through Title V Permit
2. The operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in 40 CFR 60.113 and section 6.2 of District Rule 4623 (amended 12/17/92). Determinations shall be made annually during the summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. The operator shall keep accurate records of types, storage temperature, and TVP of liquids stored to verify continued exemption from District Rule 4623 (amended 12/17/92). [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from the Heavy Oil source [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-360-3

EXPIRATION DATE: 02/28/2006

SECTION: SE07 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

63,546 GALLON FIXED ROOF STORAGE TANK (TANK ID T-9)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-420-5

EXPIRATION DATE: 02/28/2006

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

1 THERMALLY ENHANCED STEAM DRIVE OIL WELL WITH CLOSED CASING VENT

PERMIT UNIT REQUIREMENTS

1. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
4. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
6. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
7. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
10. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit
13. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1] Federally Enforceable Through Title V Permit
14. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 18, 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1] Federally Enforceable Through Title V Permit
15. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
16. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. Crude oil produced from wells with vents shut in shall be handled only in production facilities equipped with District approved vapor loss prevention devices. [District Rule 4401] Federally Enforceable Through Title V Permit
21. Permittee shall maintain a current listing of all steam enhanced wells with closed-casing vents, and shall make such records available for District inspection upon request. [District Rules 4401 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
22. VOC emission rate shall not exceed 2.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-427-5

EXPIRATION DATE: 02/28/2006

EQUIPMENT DESCRIPTION:
248 CYCLIC WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
2. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)] Federally Enforceable Through Title V Permit
4. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
6. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2] Federally Enforceable Through Title V Permit
7. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single control device shall be reduced by at least 50 percent. Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
8. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
9. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
10. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit
11. Operator shall repair each leak within 15 days of detection. The APCO may grant a 10 day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit
13. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1] Federally Enforceable Through Title V Permit
14. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 18, 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1] Federally Enforceable Through Title V Permit
15. VOC content shall be determined using ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2] Federally Enforceable Through Title V Permit
16. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3] Federally Enforceable Through Title V Permit
17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
18. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
19. The requirements of SJVUAPCD Rule 4407 (Adopted May 19, 1994) do not apply to this permit unit. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. All wells with closed casing vents to comply with Rule 4401 shall be served only by production facilities equipped with District approved emission control systems. [District Rule 4401] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-432-3

EXPIRATION DATE: 02/28/2006

SECTION: NW9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

4,200 BBL OPEN-TOP PETROLEUM STORAGE TANK (TANK ID T-8A, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-433-3

EXPIRATION DATE: 02/28/2006

SECTION: NW9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

21,000 GALLON OPEN TOP CRUDE OIL OVERFLOW TANK (TANK ID T-8B, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-434-3

EXPIRATION DATE: 02/28/2006

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14A, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-435-3

EXPIRATION DATE: 02/28/2006

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14B, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1127-436-3

EXPIRATION DATE: 02/28/2008

SECTION: SW04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

210,000 GALLON OPEN TOP CRUDE OIL STORAGE TANK (TANK ID T-1C, KERN RIVER OILFIELD)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 2.0] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 12 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
3. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
4. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
5. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
6. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
7. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rules 2520, 9.4.2 & 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

Detailed Facility Report
For Facility=1127 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

CHEVRON USA INC HEAVY OIL CENTRAL	FAC # STATUS: TELEPHONE:	S 1127 A 6613923300	TYPE: TOXIC ID:	TitleV 50300	EXPIRE ON: AREA: INSP. DATE:	02/29/2016 101 / 12/12
--	---	--	----------------------------------	-------------------------------	---	---

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1127-22-29	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3, DIS #43006-74) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-25-27	62,500,000 BTU/HR	3020-02 H	1	1,030.00	1,030.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 40-32, DIS# 43001-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION
S-1127-28-30	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-29-26	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR 44-9, DIS #43007-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-30-27	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9, DIS #43008-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-31-27	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9, DIS #43009-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-34-25	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5, DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-35-26	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5, DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-36-26	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5, DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-38-28	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3, DIS# 43007-74) A NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-39-26	62,500 KBTU STEAM GENERATOR	3020-02 H	1	1,030.00	1,030.00	A	DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #36-3, DIS# 43008-74) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION

Detailed Facility Report
For Facility=1127 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1127-42-25	62,500,000 BTU/HR	3020-02 H	1	1,030.00	1,030.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 42-3, DIS# 43003-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION
S-1127-55-25	62,500,000 BTU/HR	3020-02 H	1	1,030.00	1,030.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 65-3, DIS# 43006-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION
S-1127-57-27	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67-3, DIS# 43008-80) WITH NORTH AMERICAN GLE 1 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-66-31	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9, DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-69-29	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4, DIS# 43013-82) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-70-30	62.5 MMBtu/hr	3020-02 H	1	1,030.00	1,030.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4, DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1127-71-23	62.5 MMBTU/HR	3020-02 H	1	1,030.00	1,030.00	A	DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 79-4, DIS# 43009-82)
S-1127-73-25	62,500,000 BTU/HR	3020-02 H	1	1,030.00	1,030.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 53-32, DIS# 43012-78) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION
S-1127-112-22	62,500,000 BTU/HR	3020-02 H	1	1,030.00	1,030.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 77-32, DIS# 43011-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION
S-1127-148-16	22,300 kW Turbine	3020-08A F	1	8,171.00	8,171.00	A	22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL
S-1127-149-16	22,300 kW Turbine	3020-08A F	1	8,171.00	8,171.00	A	22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL
S-1127-159-10	56 wells	3020-09 A	56	9.34	523.04	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 56 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-5-32)
S-1127-160-16	50 wells with vapor control	3020-09 A	50	9.34	467.00	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 50 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS

Detailed Facility Report
For Facility=1127 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1127-161-22	96 wells with vapor control	3020-09 A	96	9.34	896.64	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-162-13	38 wells w/out vents	3020-09 B	38	9.34	354.92	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-164-16	49 wells w/out vents	3020-09 B	49	9.34	457.66	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 49 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-165-11	39 wells w/out vents	3020-09 B	39	9.34	364.26	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 39 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-166-14	92 wells w/out vents	3020-09 B	92	9.34	859.28	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 92 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-167-16	150 wells w/out vents	3020-09 B	150	9.34	1,400.00	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 150 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-168-15	38 wells w/out vents	3020-09 B	38	9.34	354.92	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 38 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-169-13	73 wells w/out vents	3020-09 B	73	9.34	681.82	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 73 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-171-18	220 wells	3020-09 A	220	9.34	2,054.80	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 220 STEAM ENHANCED WELLS- PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-1-5)
S-1127-173-14	26 wells	3020-09 A	26	9.34	242.84	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-3-5)
S-1127-174-17	91 wells	3020-09 A	91	9.34	849.94	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 91 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 1 CC-2-5)
S-1127-176-17	96 wells w/out vents	3020-09 B	96	9.34	896.64	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 96 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-177-16	160 wells w/out vents	3020-09 B	160	9.34	1,400.00	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 160 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-178-17	26 wells with vapor control	3020-09 A	26	9.34	242.84	A	THERMALLY ENHANCED OIL RECOVERY OPERATION WITH 26 STEAM ENHANCED WELLS WITH CLOSED CASING VENTS
S-1127-179-17	130 wells	3020-09 A	130	9.34	1,214.20	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 130 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPHTHA CC-3-31)

Detailed Facility Report
For Facility=1127 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1127-180-14	26 wells	3020-09 A	26	9.34	242.84	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 26 STEAM ENHANCED WELLS - CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (AMERICAN NAPHTHA CC-2-31)
S-1127-185-14	49 wells	3020-09 A	49	9.34	457.66	A	THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 49 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-4-32)
S-1127-187-15	44 wells w/out vents	3020-09 B	44	9.34	410.96	A	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-1-3, WITH 44 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES
S-1127-201-8	66 wells	3020-09 A	66	9.34	616.44	A	MODIFICATION OF THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 66 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-2-32)
S-1127-290-3	84,546 GALLONS	3020-05 D	1	185.00	185.00	A	84,546 GAL FIXED ROOF STORAGE TANK (TANK ID FOAM TK 1-3)
S-1127-292-3	45,486 GALLONS	3020-05 C	1	135.00	135.00	A	45,486 GAL FIXED ROOF STORAGE TANK (TANK ID DRAIN T-4)
S-1127-293-3	45,486 GALLONS	3020-05 C	1	135.00	135.00	A	45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID DRAIN T-5)
S-1127-294-3	45,486 GALLONS	3020-05 C	1	135.00	135.00	A	45,486 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 10-3)
S-1127-295-3	34,230 GALLONS	3020-05 C	1	135.00	135.00	A	34,230 GALLON FIXED ROOF STORAGE TANK (TANK ID SALVAGE TK P-7)
S-1127-325-4	12,012 GALLONS	3020-05 B	1	93.00	93.00	A	12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)
S-1127-329-3	41,580 GALLONS	3020-05 C	1	135.00	135.00	A	41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)
S-1127-330-3	21,714 GALLONS	3020-05 C	1	135.00	135.00	A	21,714 GALLON FIXED ROOF STORAGE TANK (TANK ID 34-9)
S-1127-358-1	420,000 GALLONS	3020-05 E	1	246.00	246.00	A	420,000 GALLON FIXED ROOF STORAGE TANK
S-1127-360-3	63,546 GALLONS	3020-05 D	1	185.00	185.00	A	63,546 GALLON FIXED ROOF STORAGE TANK (TANK ID T-9)
S-1127-420-5	1 WELL	3020-09 A	1	9.34	9.34	A	1 THERMALLY ENHANCED STEAM DRIVE OIL WELL WITH CLOSED CASING VENT
S-1127-427-5	248 CYCLIC WELLS CLOSED VENTS	3020-09 B	248	9.34	1,400.00	A	248 CYCLIC WELLS WITH CLOSED CASING VENTS
S-1127-432-3	176,400 GALLON TANK	3020-05 E	1	246.00	246.00	A	4,200 BBL OPEN-TOP PETROLEUM STORAGE TANK (TANK ID T-8A, KERN RIVER OILFIELD)
S-1127-433-3	21,000 GALLON	3020-05 C	1	135.00	135.00	A	21,000 GALLON OPEN TOP CRUDE OIL OVERFLOW TANK (TANK ID T-8B, KERN RIVER OILFIELD)

Detailed Facility Report
For Facility=1127 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1127-434-3	42,000 GALLON	3020-05 C	1	135.00	135.00	A	42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14A, KERN RIVER OILFIELD)
S-1127-435-3	42,000 GALLON	3020-05 C	1	135.00	135.00	A	42,000 GALLON OPEN TOP SLOP OIL STORAGE TANK (TANK ID T-14B, KERN RIVER OILFIELD)
S-1127-436-3	210,000 GALLON	3020-05 E	1	246.00	246.00	A	210,000 GALLON OPEN TOP CRUDE OIL STORAGE TANK (TANK ID T-1C, KERN RIVER OILFIELD)

Number of Facilities Reported: 1

ATTACHMENT D

Rule 4320 Emission Control Plan



RECEIVED
DEC 22 2009
SJVAPCD
Southern Region

fee ✓

William Fall
Health, Environment, and
Safety Manager

San Joaquin Valley BU
Chevron North America
Exploration and Production
P.O. Box 1392
Bakersfield, CA 93302
Tel 661 654 7038
Fax 661 654 7606

22 December 2009

San Joaquin Valley Unified Air Pollution Control District
Mr. Leonard Scandura, Permit Services Manager
2700 M St. Suite 275
Bakersfield, CA 93301.

✓ S-1127 1095747 DM6
S-1131 1095748 H.T.C.

Re: Rule 4320 Emission Control Plan
Heavy Oil Source in Central Kern County
Facility S-1127 and S-1131 (Kern River)

Via email: Leonard.Scandura@valleyair.org

Dear Mr. Scandura:

Chevron USA, Inc. (Chevron) provides the attached Rule 4320 Emission Control Plan (ECP) to the San Joaquin Valley Unified Air Pollution Control District (District) in compliance with Rule 4320 Section 6.4.

The 2009 final fuel use for equipment subject to the rule is not yet available. Rule 4320 fees estimated on the attachment are based on 2008 fuel use and subject to change once the final records are available.

If you have questions regarding the attached information, please contact Spencer Hammond at 661-654-7788.

Sincerely,

for:

William R. Fall
Chevron Health, Environmental and Safety Manager

cc: Project file, Rule 4320 ECP

Attachments: Rule 4320 Emission Control Plan Facility S-1127 & S-1131

**San Joaquin Valley Unified Air Pollution Control District
22 December 2009**

**San Joaquin Valley BU
Chevron North America
Exploration and Production**

**Attachment
Emission Control Plan
Facility № S-1127 and S-1131**

Rule 4320 Emission Control Plan
Chevron U.S.A. Inc.
Source Name: Heavy Oil Central S-1127 & S-1131

Version Date: 21-Dec-09

Permit to Operate	Heat Input Rating MMBtu per hr	Maximum Capacity MMBtu per hr	Current Operational Status	Current Equipment	Approved Fuels		Table 1 Category	Current Emissions ppmv @ 3% O ₂				Proposed Emissions ppmv @ 3% O ₂				SO _x Limits in Rule 4320 (for all units)		NO _x Compliance Strategy	Expected Fee Amount (\$)	NO _x Fee Start Date	Participant Compliance Strategy	Participant Compliance Deadline
					Fuel Type 1	HRV1		Fuel Type 2	HRV2	NO _x	CO	NO _x	CO	Current Limit	Proposed Limit							
S-1127-0022	82.5	847500	Active	Steam Generator #243	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	29	0.064	0.143	Section 5.3 Fees	10	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0023	82.5	847500	Active	Steam Generator #43-22	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 6.1 Fees	40	7/1/2010	DEUSec 6.1 pp-5/100 acf	7/1/2011		
S-1127-0028	82.5	847500	Active	Steam Generator #43-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	10	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0029	82.5	847500	Active	Steam Generator #44-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	177,833	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0030	82.5	847500	Active	Steam Generator #45-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	50	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0031	82.5	847500	Active	Steam Generator #46-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	50	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0034	82.5	847500	Active	Steam Generator #48-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	120,345	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0035	82.5	847500	Active	Steam Generator #50-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	136,474	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0036	82.5	847500	Active	Steam Generator #51-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	147,499	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0038	82.5	847500	Active	Steam Generator #36-3	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	40	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0039	82.5	847500	Active	Steam Generator #38-3	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1127-0042	82.5	847500	Active	Steam Generator #47-3	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1127-0055	82.5	847500	Active	Steam Generator #54-3	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1127-0057	82.5	847500	Active	Steam Generator #61-3	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	40	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0060	82.5	847500	Active	Steam Generator #64-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	40	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0061	82.5	847500	Active	Steam Generator #64-3	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	120,275	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0070	82.5	847500	Active	Steam Generator #80-8	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	29	15	0.064	0.143	Section 5.3 Fees	40	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1127-0011	82.5	847500	Active	Steam Generator #78-8	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1127-0013	82.5	847500	Active	Steam Generator #55-37	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1127-0112	82.5	847500	Active	Steam Generator #71-31	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	29	30	0.064	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0062	82.5	847500	Active	Steam Generator #60-34	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0063	82.5	847500	Active	Steam Generator #60-30	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0064	82.5	847500	Active	Steam Generator #60-40	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0066	82.5	847500	Active	Steam Generator #60-41	DEU	Natural Gas	330-1090	N/A	N/A	C.2.b	30	39	30	0.001	0.00785	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2012		
S-1131-0068	82.5	847500	Active	Steam Generator #60-42	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0069	82.5	847500	Active	Steam Generator #60-43	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0071	82.5	847500	Active	Steam Generator #60-44	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	129,681	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0072	82.5	847500	Active	Steam Generator #60-45	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0073	82.5	847500	Active	Steam Generator #60-47	DEU	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2012		
S-1131-0074	82.5	847500	Active	Steam Generator #60-48	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0075	82.5	847500	Active	Steam Generator #60-49	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	16	40	15	0.001	0.00785	Section 5.3 Fees	40	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0082	82.5	847500	Active	Steam Generator #60-80	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	279,604	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0087	82.5	847500	Active	Steam Generator #60-86	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	330,181	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0094	82.5	847500	Active	Steam Generator #75-45	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0096	82.5	847500	Active	Steam Generator #76-31	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0098	82.5	847500	Active	Steam Generator #76-4	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0099	82.5	847500	Active	Steam Generator #75-45	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	279,604	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0094	82.5	847500	Active	Steam Generator #75-45	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	330,181	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0096	82.5	847500	Active	Steam Generator #80-43	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	39	30	0.078	0.143	DEUSec 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0085	82.5	847500	Active	Steam Generator #50-61	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	128,855	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0077	82.5	847500	Active	Steam Generator #48	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0078	82.5	847500	Active	Steam Generator #48	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	130,037	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0079	82.5	847500	Active	Steam Generator #70	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	39	15	0.078	0.143	Section 5.3 Fees	40	7/1/2010	DEUSec 5.3 pp-5/100 acf	7/1/2011		
S-1131-0080	82.5	847500	Active	Steam Generator #140	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	41	15	0.078	0.143	Section 5.3 Fees	128,855	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0081	82.5	847500	Active	Steam Generator #141	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	41	15	0.078	0.143	Section 5.3 Fees	127,767	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0083	82.5	847500	Active	Steam Generator #143	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	41	15	0.078	0.143	Section 5.3 Fees	128,855	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0084	82.5	847500	Active	Steam Generator #144	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	41	15	0.078	0.143	Section 5.3 Fees	127,767	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0098	82.5	847500	Active	Steam Generator #111	Active	Natural Gas	330-1090	VRU Gas	80-1015	C.3	15	40	15	0.055	0.143	Section 5.3 Fees	128,855	7/1/2010	1.8 pp-5/100 acf	7/1/2011		
S-1131-0012	82.5	847500	Active	Steam Generator #4	Active	Natural Gas	330-1090	N/A	N/A	C.2.b	13	50	15	0.000	0.00785	Section 5.3 Fees	131,108	7/1/2010	Sec 5.4 1.2 Compliance	7/1/2012		
S-1131-0041	77.5	240000	Active	Steam Generator #29	DEU	Natural Gas	330-1090	VRU Gas	80-1015	C.3	30	45	30	0.184	0.143	DEUSec 5.3 Fees	40					



B. R. Fall
Health, Environment and
Safety Manager

San Joaquin Valley SBU
Chevron North America
Exploration and Production
9525 Camino Media
Bakersfield, CA 93302
Tel 661 654 7138
Fax 661 654 7004
billfall@chevron.com

March 31, 2011

RECEIVED

MAR 31 2011

SJVAPCD
Southern Region

RECEIVED

APR -6 2011

SJVAPCD
Southern Region

Mr. Dave Warner
Director of Permit Services
San Joaquin Valley Unified APCD
34946 Flyover Court
Bakersfield, CA 93308

Subject: Rule 4320 Facility Fuel Use Questionnaires
Facilities: C-0311, S-0049, S-1127, S-1128, S-1129, S-1131, S-1141, S-2010

Dear Mr. Warner:

Enclosed are the Rule 4320 Facility Fuel Use Questionnaires for the above referenced facilities. Please note that on the C-0311, S-1128 and S-1141 questionnaires we reported a weighted NOx emission limit where the actual permit limits changed during 2010. A footnote was added to the last page of the applicable questionnaire explaining each change.

Should you have any questions, please contact Kristy Rapley of my staff at (661) 654-7148.

Sincerely,

Bill Fall

RECEIVED
MAR 31 2011
SJVAPCD
Southern Region

SJVAPCD
SOUTHERN

Rule 4320 Facility Fuel Use Questionnaire
For Facility = S-1127
Sorted by Permit Number

CHEVRON USA INC
HEAVY OIL CENTRAL

PERMIT NUMBER	MOD#	EQUIPMENT DESCRIPTION	FUEL USE (MMBtu/yr) for 2010	NOx EMISSIONS LIMIT (lb/MMBtu)	RULE 4320 NOx LIMIT (ton/yr)	RULE 4320 NOx FEES (Including admin)
S-1127-0022	26	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #34-3, DIS #43006-74) WITH A NORTH AMERICAN MODEL GLE LOW NOX BURNER AND AN OPTIONAL-USE FLUE GAS RECIRCULATION (FGR) SYSTEM	-	0.0182	0.00	\$ -
S-1127-0025	27	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 40-32, DIS# 43001-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -
S-1127-0028	27	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 43010-75) WITH A NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION	792.78	0.018	0.01	\$ 69.38
S-1127-0029	23	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #44-9, DIS #43007-75) WITH FLUE GAS RECIRCULATION AND WITH A NORTH AMERICAN MODEL GLE LOW NOX BURNER	792.35	0.0182	0.01	\$ 70.11
S-1127-0030	24	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #45-9, DIS #43008-75) WITH FLUE GAS RECIRCULATION AND WITH A NORTH AMERICAN MODEL GLE LOW NOX BURNER	-	0.0182	0.00	\$ -
S-1127-0031	24	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #46-9, DIS #43009-75) WITH FLUE GAS RECIRCULATION AND WITH A NORTH AMERICAN MODEL GLE MAGNA FLAME LOW NOX BURNER	-	0.0182	0.00	\$ -
S-1127-0034	22	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER AND FLUE GAS RECIRCULATION (CUSA ID# 49-5, DIS# 43003-76)	30,750.40	0.018	0.26	\$ 2,691.15
S-1127-0035	23	MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 50-5, DIS# 43005-76) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION: REPLACE BURNER WITH NORTH AMERICAN MAGNA-FLAME GLE ULTRA-LOW NOX BURNER OR DISTRICT-APPROVED EQUIVALENT FOR RULE 4306 COMPLIANCE, RECONFIGURE FIR AS FGR, ADD (RETAIN) BLOWER MOTOR, ADD (RETAIN) VARIABLE SPEED DRIVE (VSD), UPGRADE OR REPLACE MAIN FUEL TRAIN COMPONENTS AND MODIFY CONVECTION AND RADIANT SECTION WATER/STEAM PIPING IF NECESSARY	41,717.21	0.0182	0.38	\$ 3,691.49
S-1127-0036	23	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #51-5, DIS #43004-76) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION AND A NORTH AMERICAN MODEL GLE 4231 LOW NOX BURNER WITH FLUE GAS RECIRCULATION	48,902.33	0.0182	0.45	\$ 4,327.29
S-1127-0038	25	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 35-3, DIS# 43007-74) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.018	0.00	\$ -
S-1127-0039	26	DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID #36-3, DIS# 43008-74) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -
S-1127-0042	25	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 42-3, DIS# 43003-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -
S-1127-0055	25	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 65-3, DIS# 43006-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -
S-1127-0057	24	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 67-3, DIS# 43008-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	65.41	0.018	0.00	\$ 5.72
S-1127-0066	28	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 64-9, DIS# 43005-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.018	0.00	\$ -
S-1127-0069	26	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 81-4, DIS# 43013-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.018	0.00	\$ -
S-1127-0070	27	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 80-4, DIS# 43010-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	122.09	0.0182	0.00	\$ 10.80
S-1127-0071	23	Primary Fuel (Fuel Gas) 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 79-4, DIS# 43009-82)	-	0.036	0.00	\$ -
S-1127-0073	25	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 53-32, DIS# 43012-78) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -

SJVAPCD
SOUTHERN

Rule 4320 Facility Fuel Use Questionnaire
For Facility = S-1127
Sorted by Permit Number

CHEVRON USA INC
HEAVY OIL CENTRAL

PERMIT NUMBER	MOD#	EQUIPMENT DESCRIPTION	FUEL USE (MMBtu/yr) for 2010	NOx EMISSIONS LIMIT (lb/MMBtu)	RULE 4320 NOx (ton/yr)	RULE 4320 NOx FEES (including admin)
S-1127-0112	22	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (CUSA ID# 77-32, DIS# 43011-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION	-	0.036	0.00	\$ -
Total:			123,142.57		1.12	\$ 10,865.95

Fuel use questionnaire submitted by:

KRISTY RAPLEY

AIR REPORTING TEAM LEAD

661-654-7148



3/31/2011

Name (please print)

Title

Phone

Signature

Date

ATTACHMENT E

COMMENTS AND DISTRICT RESPONSES

Summary of Chevron's general comments, and the District's responses to these general comments:

1. The abbreviated review period constitutes a violation of Chevron's right to procedural due process and an arbitrary and capricious abuse of discretion on the part of the District.

Response: The District disagrees with this assertion. The District followed the rules and procedures outlined in SIP approved District Rule 2530, and in fact went beyond these requirements by extending the comment period and allowing Chevron almost twice as long as required to review the proposed permits, and coordinating a special electronic download of the proposed permits and conditions to their computer system

2. Failure to incorporate the most current underlying applicable requirements.

Response: The District will address specific instances of this that are identified.

3. Errors in transcribing applicable requirements into the proposed permit.

Response: The District will address specific instances of this that are identified.

4. Excessive monitoring, recordkeeping or reporting provisions.

Response: The District will address specific instances of this that are identified.

5. The District should continue streamlining Chevron's permits in order to enhance efficiency.

Response: Comment noted.

Facility S-1127 TV Renewal Comments
Attachment 3

Common		TV Renewal Proposed PTO			Potential Match with Chevron Current Operating Permit (Emission System)			Chevron Title V Review Comments	District's response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-22	27	28	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	29	18	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please add CO EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-25	25	38	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	27	39	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Add CO(ppmv) EPA method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-28	28	0	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM			0	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM	PTO	Recommend drop 4231 - state "North American GLE Low-NOx Burner"	Changes made as requested.
S-1127-28	28	30	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	30	37	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4.	PTO	Add CO(ppmv) EPA method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-29	24	29	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	26	19	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Add CO(ppmv) EPA method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-30	25	30	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	27	20	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-31	25	29	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	27	20	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-34	21	31	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	25	22	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and SOx (lb/MMBtu) - ARB Method 100.	PTO	Add CO(ppmv) EPA method 10B. Test methods could be combined.	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-35	22	30	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	26	22	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and SOx (lb/MMBtu) - ARB Method 100.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-35	22	43	Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of five years and shall make such records readily available for District inspection upon request.	District Rule 4351	26	30	Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of five years and shall make such records readily available for District inspection upon request.	PTO	Rule reference should be 4320. Recommend condition be removed it is redundant with condition 46	Condition removed as higher heating value requirements are covered in conditions #2, 4, 6, and 7.

**Facility S-1127 TV Renewal Comments
Attachment 3**

Common		TV Renewal Proposed PTO			Potential Match with Chevron Current Operating Permit (Enviance System)			Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-36	24	29	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	26	19	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-38	26	30	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	28	36	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-38	26	42	Permittee shall maintain records of fuel hhw and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request.	District Rule 4351	28	37	Permittee shall maintain records of fuel hhw and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request.	PTO	Rule reference should be 4320. Recommend condition be removed it is redundant with condition 45	Condition removed as higher heating value requirements are covered in conditions #2, 4, 6, and 7.
S-1127-39	24	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	District Rules 2210, 4305 and 4306	26	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	PTO	reference to 2210 should be 2010 or 2201	Correction made to reflect Rule 2201 reference.
S-1127-39	24	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	District Rule 2520, 9.3.2	26	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	PTO	Please add SOx lb/MMBtu Method 6C	SOx Method 6C is on District's approved list of test methods; therefore, added to the condition.
S-1127-39	24	38	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	26	38	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-42	23	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	District Rules 2210, 4305 and 4306	25	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	PTO	reference to 2210 should be 2010 or 2201	Correction made to reflect Rule 2201 reference.
S-1127-42	23	39	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	25	40	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-55	23	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	District Rules 2210, 4305 and 4306	25	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	PTO	reference to 2210 should be 2010 or 2201	Correction made to reflect Rule 2201 reference.
S-1127-55	23	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	District Rule 2520, 9.3.2	25	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	PTO	Please Add SOx lb/MMBtu EPA Method 6C	SOx Method 6C is on District's approved list of test methods; therefore, added to the condition.

**Facility S-1127 TV Renewal Comments
Attachment 3**

Common		TV Renewal Proposed PTO			Potential Match with Chevron Current Operating Permit (Emission System)			Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-55	23	19	Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below.	District Rule 4305, 6.3.1 and 4351, 6.3	25	20	Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below.	PTO	Startup should be removed it does not apply	Condition removed as it is an ATC startup condition and does not apply anymore.
S-1127-55	23	38	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	25	39	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-57	25	31	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	27	36	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-70	28	27	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	District Rules 1081, 4305, 4306, and 4351	30	15	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-71	24	7	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	District Rule 2520, 9.3.2	23	7	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	PTO	Please Add SOx lb/MMbtu EPA Method 6C	SOx Method 6C is on District's approved list of test methods; therefore, added to the condition.
S-1127-71	24	41	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	23	42	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Add CO(ppmv) Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-73	23	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	District Rule 2520, 9.3.2	25	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	PTO	Please Add SOx lb/MMbtu EPA Method 6C	SOx Method 6C is on District's approved list of test methods; therefore, added to the condition.
S-1127-73	23	38	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	25	39	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Add CO(ppmv) Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.

**Facility S-1127 TV Renewal Comments
Attachment 3**

Common		TV Renewal Proposed PTO				Potential Match with Chevron Current Operating Permit (Enviance System)		Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-112	20	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	District Rules 2210, 4305 and 4306	22	1	No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below.	PTO	reference to 2210 should be 2010 or 2201	Correction made to reflect Rule 2201 reference.
S-1127-112	20	5	Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used.	District Rule 2520, 9.3.2 and 40 CFR 60.48c(g)	22	5	Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used.	PTO	reference to 40 CFR should be dropped this is not an affected facility	Reference to 40 CFR dropped as this is not an affected facility.
S-1127-112	20	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCO performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	District Rule 2520, 9.3.2	22	10	When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCO performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance.	PTO	Please Add SOx lb/Mmbtu EPA Method 6C	SOx Method 6C is on District's approved list of test methods; therefore, added to the condition.
S-1127-112	20	36	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	District Rules 1081, 4305, and 4351	22	37	The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans.	PTO	Please Add CO(ppmv) EPA Method 10B	CO EPA Method 10B is on District's approved list of test methods; therefore, added to the condition.
S-1127-148	17	8	Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20.	40 CFR 60.335(b) and District Rule 4703, 6.4	16	8	Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20.	PTO	The source test requirements must be updated per the most recent implemented ATC: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.	Conditions 8, 42, 43, 44 on the previously proposed PTO S-1127-148-17 are replaced with the following condition. This condition has been included as condition 41 on final PTO -148-17. All test methods are on District's approved test method list: "The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703]"
S-1127-148	17	42	Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20.	District Rules 2520, 9.4.1 and 4703, 6.4.1	16	42	Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20.	PTO	The source test requirements must be updated per the most recent implemented ATC: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.	
S-1127-148	17	43	Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B.	District Rules 2520, 9.4.1 and 4703, 6.4.2	16	43	Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B.	PTO	The source test requirements must be updated per the most recent implemented ATC: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.	
S-1127-148	17	44	Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20.	District Rules 2520, 9.4.1 and 4703, 6.4.3	16	44	Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20.	PTO	The source test requirements must be updated per the most recent implemented ATC: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.	

Facility S-1127 TV Renewal Comments
Attachment 3

Common		TV Renewal Proposed PTO				Potential Match with Chevron Current Operating Permit (Enviance System)		Chevron Title V Review Comments	District's Response
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text		
S-1127-149	17	8	Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20.	40 CFR 60.335(b) and District Rule 4703. 6.4	16	8	Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20.	PTO	<p>The source test requirements must be updated per the most recent implemented ATC: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.</p> <p>Conditions 8, 42, 43, 44 on the previously proposed PTO S-1127-149-17 are replaced with the following condition. This condition has been included as condition 41 on final PTO-149-17. All test methods are on District's approved test method list: The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201 and 202a; ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit.</p>
S-1127-149	17	42	Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20.	District Rules 2520. 9.4.1 and 4703. 6.4.1	16	42	Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Tests Method 7E or 20.	PTO	
S-1127-149	17	43	Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B.	District Rules 2520. 9.4.1 and 4703. 6.4.2	16	43	Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Test Methods 10 or 10B.	PTO	
S-1127-149	17	44	Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20.	District Rules 2520. 9.4.1 and 4703. 6.4.3	16	44	Source testing to measure stack gas oxygen shall be conducted using EPA Tests Methods 3, 3A, or 20.	PTO	
S-1127-160	12	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	16	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	PTO	
S-1127-161	18	22	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	22	22	An operator shall inspect all unsafe-to-monitor components during each turnaround.	PTO	
S-1127-161	18	23	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8	22	23	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	PTO	
S-1127-162	14	0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-8-3 WITH 38 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-8-3 WITH 38 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	Equipment description corrected as requested.
S-1127-164	17	0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYSTEM CC-10-3 WITH 49 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATOR, VAPOR COMPRESSOR, CONDENSATE VESSEL #V-2, AND COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYSTEM CC-10-3 WITH 49 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATOR, VAPOR COMPRESSOR, CONDENSATE VESSEL #V-2, AND COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	Equipment description corrected as requested.
S-1127-164	17	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	19	40	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule. Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-164	17	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	19	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule reference corrected.
S-1127-164	17	24	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule reference corrected.

Facility S-1127 TV Renewal Comments
Attachment 3

Common			TV Renewal Proposed PTO		Potential Match with Chevron Current Operating Permit (Enviance System)			Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-165	12	0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-2-3 WITH 39 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-2-3 WITH 39 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	The base document authorized the removal of the casing collection system the equipment descriptions should read: TEOR OPERATION WITH UP TO 39 STEAM-ENHANCED OIL PRODUCTION WELLS WITH CLOSED WELL CASING VENTS	Equipment description corrected as requested.
S-1127-165	12	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	14	40	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-165	12	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	14	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-165	12	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-166	15	0	TEOR WELL VENT VAPOR CONTROL SYSTEM CC-4-3 SERVING 92 STEAM ENHANCED WELLS, WITH HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, VAPOR COMPRESSORS AND PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	TEOR WELL VENT VAPOR CONTROL SYSTEM CC-4-3 SERVING 92 STEAM ENHANCED WELLS, WITH HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, VAPOR COMPRESSORS AND PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	The base document removed casing collection system equipment description should read: TEOR OPERATION WITH UP TO 92 STEAM-ENHANCED OIL PRODUCTION WELLS WITH CLOSED VENTS	Equipment description corrected as requested.
S-1127-166	15	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	17	40	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-166	15	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	17	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-166	15	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-167	17	0	TEOR WELL VENT VAPOR CONTROL SYSTEM CC-6-3 AND CC-7-3 SERVING 150 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, AND COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	TEOR WELL VENT VAPOR CONTROL SYSTEM CC-6-3 AND CC-7-3 SERVING 150 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, AND COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	The base document removed casing collection system equipment description should read: TEOR OPERATION WITH UP TO 150 STEAM-ENHANCED OIL PRODUCTION WELLS WITH CLOSED VENTS	Equipment description corrected as requested.
S-1127-167	17	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	19	40	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-167	17	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	19	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-167	17	24	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-168	16	0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-3-3 WITH 38 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-3-3 WITH 38 STEAM ENHANCED WELLS, HEAT EXCHANGER, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	The base document removed the casing collection system the equipment description should read: TEOR OPERATION WITH UP TO 38 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED WELL CASING VENTS	Equipment description corrected as requested.
S-1127-168	16	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	18	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.

Facility S-1127 TV Renewal Comments
Attachment 3

Common		TV Renewal Proposed PTO		Potential Match with Chevron Current Operating Permit (Enviance System)		Chevron Title V Review Comments	District's Response			
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #			Condition #	Condition Text	Permit Type
S-1127-168	16	24	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-169	14	0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-5-3, WITH 73 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES			0	THERMALLY ENHANCED OIL RECOVERY WELL VENT VAPOR CONTROL SYS CC-5-3, WITH 73 STEAM ENHANCED WELLS, HEAT EXCHANGERS, GAS/ LIQUID SEPARATORS, CONDENSATE HIGH EFFICIENCY MIST ELIMINATOR, COMPRESSED VAPOR PIPING TO AUTHORIZED DISPOSAL/INCINERATION DEVICES	PTO	The base document removed the casing collection system the equipment description should read: TEOR OPERATION WITH UP TO 73 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED WELL CASING VENTS	Equipment description corrected as requested.
S-1127-169	14	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	16	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-169	14	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-171	19	19	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-171	19	20	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-173	15	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	14	13	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-173	15	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-173	15	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-174	18	4	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	17	13	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-174	18	19	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-174	18	20	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-176	15	22	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	17	22	An operator shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-176	15	23	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8	17	23	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	PTO	Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-177	14	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	16	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-177	14	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8	16	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	PTO	Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-178	13	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	17	23	An operator shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-178	13	24	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8	17	24	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	PTO	Rule Reference should be 5.4.6	Rule reference corrected.

**Facility S-1127 TV Renewal Comments
Attachment 3**

Common		TV Renewal Proposed PTO			Potential Match with Chevron Current Operating Permit (Enviance System)			Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-179	18	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	17	14	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-179	18	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-179	18	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-180	15	4	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	14	15	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-180	15	19	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-180	15	20	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-185	15	4	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	14	13	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-185	15	19	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-185	15	20	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-187	13	6	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	15	40	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-187	13	21	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7	15	18	Permittee shall inspect all unsafe-to-monitor components during each turnaround.	PTO	Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-187	13	22	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-201	9	0	MODIFICATION OF THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 66 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-2-32)			0	MODIFICATION OF THERMALLY ENHANCED OIL RECOVERY OPERATION SERVING 66 STEAM ENHANCED WELLS - PERMANENTLY CLOSED WELL CASING VENTS, ROUTE PRODUCTION TO VAPOR CONTROLLED TANKS AND EXEMPT EQUIPMENT (MONTE CRISTO 2 CC-2-32)	PTO	Base document authorized removal of the casing collection system and operation with closed vents. Equipment descriptions should read: THERMALLY ENHANCED OIL RECOVERY OPERATION WITH UP TO 66 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS (MONTE CRISTO 2)	Equipment description corrected as requested.
S-1127-201	9	4	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	8	13	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-201	9	19	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-201	9	20	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.

Facility S-1127 TV Renewal Comments
Attachment 3

Common		TV Renewal Proposed PTO			Potential Match with Chevron Current Operating Permit (Enviance System)			Chevron Title V Review Comments	District's Response	
Permit #	Modification #	Condition #	Condition Text	Rule Number	Modification #	Condition #	Condition Text			Permit Type
S-1127-420	6	2	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	5	18	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	PTO	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-420	6	18	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-420	6	19	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.
S-1127-427	6	0	248 CYCLIC WELLS WITH CLOSED CASING VENTS				MODIFICATION OF 248 CYCLIC WELLS WITH CLOSED CASING VENTS: REVISE CYCLIC WELL REFERENCE TO STEAM ENHANCED OIL PRODUCTION WELLS	ATC	Base document revised the equipment description to steam enhanced wells. Equipment description should read: THERMALLY ENHANCED OIL RECOVERY OPERATION WITH UP TO 248 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS	Equipment description corrected as requested.
S-1127-427	6	2	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	District Rule 2520, 13.2	7	19	Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements.	ATC	This condition references the 1998 version of 4401 it should reference the June 16, 2011 rule.	Condition updated to reflect June 16, 2011 version of Rule 4401.
S-1127-427	6	16	An operator shall inspect all unsafe-to-monitor components during each turnaround.	District Rule 4401, 5.4.7					Rule Reference should be 5.4.5	Rule reference corrected.
S-1127-427	6	17	District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator.	District Rule 4401, 5.4.8					Rule Reference should be 5.4.6	Rule reference corrected.