

**NOTICE OF FINAL ACTION  
FOR THE ISSUANCE OF AUTHORITY  
TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to Houchin Community Blood Bank for the installation of a 1200 bhp tier 2 Cummins, Model QSK23-G7, or District approved equivalent, diesel-fired emergency standby internal combustion (IC) engine powering an electrical generator, at 11515 Bolthouse Drive in Bakersfield, CA.

All comments received following the District's preliminary decision on this project were considered.

Comments received by the District during the public notice period resulted in a correction on page 11 to reflect that the project did not trigger TBACT consistent with the results of the HRA. These changes were minor and did not trigger additional public notification requirements, nor did they have any impact upon the Best Available Control Technology determination or on the amount of offsets required for project approval.

The application review for Project #S-1120345 is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 34946 FLYOVER COURT, BAKERSFIELD, CA 93308.**