



JAN 16 2013

Rafael Gonzales
Selma-Kingsburg- Fowler County Sanitation District
P O Box 158
Kingsburg, Ca 93631

RE: Notice of Final Action - Authority to Construct
Project Number: C-1123117

Dear Mr. Gonzales:

The Air Pollution Control Officer has issued Authority to Construct permits to Selma-Kingsburg- Fowler County Sanitation District for a 954 bhp diesel-fired emergency standby IC engine powering an electric generator, at 11301 E. Conejo in Kingsburg, Ca.


Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on December 13, 2012. The District's analysis of the proposal was also sent to CARB on December 10, 2012. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

DW:vg

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



JAN 16 2013

Mike Tollstrup, Chief
Project Assessment Branch
Stationary Source Division
California Air Resources Board
PO Box 2815
Sacramento, CA 95812-2815

RE: Notice of Final Action - Authority to Construct
Project Number: C-1123117

Dear Mr. Tollstrup:

The Air Pollution Control Officer has issued Authority to Construct permits to Selma-Kingsburg- Fowler County Sanitation District for a 954 bhp diesel-fired emergency standby IC engine powering an electric generator, at 11301 E. Conejo in Kingsburg, Ca.

Enclosed are copies of the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue this Authority to Construct was published on December 13, 2012. The District's analysis of the proposal was also sent to CARB on December 10, 2012. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

DW:vg

Enclosures

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Fresno Bee

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF AUTHORITY
TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to Selma-Kingsburg- Fowler County Sanitation District for a 954 bhp diesel-fired emergency standby IC engine powering an electric generator, at 11301 E. Conejo in Kingsburg, Ca.

No comments were received following the District's preliminary decision on this project.

The application review for Project #C-1123117 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**



AUTHORITY TO CONSTRUCT

PERMIT NO: C-3049-5-0

ISSUANCE DATE: 01/15/2013

LEGAL OWNER OR OPERATOR: SELMA-KINGSBURG-FOWLER COUNTY

MAILING ADDRESS: PO BOX 158
KINGSBURG, CA 93631-0158

LOCATION: 11301 E CONEJO AVE
KINGSBURG, CA 93631-0095

EQUIPMENT DESCRIPTION:

954 BHP (INTERMITTENT) DOOSAN MODEL P222FE YOB TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115, and 40 CFR 60 Subpart IIII]
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, 40 CFR Part 60 Subpart IIII]
7. Emissions from this IC engine shall not exceed any of the following limits: 3.8 g-NOx/bhp-hr, 0.7 g-CO/bhp-hr, or 0.2 g-VOC/bhp-hr. [District Rule 2201, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII]
8. Emissions from this IC engine shall not exceed 0.1 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII]
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 60 Subpart IIII]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services
C-3049-5-0 Jan 15 2013 1:19PM - GONZALEV : Joint Inspection NOT Required

10. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
12. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]
13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115]
14. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII]
15. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115]
16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115]



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

Due Date
3/18/2013

Amount Due
\$ 1,136.50

Amount Enclosed

ENGTIME C1123117
3049 C200355 1/15/2013

RETURN THIS TOP PORTION ONLY, WITH REMITTANCE TO:

SELMA-KINGSBURG-FOWLER COUNTY
PO BOX 158
KINGSBURG, CA 93631-0158

SJVAPCD
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244

Thank You!



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

SJVAPCD Tax ID: 77-0262563

SELMA-KINGSBURG-FOWLER COUNTY
11301 E CONEJO AVE
KINGSBURG, CA 93631-0095

Facility ID
C3049

Invoice Date
1/15/2013

Invoice Number
C200355

Invoice Type
Project: C1123117

PROJECT NUMBER: 1123117

ENGINEERING TIME FEES
LESS PREVIOUSLY PAID PROJECT FEES APPLIED TO THIS INVOICE
PROJECT FEES DUE (Enclosed is a detailed statement outlining the fees for each item.)

\$ 1,136.50
\$ 0.00
\$ 1,136.50

Late Payment (see Rule 3010, Section 11.0 Late Fees)	
Postmarked	Total Due
After 3/18/2013 through 3/28/2013	\$ 1,250.15
After 3/28/2013	\$ 1,704.75
After 4/17/2013	Permits To Operate MAY BE SUSPENDED

Invoice Detail

Facility ID: C3049

SELMA-KINGSBURG-FOWLER COUNTY
11301 E CONEJO AVE
KINGSBURG, CA 93631-0095

Invoice Nbr: C200355
Invoice Date: 1/15/2013
Page: 1

Engineering Time Fees

Project Nbr	Quantity	Rate	Description	Fee
C1123117	11.5 hours	\$ 105.00 /h	Standard Engineering Time	\$ 1,207.50
			Less Credit For Application Filing Fees	(\$ 71.00)
			Standard Engineering Time SubTotal	\$ 1,136.50
Total Engineering Time Fees:				\$ 1,136.50

Account Summary

Facility ID: C3049

SELMA-KINGSBURG-FOWLER COUNTY
11301 E CONEJO AVE
KINGSBURG, CA 93631-0095

Statement Date: 1/15/2013

Invoice Date	Invoice Number	Invoice Due Date	Description of Fees	Amount Due
11/30/2012	C198010	02/01/2013	13/14 Annual Permits To Operate	\$ 354.00
01/15/2013	C200355	03/18/2013	Project: C1123117	\$ 1,136.50
Total Outstanding Balance:				\$ 1,490.50