

Fresno Bee

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF AUTHORITY
TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to TW Telecom of California for replacing a 380 hp Cummins diesel-fired emergency standby engine powering an electrical generator with a 1,490 bhp (intermittent) Cummins Tier 2 certified diesel-fired emergency standby engine powering an electrical generator, at 7576 Del Mar Avenue in Fresno, CA.

No comments were received following the District's preliminary decision on this project.

The application review for Project #C-1130019 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the **SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**