NOTICE OF FINAL DECISION FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND THE PROPOSED MINOR MODIFICATION OF FEDERALLY MANDATED OPERATING PERMIT

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued Authority to Construct permits to General Mills Operations for its boiler at 2000 West Turner Road in Lodi, California. The proposal was to lower the NOx emissions from the boiler to 7 ppmvd @ 3% O2 for compliance with District Rule 4320. The lower NOx emission limit is accompanied by an increase in the CO emission limit to provide the tuning flexibility necessary to reliably meet the lower NOx Limit.

No comments were received following the District's preliminary decision on this project.

The application review for Project #N-1123738, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and the District office at the address below. SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 4800 ENTERPRISE WAY, MODESTO, CA 95356.