



JUL 16 2013

Mr. Kevin Rebelo
Morning Star Packing Company
13448 S. Volta Rd.
Los Banos, CA 93635

Re: Notice of Final Action - Title V Permit
District Facility # N-1326
Project # N-1121933

Dear Mr. Rebelo:

The District has issued the Final Title V Permit for Morning Star Packing Company. The preliminary decision for this project was made on April 9, 2013. No comments were received subsequent to the District preliminary decision. Enclosed are the Final Title V Permit and public notice to be published approximately three days from the date of this letter.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Jim Swaney, Permit Services Manager, at (559) 230-5900.

Sincerely,



David Warner
Director of Permit Services

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Newspaper notice for publication in Merced Sun Star and for posting on valleyair.org

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT
NOTICE OF FINAL DECISION TO ISSUE
FEDERALLY MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue the initial Federally Mandated Operating Permit to Morning Star Packing Company at 13448 S. Volta Rd, Los Banos, California.

The District's analysis of the legal and factual basis for this proposed action, project #N-1121933, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.



Permit to Operate

FACILITY: N-1326

EXPIRATION DATE: 09/30/2017

LEGAL OWNER OR OPERATOR:

MORNING STAR PACKING COMPANY

MAILING ADDRESS:

13448 S VOLTA RD
LOS BANOS, CA 93635

FACILITY LOCATION:

13448 S VOLTA RD
LOS BANOS, CA 93635

FACILITY DESCRIPTION:

AGRICULTURAL PRODUCTS PROCESSING

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin

Executive Director / APCO

David Warner

Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: N-1326-0-1

EXPIRATION DATE: 09/30/2017

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: MORNING STAR PACKING COMPANY
Location: 13448 S VOLTA RD, LOS BANOS, CA 93635
N-1326-0-1: Jul 10 2013 3:57PM - SIONGCOJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. On July 31, 2013, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-1-8

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

130 MMBTU/HR NEBRASKA MODEL #NSF-81 NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN MODEL #D-RMB128 BURNER AND A FLUE GAS RECIRCULATION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.0033 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source testing interval, the owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306, and 4320] Federally Enforceable Through Title V Permit
26. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
27. Records of the cumulative NO_x emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall be kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. The NO_x emission limit (as NO₂) shall not exceed 0.10 lb/MMBtu. [40 CFR 60.44b(a)(1)(i)] Federally Enforceable Through Title V Permit
30. The NO_x standards apply at all times including periods of startup, shutdown, or malfunction. Compliance with the NO_x standard shall be determined on a 30-day rolling average basis. [40 CFR 60.44b(h) and (i), 40 CFR 60.46b(a)] Federally Enforceable Through Title V Permit
31. The owner or operator shall monitor the steam generating unit operating conditions and predict NO_x emission rates as specified in a plan submitted pursuant to 40 CFR 60.49b(c). The plan shall identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO_x emission rates; include the data and information that the owner or operator used to identify the relationship between NO_x emission rates and these operating conditions; and identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis during the period of operation of the unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator. [40 CFR 60.48b(g)(2) and 60.49b(c)] Federally Enforceable Through Title V Permit
32. The owner or operator shall record and maintain records of the amounts of fuel combusted during each day and calculate the annual capacity factor for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis. [40 CFR 60.49b(d)] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain records of the following information for each steam generating unit operating day: calendar date; the average hourly NO_x emission rates (expressed as NO₂) (lb/MMBtu heat input) measured or predicted; the 30-day average NO_x emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; identification of the steam generating unit operating days when the calculated 30-day average NO_x emission rates are in excess of the NO_x emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken; identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; and identification of "F" factor used for calculations, method of determination, and type of fuel combusted. [40 CFR 60.49b(g)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-2-9

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

120 MMBTU/HR NEBRASKA MODEL #NS-F-81-ECON NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN CORPORATION MODEL #D-RMB ULTRA LOW NOX BURNER WITH AN INDUCED FLUE GAS RECIRCULATION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.0052 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source testing interval, the owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306, and 4320] Federally Enforceable Through Title V Permit
26. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
27. Records of the cumulative NOx emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall be kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. The NOx emission limit (as NO2) shall not exceed 0.10 lb/MMBtu. [40 CFR 60.44b(a)(1)(i)] Federally Enforceable Through Title V Permit
30. The NOx standards apply at all times including periods of startup, shutdown, or malfunction. Compliance with the NOx standard shall be determined on a 30-day rolling average basis. [40 CFR 60.44b(h) and (i), 40 CFR 60.46b(a)] Federally Enforceable Through Title V Permit
31. The owner or operator shall monitor the steam generating unit operating conditions and predict NOx emission rates as specified in a plan submitted pursuant to 40 CFR 60.49b(c). The plan shall identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates; include the data and information that the owner or operator used to identify the relationship between NOx emission rates and these operating conditions; and identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis during the period of operation of the unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator. [40 CFR 60.48b(g)(2) and 60.49b(c)] Federally Enforceable Through Title V Permit
32. The owner or operator shall record and maintain records of the amounts of fuel combusted during each day and calculate the annual capacity factor for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis. [40 CFR 60.49b(d)] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain records of the following information for each steam generating unit operating day: calendar date; the average hourly NOx emission rates (expressed as NO2) (lb/MMBtu heat input) measured or predicted; the 30-day average NOx emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; identification of the steam generating unit operating days when the calculated 30-day average NOx emission rates are in excess of the NOx emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken; identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; and identification of "F" factor used for calculations, method of determination, and type of fuel combusted. [40 CFR 60.49b(g)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-3-10

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

120 MMBTU/HR NEBRASKA MODEL #NS-F-81-ECON NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN CORPORATION MODEL #D-RMB LOW NOX BURNER AND A FLUE GAS RECIRCULATION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emission shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.0052 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source testing interval, the owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
26. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
27. Records of the cumulative NO_x emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall be kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. The NO_x emission limit (as NO₂) shall not exceed 0.10 lb/MMBtu. [40 CFR 60.44b(a)(1)(i)] Federally Enforceable Through Title V Permit
30. The NO_x standards apply at all times including periods of startup, shutdown, or malfunction. Compliance with the NO_x standard shall be determined on a 30-day rolling average basis. [40 CFR 60.44b(h) and (i), 40 CFR 60.46b(a)] Federally Enforceable Through Title V Permit
31. The owner or operator shall monitor the steam generating unit operating conditions and predict NO_x emission rates as specified in a plan submitted pursuant to 40 CFR 60.49b(c). The plan shall identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO_x emission rates; include the data and information that the owner or operator used to identify the relationship between NO_x emission rates and these operating conditions; and identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis during the period of operation of the unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator. [40 CFR 60.48b(g)(2) and 60.49b(c)] Federally Enforceable Through Title V Permit
32. The owner or operator shall record and maintain records of the amounts of fuel combusted during each day and calculate the annual capacity factor for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis. [40 CFR 60.49b(d)] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain records of the following information for each steam generating unit operating day: calendar date; the average hourly NO_x emission rates (expressed as NO₂) (lb/MMBtu heat input) measured or predicted; the 30-day average NO_x emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; identification of the steam generating unit operating days when the calculated 30-day average NO_x emission rates are in excess of the NO_x emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken; identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; and identification of "F" factor used for calculations, method of determination, and type of fuel combusted. [40 CFR 60.49b(g)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-5-1

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

244 BHP CUMMINS MODEL 6BTA-5.9 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIREWATER PUMP

PERMIT UNIT REQUIREMENTS

1. The engine shall be equipped with a positive crankcase ventilation (PCV) system or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The daily emissions limits for the engine shall not exceed the following levels : PM 10 = 12.9 pounds/day; NOx = 93.1 pounds/day; SOx = 12.0 pounds/day; CO = 39.2 pounds/day and VOC = 14.5 pounds/day. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR 63.6625 (f), and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems". Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, 40 CFR 63.6640 (f)(ii), and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115]
10. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 40 CFR 63.6660, and 17 CCR 93115] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. On and after May 3, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)] Federally Enforceable Through Title V Permit
12. On and after May 3, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63.6585/63.6595 (a)] Federally Enforceable Through Title V Permit
13. On and after May 3, 2013, the engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63.6603/63.6640 Table 2d, Row 4.a] Federally Enforceable Through Title V Permit
14. On and after May 3, 2013, the engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 4.b] Federally Enforceable Through Title V Permit
15. On and after May 3, 2013, the engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 4.c] Federally Enforceable Through Title V Permit
16. On and after May 3, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63.6655(a)(2) and (a)(5)] Federally Enforceable Through Title V Permit
17. On and after May 3, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-8-5

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

205 MMBTU/HR NEBRASKA MODEL #N2S-7/S-95-ECON NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN CORPORATION MODEL #D-RMB ULTRA LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.0033 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source testing interval, the owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
26. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
27. Records of the cumulative NO_x emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall be kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. The NO_x emission limit (as NO₂) shall not exceed 0.10 lb/MMBtu. [40 CFR 60.44b(a)(1)(i)] Federally Enforceable Through Title V Permit
30. The NO_x standards apply at all times including periods of startup, shutdown, or malfunction. Compliance with the NO_x standard shall be determined on a 30-day rolling average basis. [40 CFR 60.44b(h) and (i), 40 CFR 60.46b(a)] Federally Enforceable Through Title V Permit
31. The owner or operator shall monitor the steam generating unit operating conditions and predict NO_x emission rates as specified in a plan submitted pursuant to 40 CFR 60.49b(c). The plan shall identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO_x emission rates; include the data and information that the owner or operator used to identify the relationship between NO_x emission rates and these operating conditions; and identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis during the period of operation of the unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator. [40 CFR 60.48b(g)(2) and 60.49b(c)] Federally Enforceable Through Title V Permit
32. The owner or operator shall record and maintain records of the amounts of fuel combusted during each day and calculate the annual capacity factor for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis. [40 CFR 60.49b(d)] Federally Enforceable Through Title V Permit
33. The owner or operator shall maintain records of the following information for each steam generating unit operating day: calendar date; the average hourly NO_x emission rates (expressed as NO₂) (lb/MMBtu heat input) measured or predicted; the 30-day average NO_x emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; identification of the steam generating unit operating days when the calculated 30-day average NO_x emission rates are in excess of the NO_x emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken; identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; and identification of "F" factor used for calculations, method of determination, and type of fuel combusted. [40 CFR 60.49b(g)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-11-3

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

90 MMBTU/HR NEBRASKA MODEL #NS-E-59 NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN CORPORATION MODEL #D-RMB RAPID MIX ULTRA LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201 and 40 CFR 60.48c] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.0033 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source testing interval, the owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rule 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
26. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
27. Records of the monthly fuel usage of this boiler shall be kept and shall be maintained on the premises at all times. [District Rule 2201 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
28. Records of the cumulative NOx emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall be kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-12-3

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

118.6 MMBTU/HR NEBRASKA MODEL #NSF-81 NATURAL GAS-FIRED BOILER WITH A TODD/RADIAN CORPORATION MODEL #D-RMB ULTRA LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4301, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
7. PM10 emissions shall not exceed 0.005 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 40 ppmvd @ 3% O2 or 0.0291 lb/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 10 ppmvd @ 3% O2 or 0.0042 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
24. Records of the cumulative NO_x emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, N-1326-2, N-1326-3, N-1326-8, N-1326-11, N-1326-12, and N-1326-13 shall kept and shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. The NO_x emission limit (as NO₂) shall not exceed 0.10 lb/MMBtu. [40 CFR 60.44b(a)(1)(i)] Federally Enforceable Through Title V Permit
27. The NO_x standards apply at all times including periods of startup, shutdown, or malfunction. Compliance with the NO_x standard shall be determined on a 30-day rolling average basis. [40 CFR 60.44b(h) and (i), 40 CFR 60.46b(a)] Federally Enforceable Through Title V Permit
28. The owner or operator shall monitor the steam generating unit operating conditions and predict NO_x emission rates as specified in a plan submitted pursuant to 40 CFR 60.49b(c). The plan shall identify the specific operating conditions to be monitored and the relationship between these operating conditions and NO_x emission rates; include the data and information that the owner or operator used to identify the relationship between NO_x emission rates and these operating conditions; and identify how these operating conditions, including steam generating unit load, will be monitored on an hourly basis during the period of operation of the unit; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator. [40 CFR 60.48b(g)(2) and 60.49b(c)] Federally Enforceable Through Title V Permit
29. The owner or operator shall record and maintain records of the amounts of fuel combusted during each day and calculate the annual capacity factor for natural gas for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis. [40 CFR 60.49b(d)] Federally Enforceable Through Title V Permit
30. The owner or operator shall maintain records of the following information for each steam generating unit operating day: calendar date; the average hourly NO_x emission rates (expressed as NO₂) (lb/MMBtu heat input) measured or predicted; the 30-day average NO_x emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; identification of the steam generating unit operating days when the calculated 30-day average NO_x emission rates are in excess of the NO_x emissions standards under §60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken; identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; and identification of "F" factor used for calculations, method of determination, and type of fuel combusted. [40 CFR 60.49b(g)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-13-1

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

8.4 MMBTU/HR HURST MODEL #SA-G-200-200 NATURAL GAS-FIRED BOILER WITH AN INDUSTRIAL COMBUSTION MODEL #LNDG-1455-20 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR)

PERMIT UNIT REQUIREMENTS

1. The combined NOx emissions from the boilers operating under permits to operate (PTOs) N-1326-1, -2, -3, -8, -11, -12, and -13 shall not exceed 33,333 pounds per year on a 12-month rolling basis. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit
4. Maximum annual heat input of the unit shall be less than 9 billion Btu per calendar year. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
5. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in this unit shall be utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Owner/operator shall have unit tuned at least twice each calendar year, from four to eight months apart, in which it operates, by a technician that is qualified, to the satisfaction of the APCO, in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rule 4306] Federally Enforceable Through Title V Permit
7. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rule 4306] Federally Enforceable Through Title V Permit
8. Emissions rates from the natural gas-fired unit shall not exceed any of the following limits: 20 ppmv NOx @ 3% O2 or 0.024 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.005 lb-PM10/MMBtu, 100 ppmv CO @ 3% O2 or 0.0739 lb-CO/MMBtu, or 2 ppmv VOC @ 3% O2 or 0.001 lb-VOC/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
9. Records of monthly and annual heat input of the unit shall be maintained. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
10. Records of the daily fuel usage by this boiler shall be maintained on the premises at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Records of tune-up and monitoring of the operational characteristics of the unit shall be maintained. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
12. Records of the cumulative NOx emissions determined on a 12-month rolling basis from the boilers operating under PTOs N-1326-1, -2, -3, -8, -11, -12, and -13 shall be updated daily. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
15. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1326-14-1

EXPIRATION DATE: 09/30/2017

EQUIPMENT DESCRIPTION:

130 BHP DUETZ MODEL BF6M1012C TIER 1 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE
POWERING A 80 KW ELECTRIC GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Emissions from this IC engine shall not exceed any of the following limits: 6.5 g-NOx/bhp-hr, 1.3 g-CO/bhp-hr, or 0.3 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. Emissions from this IC engine shall not exceed 0.10 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201, 4801, and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115, and 40 CFR 63.6625 (f)] Federally Enforceable Through Title V Permit
8. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
9. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 17 CCR 93115, and 40 CFR 63.6640 (f)(ii)] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 40 CFR 63.6660, and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. On and after May 3, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)] Federally Enforceable Through Title V Permit
17. On and after May 3, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63.6585/63.6595 (a)] Federally Enforceable Through Title V Permit
18. On and after May 3, 2013, the engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63.6603/63.6640 Table 2d, Row 4.a] Federally Enforceable Through Title V Permit
19. On and after May 3, 2013, the engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 4.b] Federally Enforceable Through Title V Permit
20. On and after May 3, 2013, the engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63.6603/63.6640 Table 2d, Row 4.c] Federally Enforceable Through Title V Permit
21. On and after May 3, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63.6655(a)(2) and (a)(5)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. On and after May 3, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.