

**NOTICE OF PRELIMINARY DECISION
FOR THE PROPOSED ISSUANCE OF
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Pixley Cogen Partners for installation of one 5.67 MW (ISO rated) combined heat and power (CHP) cogeneration system consisting of one 67.65 MMBtu/hr natural gas-fired Solar Model Taurus 60 (T-60) turbine and one 106.4 natural gas/biogas-fired MMBtu/hr Rentech duct burner with Rentech selective catalytic reduction (SCR) and CO catalyst and Heat Recovery Steam Generator (HRSG), at 11222 Road 120 in Pixley, CA.

The analysis of the regulatory basis for this proposed action, Project #S-1131975, is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be submitted by September 5, 2013 to **DAVID WARNER, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**