

**NOTICE OF FINAL ACTION  
FOR THE ISSUANCE OF  
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permits to Pixley Cogen Partners for installation of one 5.67 MW (ISO rated) combined heat and power (CHP) cogeneration system consisting of one 67.65 MMBtu/hr natural gas-fired Solar Model Taurus 60 (T-60) turbine and one 106.4 natural gas/biogas-fired MMBtu/hr Rentech duct burner with Rentech selective catalytic reduction (SCR) and CO catalyst and Heat Recovery Steam Generator (HRSG), at 11222 Road 120, Pixley, CA.

No comments were received following the District's preliminary decision on this project.

The application review for Project #S-1131975 is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm), the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.