

**AVISO DE DECISIÓN FINAL  
PARA LA OTORGACIÓN DE UN PERMISO DE  
AUTORIDAD PARA CONSTRUIR**

POR EL PRESENTE SE NOTIFICA que el Director Ejecutivo del Distrito del Aire ha otorgado permisos de Autoridad para Construir a West Kern Water District para aumentar el límite de 642 ppmv de CO a 1633 ppmv para asegurar que el motor alcanza la reducción de NOx para la cumplir con la regla 4702 y la adición de gas propano liquido como combustible secundario, localizado en Section 21, Township 30S, Range 25E, in Kern County.

Todos los comentarios que se recibieron siguiendo la decisión preliminar en este proyecto fueron considerados.

el periodo del aviso público resultaron en la adición de una condición para asegurar que ATC S-353-3-7 se implementa al mismo tiempo, o antes de S-353-3-9, y la adición de una condición para requerir una prueba de monitor portátil cuando el motor utiliza inicialmente de gas propano liquido. Estos cambios fueron menores y no provocaron requisitos adicionales de aviso público, ni tuvieron un impacto sobre la determinación de Mejor Tecnología de Control Disponible o en la cantidad de compensaciones requeridas para la aprobación de este proyecto.

La revisión de la solicitud del Proyecto #1133084 está disponible para la inspección del público en [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm), el DISTRITO PARA EL CONTROL DE LA CONTAMINACIÓN DEL AIRE DEL VALLE DE SAN JOAQUIN, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000.

**NOTICE OF FINAL ACTION  
FOR THE ISSUANCE OF  
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permit to West Kern Water District for to increase the CO limit from 642 ppmv to 1,633 ppmv to ensure the engine achieves NOx reduction for Rule 4702 compliance and adding LPG as a secondary fuel, at Section 21, Township 30S, Range 25E, in Kern County.

All comments received following the District's preliminary decision on this project were considered.

Comments received by the District during the public notice period resulted in adding a condition to ensure ATC S-353-3-7 is implemented concurrently, or prior to S-353-3-9, and adding a condition to require a portable monitor test when the engine initially uses LPG. These changes were minor and did not trigger additional public notification requirements, nor did they have any impact upon the Best Available Control Technology determination or on the amount of offsets required for project approval.

The application review for Project #1133084 is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm), the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.