

Bakersfield Californian

Newspaper notice for publication in Bakersfield Californian and for posting on
valleyair.org

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permit to West Kern Water District for to increase the CO limit from 642 ppmv to 1,633 ppmv to ensure the engine achieves NOx reduction for Rule 4702 compliance and adding LPG as a secondary fuel, at Section 21, Township 30S, Range 25E, in Kern County.

All comments received following the District's preliminary decision on this project were considered.

Comments received by the District during the public notice period resulted in adding a condition to ensure ATC S-353-3-7 is implemented concurrently, or prior to S-353-3-9, and adding a condition to require a portable monitor test when the engine initially uses LPG. These changes were minor and did not trigger additional public notification requirements, nor did they have any impact upon the Best Available Control Technology determination or on the amount of offsets required for project approval.

The application review for Project #1133084 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.