



DEC 30 2013

Randy Brock
Leprino Foods
2401 N. MacArthur Drive
Tracy, CA 95376-1826

RE: Notice of Final Action - Authority to Construct
Facility Number: N-474
Project Number: N-1132943

Dear Mr. Brock:

The Air Pollution Control Officer has issued the Authority to Construct permits to Leprino Foods for a 900 bhp Caterpillar Model C18 ATAAC Tier 2 certified diesel fired emergency standby IC engine powering an electric generator, at 2401 N. MacArthur Drive in Tracy, CA. Enclosed are the Authority to Construct permits and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permits was published on October 28, 2013. The District's analysis of the proposal was also sent to CARB on October 23, 2013. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475


Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. Randy Brock
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill at (209) 557-6400.

Sincerely,



David Warner
Director of Permit Services

DW:kc

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

Due Date
2/3/2014

Amount Due
\$ 2,049.00

ATCFEE N1132943
474 N102163 12/4/2013

Amount Enclosed

RETURN THIS TOP PORTION ONLY, WITH REMITTANCE TO:

LEPRINO FOODS
2401 MACARTHUR DR
TRACY, CA 95376

SJVAPCD
4800 Enterprise Way
Modesto, CA 95356-8718

Thank You!



San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

SJVAPCD Tax ID: 77-0262563

LEPRINO FOODS
2401 MACARTHUR DR
TRACY, CA 95376-1826

Facility ID
N474

Invoice Date
12/4/2013

Invoice Number
N102163

Invoice Type
Project: N1132943

PROJECT NUMBER: 1132943

APPLICATION FILING FEES	\$ 71.00
ENGINEERING TIME FEES	\$ 2,049.00
TOTAL FEES	\$ 2,120.00
LESS PREVIOUSLY PAID PROJECT FEES APPLIED TO THIS INVOICE	(\$ 71.00)
PROJECT FEES DUE (Enclosed is a detailed statement outlining the fees for each item.)	\$ 2,049.00

Late Payment (see Rule 3010, Section 11.0 Late Fees)	
Postmarked	Total Due
After 2/3/2014 through 2/13/2014	\$ 2,253.90
After 2/13/2014	\$ 3,073.50
After 3/5/2014	Permits To Operate MAY BE SUSPENDED

San Joaquin Valley Air Pollution Control District
4800 Enterprise Way, Modesto, CA 95356-8718, (209) 557-6400, Fax (209) 557-6475

San Joaquin Valley Air Pollution Control District

Invoice Detail

Facility ID: N474

LEPRINO FOODS
2401 MACARTHUR DR
TRACY, CA 95376-1826

Invoice Nbr: N102163
Invoice Date: 12/4/2013
Page: 1

Application Filing Fees

Project Nbr	Permit Number	Description	Application Fee
N1132943	N-474-16-0	900 BHP (INTERMITTENT) CATERPILLAR MODEL C-16 ATAAC TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRIC GENERATOR	\$ 71.00
Total Application Filing Fees:			\$ 71.00

Engineering Time Fees

Project Nbr	Quantity	Rate	Description	Fee
N1132943	20 hours	\$ 106.00 /h	Standard Engineering Time	\$ 2,120.00
			Less Credit For Application Filing Fees	(\$ 71.00)
			Standard Engineering Time SubTotal	\$ 2,049.00
Total Engineering Time Fees:				\$ 2,049.00



AUTHORITY TO CONSTRUCT

PERMIT NO: N-474-16-0

ISSUANCE DATE: 12/04/2013

LEGAL OWNER OR OPERATOR: LEPRINO FOODS
MAILING ADDRESS: 2401 MACARTHUR DR
TRACY, CA 95376

LOCATION: 2401 MACARTHUR DR
TRACY, CA 95376-1826

EQUIPMENT DESCRIPTION:
900 BHP (INTERMITTENT) CATERPILLAR MODEL C-16 ATAAC TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY
STANDBY IC ENGINE POWERING AN ELECTRIC GENERATOR

CONDITIONS

1. Permit to Operate N-474-9-2 shall be cancelled prior to or at the same time this Authority to Construct is implemented. [District Rule 2201]
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115]
7. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 4701 and 4702 and 17 CCR 93115]
8. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
9. Emissions from this IC engine shall not exceed any of the following limits: 4.11 g-NOx/bhp-hr, 0.6 g-CO/bhp-hr, or 0.22 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadreidin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

N-474-16-0: Dec 4 2013 9:52AM - CHANK : Joint Inspection NOT Required

10. Emissions from this IC engine shall not exceed 0.06 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 17 CCR 93115]
11. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
12. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations or to supply power while maintenance is performed or repairs are made to the primary power supply. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115]
13. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702]
14. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702]
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702, and 17 CCR 93115]
16. The permittee shall maintain monthly records of the type of fuel purchased. [District Rules 4701 and 4702, and 17 CCR 93115]
17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702, and 17 CCR 93115]
18. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002]