



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



FEB 20 2014

Mr. Gregory Pritchett
Chevron USA Inc.
PO Box 1392
Bakersfield, CA 93302

Re: Proposed ATC / Certificate of Conformity (Significant Mod)
District Facility # S-3371
Project # 1134520

Dear Mr. Pritchett:

Enclosed for your review is the District's analysis of an application for Authority to Construct for the facility identified above. You requested that a Certificate of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. Chevron USA Inc. (CUSA) has requested an Authority to Construct (ATC) permit for the installation of a 2063 hp natural gas-fired rich burn IC engine powering a gas compresor.

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authority to Construct with a Certificate of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authority to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,

David Warner
Director of Permit Services

DW:DT/st

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1890 E. Gattysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93309-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District
Authority to Construct Application Review
Natural Gas-Fired IC Engine

Facility Name: Chevron USA Inc.	Date: 2/5/14
Mailing Address: PO Box 1392	Engineer: David Torii
Bakersfield, CA 93302	Lead Engineer: Allan Phillips
Contact Person: Gregory Pritchett	
Telephone: 661-654-7145	
Application #(s): S-3371-7-0	
Project #: 1134520	
Deemed Complete: 12/16/13	

I. Proposal

Chevron USA Inc. (CUSA) has requested an Authority to Construct (ATC) permit for the installation of a natural gas-fired rich burn IC engine powering a gas compressor.

CUSA received their Title V Permit on 12/31/04. This modification can be classified as a Title V significant modification pursuant to Rule 2520, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. CUSA must apply to administratively amend their Title V permit.

II. Applicable Rules

Rule 2201	New and Modified Stationary Source Review Rule (4/21/11)
Rule 2520	Federally Mandated Operating Permits (6/21/01)
Rule 4001	New Source Performance Standards (4/14/99)
Rule 4002	National Emissions Standards for Hazardous Air Pollutants (5/20/04)
Rule 4101	Visible Emissions (2/17/05)
Rule 4102	Nuisance (12/17/92)
Rule 4201	Particulate Matter Concentration (12/17/92)
Rule 4301	Fuel Burning Equipment (12/17/92)
Rule 4701	Stationary Internal Combustion Engines – Phase 1 (8/21/03)
Rule 4702	Stationary Internal Combustion Engines – Phase 2 (8/18/11)
Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice

Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

III. Project Location

The engine will be located at the Lost Hills Gas Compression Facility in Lost Hills within Section 15, Township 27S, Range 21E. The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description

Gas that may be produced by CUSA or purchased from others is compressed to pipeline pressure by IC engine driven compressors and introduced to the Chevron gas pipeline system that serves Chevron and partner equipment in Kern and Fresno Counties. Currently the facility is comprised of two 1200 hp lean burn IC engine driven compressors. The proposed engine will also power a gas compressor. The proposed engine is a rich burn natural gas-fired spark ignition unit and will be equipped with non-selective catalytic reduction.

V. Equipment Listing

ATC S-3317-7-0: 2063 BHP WAUKESHA MODEL P9390GSI NATURAL GAS-FIRED IC
ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION
POWERING A GAS COMPRESSOR SERVING NATURAL GAS
DISTRIBUTION SYSTEM

VI. Emission Control Technology Evaluation

Non-Selective Catalytic Reduction (NSCR) decreases NO_x , CO and VOC emissions by using a catalyst to promote the chemical reduction of NO_x into N_2 and O_2 , and the chemical oxidation of VOC and CO into H_2O and CO_2 .

The fuel/air ratio controller, (oxygen controller) is used in conjunction with the NSCR to maintain the amount of oxygen in the exhaust stream to optimize catalyst function.

VII. General Calculations

A. Assumptions

The engine will be operated 8760 hours per year
The engine will operate at its rated capacity of 2063 hp
The engine will be fired on PUC quality natural gas

B. Emission Factors

S-3317-7-0 Emission Factors		
	g/hp·hr (ppmvd)	Source
NO _x	0.08 (5)	Applicant and BACT
SO _x	0.0094	Mass Balance Equation Below
PM ₁₀	0.02	Applicant and BACT
CO	0.6 (56)	Applicant and BACT
VOC	0.15 (25)	Applicant and BACT

$$*0.0028 \frac{\text{lb} - \text{SO}_x}{\text{MMBtu}} \times \frac{1 \text{ MMBtu}}{1,000,000 \text{ Btu}} \times \frac{2,542.5 \text{ Btu}}{\text{bhp} - \text{hr}} \times \frac{1 \text{ bhp input}}{0.35 \text{ bhp out}} \times \frac{453.6 \text{ g}}{\text{lb}} = 0.0094 \frac{\text{g} - \text{SO}_x}{\text{bhp} - \text{hr}}$$

C. Calculations

1. Pre-Project Potential to Emit (PE1)

Since this is a new emissions unit, PE1 = 0 for all pollutants.

2. Post Project Potential to Emit (PE2)

Daily Post Project Emissions					
Pollutant	Emissions Factor (g/bhp-hr)	Rating (bhp)	Daily Hours of Operation (hrs/day)	Conversion (g/lb)	PE2 Total (lb/day)
NO _x	0.08	2063	24	453.6	8.7
SO _x	0.0094	2063	24	453.6	1.0
PM ₁₀	0.02	2063	24	453.6	2.2
CO	0.6	2063	24	453.6	65.5
VOC	0.15	2063	24	453.6	16.4

Annual Post Project Emissions					
Pollutant	Emissions Factor (g/bhp-hr)	Rating (bhp)	Annual Hours of Operation (hrs/yr)	Conversion (g/lb)	PE2 Total (lb/yr)
NO _x	0.08	2063	8760	453.6	3187
SO _x	0.0094	2063	8760	453.6	375
PM ₁₀	0.02	2063	8760	453.6	797
CO	0.6	2063	8760	453.6	23,905
VOC	0.15	2063	8760	453.6	5,976

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

SSPE1 (lb/year)					
Permit Unit	NO _x	SO _x	PM ₁₀	CO	VOC
S-3317-1	25,029	232	4171	132,095	55,619
S-3317-2	25,029	232	4171	132,095	55,619
SSPE1	50,058	464	8342	264,190	111,238

4. Post Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/year)					
Permit Unit	NO _x	SO _x	PM ₁₀	CO	VOC
S-3317-1	25,029	232	4171	132,095	55,619
S-3317-2	25,029	232	4171	132,095	55,619
S-3317-7-0	3187	375	797	23,905	5976
SSPE2	53,245	839	9139	288,095	117,214

5. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
Facility emissions pre-project	50,058	464	8342	264,190	111,238
Facility emissions – post project	53,245	839	9139	288,095	117,214
Major Source Threshold	20,000	140,000	140,000	200,000	20,000
Major Source?	yes	No	No	yes	yes

This source is an existing Major Source for NO_x, CO and VOC emissions and will remain so. No change in other pollutants are proposed or expected as a result of this project.

Rule 2410 Major Source Determination:

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(i). Therefore the following PSD Major Source thresholds are applicable.

PSD Major Source Determination (tons/year)							
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀	CO _{2e}
Estimated Facility PE before Project Increase	25.0	55.6	0.2	132.1	4.2	4.2	8048
PSD Major Source Thresholds	250	250	250	250	250	250	100,000
PSD Major Source ? (Y/N)	n	n	n	n	n	n	n

$$*0.000205864 \text{ tons-CO}_2\text{e/hp-hr} \times (1200 + 1200 + 2063) \text{ hp} \times 8,760 \text{ hr/yr} = 8048 \text{ tons-CO}_2\text{e/yr}$$

As shown above, the facility is not an existing major source for PSD for at least one pollutant. Therefore the facility is not an existing major source for PSD.

6. Baseline Emissions (BE)

The BE calculation (in lbs/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201.

Since this is a new emissions unit, BE = PE1 = 0 for all pollutants.

7. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is a major source for NO_x, CO and VOC, the project's PE2 is compared to the SB 288 Major Modification Thresholds in the following table in order to determine if the SB 288 Major Modification calculation is required.

SB 288 Major Modification Thresholds			
Pollutant	Project PE2 (lb/year)	Threshold (lb/year)	SB 288 Major Modification Calculation Required?
NO _x	3187	50,000	N
SO _x	375	80,000	N
PM ₁₀	797	30,000	N
VOC	5976	50,000	N

Since none of the SB 288 Major Modification Thresholds are surpassed with this project, this project does not constitute an SB 288 Major Modification.

8. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

The determination of Federal Major Modification is based on a two-step test. For the first step, only the emission *increases* are counted. Emission decreases may not cancel out the increases for this determination.

Step 1

For new emissions units, the increase in emissions is equal to the PE2 for each new unit included in this project.

The project's combined total emission increases are compared to the Federal Major Modification Thresholds in the following table.

Federal Major Modification Thresholds for Emission Increases			
Pollutant	Total Emissions Increases (lb/yr)	Thresholds (lb/yr)	Federal Major Modification?
NO _x *	3187	0	Y
VOC*	5976	0	Y
PM ₁₀	797	30,000	N
PM _{2.5}	797	20,000	N
SO _x	375	80,000	N

*If there is any emission increases in NO_x or VOC, this project is a Federal Major Modification and no further analysis is required.

Since there is an increase in NO_x and VOC emissions, this project constitutes a Federal Major Modification, and no further analysis is required.

9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

Rule 2410 applies to pollutants for which the District is in attainment or for unclassified pollutants. The pollutants addressed in the PSD applicability determination are listed as follows:

- NO₂ (as a primary pollutant)

- SO₂ (as a primary pollutant)
- CO
- PM
- PM₁₀
- Greenhouse gases (GHG): CO₂, N₂O, CH₄, HFCs, PFCs, and SF₆

The first step of this PSD evaluation consists of determining whether the facility is an existing PSD Major Source or not (See Section VII.C.5 of this document).

In the case the facility is an existing PSD Major Source, the second step of the PSD evaluation is to determine if the project results in a PSD significant increase.

In the case the facility is NOT an existing PSD Major Source but is an existing source, the second step of the PSD evaluation is to determine if the project, by itself, would be a PSD major source.

In the case the facility is new source, the second step of the PSD evaluation is to determine if this new facility will become a new PSD major Source as a result of the project and if so, to determine which pollutant will result in a PSD significant increase.

I. Potential to Emit for New or Modified Emission Units vs PSD Major Source Thresholds

As a screening tool, the project potential to emit from all new and modified units is compared to the PSD major source threshold, and if total project potential to emit from all new and modified units is below this threshold, no further analysis will be needed.

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(i). Therefore the following PSD Major Source thresholds are applicable.

PSD Major Source Determination: Potential to Emit (tons/year)							
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀	CO ₂ e
Total PE from New and Modified Units	1.6	3.0	0.2	12.0	0.4	0.4	3720*
PSD Major Source threshold	250	250	250	250	250	250	100,000
New PSD Major Source?	n	n	n	n	n	n	n

*0.000205864 tons-CO₂e/hp-hr x 2063 hp x 8,760 hr/yr = 3720 tons-CO₂e/yr

As shown in the table above, the project potential to emit, by itself, does not exceed any of the PSD major source thresholds. Therefore Rule 2410 is not applicable and no further discussion is required.

10. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. Detailed QNEC calculations are included in Appendix A.

VIII. Compliance

Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

a. New emissions units – PE > 2 lb/day

As seen in Section VII.C.2 above, the applicant is proposing to install a new IC engine with a PE greater than 2 lb/day for NO_x, PM₁₀, CO, and VOC. BACT is triggered for NO_x, PM₁₀, CO and VOC.

b. Relocation of emissions units – PE > 2 lb/day

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore BACT is not triggered.

c. Modification of emissions units – AIPE > 2 lb/day

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore BACT is not triggered.

d. SB 288/Federal Major Modification

As discussed in Sections VII.C.7 and VII.C.8 above, this project does constitute an Federal Major Modification for NO_x and VOC emissions. Therefore BACT is triggered for NO_x and VOC for all emissions units in the project for which there is an emission increase.

2. BACT Guideline

BACT Guideline 3.3.12, applies to the natural gas-fired IC engine. [Fossil Fuel** Fired IC Engine > 50 hp] (See Appendix B)

3. Top-Down BACT Analysis

Per Permit Services Policies and Procedures for BACT, a Top-Down BACT analysis shall be performed as a part of the application review for each application subject to the BACT requirements pursuant to the District's NSR Rule.

Pursuant to the attached Top-Down BACT Analysis (see **Appendix B**), BACT has been satisfied with the following:

NOx: 5 ppmv @ 15% O₂
PM₁₀: 0.02 g/bhp-hr,
CO: 56 ppmvd @ 15% O₂, 0.6 g/bhp-hr
VOC: 25 ppmvd @15% O₂, 0.15 g/bhp-hr

B. Offsets

1. Offset Applicability

Offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals to or exceeds the offset threshold levels in Table 4-1 of Rule 2201.

The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE2	53,245	839	9139	288,095	117,214
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets triggered?	Y	N	N	Y	Y

2. Quantity of Offsets Required

As seen above, the SSPE2 is greater than the offset thresholds for NO_x, CO and VOC only. Therefore offset calculations will be required for this project.

However, Section 4.6.1 of Rule 2201 states that emissions offsets are not required for increases in CO in attainment areas provided the applicant demonstrates to the satisfaction of the APCO that the Ambient Air Quality (AAQ) Standards are not violated in the areas to be affected, such emissions will be consistent with Reasonable Further Progress, and will not cause or contribute to a violation of AAQ Standards. The District performed an AAQ Analysis and determined that this project will not result in or contribute to a violation of an AAQ Standard for CO (see Appendix C). Therefore, CO offsets are not required for this project.

The quantity of offsets in pounds per year is calculated as follows for sources with an SSPE1 greater than the offset threshold levels before implementing the project being evaluated.

$$\text{Offsets Required (lb/year)} = (\Sigma[\text{PE2} - \text{BE}] + \text{ICCE}) \times \text{DOR, for all new or modified emissions units in the project,}$$

Where,

PE2 = Post Project Potential to Emit, (lb/year)

BE = Baseline Emissions, (lb/year)

ICCE = Increase In Cargo Carrier Emissions, (lb/year)

DOR = Distance Offset Ratio, determined pursuant to Section 4.8

BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, Located at a Major Source.

otherwise,

BE = HAE

The facility is proposing to install a new emission unit; therefore BE = 0. Also, there are no increases in cargo carrier emissions; therefore offsets can be determined as follows:

$$\text{Offsets Required (lb/year)} = ([\text{PE2} - \text{BE}] + \text{ICCE}) \times \text{DOR}$$

The project is a Federal Major Modification and therefore the correct offset ratio for NO_x and VOC is 1.5:1.

As calculated in Section VII.C.6 above, the BE equals zero since the unit is a new Emission Unit.

Offsets Required (lb/year)						
	PE2	BE	ICCE	Offsets Required (PE2 - BE - ICCE)	at offset ratio of 1.5:1	Offsets Required at 1.5:1 (lb/qtr)
NO _x	3187	0	0	3187	4781	1195
VOC	5976	0	0	5976	8964	2241

The applicant has stated that the facility plans to use the following ERC certificates which have available quarterly credits as follows:

NO _x				
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-4006-2	139,558	139,557	139,557	139,557
Offsets Required at 1.5:1	1195	1195	1195	1195

VOC				
	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-3400-1	1903	2425	2836	2947
Offsets Required at 1.5:1	2241	2241	2241	2241

Per section 4.13.7 of Rule 2201, AER for VOC that occurred from April through November may be used to offset increases in VOC during any period of the year.

As seen above, the facility has sufficient credits to fully offset the quarterly emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions (for each steam generator):

- Prior to operating equipment under this Authority to Construct, permittee shall surrender NO_x emission reduction credits for the following quantity of emissions: 1st quarter – 1195 lb, 2nd quarter – 1195 lb, 3rd quarter – 1195 lb, and fourth quarter – 1195 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]
- ERC Certificate Number S-4006-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]
- Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter – 2241 lb, 2nd quarter – 2241 lb, 3rd quarter – 2241 lb, and fourth quarter – 2241 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201]
- ERC Certificate Number S-3400-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

C. Public Notification

1. Applicability

Public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed, and/or
- d. Any project with an SSPE of greater than 20,000 lb/year for any pollutant.

a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications

New Major Sources are new facilities, which are also Major Sources. Since this is not a new facility, public noticing is not required for this project for New Major Source purposes.

As demonstrated in Sections VII.C.7 and VII.C.8, this project is a Federal Major Modification. Therefore, public noticing for Federal Major Modification purposes is required.

b. PE > 100 lb/day

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. As seen in Section VII.C.2 above, this project does not include a new emissions unit which has daily emissions greater than 100 lb/day for any pollutant, therefore public noticing for PE > 100 lb/day purposes is not required.

c. Offset Threshold

The SSPE1 and SSPE2 are compared to the offset thresholds in the following table.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO _x	50,058	53,245	20,000 lb/year	No
SO _x	464	839	54,750 lb/year	No
PM ₁₀	8342	9139	29,200 lb/year	No
CO	264,190	288,095	200,000 lb/year	No
VOC	111,238	117,214	20,000 lb/year	No

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

d. SSPE > 20,000 lb/year

Public notification is required for any permitting action that results in a SSPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSPE = SSPE2 – SSPE1. The SSPE is compared to the SSPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO _x	50,058	53,245	3,187	20,000 lb/year	No
SO _x	464	839	375	20,000 lb/year	No
PM ₁₀	8342	9139	797	20,000 lb/year	No
CO	264,190	288,095	23,905	20,000 lb/year	Yes
VOC	111,238	117,214	5,976	20,000 lb/year	No

As demonstrated above, the SSIPE for CO was greater than 20,000 lb/year; therefore public noticing for SSIPE purposes is required.

2. Public Notice Action

As discussed above, public noticing is required for this project for triggering a Federal Major Modification and for having a greater than 20,000 lb/year increase in CO emissions. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

D. Daily Emission Limits (DELs)

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

Proposed Rule 2201 (DEL) Conditions:

- Emissions from the IC engine, shall not exceed any of the following limits: 5 ppmvd NO_x at 15% O₂, 0.0094 g-SO_x/bhp-hr, 0.02 g-PM₁₀/bhp-hr, 56 ppmvd CO @ 15% O₂ or 25 ppmvd VOC at 15% O₂. [District Rules 2201 and 4702, and 40 CFR 60 Subpart JJJJ]

E. Compliance Assurance

1. Source Testing

- Source testing to measure NO_x, CO and VOC emissions from this unit shall be conducted within 90 days of initial start-up and once every 8,760 hours of operation or 24 months, whichever comes first, thereafter. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

2. Monitoring

As required by District Rule 4702, *Stationary Internal Combustion Engines - Phase 2*, this IC engine is subject to monitoring requirements. Monitoring requirements, in accordance with District Rule 4702, will be discussed in Section VIII, *District Rule 4702*, of this evaluation.

3. Recordkeeping

Recordkeeping is required to demonstrate compliance with the offset, public notification and daily emission limit requirements of Rule 2201. The following condition(s) are listed on the permit to operate:

- The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Y
- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule District Rule 4702 and 40 CFR 60 Subpart JJJJ] Y
- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2201 and 4702] Y

4. Reporting

No reporting is required to demonstrate compliance with Rule 2201.

F. Ambient Air Quality Analysis (AAQA)

be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis.

The proposed location is in an attainment area for NO_x, CO, and SO_x. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO_x, CO, or SO_x.

Technical Services also performed modeling for criteria pollutants NO_x, SO_x, CO, and PM₁₀; as well as the RMR for the engine. The emission rates used for criteria pollutant modeling were

3187 lb/yr NO_x, 375 lb/yr SO_x, 23,905 lb/yr CO, and 797 lb/yr PM₁₀.

The results from the Criteria Pollutant Modeling are as follows:

Criteria Pollutant Modeling Results*

Natural Gas ICE	1 Hour	3 Hours	8 Hours	24 Hours	Annual
CO	Pass	X	Pass	X	X
NO _x	Pass	X	X	X	Pass
SO _x	Pass	Pass	X	Pass	Pass
PM ₁₀	X	X	X	Pass	Pass

*Results were taken from the attached PSD spreadsheet.

¹The criteria pollutants are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2).

G. Compliance Certification

Section 4.15.2 of this Rule requires the owner of a new Major Source or a source undergoing a Title I Modification to demonstrate to the satisfaction of the District that all other Major Sources owned by such person and operating in California are in compliance or are on a schedule for compliance with all applicable emission limitations and standards. As discussed in Section VIII above, this facility is a new major source and this project does constitute a Title I modification, therefore this requirement is applicable. CUSA's compliance certification is included in Appendix D.

H. Alternate Siting Analysis

The current project occurs at an existing facility. The applicant proposes to install a compressor engine. Since the project will provide gas compression to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a "permit amendment that does not qualify as a minor permit modification or administrative amendment."

As discussed above, the facility has applied for a Certificate of Conformity (COC); therefore, the facility must apply to modify their Title V permit with an administrative amendment, prior to operating with the proposed modifications. Continued compliance with this rule is expected. The facility may construct/operate under the ATC upon submittal of the Title V administrative amendment/minor modification application.

Rule 4001 New Source Performance Standards (NSPS)**40 CFR 60 Subpart JJJJ Standards of Performance for Stationary Spark Ignition Internal Combustion Engines**

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. 40 CFR Part 60, Subpart JJJJ applies to spark-ignited internal combustion engines.

Section 60.4230(a) states the provisions of this subpart are applicable to manufacturers, owners, and operators of stationary spark ignition (SI) internal combustion engines (ICE) as

specified in paragraphs (a)(1) through (5) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.

Section 60.4230(a)(4) states owners and operators of stationary SI ICE that commence construction after June 12, 2006, where the stationary SI ICE are manufactured: (i) on or after July 1, 2007, for engines with a maximum engine power greater than or equal to 500 HP (except lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP); (ii) on or after January 1, 2008, for lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP; (iii) on or after July 1, 2008, for engines with a maximum engine power less than 500 HP; or (iv) on or after January 1, 2009, for emergency engines with a maximum engine power greater than 19 KW (25 HP) are applicable to the provisions of this subpart.

The engine in this project commenced construction and was manufactured in 2013 or 2014 and is a non-emergency rich burn engine with a maximum engine power of 2063 HP. Therefore, this section is applicable and the engine in this project is subject to this subpart.

Sections 60.4231 and 60.4232 apply only to the manufacturers of stationary SI internal combustion engines. These sections do not apply to owners or operators of such engines. Therefore, these sections do not apply.

Section 60.4233 lists emission standards for owners and operators. Per Section 60.4233(e), owners and operators of stationary SI ICE with a maximum engine power greater than or equal to 75 KW (100 HP) (except gasoline and rich burn engines that use LPG) must comply with the emission standards in Table 1 to this subpart for their stationary SI ICE. For owners and operators of stationary SI ICE with a maximum engine power greater than or equal to 100 HP (except gasoline and rich burn engines that use LPG) manufactured prior to January 1, 2011 that were certified to the certification emission standards in 40 CFR part 1048 applicable to engines that are not severe duty engines, if such stationary SI ICE was certified to a carbon monoxide (CO) standard above the standard in Table 1 to this subpart, then the owners and operators may meet the CO certification (not field testing) standard for which the engine was certified.

Table 1 of this subpart for non-emergency natural gas-fired engines HP $\geq$ 500 and manufacture date 7/1/2010 for later lists the NO_x standard as 1.0 g/bhp-hr (equivalent to 82 ppmv @ 15% O₂), the CO standard as 2.0 g/bhp-hr (equivalent to 270 ppmv @ 15% O₂), and the VOC standard as 0.7 g/bhp-hr (equivalent to 60 ppmv @ 15% O₂). Emissions from the proposed engines meet the required emissions standards. The following condition will be placed on the permit to ensure compliance:

- Emissions from the IC engine, shall not exceed any of the following limits: 5 ppmvd NO_x at 15% O₂, 0.0094 g-SO_x/bhp-hr, 0.02 g-PM₁₀/bhp-hr, 56 ppmvd CO @ 15% O₂ or 25 ppmvd VOC at 15% O₂. [District Rules 2201 and 4702, and 40 CFR 60 Subpart JJJJ]

Section 60.4234 states owners and operators of stationary SI ICE must operate and maintain stationary SI ICE that achieve the emission standards as required in Section 60.4233 over the entire life of the engine.

District Rule 4702 requires periodic monitoring to ensure that the applicable emission limits contained in the permit are met. Additionally, the emissions rates for the engines will be listed

as a permit condition for the life of the permit. Therefore, the requirements of this section are satisfied.

Section 60.4235 applies only to SI ICE that use gasoline. The proposed engines do not use gasoline. Therefore, this section does not apply.

Section 60.4236(b) states that after July 1, 2009, owners and operators may not install stationary SI ICE with a maximum engine power of greater than or equal to 500 HP that do not meet the applicable requirements in §60.4233, except that lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP that do not meet the applicable requirements in §60.4233 may not be installed after January 1, 2010.

As previously discussed, the proposed engines meet the applicable requirements of Section 60.4233. Therefore, the requirements of Section 60.4236 are satisfied.

Section 60.4237 lists monitoring requirements for emergency stationary SI ICE. The proposed engines are not used for emergency operation. Therefore, this section does not apply.

Sections 60.4238 through 60.4242 apply only to manufacturers of stationary SI ICE. Therefore, these sections do not apply.

Section 60.4243 lists compliance requirements for owners and operators of stationary SI ICE. Section 60.4243(b)(2)(ii) states that owners or operators of a stationary SI internal combustion engine greater than 500 HP must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, the owner or operator must conduct an initial performance test and conduct subsequent performance testing every 8,760 hours or 3 years, whichever comes first, thereafter to demonstrate compliance.

As Rule 4702 requires source testing once every 24 months, the 24 month source testing requirement will be required since it is more stringent than the 3 year source testing requirement of this subpart. Source testing will be required within 90 days of initial start-up since there will be a commissioning period of up to 60 days. The following conditions will be placed on the permit to ensure compliance:

- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]
- Source testing to measure NO_x and CO emissions from this unit shall be conducted within 90 days of initial start-up and thereafter once every 24 months. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]
- This engine shall be operated and maintained in proper operating condition according to the manufacturer's specifications. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

Section 60.4243(g) states that it is expected that air-to-fuel ratio controllers will be used with the operation of three-way catalysts/non-selective catalytic reduction. The ARF controller must be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times.

The following condition will be added to the permits to ensure compliance:

- Air-to-fuel ratio controller(s) shall be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times. [District Rule 2201 and 40 CFR 60 Subpart JJJJ]

Section 60.4244 lists test methods and other procedures for owners and operators of stationary SI ICE who conduct performance tests. Three separate test runs are required for each performance test, and each performance test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load. Additionally, performance tests may not be conducted during periods of startup, shutdown, or malfunction.

The following condition will be added to the permits to ensure compliance:

- For initial emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NO_x, CO and VOC concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]
- Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

Section 60.4245(a) states that owners and operators of all stationary SI ICE must keep records of the following information:

- All notifications submitted to comply with this subpart and all documentation supporting any notification.
- Maintenance conducted on the engine.
- If the stationary SI internal combustion engine is a certified engine, documentation from the manufacturer that the engine is certified to meet the emission standards and information as required in 40 CFR parts 90, 1048, 1054, and 1060, as applicable.
- If the stationary SI internal combustion engine is not a certified engine or is a certified engine operating in a non-certified manner and subject to §60.4243(a)(2), documentation that the engine meets the emission standards.

The following condition will be placed on the permit to ensure compliance:

- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

Section 60.4245(c) states owners and operators of stationary SI ICE greater than or equal to 500 HP that have not been certified by an engine manufacturer to meet the emission standards in §60.4231 must submit an initial notification as required in §60.7(a)(1). The notification must include the information in paragraphs (c)(1) through (5) of this section.

(1) Name and address of the owner or operator;

- (2) The address of the affected source;
- (3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;
- (4) Emission control equipment; and
- (5) Fuel used.

The following condition will be placed on the permit to ensure compliance:

- Notification of the date construction of this engine commenced shall be submitted to the District and EPA and shall be postmarked no later than 30 days after such date as construction commenced. The notification shall contain the following information: 1) Name and address of the owner or operator; 2) The address of the affected source; 3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement; 4) Emission control equipment; and 5) Fuel used. [40 CFR 60, Subpart JJJJ]

Section 60.4245(d) states owners and operators of stationary SI ICE that are subject to performance testing must submit a copy of each performance test within 60 days after the test has been completed.

The following condition will be placed on the permit to ensure compliance:

- The results of each source test shall be submitted to the District and EPA within 60 days after completion of the source test. [District Rule 1081 and 40 CFR 60 Subpart JJJJ]

Therefore, compliance with the requirements of this rule is expected.

Rule 4002 National Emission Standards for Hazardous Air Pollutants (NESHAPs)

40 CFR Part 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

Engines installed after 6/12/06 shall comply with either 40 CFR 60, Subpart IIII or Subpart JJJJ. For those cases, Subpart ZZZZ is not applicable. Therefore, this subpart does not apply.

Rule 4101 Visible Emissions

Rule 4101 states that no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 (or 20% opacity). As the IC engine is fired solely on natural gas, visible emissions are not expected to exceed Ringelmann 1 or 20% opacity. Also, based on past inspections of the facility continued compliance is expected.

Rule 4102 Nuisance

Rule 4102 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 – *Risk Management Policy for Permitting New and Modified Sources* specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than or equal to one. According to the Technical Services Memo for this project (**Appendix C**), the total facility prioritization score including this project was less than or equal to one. Therefore, no future analysis is required to determine the impact from this project and compliance with the District's Risk Management Policy is expected.

Rule 4201 Particulate Matter Concentration

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

$$0.02 \frac{g-PM_{10}}{bhp-hr} \times \frac{1bhp-hr}{2,542.5 Btu} \times \frac{10^6 Btu}{8,578 dscf} \times \frac{0.35 Btu_{out}}{1 Btu_{in}} \times \frac{15.43 grain}{g} = 0.005 \frac{grain-PM}{dscf}$$

Since the particulate matter concentration is ≤ 0.1 grains per dscf, compliance with Rule 4201 is expected.

Therefore, the following condition will be listed on the permits to ensure compliance:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

Rule 4301 Fuel Burning Equipment

This rule specifies maximum emission rates in lb/hr for SO₂, NO₂, and combustion contaminants (defined as total PM in Rule 1020). This rule also limits combustion contaminants to ≤ 0.1 gr/scf. According to AP 42 (Table 1.4-2, footnote c), all PM emissions from natural gas combustion are less than 1 μ m in diameter. As shown below, each unit's maximum hourly emission rates are below the Rule 4301 limits.

District Rule 4301 Limits			
	NO ₂ (lb/hr)	Total PM (lb/hr)	SO ₂ (lb/hr)
S-3317-7-0	0.4	0.09	0.04
Rule 4301 Limit	140	10 lb/hr	200 lb/hr

As shown above, compliance with this rule is expected.

Rule 4701 Stationary Internal Combustion Engines – Phase I

The requirements of Rule 4702 are equivalent or more stringent than the requirements of this Rule. Since the proposed IC engine is subject to both Rules 4701 and 4702, compliance with Rule 4702 is sufficient to demonstrate compliance with this Rule.

Rule 4702 Internal Combustion Engines – Phase 2

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines.

Section 2.0 states that this rule applies to any internal combustion engine rated at 25 brake horsepower or greater. The proposed is rated at 2,063 bhp. Therefore, this rule is applicable to the engine.

Section 5.2, Table 2, Category 1.d. for spark-ignited internal combustion engine rated at >50 bhp used exclusively in non-agricultural operations engine type rich-burn engines four-stroke requires the owner or operator to comply with the following emission limits:

Table 2 Emission Limits for a Spark-Ignited Internal Combustion Engine Rated at >50 bhp Used Exclusively in Non-AO (All ppmv limits are corrected to 15% oxygen on a dry basis). Emission Limits are effective according to the compliance schedule specified in Section 7.5.			
Engine Type	NOx Limit (ppmv)	CO Limit (ppmv)	VOC Limit (ppmv)
1. Rich-Burn			
d. Rich-Burn Engine, not listed above	11	2000	250

The facility has proposed to achieve the following emissions:

NO_x: 5 ppmvd @ 15 % O₂;
 CO: 56.1 ppmvd @ 15 % O₂; and
 VOC: 25 ppmvd @ 15 % O₂

The proposed emissions are less than the Table 2 limits. Therefore, compliance with this section is expected.

Section 5.3 requires that all continuous emission monitoring systems (CEMS) emissions measurements shall be averaged over a period of 15 consecutive minutes. Any 15-consecutive minute block average CEMS measurement exceeding the applicable emission limits of this rule shall constitute a violation of this rule. The IC engine involved with this project does not have a CEMS installed; therefore this section of the rule is not applicable.

Sections 5.4 and 5.5 outlines calculation methodologies and requirements for percent emission reductions, if used to comply with the NO_x emission limits. The IC engine involved with this project does not propose to use percent emission reductions to comply with the NO_x emission limits; therefore this section of the rule is not applicable.

Section 5.6 outlines the requirements for payment of an annual fee in lieu of complying with a NO_x emission limit. The IC engine involved with this project does not propose to pay an annual fee in lieu of complying with the NO_x emission limits; therefore this section of the rule is not applicable.

Section 5.7 outlines sulfur oxides (SO_x) emission control requirements. On and after the compliance schedule specified in Section 7.5, operators of non-AO spark-ignited engines and non-AO compression-ignited engines shall comply with one of the following requirements:

- 5.7.1 Operate the engine exclusively on PUC-quality natural gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases; or
- 5.7.2 Limit gaseous fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet; or
- 5.7.3 Use California Reformulated Gasoline for gasoline-fired spark-ignited engines; or
- 5.7.4 Use California Reformulated Diesel for compression-ignited engines; or
- 5.7.5 Operate the engine on liquid fuel that contains no more than 15 ppm sulfur, as determined by the test method specified in Section 6.4.6; or
- 5.7.6 Install and properly operate an emission control system that reduces SO₂ emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6.

The facility is proposing to use PUC quality natural gas fuel. Therefore, compliance with this section is expected.

Section 5.8.1 outlines monitoring requirements for non-AO spark-ignited engines subject to the requirements of Section 5.2 or any engine subject to the requirements of Section 8.0. The IC engines involved with this project are non-AO spark-ignited engines subject to the requirements of Section 5.2.

Section 5.8.1 requires that for each engine with a rated brake horsepower of 1,000 bhp or greater and which is allowed by Permit-to-Operate or Permit-Exempt Equipment Registration condition to operate more than 2,000 hours per calendar year, or with an external emission control device, either install, operate, and maintain continuous monitoring equipment for NO_x, CO, and oxygen, as identified in Rule 1080 (Stack Monitoring), or install, operate, and maintain APCO approved alternate monitoring. The monitoring system may be a continuous emissions monitoring system (CEMS), a parametric emissions monitoring system (PEMS), or an alternative monitoring system approved by the APCO. APCO-approved alternate monitoring shall consist of one or more of the following:

- 5.8.1.1 Periodic NO_x and CO emission concentrations,
- 5.8.1.2 Engine exhaust oxygen concentration,
- 5.8.1.3 Air-to-fuel ratio,
- 5.8.1.4 Flow rate of reducing agents added to engine exhaust,
- 5.8.1.5 Catalyst inlet and exhaust temperature,
- 5.8.1.6 Catalyst inlet and exhaust oxygen concentration, or
- 5.8.1.7 Other operational characteristics.

The applicant has chosen to meet the requirements of Section 5.8.1 of the rule by proposing a pre-approved alternate emissions monitoring plan that specifies that the permittee perform periodic NO_x, CO, and O₂ emissions concentrations as specified in District Policy SSP-1810, dated 4/29/04. Therefore, the following conditions will be listed on proposed ATC to ensure compliance:

- The permittee shall monitor and record the stack concentration of NO_x, CO, O₂, and NH₃ at least once every month (in which a source test is not performed). NO_x, CO, and O₂ concentrations shall be performed using a portable emission monitor that meets District

specifications. NH₃ monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]

- If the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, or the NH₃ concentrations corrected to 15% O₂, as measured by District approved gas-detection tubes, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]
- {2994} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

Section 5.8.6 requires that for each engine, install and operate a nonresettable elapsed operating time meter. In lieu of installing a nonresettable time meter, the owner or operator may use an alternative device, method, or technique in determining operating time provided that the alternative is approved by the APCO and is allowed by a Permit-to-Operate condition. The owner of the engine shall properly maintain and operate the time meter or alternative device in accordance with the manufacturer's instructions.

The applicant has proposed this engine will be equipped with a nonresettable elapsed operating time meter. The following condition will be listed on the permit to ensure compliance:

- This engine shall be equipped with a nonresettable elapsed operating time meter and a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved alternative. [District Rules 2201 and 4702 and 40 CFR 60 Subpart JJJJ]

Section 5.8.7 requires that for each engine, the permittee implement the Inspection and Monitoring (I&M) plan, if any, submitted to and approved by the APCO pursuant to Section 6.5. The following condition will be listed on the permit to ensure compliance:

- {3202} This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Monitoring (I&M) plan submitted to the District. [District Rule 4702]

Section 5.8.8 requires that for each engine, collect data through the I&M plan in a form approved by the APCO. The facility will collect data through the I&M plan in a form approved by the APCO.

Section 5.8.9 requires that for each engine, the operator shall use a portable NO_x analyzer to take NO_x emission readings to verify compliance with the emission requirements of Section 5.2 or Section 8.0 during each calendar quarter in which a source test is not performed. All emission readings shall be taken with the engine operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. All NO_x emissions readings shall be reported to the APCO in a manner approved by the APCO. NO_x emission readings taken pursuant to this section shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive minute sample reading or by taking at least five (5) readings evenly spaced out over the 15 consecutive-minute period.

The alternate monitoring scheme proposed in Section 5.8.1 will satisfy the requirements of Section 5.8.9. The following conditions will be listed on the permit to ensure compliance:

- The permittee shall monitor and record the stack concentration of NO_x, CO, O₂, and NH₃ at least once every month (in which a source test is not performed). NO_x, CO, and O₂ concentrations shall be performed using a portable emission monitor that meets District specifications. NH₃ monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
- {2994} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

Section 5.9 of the rule presents the alternative monitoring requirements for various engines not subject to the normal monitoring requirements of Section 5.8. These engines are required to monitor emissions under Section 5.8, so Section 5.9 does not apply.

Section 5.10 requires that on and after the compliance schedule specified in Section 7.5, an operator of a non-AO engine shall comply with the following requirements:

- 5.10.1 An operator of an engine complying with Sections 5.7.2 or 5.7.5 shall perform an annual sulfur fuel analysis in accordance with the test methods in Section 6.4. The operator shall keep the records of the fuel analysis and shall provide it to the District upon request,
- 5.10.2 An operator of an engine complying with Section 5.7.6 by installing and operating a control device with at least 95% by weight SO_x reduction efficiency shall submit

- for approval by the APCO the proposed the key system operating parameters and frequency of the monitoring and recording not later than July 1, 2013, and
- 5.10.3** An operator of an engine complying with Section 5.7.6 shall perform an annual source test unless a more frequent sampling and reporting period is included in the Permit-to-Operate. Source tests shall be performed in accordance with the test methods in Section 6.4.

This unit is fired on PUC-quality natural gas and/or digester gas. Therefore, the following requirement will be included on the permit to comply with the SOx emissions monitoring requirement:

- If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2201 and 4702] Y
- If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D 1072, D 3031, D 4084, D 3246 or double GC for H₂S and mercaptans. [District Rules 2201 and 4702] Y
- If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. If more than one engine utilizes the same fuel source, one representative sample can be taken from the shared fuel source. [District Rules 2201 and 4702] Y

Section 6.1 requires that the operator of an engine subject to the requirements of Section 5.2 of this rule shall submit to the APCO an APCO-approvable emission control plan of all actions to be taken to satisfy the emission requirements of Section 5.2 and the compliance schedules of Section 7.0. If there is no change to the previously-approved emission control plan, the operator shall submit a letter to the District indicating that the previously approved plan is still valid.

Section 6.1.2 requires that the emission control plan shall identify the type of emission control device or technique to be applied to each engine and a construction/removal schedule, or shall provide support documentation sufficient to demonstrate that the engine is in compliance with the emission requirements of this rule.

This submitted ATC application satisfies the requirements of this section.

Section 6.2.1 requires that the owner of an engine subject to the requirements of this rule shall maintain an engine operating log to demonstrate compliance with this rule. This information shall be retained for a period of at least five years, shall be readily available, and be made available to the APCO upon request. The engine operating log shall include, on a monthly basis, the following information:

- Total hours of operation,
- Type of fuel used,
- Maintenance or modifications performed,
- Monitoring data,

- Compliance source test results, and
- Any other information necessary to demonstrate compliance with this rule.

Therefore, the following condition will be included on the permit to ensure compliance:

- The permittee shall maintain records of: (1) the date and time of NO_x, CO, O₂, and NH₃ measurements, (2) the O₂ concentration in percent and the measured NO_x, CO, and NH₃ concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2201 and 4702]
- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

Section 6.2.2 requires that the data collected pursuant to the requirements of Section 5.8 and Section 5.9 shall be maintained for at least five years, shall be readily available, and made available to the APCO upon request. Therefore, the following condition will be included on the permit to ensure compliance:

- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702]

Section 6.3.1 states the requirements of Section 6.3.2 through Section 6.3.4 shall apply to the following engines:

- 6.3.1.1 Engines that have been retrofitted with an exhaust control device, except those certified per Section 9.0;
- 6.3.1.2 Engines subject to Section 8.0;
- 6.3.1.3 An AO spark-ignited engine that is subject to the requirements of Section 8.0;
- 6.3.1.4 An AO spark-ignited engine that has been retrofitted with a catalytic emission control and is not subject to the requirements of Section 8.0.

The engine in this project has been retrofitted with an exhaust control device. Therefore, Sections 6.3.2 through Section 6.3.4 are applicable to the engines in this project.

Section 6.3.2 requires that the operator of an engine subject to the requirements of Section 5.2, which engine equipped with an exhaust control device, to demonstrate compliance with the applicable emission limits during the initial start-up and at least once every 24 months thereafter.

Section 6.3.3 requires that the test must be conducted with the unit operating at normal operating conditions and using three 30-consecutive minute test runs. In addition, VOC shall be reported as methane, VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15 percent oxygen.

Section 6.3.5 specifies that an engine that is limited by PTO condition to be fueled exclusively with PUC-quality natural gas shall not be subject to reoccurring source test requirements of Section 6.3.2 for VOC emissions.

Source testing will be required within 90 days of initial start-up.. The following conditions will be included on the permit to ensure compliance:

- Source testing to measure NOx and CO emissions from this unit shall be conducted within 90 days of initial start-up and thereafter once every 24 months. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]
- Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
- For initial emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NOx, CO and VOC concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702 and 40 CFR 60 Subpart JJJJ]

Section 6.4 requires that the compliance with the requirements of Section 5.2 shall be determined in accordance with the following test procedures or any other method approved by EPA and the APCO:

- Oxides of nitrogen - EPA Method 7E, or ARB Method 100.
- Carbon monoxide - EPA Method 10, or ARB Method 100.
- Stack gas oxygen - EPA Method 3 or 3A, or ARB Method 100.
- Volatile organic compounds - EPA Method 25A or 25B, or ARB Method 100.
- Operating horsepower determination - any method approved by EPA and the APCO.

Therefore, the following condition will be included on the permit to ensure compliance:

- The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702]

Section 6.5 requires that the owner of an engine subject to the emission limits in Section 5.2 or the requirements of Section 8.0, shall submit to the APCO for approval, an I&M plan that specifies all actions to be taken to satisfy the following requirements and the requirements of Section 5.8. The actions to be identified in the I&M plan shall include, but are not limited to, the information specified below.

Section 6.5.1 states the requirements of Section 6.5.2 through Section 6.5.9 shall apply to the following engines:

- 6.5.1.1 Engines that have been retrofitted with an exhaust control device, except those certified per Section 9.0;
- 6.5.1.2 Engines subject to Section 8.0;
- 6.5.1.3 An AO spark-ignited engine that is subject to the requirements of Section 8.0.
- 6.5.1.4 An AO spark-ignited engine that has been retrofitted with a catalytic emission control and is not subject to the requirements of Section 8.0.

The engines in this project have been retrofitted with an exhaust control device. Therefore, Sections 6.5.2 through Section 6.5.9 are applicable to the engines in this project.

Section 6.5.2 specifies procedures requiring the owner or operator to establish ranges for control equipment parameters, engine operating parameters, and engine exhaust oxygen concentrations that source testing has shown result in pollutant concentrations within the rule limits.

Section 6.5.3 specifies procedures for monthly inspections as approved by the APCO. The applicable control equipment parameters and engine operating parameters will be inspected and monitored monthly in conformance with a regular inspection schedule listed in the I&M plan. The applicant has previously proposed that the alternate monitoring program will ensure compliance with Sections 6.5.2 and 6.5.3 of the Rule. Therefore, the following condition will ensure compliance with the I&M requirements of this rule:

- The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702]

Section 6.5.4 specifies procedures for the corrective actions on the noncompliant parameter(s) that the operator will take when an engine is found to be operating outside the acceptable range for control equipment parameters, engine operating parameters, and engine exhaust NO_x, CO, VOC, or oxygen concentrations.

Section 6.5.5 specifies procedures for the operator to notify the APCO when an engine is found to be operating outside the acceptable range for control equipment parameters, engine operating parameters, and engine exhaust NO_x, CO, VOC, or oxygen concentrations.

The applicant has proposed that the alternate monitoring program will ensure compliance with these two sections of the Rule. The following condition will ensure compliance with these requirements:

- If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702]

Section 6.5.6 specifies procedures for preventive and corrective maintenance performed for the purpose of maintaining an engine in proper operating condition. The applicant has proposed that the engines will be operated and maintained per the manufacturer's specifications. Therefore, the following condition will be included on the permit to ensure compliance:

- {3202} This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Monitoring (I&M) plan submitted to the District. [District Rule 4702]

Section 6.5.7 specifies procedures and a schedule for using a portable NO_x analyzer to take NO_x emission readings pursuant to Section 5.8.9. The applicant has proposed that the alternate monitoring program will ensure compliance with this Section of the Rule. The following condition will ensure compliance with this requirement:

- {3787} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

Section 6.5.8 specifies procedures for collecting and recording required data and other information in a form approved by the APCO including, but not limited to, data collected through the I&M plan and the monitoring systems described in Sections 5.8.1 and 5.8.2. Data collected through the I&M plan shall have retrieval capabilities as approved by the APCO. The applicant has proposed that the alternate monitoring program will ensure compliance with this Section of the Rule. The following condition will ensure compliance with this requirement:

- The permittee shall maintain records of: (1) the date and time of NO_x, CO, O₂, and NH₃ measurements, (2) the O₂ concentration in percent and the measured NO_x, CO, and NH₃ concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2201 and 4702]

Section 6.5.9 specifies procedures for revising the I&M plan. The I&M plan shall be updated to reflect any change in operation. The I&M plan shall be updated prior to any planned change in operation. An engine operator that changes significant I&M plan elements must notify the District no later than seven days after the change and must submit an updated I&M plan to the APCO no later than 14 days after the change for approval. The date and time of the change to the I&M plan shall be recorded in the engine operating log. For new engines and modifications to existing engines, the I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit-to-Operate or Permit-Exempt Equipment Registration. The operator of an engine may request a change to the I&M plan at any time. The applicant has proposed that they will modify their I&M plan per this section of the Rule. Therefore, the following condition will be placed on the permit to ensure continued compliance:

- {3212} The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]

Section 7.1 requires that the owner of an engine which becomes subject to the emission limits of this rule through loss of exemption shall not operate the subject engine, except as required for obtaining a new or modified Permit-to-Operate for the engine, until the owner demonstrates full compliance with the requirements of this rule.

The engine in this project did not become subject to this rule through a loss of exemption; therefore, the requirements of this section are not applicable.

Section 7.5.1 requires an operator with non-AO spark-ignited engines at a stationary source subject to Table 2 or Section 8.0 emission limits, SOx control requirements of Section 5.7, and the SOx monitoring requirements of Section 5.10 shall comply with the schedule specified in Table 5.

Table 5 Compliance Schedule for Non-AO Spark-Ignited Engines Subject to Table 2 Emission Limits, and SOx Control and Monitoring Requirements			
Engines to be in Compliance at a Stationary Source	Emission Control Plan	Authority to Construct and Inspection and Monitoring Plan	Full Compliance
Operator with at least two engines, but less than 12 engines at a stationary source			
33% or more of the engines subject to Table 2 emission limits as of August 18, 2011	7/1/12	1/1/13	1/1/14
66% or more of the engines subject to Table 2 emission limits as of August 18, 2011	7/1/12	1/1/14	1/1/15
100% of the engines subject to Table 2 emission limits	7/1/12	1/1/15	1/1/16

The engine involved with this project will meet all the requirements of Rule 4702 at the time of initial operation. Therefore, the engine will meet the compliance schedule requirements of Table 5.

Section 8.0 allows that an operator may comply with the NOx emission requirements of Section 5.2 for a group of engines by meeting the requirements below. An operator that is subject to the requirements below shall also comply with all the applicable requirements of Sections 5.0, 6.0, and 7.0. Only engines subject to Section 5.2 are eligible for inclusion in an AECP.

The applicant has not proposed an Alternative Emission Control Plan (AECP). Therefore, this section of the Rule is not applicable to the engines involved with this project.

Therefore, compliance with the requirements of this Rule is expected.

Rule 4801 Sulfur Compounds

Rule 4801 requires that sulfur compound emissions (as SO₂) shall not exceed 0.2% by volume. Using the Ideal gas equation, the sulfur compound emissions are calculated as follows:

$$\text{Volume SO}_2 = (n \times R \times T) + P$$

$$n = \text{moles SO}_2$$

$$T (\text{standard temperature}) = 60^\circ\text{F or } 520^\circ\text{R}$$

$$R (\text{universal gas constant}) = \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot ^\circ\text{R}}$$

Natural Gas Fuel

$$2.85 \frac{\text{lb} - \text{S}}{\text{MMscf} - \text{gas}} \times \frac{1 \text{ scf} - \text{gas}}{1,000 \text{ Btu}} \times \frac{1 \text{ MMBtu}}{8,578 \text{ scf}} \times \frac{1 \text{ lb} - \text{mol}}{64 \text{ lb} - \text{S}} \times \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} - \text{mol} \cdot ^\circ\text{R}} \times \frac{520^\circ\text{R}}{14.7 \text{ psi}} \times 1,000,000 = 1.97 \text{ ppmv}$$

Since the SO_x concentration is ≤ 2,000 ppmv, the engine is expected to comply with Rule 4801.

California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

Greenhouse Gas (GHG) Significance Determination

It is determined that no other agency has or will prepare an environmental review document for the project. Thus the District is the Lead Agency for this project.

Facilities subject to the Cap and Trade regulation are subject to an industry-wide cap on overall GHG emissions. As such, any growth in emissions must be accounted for under that cap such that a corresponding and equivalent reduction in emissions must occur to

allow any increase. Therefore, it is reasonable to conclude that implementation of the Cap and Trade program will and must fully mitigate project-specific GHG emissions.

Regardless of, and independent to, the above significance determination, the District finds that, through compliance with the Cap and Trade regulation, project-specific GHG emissions would be fully mitigated. The District therefore concludes that projects occurring at facilities subject to ARB's Cap and Trade regulation would have a less than significant individual and cumulative impact on global climate change.

Facility S-3317 is subject to the Cap and Trade regulation. The District therefore concludes that the project would have a less than cumulatively significant impact on global climate change.

District CEQA Findings

The District is the Lead Agency for this project because there is no other agency with broader statutory authority over this project. The District performed an Engineering Evaluation (this document) for the proposed project and determined that the activity will occur at an existing facility and the project involves negligible expansion of the existing use. Furthermore, the District determined that the activity will not have a significant effect on the environment. The District finds that the activity is categorically exempt from the provisions of CEQA pursuant to CEQA Guideline § 15031 (Existing Facilities), and finds that the project is exempt per the general rule that CEQA applies only to projects which have the potential for causing a significant effect on the environment (CEQA Guidelines §15061(b)(3)).

IX. Recommendation

Compliance with all applicable rules and regulations is expected. Pending a successful NSR Public Noticing period, issue ATC S-3317-7-0 subject to the permit conditions on the attached draft ATC in **Appendix E**.

X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
S-3317-7-0	3020-10 F	2063 bhp	\$749

APPENDIX A
Quarterly Net Emissions Change (QNEC)

Quarterly Net Emissions Change (QNEC)

The Quarterly Net Emissions Change is used to complete the emission profile screen for the District's PAS database. The QNEC shall be calculated as follows:

$QNEC = PE2 - PE1$, where:

QNEC = Quarterly Net Emissions Change for each emissions unit, lb/qtr.

PE2 = Post Project Potential to Emit for each emissions unit, lb/qtr.

PE1 = Pre-Project Potential to Emit for each emissions unit, lb/qtr.

Using the values in Sections VII.C.2 and VII.C.6 in the evaluation above, quarterly PE2 and quarterly PE1 can be calculated as follows:

$$PE2_{\text{quarterly}} = PE2_{\text{annual}} \div 4 \text{ quarters/year}$$

$$PE1_{\text{quarterly}} = PE1_{\text{annual}} \div 4 \text{ quarters/year}$$

Quarterly NEC [QNEC]					
	PE2 (lb/yr)	PE2 (lb/qtr)	PE1 (lb/yr)	PE1 (lb/qtr)	QNEC (lb/qtr)
NO _x	3187	797	0	0	797
SO _x	375	94	0	0	94
PM ₁₀	797	199	0	0	199
CO	23,905	5,976	0	0	5,976
VOC	5,976	1,494	0	0	1,494

APPENDIX B

BACT Analysis

Best Available Control Technology (BACT) Guideline 3.3.12
Last Update: 10/1/2002

Fossil Fuel Fired IC Engine > 50 hp**

Pollutant	Achieved in Practice or in the SIP	Technologically Feasible	Alternate Basic Equipment
CO	56 ppmvd @ 15% O ₂ , 0.6 g/bhp-hr, or 1.9 lb/MW-hr		
NO _x	9 ppmvd @ 15% O ₂ , 0.15 g/bhp-hr, or 0.5 lb/MW/hr	5 ppmv @ 15% O ₂ (Selective Catalytic Reduction, or equal)	2 ppmv natural gas fired turbine
PM ₁₀	0.02 g/bhp-hr, or 0.06 lb/MW-hr		
SO _x	PUC quality natural gas, or equal.		
VOC	25 ppmvd @15% O ₂ , 0.15 g/bhp-hr, or 0.5 lb/MW-hr		

*** For the purposes of this determination, fossil fuels includes diesel, gasoline, natural gas, propane, kerosene, and similar hydrocarbon compounds derived from petroleum oil or natural gas. Fossil fuels also include similar synthetic fuels such as biodiesel and/or any fuel containing one or more fossil fuels.*

BACT is the most stringent control technique for the emissions unit and class of source. Control techniques that are not achieved in practice or contained in a state implementation plan must be cost effective as well as feasible. Economic analysis to demonstrate cost effectiveness is required for all determinations that are not achieved in practice or contained in an EPA approved State Implementation Plan.

This is a Summary Page for this Class of Source. For background information, see Permit Specific BACT Determinations on Details Page.

Top-Down BACT Analysis for S-3317-7-0

1. NO_x

Step 1 – Identify all control technologies

The following control technologies and alternative equipment options have been identified for fossil fuel-fired IC engines.

- 1) NO_x emissions 9 ppmvd @ 15% O₂, 0.15 g/bhp-hr, or 0.5 lb/MW-hr (Achieved in Practice)
- 2) NO_x emissions 5 ppmvd @ 15% O₂ (Selective Catalytic Reduction, or equal) (Technologically Feasible)
- 3) Turbine (2 ppmv, natural gas fuel) (Alternate Basic Equipment)

Step 2 - Eliminate Technologically Infeasible Options

None of the above listed technologies are technologically infeasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

Rank	Control Technology	Achieved in Practice
1	Turbine (2 ppmv, natural gas fuel)	N
2	NO _x emissions 5 ppmvd @ 15% O ₂ (Selective Catalytic Reduction, or equal)	N
3	NO _x emissions 9 ppmvd @ 15% O ₂ , 0.15 g/bhp-hr, or 0.5 lb/MW-hr	Y

There are no remaining control technologies for NO_x.

Step 4 - Cost Effectiveness Analysis

Pursuant to policy APR 1305 the cost effectiveness of alternate basic equipment or process is calculated as follows:

$$CE_{alt} = (COST_{alt} - COST_{basic}) / (EMISSION_{basic} - EMISSION_{alt}) \quad \text{where,}$$

CE_{alt} = the cost effectiveness of alternate basic equipment expressed as dollars per ton of emissions reduced

$COST_{alt}$ = the equivalent annual capital cost of the alternate basic equipment plus its annual operating cost

$COST_{basic}$ = the equivalent annual capital cost of the proposed basic equipment, without BACT, plus its annual operating cost

$EMISSION_{basic}$ = the emissions from the proposed basic equipment, without BACT.

$EMISSION_{alt}$ = the emissions from the alternate basic equipment

Option 1: Turbine (2 ppmv, natural gas fuel) (Alternate Basic Equipment)

The following cost analysis demonstrates that replacement of the proposed engine with a turbine is not cost effective when considering the capital costs.

Capital Costs

COST_{basic}

The total capital cost of a Waukesha P9390GSI 2063 hp IC engine with NSCR is **\$773,800**

COST_{alt}

Per Solar Turbines Inc., the estimated total capital cost for a similar sized turbine with SCR is **\$2,750,000**.

Annualized Capital Cost

Pursuant to District Policy APR 1305, section X (11/09/99), the capital cost for the purchase of the equipment will be spread over the expected life of the system using the capital recovery equation. The expected life of the equipment will be estimated at 10 years. A 10% interest rate is assumed in the equation and the assumption will be made that the equipment has no salvage value at the end of the ten-year cycle.

$$A = [P \times i(1+i)^n] / [(1+i)^n - 1]$$

Where: A = Annual Cost
P = Present Value
i = Interest Rate (10%)
N = Equipment Life (10 years)

$$A = P [0.1(1.1)^{10}] / [(1.1)^{10} - 1] = P \times 0.163$$

	2063 hb IC Engine with NSCR (COST _{basic})	Similar Sized Turbine With SCR (COST _{alt})	COST _{alt} - COST _{basic}
Capital Cost	\$773,800	\$2,750,000	
Annualized Cost	\$773,800 x 0.163 = \$126,129	\$2,750,000 x 0.163 = \$448,250	\$322,121

Emission Reductions

Pursuant to the District's Revised BACT Cost Effectiveness Thresholds Memo (5/14/08), District Standard Emissions that will be used to compare with the alternative equipment will be based on the emission limits for rich burn non-agricultural IC engines contained in District Rule 4702, Section 5.2, Table 2, 1.d. The following emissions factors will be used for the cost analysis:

District Standard Emissions = 0.132 g-NO_x/bhp-hr (11 ppmv @ 15% O₂ and 35% engine efficiency)

Emissions from Turbine as Alternative Equipment = 0.024 g-NO_x/bhp-hr (2 ppmv @ 15% O₂ and 35% engine efficiency)

NO_x Emission Reductions = 2063 bhp x 8,760 hours/year x (0.132 g-NO_x/bhp-hr – 0.024 g-NO_x/bhp-hr) x lb/453.6 g
= 4303 lb-NO_x/year (2.15 ton/year)

Cost Effectiveness

$CE_{alt} = (COST_{alt} - COST_{basic}) / (EMISSION_{basic} - EMISSION_{alt})$

= (\$448,250 - \$126,129)/2.15 ton = \$149,823/ton-NO_x

As shown above, the cost of NO_x reduction by installation of a turbine would be greater than the \$24,500/ton cost effectiveness threshold for NO_x in the District BACT policy, based only on the incremental capital cost of the turbine. Therefore this option is not cost-effective and is being removed from consideration.

Option 2: NO_x emissions 5 ppmvd @ 15% O₂ (Selective Catalytic Reduction, or equal) (Technologically Feasible)

The applicant has proposed this option; therefore a cost analysis is not required.

Step 5 - Select BACT

Pursuant to the above Top-Down BACT Analysis, BACT for the natural gas-fired engine must be satisfied with the following:

NO_x: NO_x emissions 5 ppmvd @ 15% O₂ (Technologically Feasible)

Therefore, the BACT NO_x requirements are satisfied.

2. VOC

Step 1 – Identify all control technologies

The following control technology has been identified for fossil fuel-fired IC engines.

- 1) VOC emissions 25 ppmvd @ 15% O₂, 0.15 g/bhp-hr, or 0.5 lb/MW-hr (Achieved in Practice)

Step 2 - Eliminate Technologically Infeasible Options

All of the options listed above are considered to be feasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

Rank	Control Technology	Achieved in Practice
1	VOC emissions 25 ppmvd @ 15% O ₂ , 0.15 g/bhp-hr, or 0.5 lb/MW-hr	Y

There are no remaining control technologies for VOC.

Step 4 - Cost Effectiveness Analysis

Option 1: VOC Emissions 25 ppmvd @ 15% O₂, 0.15 g/bhp-hr, or 0.5 lb/MW-hr (Achieved in Practice)

This option listed above has been identified as achieved in practice for VOC emissions. Therefore, a cost analysis is not necessary.

Step 5 - Select BACT

Pursuant to the above Top-Down BACT Analysis, BACT for the natural gas-fired engine must be satisfied with the following:

VOC: VOC emissions 25 ppmvd @ 15% O₂, 0.15 g/bhp-hr (Achieved in Practice)

The applicant has proposed a VOC emission limit of 0.15 g/bhp-hr. Therefore, the BACT requirements are satisfied.

3. PM10

Step 1 - Identify All Control Technologies

0.02 g/bhp-hr, or 0.06 lb/MW-hr. - Achieved-in-Practice

Step 2 - Eliminate Technologically Infeasible Options

There are no technologically infeasible options.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

0.02 g/bhp-hr, or 0.06 lb/MW-hr. - Achieved-in-Practice

Step 4 - Cost Effectiveness Analysis

There are no technologically feasible or alternate basic equipment requirements. Therefore a cost effectiveness analysis is not required.

Step 5 - Select BACT:

0.02 g/bhp-hr, or 0.06 lb/MW-hr. - Achieved-In-Practice

Therefore, the BACT PM10 requirement is satisfied.

4. CO

Step 1 - Identify All Control Technologies

56 ppmvd @ 15% O₂, 0.6 g/bhp-hr, or 1.9 lb/MW-hr. - Achieved-in-Practice

Step 2 - Eliminate Technologically Infeasible Options

There are no technologically infeasible options.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

56 ppmvd @ 15% O₂, 0.6 g/bhp-hr, or 1.9 lb/MW-hr. - Achieved-in-Practice

Step 4 - Cost Effectiveness Analysis

There are no technologically feasible or alternate basic equipment requirements. Therefore a cost effectiveness analysis is not required.

Step 5 - Select BACT:

56 ppmvd @ 15% O₂, 0.6 g/bhp-hr, or 1.9 lb/MW-hr. - Achieved-in-Practice

Therefore, the BACT CO requirement is satisfied.

APPENDIX C

AAQA and HRA

San Joaquin Valley Air Pollution Control District

Risk Management Review

To: David Torii - Permit Services
From: Cheryl Lawler - Permit Services
Date: February 6, 2014
Facility Name: Chevron USA Inc.
Location: Lost Hills Gas Compression Facility, Lost Hills
Application #(s): S-3317-7-0
Project #: S-1134520

A. RMR SUMMARY

RMR Summary			
Categories	Natural Gas ICE (Unit 7-0)	Project Totals	Facility Totals
Prioritization Score	0.02	0.02	0.02
Acute Hazard Index	N/A	N/A	N/A
Chronic Hazard Index	N/A	N/A	N/A
Maximum Individual Cancer Risk	N/A	N/A	N/A
T-BACT Required?	No		
Special Permit Conditions?	Yes		

Proposed Permit Conditions

To ensure that human health risks will not exceed District allowable levels; the following permit conditions must be included for:

Unit 7-0

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
N

III. *Conclusions*

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

The prioritization score for the project is not above 1.0. In accordance with the District's Risk Management Policy, the project is approved **without** Toxic Best Available Control Technology (T-BACT).

To ensure that human health risks will not exceed District allowable levels; the permit conditions listed on Page 1 of this report must be included for this proposed project.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

Attachments

RMR Request Form & Attachments
Natural Gas ICE Emissions Speciation Worksheet
Prioritization
AAQA Results
Facility Summary

APPENDIX D

Compliance Certification



Donald Puckett
General Manager
Operations

San Joaquin Valley
Business Unit
Chevron North America
Exploration & Production
Company
PO Box 1392
Bakersfield, CA 93302

October 9, 2013

Mr. Seyed Sadredin
San Joaquin Valley Air Pollution Control District
34946 Flyover Court
Bakersfield, CA 93308

RE: Statewide Compliance Certification

Dear Mr. Sadredin:

As required under District Rule 2201, Subsection 4.15.2 and Section 173(a)(3) of the Clean Air Act, 42 U.S.C. Section 7503, Chevron U.S.A. Inc. hereby submits this letter of certification regarding statewide compliance as of this date.

Based on reasonable inquiry and to the best of my knowledge and belief, the major stationary sources, as defined in the jurisdiction where the facilities are located, that are owned or operated by Chevron U.S.A. Inc. in the State of California as listed below are subject to emission limitations and are in compliance or on a schedule for compliance with all applicable emission limitations and standards under the Clean Air Act:

-
- El Segundo Refinery
 - Richmond Refinery
 - Banta Marketing Terminal
 - Huntington Beach Marketing Terminal
 - Montebello Marketing Terminal
 - Sacramento Marketing Terminal
 - Van Nuys Marketing Terminal
 - Cross Valley Carneras Gas Compressor Facility in Kern County
 - Kettleman City Pump Station in Kings County
 - 27G Pump Station in Kern County

 - San Joaquin Valley Business Unit:
 - Fresno County Heavy Oil Source (Coalinga)
 - Fresno County Natural Gas Source (Coalinga)
 - Kern County Central Heavy Oil Source (Kern River)
 - Kern County Western Heavy Oil Source (Midway Sunset & Cymric)
 - Kern County Western Light Oil Source (Midway Sunset, Cymric & Lost Hills)
 - Kern County Western Gas Source (Cymric & Lost Hills)
 - San Ardo (Monterey County)

APPENDIX E

Draft ATC

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT

PERMIT NO: S-3317-7-0

LEGAL OWNER OR OPERATOR: CHEVRON U S A INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

LOCATION: WEST OF LOST HILLS GAS PLANT
LOST HILLS, CA

SECTION: 15 **TOWNSHIP:** 27S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

2063 BHP WAUKESHA MODEL P9390GSI (OR EQUIVALENT) NATURAL GAS-FIRED IC ENGINE WITH NON-SELECTIVE CATALYTIC REDUCTION POWERING A GAS COMPRESSOR SERVING NATURAL GAS DISTRIBUTION SYSTEM

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 1195 lb, 2nd quarter - 1195 lb, 3rd quarter - 1195 lb, and fourth quarter - 1195 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. ERC Certificate Number S-4006-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyad Sadradin, Executive Director APCO

DAVID WARNER, Director of Permit Services

S-3317-7-0; Feb 18 2014 7:17AM - TORUS : Joint Inspection NOT Required

Southern Regional Office • 34946 Flyover Court • Bakersfield, CA 93308 • (661) 392-5500 • Fax (661) 392-5585

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 2241 lb, 2nd quarter - 2241 lb, 3rd quarter - 2241 lb, and fourth quarter - 2241 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. ERC Certificate Number S-3400-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Notification of the date construction of this engine commenced shall be submitted to the District and EPA and shall be postmarked no later than 30 days after such date as construction commenced. The notification shall contain the following information: 1) Name and address of the owner or operator; 2) The address of the affected source; 3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement; 4) Emission control equipment; and 5) Fuel used. [CFR 60, Subpart JJJJ] Federally Enforceable Through Title V Permit
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
9. This engine shall be operated and maintained in proper operating condition according to the manufacturer's specifications. [District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
10. This unit shall be fired only on PUC quality natural gas with a total sulfur content not exceeding 1.0 grains/100 dscf. [District Rule 2201] Federally Enforceable Through Title V Permit
11. If the engine is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
12. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM method D 1072, D 3031, D 4084, D 3246 or double GC for H₂S and mercaptans. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
13. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. If more than one engine utilizes the same fuel source, one representative sample can be taken from the shared fuel source. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
14. Air-to-fuel ratio controller(s) shall be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times. [District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
15. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
16. Emissions from the IC engine, shall not exceed any of the following limits: 5 ppmvd NO_x at 15% O₂, 0.0094 g-SO_x/bhp-hr, 0.02 g-PM₁₀/bhp-hr, 56 ppmvd CO @ 15% O₂ or 25 ppmvd VOC at 15% O₂. [District Rules 2201 and 4702, and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
17. Source testing to measure NO_x, CO and VOC emissions from this unit shall be conducted within 60 days of initial start-up and thereafter once every 24 months. [District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
18. For initial emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NO_x, CO and VOC concentrations shall be reported in ppmvd corrected to 15% oxygen. [District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. This engine shall be equipped with an operational nonresettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
20. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Monitoring (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit
22. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
25. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
27. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
28. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
29. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

30. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
31. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule District Rule 4702 and 40 CFR 60 Subpart JJJJ] Federally Enforceable Through Title V Permit
32. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit

DRAFT