



MAY 28 2014

Mr. Daniel Dunlap
San Joaquin Cogen, LLC
2575 Park Ln, Suite #200
Lafayette, CO 80026-3200

**Re: Notice of Preliminary Decision – Title V Permit Renewal
District Facility # N-1027
Project # N-1133668**


Dear Mr. Dunlap:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for San Joaquin Cogen, LLC at 17200 Murphy Parkway, Lathrop, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Rupi Gill, Permit Services Manager, at (209) 557-6400.

Sincerely,



Arnaud Marjollet
Director of Permit Services

AM:JK/st

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Proposed Title V Permit Renewal Evaluation
San Joaquin Cogen, LLC
N-1027**

TABLE OF CONTENTS

I.	PROPOSAL	1
II.	FACILITY LOCATION	1
III.	EQUIPMENT LISTING.....	2
IV.	GENERAL PERMIT TEMPLATE USAGE	2
V.	SCOPE OF EPA AND PUBLIC REVIEW	2
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS	2
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	5
VIII.	PERMIT REQUIREMENTS	6
IX.	PERMIT SHIELD.....	23
X.	PERMIT CONDITIONS	23
XI.	ATTACHMENTS	24
	A. DRAFT RENEWED TITLE V OPERATING PERMIT	
	B. PREVIOUS TITLE V OPERATING PERMIT	
	C. DETAILED FACILITY LIST	

TITLE V PERMIT RENEWAL EVALUATION

Power Generation Facility

Engineer: Jagmeet Kahlon

Date: April 9, 2014

Facility Number: N-1027
Facility Name: San Joaquin Cogen, LLC
Mailing Address: 2575 Park Ln, Suite #200
Lafayette, CO 80026-3200

Contact Name: Daniel Dunlap
Title: Senior Director, Regulatory Affairs
Phone: (303) 607-5600

Responsible Official: Richard Olsen
Title: Vice President, Operations

Project # : N-1133668
Deemed Complete: December 11, 2013

I. PROPOSAL

San Joaquin Cogen, LLC is requesting a renewal of their Title V permit which is going to expire on July 31, 2014. The previous Title V renewal was finalized on June 22, 2010, and included permits N-1027-1-7 and -2-2. These permits will be reviewed and modified to include up-to-date requirements from all applicable District and Federal rules since the previous Title V renewal.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

The facility is located at 17200 Murphy Parkway, Lathrop, California.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant does not propose to use any model general permit templates.

V. SCOPE OF EPA AND PUBLIC REVIEW

The applicant is not requesting the use of any model general permit templates. Therefore, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions
(amended August 18, 2011)
- District Rule 2201, New and Modified Stationary Source Review Rule
(amended April 21, 2011)
- District Rule 4702, Internal Combustion Engines
(amended November 14, 2013)
- 40 CFR Part 60 Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
(amended January 30, 2013)
- 40 CFR Part 63 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
(amended March 6, 2013)
- 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners
(amended June 25, 2013)
- 40 CFR Part 82, Subpart F, Recycling and Emissions Reduction
(amended June 25, 2013)

- 40 CFR Part 64, Compliance Assurance Monitoring (CAM)

B. Rules Removed

There are no applicable rules that were removed since the last Title V renewal in June 2010.

C. Rules Added

None

D. Rules Not Updated

- District Rule 1080, Stack Monitoring
(Amended December 17, 1992)
- District Rule 1081, Source Sampling
(Amended December 16, 1993)
- District Rule 1100, Equipment Breakdown
(Amended December 17, 1992)
- District Rule 2010, Permits Required
(Amended December 17, 1992)
- District Rule 2031, Transfer of Permits
(Amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications
(Amended December 17, 1992)
- District Rule 2080, Conditional Approval
(Amended December 17, 1992)
- District Rule 2540, Acid Rain Program
(Adopted November 13, 1997)
- District Rule 2520, Federally Mandated Operating Permits
(Amended June 21, 2001)
- District Rule 4201, Particulate Matter Concentration
(Amended December 17, 1992)

- District Rule 4202, Particulate Matter - Emission Rate
(Amended December 17, 1992)
- District Rule 4301, Fuel Burning Equipment
(Amended December 17, 1992)
- District Rule 4701, Internal Combustion Engines – Phase 1
(Amended August 21, 2003)
- District Rule 4703, Stationary Gas Turbines
(Amended September 20, 2007)
- District Rule 4801, Sulfur Compounds
(Amended December 17, 1992)
- District Rule 7012, Hexavalent Chromium – Cooling Towers
(Amended December 17, 1992)
- District Rule 8011, General Requirements
(Amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction and Other Earthmoving Activities
(Amended August 19, 2004)
- District Rule 8031, Bulk Materials
(Amended August 19, 2004)
- District Rule 8041, Carryout and Trackout
(Amended August 19, 2004)
- District Rule 8051, Open Areas
(Amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads
(Amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas
(Amended August 19, 2004)
- 40 CFR Part 60 Subpart GG, Standards of Performance for Stationary Gas Turbines
(Amended February 24, 2006)

- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos
(Amended July 20, 2004)
- 40 CFR Part 63, Subpart YYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines
(Amended April 20, 2006)
- 40 CFR Part 68, Chemical Accident Prevention Provisions
(Amended April 9, 2004)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added

None

B. Rules Not Updated

- District Rule 1070, Inspections
(amended December 17, 1992)
- District Rule 1100, Equipment Breakdown
(amended December 17, 1992)
- District Rule 1160, Emission Statements
(adopted November 18, 1992)
- District Rule 2040, Applications
(amended December 17, 1992)
- District Rule 4102, Nuisance
(amended December 17, 1992)

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the previous Title V actions.

A. Rules Updated

District Rule 2020, Exemptions

District Rule 2020 lists source categories that may be exempt from obtaining permits, and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any effect on current permit requirements and will therefore not be addressed in this evaluation. Condition 4 of permit N-1027-0-3 will ensure on-going compliance with this rule.

District Rule 2201, New and Modified Stationary Source Review Rule

District Rule 2201 was amended on April 21, 2011, after this facility's Title V permit was last renewed. This Title V permit renewal does not constitute a modification per section 3.25, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

District Rule 4702, Internal Combustion Engines

Section 2.0 - Applicability

This rule applies to any internal combustion engine rated at 25 brake horsepower or greater. The engine under permit N-1027-2 is rated at 185 bhp; therefore, this rule is applicable to this engine.

Section 4.0 – Exemptions

Pursuant to Section 4.3, except for the requirements of Section 6.2.3, the requirements of this rule shall not apply to an internal combustion engine that meets the following conditions:

- The engine is operated exclusively to preserve or protect property, human life, or public health during a disaster or state of emergency, such as a fire or flood; and
- Except for operations (stated above), the engine is limited to operate no more than 100 hours per calendar year as determined by an operational non-resettable elapsed time meter, for periodic maintenance, periodic readiness testing, and readiness testing during and after repair work of the engine; and
- The engine is operated with an operational non-resettable elapsed time meter. In lieu of installing a non-resettable elapsed time meter, the operator of an engine may use an alternative device, method, or technique, in determining operating time provided that the alternative is approved by the APCO and EPA. The operator of the engine shall properly maintain and operate the non-resettable elapsed time meter or alternative device in accordance with the manufacturer's instructions.

The engine under permit N-1027-2 powers a direct-drive firewater pump assembly (as mentioned in the equipment description). Furthermore, the engine operation is limited to 100 hours per calendar year for all maintenance, testing and required regulatory purpose. The engine operation is required to be recorded using a non-resettable elapsed time meter or other APCO approved alternative. Thus, the requirements in this rule (with an exception of requirements in 6.2.3) do not apply to this engine.

The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours

necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115]

- This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ]

Section 6.2 – Recordkeeping

Section 6.2.3 requires that an owner claiming an exemption under Section 4.2 or Section 4.3 shall maintain annual operating records. This information shall be retained for at least five years, shall be readily available, and provided to the APCO upon request. The records shall include, but are not limited to, the following:

- Total hours of operation,
- The type of fuel used,
- The purpose for operating the engine,
- For emergency standby engines, all hours of non-emergency and emergency operation shall be reported, and
- Other support documentation necessary to demonstrate claim to the exemption.

The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- The permittee shall maintain monthly records of hours of emergency and non-emergency operation. Records shall include the date, the number of hours of operation, and the purpose of the operation (e.g., load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702, and 17 CCR 93115]
- The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 4702 and 17 CCR 93115]

Compliance is expected with this Rule.

40 CFR Part 60 Subpart III, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

§ 60.4200 Am I subject to this subpart?

- (a) The provisions of this subpart are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in paragraphs (a)(1) through (4) of this section. For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator.
- (1) Manufacturers of stationary CI ICE with a displacement of less than 30 liters per cylinder where the model year is:
- (i) 2007 or later, for engines that are not fire pump engines;
 - (ii) The model year listed in Table 3 to this subpart or later model year, for fire pump engines (i.e., starting 2009 year model for $175 \leq \text{HP} \leq 750$).
- (2) Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are:
- (i) Manufactured after April 1, 2006, and are not fire pump engines, or
 - (ii) Manufactured as a certified National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.
- (3) Owners and operators of any stationary CI ICE that are modified or reconstructed after July 11, 2005 and any person that modifies or reconstructs any stationary CI ICE after July 11, 2005.
- (4) The provisions of §60.4208 of this subpart are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005.

Based on the records in District's permit database, the 185 bhp fire pump engine under permit N-1027-2 was constructed sometime between July 1991 and December 1991. Furthermore, the unit was never modified or reconstructed after the installation. Therefore, this unit is not subject to the requirements of this subpart.

40 CFR Part 63 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

§ 63.6585 Am I subject to this subpart?

This subpart applies to owners and operators of stationary reciprocating internal combustion engines (RICE) operated at a major or area source of Hazardous Air Pollutant (HAP) emissions.

Section (b) states a major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site.

Section (c) states an area source of HAP emissions is a source that is not a major source.

The facility's potential combined HAP emissions are 2.4 tons/year. This potential is below the major source of HAP emissions; therefore, this facility is an area source for HAP emissions.

§ 63.6590 What parts of my plant does this subpart cover?

This subpart applies to each affected source.

(a) *Affected source.* An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

(1) *Existing stationary RICE*

(i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.

(ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

(2) *New stationary RICE*

- (i) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after December 19, 2002.
- (ii) A stationary RICE with a site rating of equal to or less than 500 brake HP located at a major source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.
- (iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

The engine under permit N-1027-2 is an existing stationary RICE since it is located at an area source of HAP emissions and has commenced construction before June 12, 2006.

Section (c) Stationary RICE subject to Regulations under 40 CFR Part 60

An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.

- (1) A new or reconstructed stationary RICE located at an area source;
- (2) A new or reconstructed 2SLB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (3) A new or reconstructed 4SLB stationary RICE with a site rating of less than 250 brake HP located at a major source of HAP emissions;

- (4) A new or reconstructed spark ignition 4 stroke rich burn (4SRB) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (5) A new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis;
- (6) A new or reconstructed emergency or limited use stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions;
- (7) A new or reconstructed compression ignition (CI) stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.

The engine under permit N-1027-2 is an existing RICE located at an area source and is not subject to requirements in 40 CFR part 60 subpart IIII (discussed previously). Therefore, further evaluation is required to determine the applicable requirements under this subpart.

§63.6603 What emission limitations, operating limitations, and other requirements must I meet if I own or operate an existing stationary RICE located at an area source of HAP emissions?

This section states that compliance with the numerical emission limitations established in this subpart is based on the results of testing the average of three 1-hour runs using the testing requirements and procedures in §63.6620 and Table 4 to this subpart.

Section (a) states if you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart and the operating limitations in Table 2b to this subpart that apply to you.

The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with the requirements in Table 2d. Note that this engine is not subject to any operating limitations in Table 2b.

- The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR Part 63 Subpart ZZZZ]

- The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [40 CFR Part 63 Subpart ZZZZ]
- The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ]
- The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ]

§63.6604 What fuel requirements must I meet if I own or operate a stationary CI RICE?

Section (b) states that beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in §63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in §63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.

The engine under permit N-1027-2 is required to use CARB certified diesel containing no more than 15 ppmv sulfur by weight. Further, the CARB diesel fuel specification requires no more than 10 v% of aromatic hydrocarbon content (<http://www.arb.ca.gov/enf/fuels/dieselspecs.pdf>). The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [San Joaquin County Rule 407, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ]

§63.6612 By what date must I conduct the initial performance tests or other initial compliance demonstrations if I own or operate an existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing stationary RICE located at an area source of HAP emissions?

For the engine under permit N-1027-2, there are no applicable emissions limitations to comply from this subpart. As such, no initial performance tests are required.

§63.6625 What are my monitoring, installation, collection, operation, and maintenance requirements?

Section (e)(3) states that if you own or operate an existing emergency or black start stationary RICE located at an area source of HAP emissions, you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ]

Section (f) states that if you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency

stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.

The engine under permit N-1027-2 is already equipped with the non-resettable hour meter. The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ]

Section (h) states if you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to this subpart apply. The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ]

§63.6630 How do I demonstrate initial compliance with the emission limitations, operating limitations, and other requirements?

Section (a) states that you must demonstrate initial compliance with each emission limitation, operating limitation, and other requirement that applies to you according to Table 5 of this subpart.

Section (b) states during the initial performance test, you must establish each operating limitation in Tables 1b and 2b of this subpart that applies to you.

Section (c) states that you must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in §63.6645.

The engine under permit N-1027-2 is not subject to the items in Tables 1b, 2b and 5 of this subpart. Therefore, no further discussion is required.

§63.6640 How do I demonstrate continuous compliance with the emission limitations, operating limitations, and other requirements?

(a) You must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you according to methods specified in Table 6 to this subpart.

(b) You must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to this subpart that apply to you. These instances are deviations from the emission and operating limitations in this subpart. These deviations must be reported according to the requirements in §63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

(e) You must also report each instance in which you did not meet the requirements in Table 8 to this subpart that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to this subpart, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.

The engine under permit N-1027-2 is not subject to emissions or operating limitations in this subpart. Therefore, no further discussion is required.

§63.6645 What notifications must I submit and when?

(a) You must submit all of the notifications in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following:

- (1) An existing stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions.
- (2) An existing stationary RICE located at an area source of HAP emissions.
- (3) A stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.
- (4) A new or reconstructed 4SLB stationary RICE with a site rating of greater than or equal to 250 HP located at a major source of HAP emissions.
- (5) This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.

§§63.7(b) and (c) covers notification of performance test and quality assurance program, 63.8(e) covers performance evaluation of continuous monitoring systems, (f)(4) covers the use of alternative monitoring procedures and (f)(6) covers alternative to the relative accuracy test, 63.9(b) through (e) covers initial notifications when a source becomes subject to a relevant standard (i.e., The notification, which shall be submitted not later than 120 calendar days after the effective date of the relevant standard or within 120 calendar days after the source becomes subject to the relevant standard), 63.9 (g) covers additional notification requirements for sources with continuous monitoring systems, and 63.9(h) covers notification of compliance status.

The engine under permit N-1027-2 is not subject to emissions or operating limitations in this subpart. However, it is subject to the other management practices in this subpart.

§63.6650 What reports must I submit and when?

- (a) You must submit each report in Table 7 of this subpart that applies to you.
- (b) Unless the Administrator has approved a different schedule for submission of reports under §63.10(a), you must submit each report by the date in Table 7 of this subpart and according to the requirements in paragraphs (b)(1) through (b)(9) of this section.

- (c) The Compliance report must contain the information in paragraphs (c)(1) through (6) of this section.
- (d) For each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in this subpart, the Compliance report must contain the information in paragraphs (c)(1) through (4) of this section and the information in paragraphs (d)(1) and (2) of this section.
- (e) For each deviation from an emission or operating limitation occurring for a stationary RICE where you are using a CMS to comply with the emission and operating limitations in this subpart, you must include information in paragraphs (c)(1) through (4) and (e)(1) through (12) of this section.
- (f) Each affected source that has obtained a title V operating permit pursuant to 40 CFR part 70 or 71 must report all deviations as defined in this subpart in the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of this subpart along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in this subpart, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority.
- (g) If you are operating as a new or reconstructed stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, you must submit an annual report according to Table 7 of this subpart by the date specified unless the Administrator has approved a different schedule, according to the information described in paragraphs (b)(1) through (b)(5) of this section. You must report the data specified in (g)(1) through (g)(3) of this section.
- (h) If you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in §63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in §63.6640(f)(4)(ii), you must submit an annual report according to the requirements in paragraphs (h)(1) through (3) of this section.

The engine under permit N-1027-2 does not fit in any category in Table 7. Additionally, the unit is not subject to emissions or operating limitations in this subpart.

§63.6655 What records must I keep?

Section (e) states that you must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE:

- (1) An existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions.
- (2) An existing stationary emergency RICE.
- (3) An existing stationary RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to this subpart.

The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ]

§63.6660 In what form and how long must I keep my records?

- (a) Your records must be in a form suitable and readily available for expeditious review according to §63.10(b)(1).
- (b) As specified in §63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.
- (c) You must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to §63.10(b)(1).

The following condition(s) in draft permit N-1027-2-3 enforce on-going compliance with this section:

- All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 4701 and 4702, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ]

Compliance is expected with this subpart.

40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners

There are applicable requirements from Title VI of the CAA (Stratospheric Ozone) that apply to all sources. These requirements pertain to air conditioners, chillers and refrigerators located at a Title V source and to disposal of air conditioners or maintenance/recharging/disposal of motor vehicle air conditioners (MVAC). These requirements are addressed in condition 28 of draft Title V permit N-1027-0-3.

40 CFR Part 82, Subpart F, Recycling and Emissions Reduction

There are applicable requirements from Title VI of the CAA (Stratospheric Ozone) that apply to all sources. These requirements pertain to air conditioners, chillers and refrigerators located at a Title V source and to disposal of air conditioners or maintenance/recharging/disposal of motor vehicle air conditioners (MVAC). These requirements are addressed in condition 27 of the draft Title V permit N-1027-0-3.

40 CFR Part 64, Compliance Assurance Monitoring (CAM)

40 CFR Part 64 requires CAM for units that meet the following three criteria:

1. Unit must have an emission limit for the pollutant;
2. Unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), SCR system, baghouses, and thermal/catalytic oxidizers; and
3. Unit must have a pre-control potential to emit of greater than the major source thresholds.

N-1027-1: GENERAL ELECTRIC LM5000 NATURAL GAS FIRED GAS
TURBINE ENGINE WITH STEAM INJECTION, AMMONIA INJECTION,
SELECTIVE CATALYTIC REDUCTION, AND AN OXIDATION CATALYST
SERVING A 48.6 MW COGENERATION PLANT

NO_x, CO:

This unit is equipped with CEMS to monitor NO_x and CO emissions. Therefore, CAM is not required for NO_x and CO emissions.

SO_x, PM₁₀:

The unit does not have add-on control equipment to reduce SO_x or PM₁₀ emissions. Therefore, CAM is not required for these pollutants.

VOC:

The permit limits VOC emissions to 93 pounds per day.

This unit is equipped with an oxidation catalyst, which is primarily designed to reduce CO emissions. However, the catalyst has a secondary effect in reducing the VOC emissions. VOC control efficiency for an oxidation catalyst is about 40%.

The unit's pre-control potential to emit is 56,575 lb-VOC/yr¹, which is above the Major Source threshold of 20,000 lb-VOC/yr.

Therefore, CAM is required for VOC emissions.

Condition #13 of PTO N-1027-1-7 requires that the temperature of the exhaust gas leaving the oxidation catalyst shall be greater than 600°F at all times, except during startup or shutdown. This temperature can be used as a surrogate parameter to ensure the proper operation of the oxidation catalyst. Furthermore, the facility will be required to monitor this parameter during the testing for VOC emissions on an annual basis. The following conditions ensure compliance:

- The selective catalytic reduction (SCR) system shall be installed in the path of the heat recovery boiler where the temperature range is 575 to 750°F. The temperature of the exhaust gas leaving the catalytic oxidation reduction (COR) system shall be greater than 600°F at all times, except during periods of startup or shutdown. [District NSR Rule and 40 CFR Part 64]

¹(93 lb-VOC/day) × (365 days/yr) × (1/(1-0.4)) = 56,575 lb-VOC/yr

- The permittee shall provide a continuous temperature monitoring and recording system to indicate the flue gas temperature through the SCR and COR systems. [District NSR Rule and 40 CFR Part 64]
- The owner or operator shall measure and record flue gas temperature leaving the COR system during each source test while measuring VOC emissions. [40 CFR Part 64]

N-1027-2: 185 HP CATERPILLAR MODEL 3208 NA-210 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIREWATER PUMP

This engine is not equipped with any add-on control equipment. Therefore, this unit is not subject to CAM requirements.

B. Rules Removed

None

C. Rules Added

None

D. Rules Not Updated

- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)

- District Rule 2520, Federally Mandated Operating Permits
(amended June 21, 2001)
- District Rule 4201, Particulate Matter Concentration
(amended December 17, 1992)

These rules are not discussed in this evaluation as these rules are not amended, except as provided below.

District Rule 2520, Federally Mandated Operating Permits

There are no federally applicable GHG requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

By using the model general permit template(s) listed in Section IV of this evaluation, the applicant has requested that a permit shield be issued for requirements addressed in the template(s). The basis for each permit shield is discussed in the Permit Shield section of each template.

B. Requirements not Addressed by Model General Permit Templates

The applicant has not requested a permit shield based on any permit requirements or for any subsumed requirements. Therefore, no further discussion is necessary.

X. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit

XI. ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: N-1027-0-3

EXPIRATION DATE: 07/31/2014

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; San Joaquin County Rule 110] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; San Joaquin County Rule 110] Federally Enforceable Through Title V Permit
3. {2287} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (8/18/11). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {2289} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. {2290} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {2291} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. {2293} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SAN JOAQUIN COGEN, LLC
Location: 17200 MURPHY PARKWAY, LATHROP, CA 95330
N-1027-0-3 Apr 9 2014 9:39AM -- KAHLOJ

10. {2294} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. {2295} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. {2296} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. {2297} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. {2298} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. {2299} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. {2300} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. {2301} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. {2302} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. {2303} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. {2304} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. {2305} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. {2310} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. {2311} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. {2312} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment traffic area that anticipates more than 50 or more Average Annual Daily Trips(AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment traffic area that anticipates 150 vehicle daily trips (VDT), or 150 VDT that are utilized intermittently for a period of 30 days or less during the calendar year shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. {2319} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. {2320} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. {2321} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. {2322} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: San Joaquin County Rule 401 and San Joaquin County Rule 110. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, and 5.8 (12/17/09); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071 (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere that causes a public nuisance. [District Rule 4102]
42. The facility shall comply with all applicable requirements of Rule 4663. [District Rule 4663] Federally Enforceable Through Title V Permit
43. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin December 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1027-1-8

EXPIRATION DATE: 07/31/2014

EQUIPMENT DESCRIPTION:

GENERAL ELECTRIC LM5000 NATURAL GAS FIRED GAS TURBINE ENGINE WITH STEAM INJECTION, AMMONIA INJECTION, SELECTIVE CATALYTIC REDUCTION, AND AN OXIDATION CATALYST SERVING A 48.6 MW COGENERATION PLANT

PERMIT UNIT REQUIREMENTS

1. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8 (c)] Federally Enforceable Through Title V Permit
2. Startup or shutdown periods is the time during which the exhaust gas is not within the normal operating temperature range. The duration of each start-up or each shutdown shall not exceed two hours. [District Rule 4703] Federally Enforceable Through Title V Permit
3. The SCR system shall have an effective catalyst volume of at least 904 cubic feet at all times. [District NSR Rule and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit
4. The gas turbine shall be equipped with an automatic air/fuel ratio control system. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emissions from the gas turbine shall not exceed any of the following limits: 80 lbs-PM10/day, 148 lbs-NOx/day as (NO2), 7 lbs-SOx/day as (SO2), 289 lbs-CO/day and 93 lbs-VOC/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. NOx emission concentrations from the gas turbine exhaust stack shall not exceed 3.8 ppmv dry calculated to 15% O2, except during periods of startup and shutdown as defined in this permit. [District NSR Rule; District Rule 4703, 5.1; and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
7. CO emissions concentrations from the gas turbine exhaust stack shall not exceed 12 ppmv dry calculated to 15% O2, except during periods of startup and shutdown as defined in this permit. [District NSR Rule and District Rule 4703, 5.2] Federally Enforceable Through Title V Permit
8. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Results of the CEM system shall meet all applicable requirements of CFR 60.13. [40 CFR 60.13] Federally Enforceable Through Title V Permit
10. NOx emissions concentrations measured for compliance shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance all applicable requirements of 40 CFR Part 60. CO, PM10, VOC and SOx emissions concentrations measured for compliance shall be averaged over a 15-minute sampling period. [District Rule 1081, 4.0] Federally Enforceable Through Title V Permit
11. The ammonia slip shall not exceed 20 ppmv dry at 15% O2. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13 (h)] Federally Enforceable Through Title V Permit
13. The selective catalytic reduction (SCR) system shall be installed in the path of the heat recovery boiler where the temperature range is 575 to 750°F. The temperature of the exhaust gas leaving the catalytic oxidation reduction (COR) system shall be greater than 600°F at all times, except during periods of startup or shutdown. [District NSR Rule and 40 CFR Part 64] Federally Enforceable Through Title V Permit
14. The owner or operator shall measure and record flue gas temperature leaving the COR system during each source test while measuring VOC emissions. [40 CFR Part 64] Federally Enforceable Through Title V Permit
15. This unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(b) and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
16. The sulfur content of each fuel source shall be documented in a current valid purchase contract, a supplier certification, tariff or transportation contract, or tested daily in accordance with the requirements of 40 CFR 60.334 (h) and (i). [40 CFR 60.334(h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
17. If the sulfur content of the natural gas being fired in the turbine is determined using daily testing, then ASTM D1072, D3246, D4468, or D6667 shall be used to make this determination. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
18. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with U.S. EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The stack height shall be minimum of 50 feet and shall be adequate for stack sampling pursuant to EPA reference methods for source testing. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (amended December 17, 1992). [40 CFR Part 60; District NSR Rule; District Rule 4703; District Rule 1081, 3.0, 5.0, and 6.0] Federally Enforceable Through Title V Permit
19. Source testing for NO_x, CO, VOC and ammonia slip shall be conducted on an annual basis. [District NSR Rule] Federally Enforceable Through Title V Permit
20. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days after testing day. [District Rule 1081] Federally Enforceable Through Title V Permit
21. {2268} The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
22. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with CEMS for NO_x, CO, and O₂. CEMS shall meet the performance specification requirements in 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the U.S. EPA. CEMS data shall be used to determine compliance with emission limits. [District Rule 1080, 4.0 and 5.0; District NSR Rule, District Rule 4703 and 40 CFR 60.13] Federally Enforceable Through Title V Permit
23. A CEMS system shall be used to demonstrate compliance with the NO_x emission limits at 30, 50, 75, and 100% of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. [40 CFR 60.335] Federally Enforceable Through Title V Permit
24. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEMS equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080, 6.0 and 40 CFR Part 60] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. All continuous monitoring and recording instruments shall be installed, calibrated, operated and shall be reported in accordance with the requirements of 40 CFR, Part 51. [District NSR Rule and District Rule 4001] Federally Enforceable Through Title V Permit
26. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
27. {2250} The continuous NOx and O2 monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
28. {2251} The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
29. On days of turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emissions limits with CEMS data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstration shall be maintained and made available for District inspection for a period of five years. [District Rule 1080, 7.1; District NSR Rule; District Rule 2520, 9.3.2, 9.4.2] Federally Enforceable Through Title V Permit
30. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the CEMS shall be in continuous operation while the turbine is operating. NOx emissions in ppmv (corrected to 15% O2) and CO and O2 concentrations must be recorded continuously (except as noted elsewhere) and data shall be reduced to 15-minute averages per 40 CFR Part 60.13 (e)(2). [District NSR Rule, 40 CFR 60.13] Federally Enforceable Through Title V Permit
31. Records shall be maintained and shall contain the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEMS that have been installed pursuant to District Rule 1080; emission measurements; and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 1080, 4.0 and 7.3; District NSR Rule; District Rule 4703; 40 CFR 60.332(a), (b); 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
32. Permittee shall maintain on file copies of natural gas bills. Certification of the sulfur content by the gas supplier on the Fuel Gas Tariff will be an acceptable alternative for verifying compliance with fuel sulfur limit. [40 CFR 60.334 (b); 40 CFR 60.334(h)(3) ; District NSR Rule; District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken, and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. For clarification, operator shall use the same averaging periods as written into the permit for demonstrating compliance. [40 CFR 60.7(c); District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
34. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMS within 96 hours of occurrence. The APCO shall be notified within eight hours after the detection of a breakdown of CEMS monitoring equipment and 24 hours prior to a planned shutdown of monitoring equipment greater than 4 hours in duration. [40 CFR 60.334(c); District Rule 1080, 9.0 and 10.0; District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
35. The permittee shall provide a continuous temperature monitoring and recording system to indicate the flue gas temperature through the SCR and COR systems. [District NSR Rule and 40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. A daily log of the hourly ammonia injection rate and of the pressure drop across the catalyst shall be maintained on the premises at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
37. {1711} The following types of units are not affected units subject to the requirements of the Acid Rain Program: 1) A simple combustion turbine that commenced operation before November 15, 1990, 2) Any unit that, during 1985, did not serve a generator that produced electricity for sale and that did not, as of November 15, 1990, and does not currently, serve a generator that produces electricity for sale, 3) A cogeneration facility which for a unit that commenced construction prior to November 15, 1990, was constructed for the purpose of supplying equal to or less than one-third its potential electrical output capacity or equal to or less than 219,000 Mwe-hrs actual electric output on an annual basis to any utility power distribution system for sale. Therefore, the requirements of 40 CFR 72.6 do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. There shall be no visible emissions (except for uncombined water) from the entire system. [District NSR Rule] Federally Enforceable Through Title V Permit
39. The turbine shall be designed and operated at STIG (Trademark GE) conditions in accordance with manufacture's recommended operating procedures. [District NSR Rule, 40 CFR Part 64] Federally Enforceable Through Title V Permit
40. Per the Settlement Agreement entered into as of 06/22/1989, by and between California Attorney General John Van de Kamp and San Joaquin CoGen LLC, San Joaquin CoGen LLC is required to mitigate permitted emissions of PM10 to 0 lb/day & NOx to 85 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
41. Turbine washing operation shall take place only when the turbine is off-line. [District NSR Rule] Federally Enforceable Through Title V Permit
42. VOC emissions from the off-line turbine wash operation shall not exceed 9.8 lb per day. [District NSR Rule] Federally Enforceable Through Title V Permit
43. Records of daily amount of organic solvent used, Material Safety Data Sheet (MSDS) or product data sheet showing the name of the organic solvent, chemical composition, boiling point, and VOC content, mix ratios by volume of components added to the cleaning solvent, shall be maintained, retained on the premises for at least five years and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
44. Compliance with permit conditions in the Title V permit shall be deemed compliance with the 40 CFR 60.332(c), 60.333 (a) and (b); 60.334(b), (b)(1), (b)(2), (b)(3), (h)(1), (i), (j); 60.335(b)(10). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
45. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1027-2-3

EXPIRATION DATE: 07/31/2014

EQUIPMENT DESCRIPTION:

185 BHP CATERPILLAR MODEL 3208 NA-210 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIREWATER PUMP

PERMIT UNIT REQUIREMENTS

1. NOx emissions from the engine shall not exceed 8.0 g/hp-hr, averaged over 15 consecutive minutes. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [San Joaquin County Rule 407, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with San Joaquin County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
11. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: N-1027-0-2

EXPIRATION DATE: 07/31/2014

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; San Joaquin County Rule 110] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; San Joaquin County Rule 110] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SAN JOAQUIN COGEN, LLC
Location: 17200 MURPHY PARKWAY, LATHROP, CA 95330
N-1027-0-2 Apr 8 2014 9:38AM -- KAJ-LONJ

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/04) or Rule 8011 (8/19/04). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment traffic area that anticipates more than 50 or more Average Annual Daily Trips(AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment traffic area that anticipates 150 vehicle daily trips (VDT), or 150 VDT that are utilized intermittently for a period of 30 days or less during the calendar year shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/04) or Rule 8011 (8/19/04). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: San Joaquin County Rule 401 and San Joaquin County Rule 110. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601, sections 5.1, 5.2, 5.3, and 5.8 (12/17/09); 8021 (8/19/04); 8031 (8/19/04); 8041 (8/19/04); 8051 (8/19/04); 8061 (8/19/04); and 8071 (9/16/04). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere that causes a public nuisance. [District Rule 4102]
42. The facility shall comply with all applicable requirements of Rule 4663. [District Rule 4663] Federally Enforceable Through Title V Permit
43. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin December 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1027-1-7

EXPIRATION DATE: 07/31/2014

EQUIPMENT DESCRIPTION:

GENERAL ELECTRIC LM5000 NATURAL GAS FIRED GAS TURBINE ENGINE WITH STEAM INJECTION, AMMONIA INJECTION, SELECTIVE CATALYTIC REDUCTION, AND AN OXIDIZATION CATALYST SERVING A 48.6 MW COGENERATION PLANT

PERMIT UNIT REQUIREMENTS

1. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. [40 CFR 60.8 (c)] Federally Enforceable Through Title V Permit
2. Startup or shutdown periods is the time during which the exhaust gas is not within the normal operating temperature range. The duration of each start-up or each shutdown shall not exceed two hours. [District Rule 4703] Federally Enforceable Through Title V Permit
3. The SCR system shall have an effective catalyst volume of at least 904 cubic feet at all times. [District NSR Rule and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit
4. The gas turbine shall be equipped with an automatic air/fuel ratio control system. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Emissions from the gas turbine shall not exceed any of the following limits: 80 lbs-PM10/day, 148 lbs-NOx/day as (NO2), 7 lbs-SOx/day as (SO2), 289 lbs-CO/day and 93 lbs-VOC/day. [District NSR Rule] Federally Enforceable Through Title V Permit
6. NOx emission concentrations from the gas turbine exhaust stack shall not exceed 3.8 ppmv dry calculated to 15% O2, except during periods of startup and shutdown as defined in this permit. [District NSR Rule; District Rule 4703, 5.1; and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
7. CO emissions concentrations from the gas turbine exhaust stack shall not exceed 12 ppmv dry calculated to 15% O2, except during periods of startup and shutdown as defined in this permit. [District NSR Rule and District Rule 4703, 5.2] Federally Enforceable Through Title V Permit
8. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Results of the CEM system shall meet all applicable requirements of CFR 60.13. [40 CFR 60.13] Federally Enforceable Through Title V Permit
10. NOx emissions concentrations measured for compliance shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance all applicable requirements of 40 CFR Part 60. CO, PM10, VOC and SOx emissions concentrations measured for compliance shall be averaged over a 15-minute sampling period. [District Rule 1081, 4.0] Federally Enforceable Through Title V Permit
11. The ammonia slip shall not exceed 20 PPMV dry at 15% O2. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13 (h)] Federally Enforceable Through Title V Permit
13. The selective catalytic reduction (SCR) system shall be installed in the path of the heat recovery boiler where the temperature range is 575 to 750 °F. The temperature of the exhaust gas leaving the catalytic oxidation reduction (COR) system shall be greater than 600 °F at all times, except during periods of startup or shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
14. This unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(b) and San Joaquin County Rule 407] Federally Enforceable Through Title V Permit
15. The sulfur content of each fuel source shall be documented in a current valid purchase contract, a supplier certification, tariff or transportation contract, or tested daily in accordance with the requirements of 40 CFR 60.334 (h) and (i). [40 CFR 60.334(h) and 40 CFR 60.334(i)] Federally Enforceable Through Title V Permit
16. If the sulfur content of the natural gas being fired in the turbine is determined using daily testing, then ASTM D1072, D3246, D4468, or D6667 shall be used to make this determination. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit
17. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with U.S. EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The stack height shall be minimum of 50 feet and shall be adequate for stack sampling pursuant to EPA reference methods for source testing. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (amended December 17, 1992). [40 CFR Part 60; District NSR Rule; District Rule 4703; District Rule 1081, 3.0, 5.0, and 6.0] Federally Enforceable Through Title V Permit
18. Source testing for NO_x, CO, VOC and ammonia slip shall be conducted on an annual basis. [District NSR Rule] Federally Enforceable Through Title V Permit
19. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days after testing day. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The owner or operator shall provide source test information annually regarding the exhaust gas NO_x and CO concentration corrected to 15% O₂ (dry). EPA Methods 7E or 20 shall be used for NO_x emissions. EPA Methods 10 or 10B shall be used for CO emissions. EPA Methods 3, 3A, or 20 shall be used for Oxygen content of the exhaust gas. [40 CFR 60.8(a) and District Rule 4703, 5.1, 6.3.1, 6.4.1, 6.4.2, and 6.4.3] Federally Enforceable Through Title V Permit
21. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with CEMS for NO_x, CO, and O₂. CEMS shall meet the performance specification requirements in 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the U.S. EPA. CEMS data shall be used to determine compliance with emission limits. [District Rule 1080, 4.0 and 5.0; District NSR Rule, District Rule 4703 and 40 CFR 60.13] Federally Enforceable Through Title V Permit
22. A CEMS system shall be used to demonstrate compliance with the NO_x emission limits at 30, 50, 75, and 100% of peak load or at four points in the normal operating range of the gas turbine, including the minimum point in the range and peak load. All loads shall be corrected to ISO conditions using the appropriate equations supplied by the manufacturer. [40 CFR 60.335] Federally Enforceable Through Title V Permit
23. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEMS equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080, 6.0 and 40 CFR Part 60] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. All continuous monitoring and recording instruments shall be installed, calibrated, operated and shall be reported in accordance with the requirements of 40 CFR, Part 51. [District NSR Rule and District Rule 4001] Federally Enforceable Through Title V Permit
25. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
26. The continuous NO_x and O₂ monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rule 1080, 6.3, 6.5, 6.6 and 7.2] Federally Enforceable Through Title V Permit
27. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
28. On days of turbine engine startup/shutdown, permittee shall demonstrate compliance with NO_x and CO daily emissions limits with CEMS data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstration shall be maintained and made available for District inspection for a period of five years. [District Rule 1080, 7.1; District NSR Rule; District Rule 2520, 9.3.2, 9.4.2] Federally Enforceable Through Title V Permit
29. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the CEMS shall be in continuous operation while the turbine is operating. NO_x emissions in ppmv (corrected to 15% O₂) and CO and O₂ concentrations must be recorded continuously (except as noted elsewhere) and data shall be reduced to 15-minute averages per 40 CFR Part 60.13 (e)(2). [District NSR Rule, 40 CFR 60.13] Federally Enforceable Through Title V Permit
30. Records shall be maintained and shall contain the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEMS that have been installed pursuant to District Rule 1080; emission measurements; and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 1080, 4.0 and 7.3; District NSR Rule; District Rule 4703; 40 CFR 60.332(a), (b); 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
31. Permittee shall maintain on file copies of natural gas bills. Certification of the sulfur content by the gas supplier on the Fuel Gas Tariff will be an acceptable alternative for verifying compliance with fuel sulfur limit. [40 CFR 60.334 (b); 40 CFR 60.334(h)(3) ; District NSR Rule; District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken, and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. For clarification, operator shall use the same averaging periods as written into the permit for demonstrating compliance. [40 CFR 60.7(c); District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
33. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMS within 96 hours of occurrence. The APCO shall be notified within eight hours after the detection of a breakdown of CEMS monitoring equipment and 24 hours prior to a planned shutdown of monitoring equipment greater than 4 hours in duration. [40 CFR 60.334(c); District Rule 1080, 9.0 and 10.0; District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
34. The permittee shall provide a continuous temperature monitoring and recording system to indicate the flue gas temperature through the SCR and COR systems. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

35. A daily log of the hourly ammonia injection rate and of the pressure drop across the catalyst shall be maintained on the premises at all times. [District NSR Rule] Federally Enforceable Through Title V Permit
36. The following types of units are not affected units subject to the requirements of the Acid Rain Program: 1) A simple combustion turbine that commenced operation before November 15, 1990, 2) Any unit that, during 1985, did not serve a generator that produced electricity for sale and that did not, as of November 15, 1990, and does not currently, serve a generator that produces electricity for sale, 3) A cogeneration facility which for a unit that commenced construction prior to November 15, 1990, was constructed for the purpose of supplying equal to or less than one-third its potential electrical output capacity or equal to or less than 219,000 Mwe-hrs actual electric output on an annual basis to any utility power distribution system for sale. Therefore, the requirements of 40 CFR 72.6 do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
37. There shall be no visible emissions (except for uncombined water) from the entire system. [District NSR Rule] Federally Enforceable Through Title V Permit
38. The turbine shall be designed and operated at STIG (Trademark GE) conditions in accordance with manufacture's recommended operating procedures. [District NSR Rule, 40 CFR Part 64] Federally Enforceable Through Title V Permit
39. Per the Settlement Agreement entered into as of 06/22/1989, by and between California Attorney General John Van de Kamp and San Joaquin CoGen LLC, San Joaquin CoGen LLC is required to mitigate permitted emissions of PM10 to 0 lb/day & NOx to 85 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
40. Turbine washing operation shall take place only when the turbine is off-line. [District NSR Rule] Federally Enforceable Through Title V Permit
41. VOC emissions from the off-line turbine wash operation shall not exceed 9.8 lb per day. [District NSR Rule] Federally Enforceable Through Title V Permit
42. Records of daily amount of organic solvent used, Material Safety Data Sheet (MSDS) or product data sheet showing the name of the organic solvent, chemical composition, boiling point, and VOC content, mix ratios by volume of components added to the cleaning solvent, shall be maintained, retained on the premises for at least five years and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the 40 CFR 60.332(c), 60.333 (a) and (b); 60.334(b), (b)(1), (b)(2), (b)(3), (h)(1), (i), (j); 60.335(b)(10). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
44. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1027-2-2

EXPIRATION DATE: 07/31/2014

EQUIPMENT DESCRIPTION:

185 HP CATERPILLAR MODEL 3208 NA-210 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIREWATER PUMP

PERMIT UNIT REQUIREMENTS

1. NOx emissions from the engine shall not exceed 8.0 g/hp-hr, averaged over 15 consecutive minutes. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [San Joaquin County Rule 407 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115]
8. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702, and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with San Joaquin County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

SJVUAPCD
NORTHERN

Detailed Facility Report

For Facility=1027

4/9/14

9:39 am

Sorted by Facility Name and Permit Number

SAN JOAQUIN COGEN, LLC 17200 MURPHY PARKWAY LATHROP, CA 95330	FAC # N-1027	TYPE: TitleV	EXPIRE ON: 07/31/2014
	STATUS: A	TOXIC ID: 21108	AREA: 21
	TELEPHONE: 7012216462	INSP. DATE: 08/14	

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
N-1027-1-7	48,600 Kilowatts	3020-08A G	1	10,215.00	10,215.00	A	GENERAL ELECTRIC LM5000 NATURAL GAS FIRED GAS TURBINE ENGINE WITH STEAM INJECTION, AMMONIA INJECTION, SELECTIVE CATALYTIC REDUCTION, AND AN OXIDIZATION CATALYST SERVING A 48.6 MW COGENERATION PLANT
N-1027-2-2	185 bhp IC engine	3020-10 B	1	117.00	117.00	A	185 HP CATERPILLAR MODEL 3208 NA-210 DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIREWATER PUMP

Number of Facilities Reported: 1