

Fresno Bee

Newspaper notice for publication in Fresno Bee and for posting on valleyair.org

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permit to City of Fresno/Facilities Management for replacing the existing 299 bhp diesel-fired emergency standby engine (permit unit C-7-1-0) with a 909 bhp diesel-fired emergency standby engine, at 2600 Fresno Street in Fresno, CA.

No comments were received following the District's preliminary decision on this project.

The application review for Project #1150822 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.