



AUG 26 2015

Mr. Dave Waggoner
Ingomar Packing Company
P. O. Box 1448
Los Banos, CA 93635

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # N-1276
Project # N-1151370**

Dear Mr. Waggoner:

The Air Pollution Control Officer has issued Authorities to Construct (N-1276-3-15 and N-1276-15-5) with Certificates of Conformity to Ingomar Packing Company at 9950 S. Ingomar Grade, Los Banos, CA. Modification to increase annual fuel usage on boiler N-1276-15-4 and reduce annual fuel usage on boiler N-1276-3-14. Enclosed are the Authorities to Construct and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permit was published on July 20, 2015. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on July 15, 2015. No comments were received following the District's preliminary decision on this project.

Prior to operating with the modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms have been enclosed for your use. These forms may also be found on the District's website at www.valleyair.org.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. Dave Waggoner
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Mike Tollstrup, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email



Facility # N-1276
INGOMAR PACKING COMPANY
P O BOX 1448
LOS BANOS, CA 93635

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice.** Please pay enclosed invoice before due date.
2. **Fully Understand ATC.** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
3. **Follow ATC.** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
4. **Notify District.** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
5. **Source Test.** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
6. **Maintain Records.** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for 5 years.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at
any of the telephone numbers listed below.**

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95358-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: N-1276-3-15

ISSUANCE DATE: 08/24/2015

LEGAL OWNER OR OPERATOR: INGOMAR PACKING COMPANY

MAILING ADDRESS: P O BOX 1448
LOS BANOS, CA 93635

LOCATION: 9950 S INGOMAR GRADE
LOS BANOS, CA 93635

EQUIPMENT DESCRIPTION:

MODIFICATION OF 156 MMBTU/HR NEBRASKA MODEL N25-T-84 BOILER WITH A TODD RMB ULTRA-LOW NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM: REDUCE THE ANNUAL HEAT INPUT FROM 1,063,560 MMBTU/YR TO 1,023,560 MMBTU/YR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions from any combustion source shall not exceed 0.1 grains/dscf (calculated to 12% carbon dioxide). [District Rule 4201 and District Rule 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. The facility-wide fuel usage shall not exceed 19,600 MMBtu in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The facility-wide CO emissions shall not exceed 167,538 pounds during any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A record of the daily facility-wide fuel usage, in Btu, shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

N-1276-3-15 Aug 24 2015 11:10AM - GILLR Joint Inspection NOT Required

8. A record of the cumulative annual facility-wide CO emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
9. A record of the cumulative annual facility-wide NOx emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
10. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
13. This unit shall be fired only on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
14. The fuel usage of this unit shall not exceed 1,023,560 MMBtu during any rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
15. NOx emissions shall not exceed 7 ppmvd @ 3% O2 (referenced as NO2) or 0.008 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
16. CO emissions shall not exceed 100 ppmvd @ 3% O2 or 0.074 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
17. VOC emissions shall not exceed 0.0055 lb/MMBtu (referenced as methane). [District Rule 2201] Federally Enforceable Through Title V Permit
18. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. PM10 emissions shall not exceed 0.0024 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Source testing to determine compliance with the NOx and CO emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

26. Source testing to measure NOx emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. The flue gas recirculation valve(s) setting shall be monitored at least on a weekly basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified, to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
36. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
37. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320] Federally Enforceable Through Title V Permit
38. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

39. A record of the annual fuel usage of this unit, on a rolling 12-month basis, shall be kept. The record shall be in MMBtu and shall be updated at least once during each calendar month that the unit operates. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
41. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
42. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
43. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
44. This unit is subject to the requirements of 40 CFR Part 60, Subpart Db: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units. [District Rule 4001] Federally Enforceable Through Title V Permit
45. The permittee shall comply with the emission monitoring requirements for nitrogen oxides given in 40 CFR Part 60.48b. [District Rule 4001] Federally Enforceable Through Title V Permit
46. The permittee shall comply with the reporting requirements of 40 CFR Part 60.48b. [District Rule 4001] Federally Enforceable Through Title V Permit
47. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR part 64] Federally Enforceable Through Title V Permit
48. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR part 64] Federally Enforceable Through Title V Permit
49. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: N-1276-15-5

ISSUANCE DATE: 08/24/2015

LEGAL OWNER OR OPERATOR: INGOMAR PACKING COMPANY

MAILING ADDRESS: P O BOX 1448
LOS BANOS, CA 93635

LOCATION: 9950 S INGOMAR GRADE
LOS BANOS, CA 93635

EQUIPMENT DESCRIPTION:

MODIFICATION OF 98 MMBTU/HR NATURAL GAS-FIRED NEBRASKA MODEL NS-F/S 68 BOILER EQUIPPED WITH A TODD VARI-FLAME MODEL #V8151G0XXX LOW NOX BURNER, AN INDUCED FLUE GAS RECIRCULATION SYSTEM AND A CRI CATASTACK SELECTIVE CATALYTIC REDUCTION SYSTEM WITH AMMONIA INJECTION: INCREASE ANNUAL HEAT INPUT FROM 200,000 MMBTU/YR TO 240,000 MMBTU/YR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions from any combustion source shall not exceed 0.1 grains/dscf (calculated to 12% carbon dioxide). [District Rule 4201 and District Rule 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
5. The facility-wide fuel usage shall not exceed 19,600 MMBtu in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The facility-wide CO emissions shall not exceed 167,538 pounds during any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A record of the daily facility-wide fuel usage, in Btu, shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

N-1276-15-5 Aug 24 2015 11:10AM - GILLR Joint Inspection NOT Required

8. A record of the cumulative annual facility-wide CO emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
9. A record of the cumulative annual facility-wide NOx emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
11. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The unit shall be fired only on PUC-quality natural gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. The heat input into this unit shall not exceed 240,000 MMBtu during any one rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
14. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
15. NOx emissions shall not exceed 5 ppmvd @ 3% O2 or 0.0062 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. CO emissions shall not exceed 50 ppmvd @ 3% O2 or 0.037 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. VOC emissions shall not exceed 0.0055 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
18. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
19. PM10 emissions shall not exceed 0.0076 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Ammonia (NH3) emissions shall not exceed 10 ppmvd @ 3% O2 over a 15 minute averaging period. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Source testing to determine compliance with the NOx, CO and ammonia emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320]
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. For NOx and CO emission source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with that limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

26. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320]
30. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
32. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃ and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. Ammonia monitoring shall be conducted utilizing Draeger tubes or another District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. Ammonia emission readings shall be taken at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. If the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer or the NH₃ monitoring equipment continue to show emission limit violations after 1 hour of operation following detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃ and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
38. A record of the fuel usage of this unit, on a 12 month rolling total basis, shall be kept. The record shall be updated at least once every calendar month. [District Rule 2201] Federally Enforceable Through Title V Permit
39. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

40. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
41. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
42. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
43. This unit is subject to the requirements of 40 CFR Part 60, Subpart Dc: Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units. [40 CFR Part 60, Subpart Dc] Federally Enforceable Through Title V Permit