



DEC 18 2015

Ed McNair
Defense Distribution Depot San Joaquin - Tracy
P.O.Box 960001
Stockton, CA 95296

Re: Notice of Preliminary Decision - Authority to Construct
Facility Number: N-263
Project Number: N-1153073

Dear Mr. McNair:

Enclosed for your review and comment is the District's analysis of Defense Distribution Depot San Joaquin - Tracy's application for an Authority to Construct for the installation of a 755 horsepower transportable Tier 2 certified diesel engine to power emergency power in the event of an electrical outage, at 25600 Chrisman Road in Tracy.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice period, the District intends to issue the Authority to Construct. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. Wai-Man So of Permit Services at (209) 557-6449.

Sincerely,



Arnaud Marjollet
Director of Permit Services

AM:WMS

Enclosures

cc: Mike Tollstrup, CARB (w/ enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District Authority to Construct

*Emergency standby transportable diesel-fired IC engine
powers an electrical generator*

Facility Name:	Defense Distribution Depot San Joaquin – Tracy	Date:	December 9, 2015
Mailing Address:	P.O. Box 960001 Stockton, CA 95296	Engineer:	Wai-Man So
Contact Person:	Edward McNair (Specialist)	Lead Engineer:	Nick Peirce
Telephone:	(209) 839 – 5539		Shannon Gutierrez (Specialist)
Email:	Edward.McNair@dla.mil		(209) 839 – 4862
			Shannon.gutierrez@dla.mil
Application #(s):	N-263-51-0		
Project #:	N-1153073		
Deemed Complete:	November 23, 2015		

I. PROPOSAL

Defense Distribution Depot San Joaquin - Tracy (hereinafter DDDSJT) is requesting an Authority to Construct (ATC) for the installation of a 755 bhp transportable Tier 2 certified diesel-fired emergency standby IC engine powering an electrical generator to be used in various locations within the facility. This IC engine was formerly permitted under N-754-59-0 which was deleted on Feb 5, 2015. See copy of the Permit to Operate N-754-59-0 in Appendix II of this document.

II. APPLICABLE RULES

District Rule 2201	New and Modified Stationary Source Review Rule (04/21/11)
District Rule 2410	Prevention of Significant Deterioration (effective 11/26/12)
District Rule 2520	Federally Mandated Operating Permit (06/21/2001)
District Rule 4001	New Source Performance Standard (04/14/1999)
District Rule 4002	National Emission Standards for Hazardous Air Pollutants (05/20/04)
District Rule 4101	Visible Emissions (2/17/05)
District Rule 4102	Nuisance (12/17/92)
District Rule 4201	Particulate Matter Concentration (12/17/92)
District Rule 4701	Stationary Internal Combustion Engines – Phase 1 (8/21/2003)
District Rule 4702	Stationary Internal Combustion Engines – Phase 2 (11/14/2013)
District Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice
Title 17 California Code of Regulations (CCR),	Section 93116

- Airborne Toxic Control Measure (ATCM) for Portable Compression-Ignition Diesel Engines
- California Environmental Quality Act (CEQA)
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

III. PROJECT LOCATION

The facility is located at 25600 Chrisman Road in Tracy, California. The equipment will not be located within 1,000 feet to the outer boundary of any K-12 school. Pursuant to California Health and Safety Code 42301.6, a school notification is not required.

IV. PROCESS DESCRIPTION

The diesel-fired emergency standby engine powers an electrical generator. Other than emergency operation, the engine may be operated up to 50 hours per calendar year for maintenance and testing purposes.

V. EQUIPMENT LISTING

TRANSPORTABLE EMERGENCY STANDBY 755 BHP (INTERMITTENT) CUMMINS MODEL # QSX 15-G9 NR2 TIER 2 CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN ELECTRICAL GENERATOR

VI. EMISSION CONTROL TECHNOLOGY EVALUATION

NO_x, CO, VOC and PM₁₀:

Per District Guidance Document FYI-324 and the District BACT Guideline 3.1.1, the facility is required to install the latest available tier certification standard for emergency engines as noted below. A new emergency engine shall meet the requirements as follows:

- 50 ≤ bhp < 75: Tier 4 Interim certification standards
- 75 ≤ bhp < 750: Tier 3 certification standards
- ≥ 750 bhp: Tier 2 certification standards

The proposed unit is a 755 bhp Tier 2 certified emergency engine which meets the requirements of District Policy FYI-324.

SO_x:

The use of very low-sulfur diesel fuel reduces SO_x emissions by over 99% from standard diesel fuel.

VII. GENERAL CALCULATIONS

A. Assumptions

Emergency operating schedule:	24 hours/day
Non-emergency operating schedule:	50 hours/year (per applicant)
Density of diesel fuel:	7.1 lb/gal
EPA F-factor (adjusted to 60 °F):	9,051 dscf/MMBtu
Fuel heating value:	137,000 Btu/gal
BHP to Btu/hr conversion:	2,542.5 Btu/bhp-hr
PM10 fraction of diesel exhaust:	0.96 (CARB, 1988)

B. Emission Factors

Pre-Project Emission Factors (EF1)

The proposed engine is considered a new emissions unit to the facility. Therefore, EF1 is equal to zero.

Post-Project Emission Factors (EF2)

Except SO_x, emissions factors are taken from the current permit N-754-59-0 (see copy of the current permit in Appendix II of this document).

Only California Air Resources Board (CARB) certified diesel fuel containing no more than 0.0015% sulfur by weight could be used. The emission factor for SO_x is calculated by following equation:

$$\frac{0.000015 \text{ lb - S}}{\text{lb - fuel}} \times \frac{7.1 \text{ lb - fuel}}{\text{gallon}} \times \frac{2 \text{ lb - SO}_2}{1 \text{ lb - S}} \times \frac{1 \text{ gal}}{137,000 \text{ Btu}} \times \frac{1 \text{ bhp input}}{0.35 \text{ bhp out}} \times \frac{2,542.5 \text{ Btu}}{\text{bhp - hr}} \times \frac{453.6 \text{ g}}{\text{lb}}$$

$$= 0.0051 \frac{\text{g - SO}_x}{\text{bhp - hr}}$$

Pollutant	Post-Project Emission Factors (EF2)	Source
NO _x	4.54 g/hp-hr	PTO N-754-59-0
SO _x	0.0051 g/hp-hr	Mass balance equation above
PM ₁₀	0.14 g/hp-hr	PTO N-754-59-0
CO	2.61 g/hp-hr	PTO N-754-59-0
VOC	0.4 g/hp-hr	PTO N-754-59-0

C. Potential to Emit (PE) Calculations

1. Daily and Annual PE

Pre-Project Potential to Emit (PE1)

This is considered a new emissions unit. Therefore, PE1 is equal to zero.

Post-Project Potential to Emit (PE2)

The PE2 for each pollutant is calculated as follow:

$$PE2 = EF2 \text{ (g/hp-hr)} \times \text{Power Rating (hp)} \times \text{Operating Schedule (hr/day or hr/year)} \div \text{Conversion (g/lb)}$$

$$\text{Daily PE2} = EF2 \text{ (g/hp-hr)} \times 755 \text{ (hp)} \times 24 \text{ (hr/day)} \div 453.6 \text{ (g/lb)}$$

$$\text{Annual PE2} = EF2 \text{ (g/hp-hr)} \times 755 \text{ (hp)} \times 50 \text{ (hr/yr)} \div 453.6 \text{ (g/lb)}$$

Pollutant	Post-Project Potential to Emit (PE2)						
	EF2 (g/hp-hr)	Power Rating (hp)	Operating Schedule		Conversion (g/lb)	Daily PE2 (lb/day)	Annual PE2 (lb/yr)
			(hr/day)	(hr/yr)			
NO _x	4.54	755	24	50	453.6	181.4	378
SO _x	0.0051	755	24	50	453.6	0.2	0
PM ₁₀	0.14	755	24	50	453.6	5.6	12
CO	2.61	755	24	50	453.6	104.3	217
VOC	0.4	755	24	50	453.6	16.0	33

2. Quarterly Net Emissions Change

The Quarterly Net Emissions Changes (QNEC) is calculated for each pollutant, for each unit, as the difference between the quarterly PE2 and the quarterly baseline emissions (BE). The annual emissions are evenly distributed throughout each quarter using the following equation:

$$QNEC \text{ (lb/quarter)} = [\text{Annual PE2} - \text{Annual PE1}] \text{ (lb/year)} / 4 \text{ (quarter/year)}$$

Pollutant	Quarterly Net Emissions Change (QNEC)			
	1 st Quarter (lb/quarter)	2 nd Quarter (lb/quarter)	3 rd Quarter (lb/quarter)	4 th Quarter (lb/quarter)
NO _x	94	94	95	95
SO _x	0	0	0	0
PM ₁₀	3	3	3	3
CO	54	54	54	55
VOC	8	8	8	9

3. Adjusted increase in Permitted Emissions (AIPE)

AIPE is used to determine if Best Available Control Technology (BACT) is required for emission units that are being modified.

This is a new emission unit. Therefore, AIPE calculations are not required.

D. Facility Emissions

1. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

PE values for permit unit N-263-50 were taken from engineering evaluation under project N-1132228. Except permit unit N-263-50, PE values were taken from engineering evaluation under project N-1131649.

Permit Number	Pollutants (lb/yr)				
	NO _x	SO _x	PM ₁₀	CO	VOC
N-263-9-0	0	0	2,102	0	0
N-263-12-1	0	0	73	0	693
N-263-20-0	175	0	18	53	20
N-263-21-0	97	0	10	29	11
N-263-31-0	204	0	5	68	9
N-263-34-1	1,270	36	280	1,067	11,600
N-263-36-0	30	0	5	13	5
N-263-38-1	0	0	0	0	863
N-263-41-0	26	0	2	12	5
N-263-43-0	173	0	8	76	29
N-263-45-0	0	0	2,403	0	0
N-263-46-0	0	0	0	0	5,658
N-263-47-0	31	0	2	14	2
N-263-48-0	739	1	25	427	49
N-263-49-0	739	1	25	427	49
N-263-50-0	82	0	4	22	4
ERC	0	0	0	0	0
SSPE1	3,566	38	4,962	2,208	18,997

2. Post-Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

Permit Number	Pollutants (lb/yr)				
	NO _x	SO _x	PM ₁₀	CO	VOC
N-263-9-0	0	0	2,102	0	0
N-263-12-1	0	0	73	0	693
N-263-20-0	175	0	18	53	20
N-263-21-0	97	0	10	29	11
N-263-31-0	204	0	5	68	9
N-263-34-1	1,270	36	280	1,067	11,600
N-263-36-0	30	0	5	13	5
N-263-38-1	0	0	0	0	863
N-263-41-0	26	0	2	12	5
N-263-43-0	173	0	8	76	29
N-263-45-0	0	0	2,403	0	0
N-263-46-0	0	0	0	0	5,658
N-263-47-0	31	0	2	14	2
N-263-48-0	739	1	25	427	49
N-263-49-0	739	1	25	427	49
N-263-50-0	82	0	4	22	4
ATC N-263-51-0	378	0	12	217	33
ERC	0	0	0	0	0
SSPE2	3,944	38	4,974	2,425	19,030

3. Stationary Source Increase in Permitted Emissions (SSIPE)

SSIPE calculations are used to determine if the project triggers public notice pursuant to District Rule 2201, § 5.4.5. If SSIPE results greater than 20,000 lb/yr for any one pollutant then project requires public notification. At this time, it is District Practice to define the SSIPE as the difference of SSPE2 to SSPE1, and calculated by the following equation:

$$\text{SSIPE (lb/yr)} = \text{SSPE2 (lb/yr)} - \text{SSPE1 (lb/yr)}$$

SSIPE	Pollutants (lb/yr)				
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE2	3,944	38	4,974	2,425	19,030
SSPE1	3,566	38	4,962	2,208	18,997
SSIPE	378	0	12	217	33

As shown above, SSIPE is less than 20,000 pounds for each pollutant.

4. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- emissions from non-road IC engines (i.e. IC engines at a particular site at this facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

There is no ERC listed for this facility.

Pursuant to the CAA, Title III, Section 302(z), a stationary source does not include "those emission resulting directly from an internal combustion engine for transportation purposes or from a non-road engine as defined in CAA, Title II, Section 7550". CAA, Title II, Section 7550 states non-road engine as an internal combustion engine (including the fuel system) that is not used in a motor vehicle or a vehicle used solely for competition.

Therefore, the emissions from the proposed transportable engine, under permit unit N-263-51, shall not be included in the determination of a major source as defined in District Rule 2201, Section 3.24.

Rule 2201 Major Source Determination (lb/year)						
	NO _x	SO _x	PM10	PM2.5	CO	VOC
SSPE1	3,566	38	4,962	4,962	2,208	18,997
SSPE2	3,944	38	4,974	4,974	2,425	19,030
Major Source Threshold	20,000	140,000	140,000	200,000	200,000	20,000
Major Source	No	No	No	No	No	No

Note: PM2.5 assumed to be equal to PM10

As shown above, the facility is not an existing Major Source for any pollutant, and also is not becoming a Major Source as a result of this project.

Rule 2410 Major Source Determination:

The facility or the equipment evaluated under this project are not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination (tons/year)						
	NO2	VOC	SO2	CO	PM	PM10
Estimated Facility PE before Project Increase	1.8	9.5	1.9E-2	1.1	2.5	2.5
PSD Major Source Thresholds	250	250	250	250	250	250
Existing PSD Major Source ? (Y/N)	N	N	N	N	N	N

As shown above, the facility is not an existing major source for PSD for any pollutant. Therefore, the facility is not an existing major source for PSD.

5. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, Located at a Major Source.

Otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201

As shown in Section VII.D.4 above, the facility is not a Major Source for any pollutant. Therefore, BE = PE1.

Since this is a new emissions unit, BE = PE1 = 0 for all pollutant.

6. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is not a Major Source for any of the pollutants addressed in this project, this project does not constitute an SB 288 Major Modification.

7. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

Since this facility is not a Major Source for any pollutants, this project does not constitute a Federal Major Modification. Additionally, since the facility is not a major source for PM₁₀ (140,000 lb/year), it is not a major source for PM_{2.5} (200,000 lb/year).

8. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

Rule 2410 applies to any pollutant regulated under the Clean Air Act, except those for which the District has been classified nonattainment. The pollutants which must be addressed in the PSD applicability determination for sources located in the SJV are: (See 52.21 (b) (23) definition of significant)

- NO₂ (as a primary pollutant)
- SO₂ (as a primary pollutant)
- CO
- PM
- PM₁₀

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). The PSD Major Source threshold is 250 tpy for any regulated NSR pollutant. For the purpose of determining major source for PSD, the following sources of emissions shall be excluded:

- emissions from non-road IC engines (i.e. IC engines at a particular location at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Therefore, the emissions from the proposed transportable (non-road) engine shall not be included in the PSD major source determination.

PSD Major Source-Determination: Potential to Emit (tons/year)						
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀
Total PE from the new unit	0	0	0	0	0	0
PSD Major Source Thresholds	250	250	250	250	250	250
New PSD Major Source ? (Y/N)	N	N	N	N	N	N

As shown in the table above, the project potential to emit for the project, by itself, does not exceed any PSD major source thresholds. Therefore Rule 2410 is not applicable and no further discussion is required.

VIII.COMPLIANCE

District Rule 2201 New and Modified Stationary Source Review Rule

1. Best Available Control Technology (BACT)

A. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis for the following*:

- a) Any new emissions unit with a potential to emit exceeding two pounds per day,
- b) The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c) Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- d) Any new or modified emissions unit, in a stationary source project, which results in a Major Modification.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

As discussed in Section I of this document, the facility is proposing to install a new transportable emergency standby IC engine. Additionally, as determined in Sections VII.D.6 and VII.D.7 of this document, this project does not result in an SB 288 Major Modification or Federal Major Modification. Therefore, BACT can only be triggered if the daily emissions exceed 2.0 lb/day for any pollutant. The daily emission from the new unit is compared to the BACT threshold levels in the following table:

New Emissions Unit BACT Applicability				
Pollutant	Daily Emissions (lb/day)	BACT Threshold (lb/day)	SSPE2 (lb/yr)	BACT Triggered?
NO _x	181.4	> 2.0	n/a	Yes
SO _x	0.2	> 2.0	n/a	No
PM ₁₀	5.6	> 2.0	n/a	Yes
CO	104.3	> 2.0 and SSPE2 ≥ 200,000 lb/yr	2,425	No
VOC	16.0	> 2.0	n/a	Yes

As shown above, BACT will be triggered for NO_x, PM₁₀, and VOC emissions from the engine.

B. BACT Guideline

BACT Guideline 3.1.1, which appears in Appendix III of this document, covers diesel-fired emergency IC engine powering electrical generator.

C. Top Down BACT Analysis

Per District Policy APR 1305, Section IX, "A top-down BACT analysis shall be performed as a part of the Application Review for each application subject to the BACT requirements pursuant to the District's NSR Rule for source categories or classes covered in the BACT Clearinghouse, relevant information under each of the following steps may be simply cited from the Clearinghouse without further analysis." The "Top-Down BACT Analysis" for NO_x emissions is performed in Appendix III of this document. According to this analysis, BACT is satisfied with:

- NO_x: Latest EPA Tier Certification level for applicable horsepower range
- PM₁₀: 0.15 g/hp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)
- VOC: Latest EPA Tier Certification level for applicable horsepower range

The proposed engine meets the above requirements. Therefore, BACT is satisfied for NO_x, PM₁₀, and VOC emissions.

2. Offsets

Since emergency IC engines are exempt from the offset requirements of Rule 2201, per Section 4.6.2, offsets are not required for this engine, and no offset calculations are required.

3. Public Notification

District Rule 2201, § 5.4, requires a public notification for the affected pollutants from the following types of projects:

a. New Major Source, Federal Major Modification, and SB 288 Major Modification

This facility is not becoming a new major source, and the proposed project will trigger neither Federal Major Modification nor SB 288 Major Modification. Therefore, public noticing for these purposes is not required.

b. New emission unit with PE > 100 lb/day for any one pollutant

The PE2 for the new unit is compared to the daily PE public notice thresholds below:

PE > 100 lb/day Public Notice Thresholds			
Pollutant	PE2 (lb/day)	Public Notice Threshold	Public Notice Triggered?
NO _x	181.4	100 lb/day	Yes
SO _x	0.2	100 lb/day	No
PM ₁₀	5.6	100 lb/day	No
CO	104.3	100 lb/day	Yes
VOC	16.0	100 lb/day	No

Therefore, public noticing for PE > 100 lb/day purposes is required.

c. Modifications with SSPE1 below an Offset threshold and SSPE2 above an Offset threshold on a pollutant-by-pollutant basis

The proposed project does not result in SSPE from below offset threshold level to above offset threshold level for any one pollutant. Therefore, public noticing for this purpose is not required.

d. New stationary sources with SSPE2 exceeding Offset thresholds

There is no new stationary source with SSPE2 exceeding offset thresholds as a result of this project. Therefore, public noticing for this purpose is not required.

e. Any permitting action with an SSIPE exceeding 20,000 lb/yr for any one pollutant

The proposed project does not result in SSIPE exceeding 20,000 lb/yr for any one pollutant. Therefore, public noticing for this purpose is not required.

As discussed above, public noticing is required for this project for NO_x and CO emissions in each excess of 100 lb/day. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

4. Daily Emission Limits (DELs)

Daily Emissions Limitations (DELs) and other enforceable conditions are required by Section 3.16 to restrict a unit's maximum daily emissions. Therefore, the following conditions will be listed on the permit to ensure compliance:

- *Emissions from this IC engine shall not exceed any of the following limits: 4.54 g-NO_x/bhp-hr, 2.61 g-CO/bhp-hr, or 0.4 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93116]*
- *Emissions from this IC engine shall not exceed 0.14 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 17 CCR 93116]*

In addition, the DEL for SO_x is established by the sulfur content of the fuel being combusted in the engine. Therefore, the following condition will be listed on the permit to ensure compliance:

- *Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93116]*

5. Compliance Assurance

a. Source Testing

Pursuant to District Policy APR 1705, source testing is not required for emergency standby IC engine to demonstrate compliance with Rule 2201.

b. Monitoring

No monitoring is required to demonstrate compliance with Rule 2201.

c. Recordkeeping

Recordkeeping requirements, in accordance with District Rule 4702, will be discussed in Section VIII, *District Rule 4702*, of this evaluation.

d. Reporting

No reporting is required to ensure compliance with Rule 2201.

6. Ambient Air Quality Analysis

Per Section 4.14 of Rule 2201, ambient air quality analysis (AAQA) shall be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse the violation of an Ambient Air Quality Standard (AAQS). Refer to Appendix VI of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO_x, CO, and SO_x. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO_x, CO, or SO_x. The proposed location is in a non-attainment area for the state's PM₁₀ as well as federal and state PM_{2.5} thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM₁₀ and PM_{2.5}.

Compliance with the requirements of this rule is expected.

District Rule 2410 Prevention of Significant Deterioration

The provisions of this rule shall apply to any source and the owner or operator of any source subject to any requirements under Title 40 Code of Federal Regulations (40 CFR) Part 52.21 as incorporated into this rule.

As demonstrated in Section VII.D.8 of this document, the proposed project is not subject to the requirements of Rule 2410; therefore no further discussion is required.

District Rule 2520 Federally Mandated Operating Permit

Since this facility's potential to emit does not exceed any major source thresholds of Rule 2201, this facility is not a major source, and Rule 2520 does not apply.

District Rule 4001 New Source Performance Standards (NSPS)

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60.

40 CFR 60 Subpart IIII – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Pursuant to §60.4200 of this Subpart, this engine is subject to this federal regulation. However, the District has not been delegated the authority to implement the requirement of this regulation for non-Major Sources. Therefore, the following condition will be listed on the permit:

- *U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002]*

District Rule 4002 National Emission Standards for Hazardous Air Pollutants

This rule incorporates NESHAPs from Part 61, Chapter I, Subchapter C, Title 40, CFR and the NESHAPs from Part 63, Chapter I, Subchapter C, Title 40, CFR; and applies to all sources of hazardous air pollution listed in 40 CFR Part 61 or 40 CFR Part 63.

40 CFR 63 Subpart ZZZZ – National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Emissions (RICE)

Pursuant to §63.6585 of this Subpart, this engine is subject to this federal regulation. However, the District has not been delegated the authority to implement the requirement of this regulation for non-Major Sources. Therefore, the following condition will be listed on the permit:

- *U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002]*

District Rule 4101 Visible Emissions

District Rule 4101, Section 5.0, indicates that no air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour, which is dark or darker than Ringelmann 1 or equivalent to 20% opacity. The following condition will be listed on the permit to ensure compliance:

- *{15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]*

District Rule 4102 Nuisance

Section 4.0 prohibits discharge of air contaminants, which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. The following condition will be listed on the permit to ensure compliance:

- *{98} No air contaminant shall be released into the atmosphere, which causes a public nuisance. [District Rule 4102]*

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905-1 (March 2, 2001) - Risk Management Policy for Permitting New and Modified Sources specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than one. According to the Technical Services Memo for this project, in the Appendix VI of this document, the total facility prioritization score including this project was greater than one. Therefore, an HRA was required to determine the short-term acute and long-term chronic exposure from this project. The cancer risk for this project is shown below:

HRA Summary		
Unit	Cancer Risk	T-BACT Required
N-263-51-0	0.38 per million	No

BACT for toxic emission control (T-BACT) is required if the cancer risk exceeds one in one million. As demonstrated above, T-BACT is not required for this project because the HRA indicates that the risk is not above the District's thresholds for triggering T-BACT requirements; therefore, compliance with the District's Risk Management Policy and Rule 4102 is expected.

District Rule 4201 Particulate Matter Concentration

Section 3.0 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot, which, as calculated below, is equivalent to a PM₁₀ emission factor of 0.4 g-PM₁₀/bhp-hr.

$$0.1 \frac{\text{grain-PM}}{\text{dscf}} \times \frac{\text{g}}{15.43 \text{ grain}} \times \frac{1 \text{ Btu}_{in}}{0.35 \text{ Btu}_{out}} \times \frac{9,051 \text{ dscf}}{10^6 \text{ Btu}} \times \frac{2,542.5 \text{ Btu}}{1 \text{ bhp-hr}} \times \frac{0.96 \text{ g-PM}_{10}}{1 \text{ g-PM}} = 0.4 \frac{\text{g-PM}_{10}}{\text{bhp-hr}}$$

The engine has a PM₁₀ emission factor less than 0.4 g/bhp-hr. Therefore, compliance with District Rule 4201 requirements is expected and a permit condition will be listed on the permit as follows:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

District Rule 4701 Internal Combustion Engines – Phase 1

The purpose of this rule is to limit the emissions of nitrogen oxides (NOx), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. Except as provided in Section 4.0, the provisions of this rule apply to any internal combustion engine, rated greater than 50 bhp which requires a PTO.

The proposed engine is also subject to District Rule 4702, Internal Combustion Engines. Since emissions limits of District Rule 4702 and all other requirements are equivalent or more stringent than District Rule 4701 requirements, compliance with District Rule 4702 requirements will satisfy requirements of District Rule 4701.

District Rule 4702 Internal Combustion Engines – Phase 2

The following table demonstrates how the proposed engine will comply with the requirements of District Rule 4702.

District Rule 4702 Requirements Emergency Standby IC Engines	Proposed Method of Compliance with District Rule 4702 Requirements
<p>Operation of emergency standby engines is limited to 100 hours or less per calendar year for non-emergency purposes, verified through the use of a non-resettable elapsed operating time meter.</p>	<p>The applicant proposed to limit the engine operation for the purposes of maintenance and testing to 50 hours/year. Therefore, compliance is expected. The following conditions will be included on the permits:</p> <ul style="list-style-type: none"> • This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per year. [District Rules 2201, 4701, and 4702]

<p>Emergency standby engines cannot be used to reduce the demand for electrical power when normal electrical power line service has not failed, or to produce power for the electrical distribution system, or in conjunction with a voluntary utility demand reduction program or interruptible power contract.</p>	<p>The following conditions will be included on the permit:</p> <ul style="list-style-type: none"> • An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702, and 17 CCR 93116] • This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702]
<p>The owner/operator must operate and maintain the engine(s) and any installed control devices according to the manufacturers written instructions.</p>	<p>The following condition will be included on the permit:</p> <ul style="list-style-type: none"> • {4621} This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier.. [District Rule 4702]
<p>Install and operate a non-resettable elapsed time meter. In lieu of installing a non-resettable elapsed time meter, the operator may use an alternative device, method, or technique, in determining operating time provided that the alternative is approved by the APCO & EPA and is allowed by Permit to Operate condition. The operate shall properly maintain & operate the non-resettable elapsed time meter or alternative device in accordance with the manufacturer's instructions.</p>	<p>The following condition will be included on the permit:</p> <ul style="list-style-type: none"> • This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rule 4702]
<p>The owner/operator must monitor the operational characteristics of each engine as recommended by the engine manufacturer or emission control system supplier.</p>	<p>The following condition will be included on the permit:</p> <ul style="list-style-type: none"> • {3478} During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]

<p>Records of the total hours of operation of the emergency standby engine, type of fuel used, purpose for operating the engine, all hours of non-emergency and emergency operation, and support documentation must be maintained. All records shall be retained for a period of at least five years, shall be readily available, and be made available to the APCO upon request.</p>	<p>The following conditions will be included on the permits:</p> <ul style="list-style-type: none"> • The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702] • The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93116] • All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93116]
---	--

District Rule 4801 Sulfur Compounds

Rule 4801 requires that sulfur compound emissions (as SO₂) shall not exceed 0.2% by volume. Using the ideal gas equation, the sulfur compound emissions are calculated as follows:

$$\text{Volume SO}_2 = (n \times R \times T) \div P$$

n = moles SO₂

T (standard temperature) = 60 °F or 520 °R

$$R \text{ (universal gas constant)} = \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot \text{°R}}$$

$$\frac{0.000015 \text{ lb-S}}{\text{lb-fuel}} \times \frac{7.1 \text{ lb}}{\text{gal}} \times \frac{64 \text{ lb-SO}_2}{32 \text{ lb-S}} \times \frac{1 \text{ MMBtu}}{9,051 \text{ scf}} \times \frac{1 \text{ gal}}{0.137 \text{ MMBtu}} \times \frac{\text{lb-mol}}{64 \text{ lb-SO}_2} \times \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb-mol} \cdot \text{°R}} \times \frac{520 \text{ °R}}{14.7 \text{ psi}} \times 1,000,000 = 1.0 \text{ ppmv}$$

Since 1.0 ppmv is ≤ 2,000 ppmv, this engine is expected to comply with Rule 4801. Therefore, the following condition will be listed on the permit to ensure compliance:

- Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115]

California Health & Safety Code 42301.6 (School Notice)

As discussed in Section III of this document, a school notice is not required for this project.

Title 17 California Code of Regulations (CCR), Section 93116

– Airborne Toxic Control Measure (ATCM) for Portable Engines Rated at 50 Horsepower and Greater

§ 93116.1 – Applicability:

Except as provided in §93116.1(b), all portable engines having a maximum rated horsepower of 50 bhp and greater and fueled with diesel are subject to this regulation.

§ 93116.2 – Definitions:

§93116.2(a)(40) states “*Transportable*” means the same as portable.

§93116.2(a)(29) states “*Portable*” means designed and capable of being carried or moved from one location to another. Indicia of portability include, but are not limited to, wheels, skids, carrying handles, dolly, trailer, or platform. For the purposes of this regulation, dredge engines on a boat or barge are considered portable. The engine is not portable if:

- (A) the engine or its replacement is attached to a foundation, or if not so attached, will reside at the same location for more than 12 consecutive months. The period during which the engine is maintained at a storage facility shall be excluded from the residency time determination. Any engine, such as a back-up or stand-by engine, that replace engine(s) at a location, and is intended to perform the same or similar function as the engine(s) being replaced, will be included in calculating the consecutive time period. In that case, the cumulative time of all engine(s), including the time between the removal of the original engine(s) and installation of the replacement engine(s), will be counted toward the consecutive time period; or
- (B) the engine remains or will reside at a location for less than 12 consecutive months if the engine is located at a seasonal source and operates during the full annual operating period of the seasonal source, where a seasonal source is a stationary source that remains in a single location on a permanent basis (at least two years) and that operates at that single location at least three months each year; or
- (C) the engine is moved from one location to another in an attempt to circumvent the portable residence time requirements.

The proposed engine is portable and is subject to this regulation.

§ 93116.3 – Requirements:

(a) Fuel and Fuel Additive Requirements:

This regulation stipulates that diesel-fueled portable engines shall only use one of the following fuels:

- (1) CARB Diesel Fuel; or
- (2) An alternative diesel fuel that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines; or
- (3) CARB diesel fuel utilizing fuel additives that have been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

The proposed engine will solely use CARB certified diesel fuel and therefore comply with this requirement.

(b) Diesel PM Standards:

- (2) Portable diesel-fueled engines that have not been permitted or registered prior to January 1, 2010, shall not be permitted or registered unless they are certified to the most stringent standard contained in the federal or California emission standards for nonroad engines with the following exception:

- (E) Until January 2017, a district may issue a permit or registration for an engine not meeting the most stringent of the federal or California emission standard for nonroad engines if: (1) The engine is certified to meet an emission standard set pursuant to 40 CFR Part 89, Part 1039, or set forth in the equivalent categories of title 13, Cal. Code Regs;

40 CFR Part 89, Table 1 specifies the emission standard for the size of the proposed engine as follows:

Rated Power	Tier	Model Year	NOx	HC	NMHC + NOx	CO	PM
			(g/kW-hr) / [g/bhp-hr]				
kW > 560 (hp > 750)	1	2000	(9.2) [6.9]	(1.3) [1.0]	—	—	—
	2	2006	—	—	(6.4) [4.8]	(3.5) [2.6]	(0.20) [0.15]

The proposed engine is an EPA certified Tier 2 engine with the following certified emission standard:

Rated Power	Tier	Model Year	NMHC + NOx	CO	PM10
			(g/bhp-hr)		
755 hp	2	2011	4.8	2.6	0.14

- (3) Certified diesel-fired engines used exclusively in emergency applications or qualifying as low-use engines shall satisfy one of the following requirements by January 1, 2020:
- (A) The portable diesel-fueled engine is certified to Tier 4 emission standards for newly manufactured nonroad engines; or
 - (B) The portable diesel-fueled engine is equipped with properly functioning level-3 verified technology; or
 - (C) The portable diesel-fueled engine is equipped with a combination of verified emissions control strategies that have been verified together to achieve at least 85 percent reduction in diesel PM emissions.

The proposed emergency standby engine is an EPA Tier 2 certified engine that meets the emission standard set forth in 40 CFR Part 89. Therefore, the proposed engine meets the current requirements of this regulation. The following condition will be listed on the permit to ensure compliance of the future requirements of this regulation:

- *By January 1, 2020, this engine shall satisfy one of the following requirements: (1) replace with an engine that is certified to Tier 4 emission standards, (2) equip with a properly functioning level-3 verified technology; or (3) equip with a combination of verified emission control strategies that have been verified together to achieve at least 85 percent reduction in diesel PM emissions. [17 CCR 93116]*

(c) Fleet Requirements:

§ 93116.3(c)(3)(B) states, portable diesel-fueled engines used exclusively in emergency applications shall be excluded from the fleet requirements.

The proposed engine will be used exclusively in emergency standby applications purposes; therefore, the proposed engine is not subjected to the fleet requirements of this ATCM.

Compliance with the applicable requirements of this ATCM is expected.

California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and

- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

The District performed an Engineering Evaluation (this document) for the proposed project and determined that the project qualifies for ministerial approval under the District's Guideline for Expedited Application Review (GEAR). Section 21080 of the Public Resources Code exempts from the application of CEQA those projects over which a public agency exercises only ministerial approval. Therefore, the District finds that this project is exempt from the provisions of CEQA.

IX. RECOMMENDATION

Pending a successful NSR Public Noticing period, Issue Authority to Construct N-263-51-0 subject to the permit conditions listed on the attached draft Authority to Construct in Appendix I.

X. BILLING INFORMATION

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
N-263-51-0	3020-10-D (400 or Greater but less Than 800 bhp)	755 bhp	\$502

APPENDICES

- Appendix I: Draft Authority to Construct (ATC)*
- Appendix II: Previous Permit to Operate N-754-59-0*
- Appendix III: BACT Guideline & Top-Down BACT Analysis*
- Appendix IV: AAQA & RMR Summaries*

APPENDIX I

Draft Authority to Construct (ATC)

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT

PERMIT NO: N-263-51-0

LEGAL OWNER OR OPERATOR: DEFENSE DISTRIB DEPOT SAN JOAQUIN-TRACY
MAILING ADDRESS: PO BOX 960001
STOCKTON, CA 95296-0710

LOCATION: 25600 CHRISMAN RD
TRACY, CA 95376

EQUIPMENT DESCRIPTION:
TRANSPORTABLE EMERGENCY STANDBY 755 BHP (INTERMITTENT) CUMMINS MODEL # QSX 15-G9 NR2 TIER 2
CERTIFIED DIESEL-FIRED IC ENGINE POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. The engine shall not reside at one location or site at the facility for more than 12 consecutive months. The period during which the engine is maintained at a storage location shall be excluded from the residency time determination. [17 CCR 93116]
2. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
4. {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
5. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rules 4701 and 4702]
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93116]

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (209) 557-6400 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

Arnaud Marjolle, Director of Permit Services

N-263-51-0 Doc 9 2015 1:22PM - SOW Joint Inspection NOT Required

8. Emissions from this IC engine shall not exceed any of the following limits: 4.54 g-NO_x/bhp-hr, 2.61 g-CO/bhp-hr, or 0.4 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93116]
9. Emissions from this IC engine shall not exceed 0.14 g-PM₁₀/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4201 and 17 CCR 93116]
10. {4261} This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
11. {3478} During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
12. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702, and 17 CCR 93116]
13. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702]
14. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 2201, 4701, and 4702]
15. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4701 and 4702]
16. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93116]
17. The permittee shall maintain records of the date and location where the engine resided during each 12 consecutive months period. The records shall be updated at least monthly. [17 CCR 93116]
18. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93116]
19. By January 1, 2020, this engine shall satisfy one of the following requirements: (1) replace with an engine that is certified to Tier 4 emission standards, (2) equip with a properly functioning level-3 verified technology; or (3) equip with a combination of verified emission control strategies that have been verified together to achieve at least 85 percent reduction in diesel PM emissions. [17 CCR 93116]
20. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002]

DRAFT

APPENDIX II

Previous Permit to Operate N-754-59-0

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-754-59-0

EXPIRATION DATE: 07/31/2018

EQUIPMENT DESCRIPTION:

755 BHP CUMMINS MODEL # QSX 15-G9 NR2 TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (BLDG 330, WEST GENERATOR #2)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115]
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115]
7. Emissions from this IC engine shall not exceed any of the following limits: 4.54 g-NOx/bhp-hr; 2.61 g-CO/bhp-hr; or 0.4 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115]
8. The PM10 emissions rate shall not exceed 0.14 g/bhp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201 and 17 CCR 93115]
9. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]
10. The engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per year. [District Rules 2201 and 4702 and 17 CCR 93115]
11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: US ARMY GARRISON PRESIDIO OF MONTEREY
Location: 700 E ROTH RD, LATHROP, CA 95231
N-754-59-0; Oct 8 2014 11:18AM - DAVLAE

14. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115]
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115]
16. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in these subparts. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rules 4001 and 4002]

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: US ARMY GARRISON PRESIDIO OF MONTEREY
Location: 700 E ROTH RO, LATHROP, CA 95231

N-754-59-0: Oct 8 2014 11:16AM - DAVEAE

APPENDIX III

BACT Guideline & Top-Down BACT Analysis

San Joaquin Valley Unified Air Pollution Control District

Best Available Control Technology (BACT) Guideline 3.1.1
Last Update: 9/10/2013
Emergency Diesel IC Engine

Pollutant	Achieved in Practice or in the SIP	Technologically Feasible	Alternate Basic Equipment
CO	Latest EPA Tier Certification level for applicable horsepower range*		
NOX	Latest EPA Tier Certification level for applicable horsepower range*		
PM10	0.15 g/bhp-hr		
SOX	Very low sulfur diesel fuel (15 ppmw sulfur or less)		
VOC	Latest EPA Tier Certification level for applicable horsepower range*		

**Note: for emergency engines 50 ≤ bhp < 75, Tier 4 Interim certification is the requirement; for emergency engines 75 ≤ bhp < 750, Tier 3 certification is the requirement; for emergency engines ≥ 750 bhp, Tier 2 certification is the requirement.*

BACT is the most stringent control technique for the emissions unit and class of source. Control techniques that are not achieved in practice or contained in a state implementation plan must be cost effective as well as feasible. Economic analysis to demonstrate cost effectiveness is required for all determinations that are not achieved in practice or contained in an EPA approved State Implementation Plan.

Top-Down BACT Analysis for NO_x & VOC emissions

BACT Guideline 3.1.1 applies to emergency diesel-fired IC engines. In accordance with the District BACT policy, information from that guideline will be utilized without further analysis:

Step 1 - Identify all control technologies

Achieved in Practice or contained in the SIP:

NO_x: Latest EPA Tier Certification level for applicable horsepower range

VOC: Latest EPA Tier Certification level for applicable horsepower range

Technologically Feasible:

There is no technologically feasible control technology listed on this guideline.

Alternate Basic Equipment:

There is no alternate basic equipment listed on this guideline.

Step 2 - Eliminate technologically infeasible options

There are no technologically infeasible options that can be eliminated from step 1.

Step 3 - Rank remaining options by control effectiveness

Ranking of the control technologies is not required since the applicant has proposed utilize the only control technology, achieved in practice control technology listed on this guideline.

Step 4 - Cost Effectiveness Analysis

Pursuant to District BACT Policy APR 1305 IX.D.3 (11/99), a cost-effective analysis is not required since the applicant has proposed utilize the most stringent control technology option listed in Step 3. Therefore, the cost effectiveness analysis is not required.

Step 5 - Select BACT

BACT for NO_x and VOC emissions from the proposed IC engine is the latest EPA Tier Certification level for the applicable horsepower range. The applicant has proposed to install a transportable Tier 2 certified 755 bhp emergency standby diesel-fired IC engine, which meets the latest Tier Certification for engine this size as shown in previous page. Therefore, BACT is satisfied for NO_x and VOC emissions.

Top-Down BACT Analysis PM₁₀ emissions

BACT Guideline 3.1.1 applies to emergency diesel-fired IC engines. In accordance with the District BACT policy, information from that guideline will be utilized without further analysis:

Step 1 - Identify all control technologies

Achieved in Practice or contained in the SIP:

PM₁₀: 0.15 g/hp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)

Technologically Feasible:

There is no technologically feasible control technology listed on this guideline.

Alternate Basic Equipment:

There is no alternate basic equipment listed on this guideline.

Step 2 - Eliminate technologically infeasible options

There are no technologically infeasible options that can be eliminated from step 1.

Step 3 - Rank remaining options by control effectiveness

Ranking of the control technologies is not required since the applicant has proposed utilize the only control technology, achieved in practice control technology listed on this guideline.

Step 4 - Cost Effectiveness Analysis

Pursuant to District BACT Policy APR 1305 IX.D.3 (11/99), a cost-effective analysis is not required since the applicant has proposed utilize the most stringent control technology option listed in Step 3. Therefore, the cost effectiveness analysis is not required.

Step 5 - Select BACT

BACT for PM₁₀ emissions from the proposed IC engine is 0.15 g/hp-hr or the latest EPA Tier Certification level for the applicable horsepower range, whichever is more stringent (ATCM). The applicant has proposed to install a transportable Tier 2 certified 755 bhp emergency standby diesel-fired IC engine with certified PM₁₀ emissions of 0.14 g/hp-hr, which also meets the latest Tier Certification for engine this size as shown in previous page. Therefore, BACT is satisfied for PM₁₀ emissions.

APPENDIX VI
AAQA & RMR Summaries

San Joaquin Valley Air Pollution Control District Risk Management Review

To: Wai-Man So, AQE - Permit Services
 From: Jessica Coria, AQS - Permit Services
 Date: December 8, 2015
 Facility Name: Defense Distribution Depot San Joaquin-Tracy
 Location: 25600 Chrisman Road
 Application #(s): N-263-51-0
 Project #: N-1153073

A. RMR SUMMARY

RMR Summary			
Categories	Diesel-Fired IC Engine (Unit 51-0)	Project Totals	Facility Totals
Prioritization Score	N/A ¹	N/A ¹	1.0
Acute Hazard Index	N/A ²	N/A ²	0.18
Chronic Hazard Index	N/A ²	N/A ²	0.00
Maximum Individual Cancer Risk (10 ⁻⁶)	0.38	0.38	5.41
T-BACT Required?	No		
Special Permit Conditions?	Yes		

- 1 Prioritization for this unit was not conducted since it has been determined that all diesel-fired IC engines will result in a prioritization score greater than 1.0.
- 2 Acute and Chronic Hazard Indices were not calculated since there is no risk factor, or the risk factor is so low that the risk has been determined to be insignificant for this type of unit.

Proposed Permit Conditions

To ensure that human health risks will not exceed District allowable levels; the following permit conditions must be included for:

Unit # 51-0

1. The PM10 emissions rate shall not exceed **0.14 g/bhp-hr** based on US EPA certification using ISO 8178 test procedure. [District Rules 2201]
2. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed **50 hours** per calendar year. [District Rule 4702 and 17 CCR 93115]

B. RMR REPORT

I. Project Description

Technical Services received a request on November 23, 2015, to perform an Ambient Air Quality Analysis and a Risk Management Review for the installation of a 755 bhp diesel-fired emergency IC engine powering an electrical generator to be used at various locations within the facility.

II. Analysis

Technical Services performed a screening level health risk assessment using the District developed DICE database.

The following parameters were used for the review:

Analysis Parameters Unit 1-0			
Source Type	Point	Location Type	Rural
BHP	755	PM ₁₀ g/hp-hr	0.14
Closest Receptor (m)	170	Quad	4
Max Hours per Year	50	Type of Receptor	Residential

Technical Services performed modeling for criteria pollutants CO, NO_x, SO_x and PM_{10i}; as well as a RMR. The emission rates used for criteria pollutant modeling were 217 lb/yr CO, 378 lb/yr NO_x, 0.0 lb/yr SO_x, and 12 lb/yr PM₁₀. The engineer supplied the maximum fuel rate for the IC engine used during the analysis.

The results from the Criteria Pollutant Modeling are as follows:

Criteria Pollutant Modeling Results*

Diesel ICE	1 Hour	3 Hours	8 Hours.	24 Hours	Annual
CO	NA ¹	X	NA ¹	X	X
NO _x	NA ¹	X	X	X	Pass
SO _x	NA ¹	NA ¹	X	NA ¹	Pass
PM ₁₀	X	X	X	NA ¹	Pass ²
PM _{2.5}	X	X	X	NA ¹	Pass ²

*Results were taken from the attached PSD spreadsheet.

¹The project is an intermittent source as defined in APR-1920. In accordance with APR-1920, compliance with short-term (i.e., 1-hour, 3-hour, 8-hour and 24-hour) standards is not required.

²The criteria pollutants are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2).

III. Conclusion

The cancer risk associated with the operation of the proposed diesel IC engine is less than 1.0 in a million. In accordance with the District's Risk Management Policy, the project is approved without Toxic Best Available Control Technology (T-BACT) for PM10.

To ensure that human health risks will not exceed District allowable levels; the permit conditions listed on page 1 of this report must be included for this proposed unit .

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

IV. Attachments

- A. RMR request from the project engineer
- B. Additional information from the applicant/project engineer
- C. Toxic emissions summary
- D. Prioritization score
- E. Facility Summary