



Mr. Kenneth Bork
Freeport-McMoRan Oil and Gas
1200 Discovery Drive Suite 500
Bakersfield, CA 93309

**Re: Proposed ATC / Certificate of Conformity (Significant Mod)
District Facility # S-1372
Project # S-1160094**

Dear Mr. Bork:


Enclosed for your review is the District's analysis of an application for Authorities to Construct for the facility identified above. You requested that Certificates of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. The modification consisted of removing the PM10 source test requirements for two steam generators.

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authorities to Construct with Certificates of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authorities to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District
Authority to Construct Application Review
Remove Steam Generator Source Testing Requirement

Facility Name:	Freeport-McMoRan Oil and Gas	Date:	February 16, 2016
Mailing Address:	1200 Discovery Drive Suite 500 Bakersfield, CA 93309	Engineer:	Steve Davidson
		Lead Engineer:	Dan Klevann
		Date:	February 23-16
Contact Person:	Kenneth R. Bork		
Telephone:	(661) 395-5458		
Fax:	(661) 330-0428		
E-Mail:	kbork@fmi.com		
Application #(s):	S-1372-127-26 & '-317-16		
Project #:	S-1160094		
Deemed Complete:	February 2, 2016		

I. Proposal

Freeport-McMoRan Oil and Gas (FMOG) is a producer of crude oil and natural gas. FMOG has submitted an Authority to Construct (ATC) application for removing PM₁₀ source test requirements for two steam generators (S-1372-127-26 & '-317-16) equipped with a shared post combustion sulfur scrubber with wet electrostatic precipitator (ESP).

Currently, the permits require the FMOG to source test for PM₁₀ using EPA Method 201A. However, EPA has revised the rule to clarify that Method 201A cannot be used to measure emissions from stacks that have entrained moisture droplets (e.g., from a wet scrubber stack) since these stacks may have water droplets that are larger than the cut size of the PM₁₀ sizing device. Because EPA has revised the applicability to of Method 201A, FMOG has been using EPA test method 202 which measures total PM (not PM₁₀).

FMOG has consistently shown a history of compliance with PM₁₀ limits on the permit and the last source test of both units has shown compliance (see Appendix C); therefore, FMOG has requested to remove the source test requirement and replace it with a requirement to weekly monitor the ESP's secondary voltage.

Additionally, FMOG proposes to remove each permit's annual PM₁₀ emissions of 4,161 lb-PM₁₀ per year. The units are included in a SLC shared with permits S-1372-1, '-2, '4, '-16, '-24, '-127, and '-137. Therefore, the condition is redundant and the condition from the Permits to Operate will be removed.

FMOG has a Title V Permit. This modification can be classified as a Title V significant modification pursuant to Rule 2520, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that

manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. FMOG must apply to administratively amend their Title V permit.

II. Applicable Rules

Rule 2201	New and Modified Stationary Source Review Rule (4/21/11)
Rule 2520	Federally Mandated Operating Permits (6/21/01)
Rule 4001	New Source Performance Standards (4/14/99)
Rule 4002	National Emissions Standards for Hazardous Air Pollutants (5/20/04)
Rule 4101	Visible Emissions (2/17/05)
Rule 4102	Nuisance (12/17/92)
Rule 4201	Particulate Matter Concentration (12/17/92)
Rule 4301	Fuel Burning Equipment (12/17/92)
Rule 4305	Boilers, Steam Generators and Process Heaters – Phase II (8/21/03)
Rule 4306	Boilers, Steam Generators and Process Heaters – Phase III (10/16/08)
Rule 4320	Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater Than 5.0 MMBtu/hr (10/16/2008)
Rule 4405	Oxides of Nitrogen Emissions from Existing Steam Generators Used in Thermally Enhanced Oil Recovery - Central/Western Kern County Fields (12/17/92)
Rule 4406	Sulfur Compounds From Oil-Field Steam Generators – Kern County (12/17/92)
Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)	
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines	
Federal NSR Requirements for PM2.5 – 40 CFR Part 51 Appendix S	

III. Project Location

The equipment is located at McKitterick Front lease, within the Heavy Oil western stationary source (NW/4 of Section 6, Township 30S, Range 22E). The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description

The steam generators produce steam which is injected into the formation to lower the viscosity of the oil thereby facilitating the extraction of the oil. The casing gas produced in the thermally enhanced oil recovery (TEOR) operation S-1372-100 is currently authorized for combustion in the steam generators. The steam generators '-127 and '-317 be equipped with a shared SO_x scrubber and wet ESP.

V. Equipment Listing

Pre-Project Equipment Description:

S-1372-127-14: 62.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR #43 EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR, O2 CONTROLLER, AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-317 (MCKITTRICK FRONT LEASE)

S-1372-317-24: 67.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-127 (MCKITTRICK FRONT LEASE)

Proposed Modification:

Remove PM₁₀ source test requirements .

S-1372-127-26: MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR #43 EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR, O2 CONTROLLER, AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-317 (MCKITTRICK FRONT LEASE): REMOVE PM10 SOURCE TEST REQUIREMENT

S-1372-317-16: MODIFICATION OF 67.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-127 (MCKITTRICK FRONT LEASE): REMOVE PM10 SOURCE TEST REQUIREMENT

VI. Emission Control Technology Evaluation

Steam generators S-1372-127 and '-317 are equipped with a Turbosonic spray tower and Turbosonic "SonicKleen" wet ESP. The removal efficiency of the wet ESP were not stated in the manufacturer literature included with the application for project S1080384. However, the combination scrubber/wet ESP is expected to remove at least 95% of the SOx emissions.

VII. General Calculations

A. Assumptions

The applicant is not proposing to modify the units or change the emissions limit for either of the steam generators in this project. Therefore, this is not an NSR modification and

calculations are not required. Emissions from project S10080384 are listed below for future reference.

1. Potential to Emit

PE (S-1327-127-26)		
	Daily Emissions (lb/day)	Annual Emissions (lb/year)
NO _x	37.5	9855
SO _x	486.0	392,448*
PM ₁₀	11.4	4161
CO	126.0	20,258
VOC	4.5	1643

* SOx emissions are part of an SLC that includes permits S-1372-1, '-2, '4, '-16, '-24, '-127, and '-137.

PE (S-1327-317-16)		
	Daily Emissions (lb/day)	Annual Emissions (lb/year)
NO _x	40.2	10,6435
SO _x	486.0	392,448*
PM ₁₀	12.3	4161
CO	50.2	21,878
VOC	6.3	2300

* SOx emissions are part of an SLC that includes permits S-1372-1, '-2, '4, '-16, '-24, '-127, and '-137.

VIII. Compliance

Rule 2201 New and Modified Stationary Source Review Rule

As stated above, this project is not an NSR modification; therefore, this rule is not applicable and further discussion is not required.

Rule 2410 Prevention of Significant Deterioration

This project does not result in a new PSD major source or PSD major modification. No further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a "permit amendment that does not qualify as a minor permit modification or administrative amendment."

Minor permit modifications do not relax monitoring, reporting, or recordkeeping requirements in the permit and are not significant changes in existing monitoring permit terms or conditions.

The removal of source test conditions is a relaxation in monitoring conditions. As a result, the proposed project constitutes a Significant Modification to the Title V Permit.

As discussed above, the facility has applied for a Certificate of Conformity (COC); therefore, the facility must apply to modify their Title V permit with an administrative amendment, prior to operating with the proposed modifications. Continued compliance with this rule is expected.

Rule 4001 New Source Performance Standards (NSPS)

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. 40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Industrial Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction).

40 CFR Part 60, Subpart A, section 14, defines the meaning of modification to which the standards are applicable. §60.14, paragraph (a) states that the following will be considered a modification: (a) "Except as provided under paragraphs (e) and (f) of this section, any physical or operational change to an existing facility which results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies shall be considered a modification within the meaning of section 111 of the Act. Upon modification, an existing facility shall become an affected facility for each pollutant to which a standard applies and for which there is an increase in the emission rate to the atmosphere".

No newly constructed or reconstructed units are proposed in this project, nor is the unit being modified (as defined above). Those units burning TEOR gas have been previously authorized to burn TEOR waste gas. All of the units were constructed prior to 6/9/89 and have not been modified, by definition, since. Therefore, the requirements of these sections do not apply to the unit.

Rule 4002 National Emission Standards for Hazardous Air Pollutants (NESHAPs)

This rule incorporates NESHAPs from Part 61, Chapter I, Subchapter C, Title 40, CFR and the NESHAPs from Part 63, Chapter I, Subchapter C, Title 40, CFR; and applies to all sources of hazardous air pollution listed in 40 CFR Part 61 or 40 CFR Part 63. However, no subparts of 40 CFR Part 61 or 40 CFR Part 63 apply to steam generators.

Rule 4101 Visible Emissions

Per Section 5.0, no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 (or 20% opacity). As the steam generators and flare are fired solely on gaseous fuel, visible emissions are not expected to exceed Ringelmann 1 or 20% opacity. Also, based on past inspections of the facility, continued compliance is expected.

Rule 4102 Nuisance

Rule 4102 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 – *Risk Management Policy for Permitting New and Modified Sources* specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

As demonstrated above, there are no increases in emissions associated with this project; therefore, a health risk assessment is not necessary and no further risk analysis is required.

Rule 4201 Particulate Matter Concentration

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

F-Factor for NG:	8,578 dscf/MMBtu at 60 °F
PM10 Emission Factor:	0.014 lb-PM10/MMBtu (highest emissions factor)
Percentage of PM as PM10 in Exhaust:	100%
Exhaust Oxygen (O ₂) Concentration:	3%
Excess Air Correction to F Factor =	$\frac{20.9}{(20.9 - 3)} = 1.17$

$$GL = \left(\frac{0.014 \text{ lb-PM}}{\text{MMBtu}} \times \frac{7,000 \text{ grain}}{\text{lb-PM}} \right) / \left(\frac{8,578 \text{ ft}^3}{\text{MMBtu}} \times 1.17 \right)$$

$$GL = 0.0098 \text{ grain/dscf} < 0.1 \text{ grain/dscf}$$

Therefore, compliance with District Rule 4201 requirements is expected and a permit condition will be listed on the permit as follows:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

Rule 4301 Fuel Burning Equipment

This rule specifies maximum emission rates in lb/hr for SO₂, NO₂, and combustion contaminants (defined as total PM in Rule 1020). This rule also limits combustion contaminants to ≤ 0.1 gr/scf. According to AP 42 (Table 1.4-2, footnote c), all PM emissions from natural gas combustion are less than 1 μm in diameter.

District Rule 4301 Limits			
Pollutant	NO₂ (lbs/hr)	Total PM (lbs/hr)	SO₂ (lbs/hr)
S-1372-127	1.56	0.88	20.25
S-1372-317	1.68	0.95	20.25
Rule Limit (lb/hr)	140	10	200

The above table indicates compliance with the maximum lb/hr emissions in this rule; therefore, continued compliance is expected.

Rule 4305 Boilers, Steam Generators and Process Heaters – Phase 2

The unit is TEOR/TVC/natural gas-fired with a maximum heat input of 62.4 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4305, the unit is subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters – Phase 2*. In addition, the unit is also subject to District Rule 4306, *Boilers, Steam Generators and Process Heaters – Phase 3*.

Since emissions limits of District Rule 4306 and all other requirements are equivalent or more stringent than District Rule 4305 requirements, compliance with District Rule 4306 requirements will satisfy requirements of District Rule 4305.

Rule 4306 Boilers, Steam Generators and Process Heaters – Phase 3

Each steam generator is natural gas/TEOR gas-fired with maximum heat input ratings ranging from 25.2 MMBtu/hr to 67.5 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4306, these units are subject to District Rule 4306. Each subject steam generator currently meets Rule 4306 requirements and continued compliance is expected.

Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater Than 5.0 MMBtu/hr

This rule applies to any gaseous fuel or liquid fuel fired boiler, steam generator, or process heater with a total rated heat input greater than 5 million Btu per hour. The purpose of this rule is to limit emissions of oxides of nitrogen (NO_x), carbon monoxide (CO), oxides of sulfur (SO₂), and particulate matter 10 microns or less (PM₁₀) from boilers, steam generators, and process heaters.

The units in project are currently in compliance with this rule. The proposal is not expected to bring these units out of compliance. Continued compliance is expected.

Rule 4406 Sulfur Compounds from Oil-Field Steam Generators - Kern County

This rule limits sulfur compound emissions from existing steam generators used in oil field operations prior to September 12, 1979. The limit imposed by the rule is 0.11 lb S/MMBtu, either individually or on average basis for all of an operating steam generator subject to the rule requirements.

FMOG has submitted a Rule 4406 Compliance Plan with the District which demonstrated compliance with the rule. This project results in no increase in permitted SO₂ or sulfur emissions, but rather a reduction in sulfur emissions and SO₂ emissions. Therefore, continued compliance this rule is expected.

Rule 4801 Sulfur Compounds

This rule limits sulfur compounds emissions at the point of discharge is 0.2 percent by volume, 2,000 ppmv, calculated as sulfur dioxide (SO₂), on a dry basis averaged over 15 consecutive minutes. Expected emissions of post combustion scrubbed TEOR gas is calculated below:

$$\text{lb-mol-SO}_2/\text{exhaust volume} = \text{lb-SO}_2/\text{MMBtu} / \text{F factor} =$$

$$[(0.324 \text{ lb-SO}_2/\text{MMBtu}) \times (\text{lb-mol}/64 \text{ lb})] / (8,578 \text{ dscf/MMBtu}) = 5.9\text{E-}7 \text{ lb-mol/dscf}$$

$$\text{Volume SO}_2 = nRT/P$$

where:

$$n = \text{moles SO}_x$$

$$T (\text{standard temperature}) = 60 \text{ }^\circ\text{F} = 520 \text{ }^\circ\text{R}$$

$$R (\text{universal gas constant}) = 10.73 \text{ psi-ft}^3/\text{lb-mol-}^\circ\text{R}$$

$$P = 14.7 \text{ psi}$$

$$\text{Volume SO}_2 = (5.9\text{E-}7 \text{ lb-mol/dscf}) \times (10.73 \text{ psi-ft}^3/\text{lb-mol-}^\circ\text{R}) \times (520 \text{ }^\circ\text{R}) / 14.7 \text{ psi}$$

$$= 2.2 \text{ E-}4 \text{ dscf/dscf exhaust}$$

$$= 220 \text{ ppmv} < 2,000 \text{ ppmv}$$

Therefore, compliance this rule is expected.

California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;

- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

The District performed an Engineering Evaluation (this document) for the proposed project and determined that all project specific emission unit(s) do not trigger Best Available Control Technology (BACT) and do not trigger Toxic Best Available Control Technology (T-BACT) requirements.

Issuance of permits for emissions units not subject to BACT or T-BACT requirements is a matter of ensuring conformity with applicable District rules and regulations and does not require discretionary judgment or deliberation. Thus, the District concludes that this permitting action constitutes a ministerial approval. Section 21080 of the Public Resources Code exempts from the application of CEQA those projects over which a public agency exercises only ministerial approval. Therefore, the District finds that this project is exempt from the provisions of CEQA.

IX. Recommendation

Each permit's annual PM₁₀ emissions of 4,161 lb-PM₁₀ per year is included by the SLC shared with permits S-1372-1, '-2, '4, '-16, '-24, '-127, and '-137. Therefore, it is redundant and the following condition from the current Permits to Operate will be removed:

- PM₁₀ emissions from this unit shall not exceed 4,161 lb-PM₁₀/yr. [District Rule 2201] Y

Include the following monitoring condition:

- The wet ESP's secondary DC voltage shall be monitored weekly to ensure it is operating between 35 to 50KV. [District Rule 2201] Y
- Permittee shall maintain records of the wet ESP's secondary DC voltage and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Y

Modify the following conditions from the current Permits to Operate (strike out format):

- When any unit connected to scrubber/wet ESP is burning TEOR gas, scrubber/wet ESP shall be operating and permittee shall demonstrate compliance with ~~PM₁₀ and~~ sulfur oxide emissions limit by stack source testing within 60 days of initial scrubbing date and annually thereafter unless no TEOR gas has been burned since the last scrubber performance source test. Sulfur removal efficiency of scrubber/wet ESP shall be demonstrated during initial stack source test and calculated with subsequent tests. Ongoing compliance with sulfur oxide emissions limit shall be by calculation using the scrubber liquid pH, the demonstrated sulfur removal efficiency, and the fuel gas sulfur content. Fuel gas sulfur content shall be obtained by sample analysis at least quarterly. [District Rule 2201] Y

Annual source testing shall resume if any test fails to show compliance. [District Rule 2201] Y

Compliance with all applicable rules and regulations is expected. Issue ATC S-1372-127-26 and S-1372-317-16 subject to the permit conditions on the attached draft ATC in **Appendix C**.

X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
S-1372-127-26	3020-02-H	62.5 MMBtu/hr	\$1080.00
S-1372-317-16	3020-02-H	67.5 MMBtu/hr	\$1080.00

Appendixes

- A: Current PTO(s)
- B: Compliance Certification
- C: Draft ATC

APPENDIX A
Current PTOs

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-127-24

EXPIRATION DATE: 05/31/2016

SECTION: 06 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR #43 EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR, O2 CONTROLLER, AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-317 (MCKITTRICK FRONT LEASE)

PERMIT UNIT REQUIREMENTS

1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of gas combusted in the unit shall be installed, utilized and maintained for each fuel line. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Exhaust from unit shall be directed only to SO2 scrubber/wet ESP authorized herein except when burning PUC quality natural gas exclusively. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Scrubber/wet ESP shall be in operation when combusting TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Except during start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 9 ppmvd NOx @ 3% O2 or 0.011 lb-NOx/MMBtu, 0.324 lb-SOx/MMBtu, 0.008 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O2 or 0.0364 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. During start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, 0.324 lb-SOx/MMBtu, 0.008 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O2 or 0.0364 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
9. Duration of startup and shutdown shall not exceed 2 hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Daily records of start-up and shutdown durations and number of occurrences of each shall be maintained. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Total sulfur oxide (SO_x as SO₂) emissions shall not exceed 1,075.2 lb/day from steam generators S-1372-1, '2, '4, '127, '317, and flare '100. [District Rule 2201] Federally Enforceable Through Title V Permit
12. PM₁₀ emissions from this unit shall not exceed 4,161 lb-PM₁₀/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. All vapor recovery gas burned in this device shall first be treated by the scrubber/wet ESP so at least 95% by weight of the sulfur is removed. [District Rules 2201, 4301, 4320, 4406, and 4801] Federally Enforceable Through Title V Permit
14. Compliance with the 95% by weight sulfur removal efficiency shall be conducted at least once every twelve months. [District Rule 4320] Federally Enforceable Through Title V Permit
15. The SO_x emission control system efficiency shall be determined using the following equation: Percent Control Efficiency = $[(\text{CSO}_2, \text{inlet} - \text{CSO}_2, \text{outlet}) / \text{CSO}_2, \text{inlet}] \times 100$, where "CSO₂, inlet" is equal to the concentration of SO_x (expressed as SO₂) at the inlet side of the SO_x emission control system (in lb/dscf) and "CSO₂, outlet" is equal to the concentration of SO_x (expressed as SO₂) at the outlet side of the SO_x emission control system (in lb/dscf). [District Rule 4320] Federally Enforceable Through Title V Permit
16. The total gas fired in this unit, on a monthly average, shall be less than 50% PUC quality natural gas, by volume. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet and no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet. PUC quality natural gas also means high methane gas of at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall maintain monthly records of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
18. Scrubber/wet ESP control efficiency shall not be less than 95% by weight sulfur compounds. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Scrubber liquor pH shall be maintained within the range demonstrated to achieve compliance with SO₂ emissions limit and control efficiency performance, and shall be continuously monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Scrubber mist eliminator shall be properly cleaned and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than that demonstrated to achieve compliance during source testing. [District Rule 2201] Federally Enforceable Through Title V Permit
22. When any unit connected to scrubber/wet ESP is burning TEOR gas, scrubber/wet ESP shall be operating and permittee shall demonstrate compliance with PM₁₀ and sulfur oxide emissions limit by stack source testing within 60 days of initial scrubbing date and annually thereafter unless no TEOR gas has been burned since the last scrubber performance source test. Sulfur removal efficiency of scrubber/wet ESP shall be demonstrated during initial stack source test and calculated with subsequent tests. Ongoing compliance with sulfur oxide emissions limit shall be by calculation using the scrubber liquid pH, the demonstrated sulfur removal efficiency, and the fuel gas sulfur content. Fuel gas sulfur content shall be obtained by sample analysis at least quarterly. [District Rule 2201] Federally Enforceable Through Title V Permit
23. When unit is operated without scrubber/wet ESP, permittee shall demonstrate compliance with the sulfur oxide emissions limit by analysis of the fuel gas sulfur content within 60 days of initiating operation without scrubber. Analyses, as approved by the APCO, provided by the gas supplier may be used to satisfy this requirement. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. When complying with PM10 and SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Methods 5 or 201A, 6, 6B, 8, or ARB 100. When operating unscrubbed, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 may be used to calculate SOx emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every 36 months unless testing is required by scrubber operational mode change as noted above. Annual source testing shall resume if any test fails to show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
31. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
33. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

34. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
35. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
36. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
37. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
38. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
39. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
41. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
42. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
43. In lieu of the annual source testing requirements of Rule 4320, compliance with the applicable emission limits may be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided that all of the conditions in Section 6.3.2 are met and documented. [District Rule 4320] Federally Enforceable Through Title V Permit
44. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx and CO limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
45. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
46. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

47. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
48. The number of representative units source tested to demonstrate compliance for NOx and CO limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
49. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
50. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
51. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
52. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit
53. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
54. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
55. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [District Rule 4406]
56. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4801 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
57. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

58. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-317-14

EXPIRATION DATE: 05/31/2016

SECTION: 06 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

67.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-127 (MCKITTRICK FRONT LEASE)

PERMIT UNIT REQUIREMENTS

1. Unit shall be fired only on PUC quality natural gas or TEOR waste gas. [District NSR Rule] Federally Enforceable Through Title V Permit
2. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of gas combusted in the unit shall be installed, utilized and maintained for each fuel line. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Exhaust from unit shall be directed only to SO₂ scrubber/wet ESP listed on S-1372-127 except when burning PUC quality natural gas exclusively. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Scrubber/wet ESP listed on S-1372-127 shall be in operation when combusting TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
7. This steam generator shall be exclusively fired on PUC quality natural gas when steam generators S-1372-13, 16, and 24 are gas fired and incinerating TEOR waste gas. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
9. Duration of startup and shutdown shall not exceed 2 hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Except during start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 9 ppmvd NOX @ 3% O₂ or 0.011 lb-NOX/MMBtu, 0.324 lb-SOX/MMBtu, 0.008 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.0364 lb-CO/MMBtu, or 0.039 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. During start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NOX @ 3% O2 or 0.018 lb-NOX/MMBtu, 0.324 lb-SOX/MMBtu, 0.008 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O2 or 0.0364 lb-CO/MMBtu, or 0.039 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1,075.2 lb/day from steam generators S-1372-1, '2, '4, '127, '317, and flare '100. [District Rule 2201] Federally Enforceable Through Title V Permit
13. PM10 emissions from this unit shall not exceed 4,161 lbs-PM10/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. All vapor recovery gas burned in this device shall first be treated by the scrubber/wet ESP so at least 95% by weight of the sulfur is removed. [District Rules 2201, 4301, 4320, 4406, and 4801] Federally Enforceable Through Title V Permit
15. Compliance with the 95% by weight sulfur removal efficiency shall be conducted at least once every twelve months. [District Rule 4320] Federally Enforceable Through Title V Permit
16. The SOx emission control system efficiency shall be determined using the following equation: Percent Control Efficiency = $[(CSO_2, \text{inlet} - CSO_2, \text{outlet}) / CSO_2, \text{inlet}] \times 100$, where "CSO2, inlet" is equal to the concentration of SOx (expressed as SO2) at the inlet side of the SOx emission control system (in lb/dscf) and "CSO2, outlet" is equal to the concentration of SOx (expressed as SO2) at the outlet side of the SOx emission control system (in lb/dscf). [District Rule 4320] Federally Enforceable Through Title V Permit
17. The total gas fired in this unit, on a monthly average, shall be less than 50% PUC quality natural gas, by volume. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet and no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet. PUC quality natural gas also means high methane gas of at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall maintain monthly records of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
19. When complying with PM10 and SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Methods 5 or 201A, 6, 6B, 8, or ARB 100. When operating unscrubbed, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 may be used to calculate SOx emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every 36 months unless testing is required by scrubber operational mode change as noted above. Annual source testing shall resume if any test fails to show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District Rule 1070] Federally Enforceable Through Title V Permit
22. Daily records of start-up and shutdown durations and number of occurrences of each shall be maintained. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Permittee shall maintain daily records of volume of natural gas burned and TEOR waste gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
24. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR waste gas incinerated in this unit. [District Rule 4406, 4.0] Federally Enforceable Through Title V Permit
25. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rule 4406, 4.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081] Federally Enforceable Through Title V Permit
27. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
31. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
34. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
35. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
36. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
39. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
41. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
42. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
43. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
44. In lieu of the annual source testing requirements of Rule 4320, compliance with the applicable emission limits may be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided that all of the conditions in Section 6.3.2 are met and documented. [District Rule 4320] Federally Enforceable Through Title V Permit
45. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx and CO limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
46. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
47. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
48. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
49. The number of representative units source tested to demonstrate compliance for NOx and CO limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

50. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
51. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
52. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
53. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit
54. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
55. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
56. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [District Rule 4406]
57. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4801 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
58. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

APPENDIX B
Compliance Certification



San Joaquin Valley Unified Air Pollution Control District



TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE
 MINOR PERMIT MODIFICATION AMENDMENT

COMPANY NAME: Freeport-McMoRan Oil & Gas	FACILITY ID: S-1372
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: Freeport-McMoRan Oil & Gas	
3. Agent to the Owner: Kenneth R. Bork	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- KRB* Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- KRB* Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- KRB* Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- KRB* Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:

SK

Signature of Responsible Official

5/21/2014

Date

STEVEN P. RUSCH

Name of Responsible Official (please print)

Vice President EH&S and Government Affairs

Title of Responsible Official (please print)

APPENDIX C
December 16, 2015 Source Test Results
and
Source test History

12-16-15

Facility: 5 1372 FREEPORT-MC MORAN OIL & GAS

Permit ID: 127

Mod#: 24

Test Tracking

Periodic Test Setup

Test Equipment Details

Test Result Details

Representative Test

Unit Identification:

SG 43 RETEST

1 Unit Total

Description:

Add New Unit

Save

Cancel

Test Results For: SG 43 RETEST

Pollutant	Units	Limit	Result	Failed	O2 Correction (%)	# Runs	Description
PM10	gr/gscf	0.1	0.038	<input type="checkbox"/>		3	
PM10	lbs/MMBtu	0.008	0.006	<input type="checkbox"/>		3	
PM10	gr/dscf@12%CO2	0.1	0.037	<input type="checkbox"/>		3	

Add New Pollutant...

Close

Save

12-16-15

Facility: S 1372 FREEPORT-MC MORAN OIL & GAS

Permit ID: 317

Mod#: 14

Test Tracking

Periodic Test Setup

Test Equipment Details

Test Result Details

Representative Test

Unit Identification:

SG 47 RETEST

1 Unit Total

Description:

[Empty description box]

Add New Unit

Save

Cancel

Test Results For: SG 47 RETEST


Pollutant	Units	Limit	Result	Failed	O2 Correction (%)	# Runs	Description
PM10	lbs/MMBtu	0.008	0.006	<input type="checkbox"/>		3	
PM10	gr/dscf@12%CO2	0.1	0.0037	<input type="checkbox"/>		3	
PM10	gr/dscf	0.1	0.0038	<input type="checkbox"/>		3	

Add New Pollutant

Close

Save

WESP EMISSIONS



APPENDIX D
Draft ATCs

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-1372-127-26

LEGAL OWNER OR OPERATOR: FREEPORT-MC MORAN OIL & GAS
MAILING ADDRESS: 1200 DISCOVERY DRIVE, SUITE 500
BAKERSFIELD, CA 93309

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
CA

SECTION: 06 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 62.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR #43 EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR, O2 CONTROLLER, AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-317 (MCKITTRICK FRONT LEASE): REMOVE PM10 SOURCE TEST REQUIREMENT

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District Rule 2201] Federally Enforceable Through Title V Permit
4. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of gas combusted in the unit shall be installed, utilized and maintained for each fuel line. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
5. Exhaust from unit shall be directed only to SO2 scrubber/wet ESP authorized herein except when burning PUC quality natural gas exclusively. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

DRAFT

Arnaud Marjolle, Director of Permit Services

S-1372-127-26 : Apr 4 2016 7:56AM - DAVIDSOS : Joint Inspection NOT Required

6. Scrubber/wet ESP shall be in operation when combusting TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Except during start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 9 ppmvd NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu, 0.324 lb-SO_x/MMBtu, 0.008 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.0364 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. During start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.324 lb-SO_x/MMBtu, 0.008 lb-PM₁₀/MMBtu, 50 ppmvd CO @ 3% O₂ or 0.0364 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
11. Duration of startup and shutdown shall not exceed 2 hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Daily records of start-up and shutdown durations and number of occurrences of each shall be maintained. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. Total sulfur oxide (SO_x as SO₂) emissions shall not exceed 1,075.2 lb/day from steam generators S-1372-1, '2, '4, '127, '317, and flare '100. [District Rule 2201] Federally Enforceable Through Title V Permit
14. All vapor recovery gas burned in this device shall first be treated by the scrubber/wet ESP so at least 95% by weight of the sulfur is removed. [District Rules 2201, 4301, 4320, 4406, and 4801] Federally Enforceable Through Title V Permit
15. Compliance with the 95% by weight sulfur removal efficiency shall be conducted at least once every twelve months. [District Rule 4320] Federally Enforceable Through Title V Permit
16. The SO_x emission control system efficiency shall be determined using the following equation: Percent Control Efficiency = $[(\text{CSO}_2, \text{inlet} - \text{CSO}_2, \text{outlet}) / \text{CSO}_2, \text{inlet}] \times 100$, where "CSO₂, inlet" is equal to the concentration of SO_x (expressed as SO₂) at the inlet side of the SO_x emission control system (in lb/dscf) and "CSO₂, outlet" is equal to the concentration of SO_x (expressed as SO₂) at the outlet side of the SO_x emission control system (in lb/dscf). [District Rule 4320] Federally Enforceable Through Title V Permit
17. The total gas fired in this unit, on a monthly average, shall be less than 50% PUC quality natural gas, by volume. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet and no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet. PUC quality natural gas also means high methane gas of at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall maintain monthly records of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit
19. Scrubber/wet ESP control efficiency shall not be less than 95% by weight sulfur compounds. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Scrubber liquor pH shall be maintained within the range demonstrated to achieve compliance with SO₂ emissions limit and control efficiency performance, and shall be continuously monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

21. Scrubber mist eliminator shall be properly cleaned and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
22. The wet ESP's secondary DC voltage shall be monitored weekly to ensure it is operating between 35 to 50KV [District Rule]
23. Scrubber recirculation liquor liquid to gas ratio shall be maintained at no less than that demonstrated to achieve compliance during source testing. [District Rule 2201] Federally Enforceable Through Title V Permit
24. When any unit connected to scrubber/wet ESP is burning TEOR gas, scrubber/wet ESP shall be operating and permittee shall demonstrate compliance with sulfur oxide emissions limit by stack source testing within 60 days of initial scrubbing date and annually thereafter unless no TEOR gas has been burned since the last scrubber performance source test. Sulfur removal efficiency of scrubber/wet ESP shall be demonstrated during initial stack source test and calculated with subsequent tests. Ongoing compliance with sulfur oxide emissions limit shall be by calculation using the scrubber liquid pH, the demonstrated sulfur removal efficiency, and the fuel gas sulfur content. Fuel gas sulfur content shall be obtained by sample analysis at least quarterly. [District Rule 2201] Federally Enforceable Through Title V Permit
25. When unit is operated without scrubber/wet ESP, permittee shall demonstrate compliance with the sulfur oxide emissions limit by analysis of the fuel gas sulfur content within 60 days of initiating operation without scrubber. Analyses, as approved by the APCO, provided by the gas supplier may be used to satisfy this requirement. [District Rule 2201] Federally Enforceable Through Title V Permit
26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Methods 6, 6B, 8, or ARB 100. When operating unscrubbed, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 may be used to calculate SOx emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every 36 months unless testing is required by scrubber operational mode change as noted above. Annual source testing shall resume if any test fails to show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
32. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. Source testing to measure NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
35. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
39. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
41. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
42. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
43. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
44. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
45. In lieu of the annual source testing requirements of Rule 4320, compliance with the applicable emission limits may be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided that all of the conditions in Section 6.3.2 are met and documented. [District Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

46. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx and CO limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
47. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
48. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
49. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
50. The number of representative units source tested to demonstrate compliance for NOx and CO limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
51. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
52. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
53. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
54. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit
55. {519} Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

56. Permittee shall maintain records of the wet ESP's secondary DC voltage and shall be made readily available for District inspection upon request [District Rule 2201] Federally Enforceable Through Title V Permit
57. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
58. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [District Rule 4406]
59. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4801 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
60. {565} Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
61. {1670} This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-1372-317-16

LEGAL OWNER OR OPERATOR: FREEPORT-MC MORAN OIL & GAS
MAILING ADDRESS: 1200 DISCOVERY DRIVE, SUITE 500
BAKERSFIELD, CA 93309

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
CA

SECTION: 06 TOWNSHIP: 30S RANGE: 22E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 67.5 MMBTU/HR NATURAL GAS/TEOR GAS-FIRED STEAM GENERATOR EQUIPPED WITH A NORTH AMERICAN MODEL MAGNA-FLAME G-LE LOW NOX BURNER, FGR AND EXHAUST GAS SOX SCRUBBER W/ESP SHARED WITH S-1372-127 (MCKITTRICK FRONT LEASE); REMOVE PM10 SOURCE TEST REQUIREMENT

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Unit shall be fired only on PUC quality natural gas or TEOR waste gas. [District NSR Rule] Federally Enforceable Through Title V Permit
4. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of gas combusted in the unit shall be installed, utilized and maintained for each fuel line. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
5. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Exhaust from unit shall be directed only to SO2 scrubber/wet ESP listed on S-1372-127 except when burning PUC quality natural gas exclusively. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

DRAFT

Arnaud Marjolle, Director of Permit Services

S-1372-317-16 - Apr 4 2016 7:56AM - DAVIDSOS : Joint Inspection NOT Required

7. Scrubber/wet ESP listed on S-1372-127 shall be in operation when combusting TEOR gas. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
9. This steam generator shall be exclusively fired on PUC quality natural gas when steam generators S-1372-13, 16, and 24 are gas fired and incinerating TEOR waste gas. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
11. Duration of startup and shutdown shall not exceed 2 hours each per occurrence and, combined, shall not exceed 4 hours per day. During startup or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of startup and shutdown periods. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 9 ppmvd NOX @ 3% O2 or 0.011 lb-NOX/MMBtu, 0.324 lb-SOX/MMBtu, 0.008 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O2 or 0.0364 lb-CO/MMBtu, or 0.039 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. During start-up and shutdown, emissions from the steam generator shall not exceed any of the following limits: 15 ppmvd NOX @ 3% O2 or 0.018 lb-NOX/MMBtu, 0.324 lb-SOX/MMBtu, 0.008 lb-PM10/MMBtu, 50 ppmvd CO @ 3% O2 or 0.0364 lb-CO/MMBtu, or 0.039 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1,075.2 lb/day from steam generators S-1372-1, '2, '4, '127, '317, and flare '100. [District Rule 2201] Federally Enforceable Through Title V Permit
15. All vapor recovery gas burned in this device shall first be treated by the scrubber/wet ESP so at least 95% by weight of the sulfur is removed. [District Rules 2201, 4301, 4320, 4406, and 4801] Federally Enforceable Through Title V Permit
16. Compliance with the 95% by weight sulfur removal efficiency shall be conducted at least once every twelve months. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The SOx emission control system efficiency shall be determined using the following equation: Percent Control Efficiency = $[(\text{CSO}_2, \text{inlet} - \text{CSO}_2, \text{outlet}) / \text{CSO}_2, \text{inlet}] \times 100$, where "CSO2, inlet" is equal to the concentration of SOx (expressed as SO2) at the inlet side of the SOx emission control system (in lb/dscf) and "CSO2, outlet" is equal to the concentration of SOx (expressed as SO2) at the outlet side of the SOx emission control system (in lb/dscf). [District Rule 4320] Federally Enforceable Through Title V Permit
18. The total gas fired in this unit, on a monthly average, shall be less than 50% PUC quality natural gas, by volume. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet and no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet. PUC quality natural gas also means high methane gas of at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of the volume of PUC quality natural gas and the total gas fired in this unit. Permittee shall keep monthly records of the percentage by volume of PUC quality gas fired and indicate if the volume of PUC quality gas fired is less than 50%. [District Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

20. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Methods 6, 6B, 8, or ARB 100. When operating unscrubbed, a grab sample analysis by double GC performed in the laboratory and EPA Method 19 may be used to calculate SOx emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every 36 months unless testing is required by scrubber operational mode change as noted above. Annual source testing shall resume if any test fails to show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Sulfur compound (SO₂) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H₂S concentration. [District Rule 1070] Federally Enforceable Through Title V Permit
23. The wet ESP's secondary DC voltage shall be monitored weekly to ensure it is operating between 35 to 50KV [District Rule]
24. Permittee shall maintain daily records of volume of natural gas burned and TEOR waste gas incinerated. [District NSR Rule] Federally Enforceable Through Title V Permit
25. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the TEOR waste gas incinerated in this unit. [District Rule 4406, 4.0] Federally Enforceable Through Title V Permit
26. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NO_x testing, except for natural gas purchased from a PUC regulated utility. [District Rule 4406, 4.0] Federally Enforceable Through Title V Permit
27. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081] Federally Enforceable Through Title V Permit
28. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

32. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
33. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
34. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
35. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
37. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
39. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
40. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
41. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
42. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
43. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
44. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
45. In lieu of the annual source testing requirements of Rule 4320, compliance with the applicable emission limits may be demonstrated by submittal of annual emissions test results to the District from a unit or units that represents a group of units, provided that all of the conditions in Section 6.3.2 are met and documented. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx and CO limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx or CO emissions limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2, 4306, 4320 and 4321, 6.3.2] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

47. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NO_x and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 4305, 6.3.2, 4306, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
48. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
49. All units in a group for which representative units are source tested to demonstrate compliance for NO_x and CO limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
50. The number of representative units source tested to demonstrate compliance for NO_x and CO limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 4305, 6.3.2, 4306, 6.3.2, 4320 and 4351, 6.3.2] Federally Enforceable Through Title V Permit
51. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
52. When complying with SO_x emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
53. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3246, D 4084, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
54. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit
55. {519} Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
56. Permittee shall maintain records of the wet ESP's secondary DC voltage and shall be made readily available for District inspection upon request [District Rule 2201] Federally Enforceable Through Title V Permit
57. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

58. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [District Rule 4406]
59. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rules 4801 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
60. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT