



JUL 0 6 2016

Mr. Jeffrey Beecher Tricor Refining LLC 1134 Manor St Bakersfield, CA 93308

Final - Authority to Construct / Certificate of Conformity (Significant

District Facility # S-44 Project # 1153979

Dear Mr. Beecher:

The Air Pollution Control Officer has issued an Authority to Construct (Authority to Construct (ATC) S-44-4-19) with a Certificate of Conformity to Tricor Refining LLC at 1134Manor St, Bakersfield, CA. The project authorizes modification to a refinery heater. Enclosed are the Authority to Construct and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permit was published on April 7, 2016. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on April 12, 2016. No comments were received following the District's preliminary decision on this project.

Prior to operating with the modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms have been enclosed for your use. These forms may also be found on the District's website at www.valleyair.org.

> Seyed Sadredin Executive Director/Air Pollution Control Officer

Mr. Jeffrey Beecher Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

Arnaud Marjollet

Director of Permit Services

Enclosures

CC:

Tung Le, CARB (w/enclosure) via email Gerardo C. Rios, EPA (w/enclosure) via email CC:





Facility # S-44 TRICOR REFINING, LLC PO BOX 5877 BAKERSFIELD, CA 93308

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

- 1. Pay Invoice: Please pay enclosed invoice before due date.
- 2. Modify Your Title V Permit. Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at http://www.valleyair.org/busind/pto/ptoforms/1ptoformidx.htm.
- 3. Fully Understand ATC: Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
- 4. Follow ATC: You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
- 5. **Notify District**: You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
- 6. Source Test: Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source testing.htm for source testing resources.
- 7. Maintain Records: Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

For assistance, please contact District Compliance staff at any of the telephone numbers listed below.

> Seyed Sadredin Executive Director/Air Pollution Control Officer

Northern Region 4800 Enterprise Way Modesto, CA 95356-8718 Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office) 1990 E. Gettysburg Avenue Fresno, CA 93726-0244 Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region 34946 Flyover Court Bakersfield, CA 93308-9725 Tel: 661-392-5500 FAX: 661-392-5585





AUTHORITY TO CONSTRUCT

PERMIT NO: S-44-4-19 ISSUANCE DATE: 06/01/2016

LEGAL OWNER OR OPERATOR: TRICOR REFINING, LLC

MAILING ADDRESS: PO BOX 5877

BAKERSFIELD, CA 93308

LOCATION: 1134 MANOR STREET

BAKERSFIELD, CA

SECTION: 07 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

MODIFICATION OF DORMANT 4.5 MMBTU/HR LUBE OIL FINISHING PLANT - UTILITY FRACTIONATOR INCLUDING THREE ATMOSPHERIC COLUMN NOS. D-11, D-21, & D-31, STANDBY HEATER NOS. 11, 21, & 31, AND HEAT OIL EXCHANGER NOS. E 551, E-552, & E-553: INSTALL CLEARSIGN DUPLEX BURNER ARCHITECTURE IN HEATER #21, INCREASE RATING TO 15 MMBTU/HR, REDUCE NOX TO 6 PPMV @ 3% O2, REMOVE DORMANT STATUS, AND REVISE SLC TO INCLUDE ONLY HEATERS #11 AND #31

CONDITIONS

- 1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
- 2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
- 3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter 345 lb, 2nd quarter 345 lb, 3rd quarter 345 lb, and fourth quarter 345 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

- 4. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter 299 lb, 2nd quarter 300 lb, 3rd quarter 300 lb, and fourth quarter 300 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. SOx ERCs may be used for PM10 offsets at a 1.0 interpollutant offset ratio. [District Rule 2201] Federally Enforceable Through Title V Permit
- 5. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter 271 lb, 2nd quarter 271 lb, 3rd quarter 271 lb, and fourth quarter 272 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
- 6. ERC Certificate Numbers S-3210-1, S-3461-2, and S-3465-5 (or certificates split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
- 7. No modification to Heaters #11 and #31 shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
- 8. The fuel supply line shall be physically disconnected from Heaters #11 and #31 while dormant. [District Rules 2201, 4306, 4307] Federally Enforceable Through Title V Permit
- 9. Heaters #11 and #31 shall not be operated for any reason until Authority to Construct permits are issued approving all necessary retrofits required to comply with the applicable requirements of either Rule 4306 or 4307 and all other applicable District regulations. [District Rules 4306, 4307] Federally Enforceable Through Title V Permit
- 10. Heaters #11, #21, and #31shall not be fired during operation of gas turbine engine (S-73-2) except as provided below. [District Rule 2201] Federally Enforceable Through Title V Permit
- 11. Gas turbine engine may operate concurrently with heaters listed in any single permit S-44-1, -2, -3, -4, or -6 provided the cumulative concurrent operation of gas turbine engine with any heaters listed in any of permit units S-44-1, -2, -3, -4, and -6 does not exceed 360 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
- 12. Permittee shall notify the District in writing within 24 hours upon firing of heaters. [District Rule 2201] Federally Enforceable Through Title V Permit
- 13. Refinery produced fuel gas shall be treated in H2S scrubber listed in S-44-13. [District Rule 2201] Federally Enforceable Through Title V Permit
- 14. Refinery produced fuel gas shall be burned in C.B. boiler S-44-13 and/or solvent plant Heater S-44-2. [District Rule 2201] Federally Enforceable Through Title V Permit
- 15. Heaters #11 and #31 shall not be fired at greater than 4.5 MMBTU/hr combined for the two heaters. [District Rule 2201] Federally Enforceable Through Title V Permit
- 16. Crude oil throughput for S-44-1 and S-44-4 combined shall not exceed 12,800 barrels per day. [District Rule 2201] Federally Enforceable Through Title V Permit
- 17. Standby Heaters #11 and #31 and Heater #21 shall be fired solely on PUC regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
- 18. Emissions from either of the standby Heaters (#11 and 31) shall not exceed any of the following limits: 0.10 lb-NOx/MMBtu, 0.084 lb-CO/MMBtu, 0.0055 lb-VOC/MMBtu, 0.0076 PM10/MMBtu, or 0.00285 lb-SOx/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
- 19. Emissions from Heater #21 shall not exceed any of the following limits: 6 ppmv NOx @ 3% O2 or 0.007 lb-NOx/MMBtu, 50 ppmv CO @ 3% O2 or 0.037 lb-CO/MMBtu, 0.0055 lb-VOC/MMBtu, 0.0076 PM10/MMBtu, or 0.00285 lb-SOx/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

- 20. Sum of annual emissions from heaters and boilers listed on permits S-44-1, -2, -3, -4, -5, -6 and -13 shall not exceed any of the the following: NOx 94.95 tpy, CO 154.66 tpy, VOC 7.39 tpy, PM10 18.10 tpy or SOx 30.70 tpy. [District Rule 2201] Federally Enforceable Through Title V Permit
- 21. Upon resuming operation of Heaters #11 and #31, the stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305] Federally Enforceable Through Title V Permit
- 22. Sampling facilities for source testing shall be provided in accordance with the provisions of District Rule 1081 (amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
- 23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 25. Source testing to measure NOx and CO emissions from Heater #21 while fired on natural gas shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 26. Source testing to measure NOx and CO emissions from Heater #21, while fired on natural gas, shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 27. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 28. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 29. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 30. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
- 31. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 32. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 33. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
- 34. Upon resuming operation of Heaters #11 and #31, source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305, and 4351] Federally Enforceable Through Title V Permit
- 35. Upon resuming operation of Heaters #11 and #31, source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305, and 4351] Federally Enforceable Through Title V Permit

- 36. Upon resuming operation of Heaters #11 and #31, if permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305, and 4351] Federally Enforceable Through Title V Permit
- 37. Upon resuming operation of Heaters #11 and #31, source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305, and 4351] Federally Enforceable Through Title V Permit
- 38. Upon resuming operation of Heaters #11 and #31, compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
- 39. Upon resuming operation of Heaters #11 and #31, source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
- 40. Upon resuming operation of Heaters #11 and #31, the results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
- 41. Upon resuming operation of Heaters #11 and #31, the following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
- 42. Upon resuming operation of Heaters #11 and #31, if the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed for more than one hour the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
- 43. The permittee shall monitor and record the Heater #21 stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the same calendar month. [District Rules 4305, 4306 and 4320]
- 44. If either the Heater #21 NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320]
- 45. All Heater #21 alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]

- 46. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]
- 47. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 1070, 2201, 2520, 9.4.2, 4305, and 4320] Federally Enforceable Through Title V Permit
- 48. Permittee shall maintain accurate records of fuel type, annual fuel consumption, annual emissions from the Heaters, and daily crude oil throughput. [District Rule 2201] Federally Enforceable Through Title V Permit
- 49. Permittee shall maintain records of hours of concurrent operation of gas turbine engine S-73-2 with any Heaters listed in permit units S-44-1, -2, -3, -4 & -6. [District Rule 2201] Federally Enforceable Through Title V Permit
- 50. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2201, 2520, 9.4.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
- 51. Upon resuming operation of Heaters #11 and #31, the portable analyzer shall be calibrated each day of use with a two-point calibration method (zero and span) at beginning of the day. Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 52. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(amended December 16,1993). [District Rule 1081, and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
- 53. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type of fuel combusted. [District Rule 2520, 9.3.2 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
- 54. Particulate matter emissions shall not exceed 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
- 55. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by maintaining copies of fuel invoices, gas purchase contracts, or supplier certifications. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
- 56. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period (Kern County Rule 407). Compliance with this requirement may be demonstrated by maintaining copies of fuel invoices, gas purchase contracts, or supplier certifications. [District Rule 4801] Federally Enforceable Through Title V Permit
- 57. Nitrogen oxide (NOx) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen, and lb/MMBtu rates shall be calculated as lb NO2/MMBtu of heat input (hhv). [District Rule 4305, 5.0, 8.2 and/or 4351, 8.1] Federally Enforceable Through Title V Permit
- 58. Nitrogen oxide (NOx) emissions from each heater shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2] Federally Enforceable Through Title V Permit
- 59. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081(amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
- 60. Upon resuming operation of Heaters #11 and #31, annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

- 61. Upon resuming operation of Heaters #11 and #31, the following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 4305, 6.3.2] Federally Enforceable Through Title V Permit
- 62. Upon resuming operation of Heaters #11 and #31, all units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rule 4305, 6.3.2] Federally Enforceable Through Title V Permit
- 63. Upon resuming operation of Heaters #11 and #31, all units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rule 4305, 6.3.2] Federally Enforceable Through Title V Permit
- 64. Upon resuming operation of Heaters #11 and #31, the number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit