



AUG 12 2016

Mr. Sonnie Pineda
Elk Hills Power, LLC
P O Box 460
Tupman, CA 93276

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # S-3523
Project # S-1152677**

Dear Mr. Pineda:

The District has issued the Final Renewed Title V Permit for Elk Hills Power, LLC (see enclosure). The preliminary decision for this project was made on June 28, 2016. A summary of the comments and the District's response to each comment is included as an attachment to the engineering evaluation. These permits address all deficiencies cited by the EPA.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Facility # S-3523
ELK HILLS POWER LLC
PO BOX 460
TUPMAN, CA 93276

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Permit to Operate

FACILITY: S-3523

EXPIRATION DATE: 02/28/2021

LEGAL OWNER OR OPERATOR: ELK HILLS POWER LLC
MAILING ADDRESS: PO BOX 460
TUPMAN, CA 93276

FACILITY LOCATION: 4026 SKYLINE RD
TUPMAN, CA 93276

FACILITY DESCRIPTION: ELECTRIC POWER GENERATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-3523-0-3

EXPIRATION DATE: 02/28/2021

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rules 2010 and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 2080, and 2520] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: ELK HILLS POWER LLC
Location: 4026 SKYLINE RD, TUPMAN, CA 93276
S-3523-0-3 : Aug 3 2016 7:45AM - HEINENG

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520 and 1100] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit.

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin September 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-1-12

EXPIRATION DATE: 02/28/2021

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #1 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-2 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NOx, CO, and O2. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [District Rules 1080, 4703 and 2201, 40 CFR 60.334(c), 40 CFR 64.3, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080 and 40 CFR 64.3] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality Improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District Rules 2201 and 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District Rule 2201] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rule 2201, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [40 CFR 60.334(h)(3); 40 CFR 60.48(g)(1) and District Rule 2520] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NO_x (as NO₂) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District Rule 2201] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NO_x or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NO_x or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM₁₀ - 15.0 lb/hr, SO_x (as SO₂) - 3.6 lb/hr, NO_x (as NO₂) - 15.8 lb/hr and 2.5 ppmvd @ 15% O₂, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 12.5 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District Rules 2201, 4001, and 4703, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM₁₀ - 360.0 lb/day, SO_x (as SO₂) - 86.4 lb/day, NO_x (as NO₂) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3,948.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM₁₀ - 720.0 lb/day, SO_x (as SO₂) - 172.8 lb/day, NO_x (as NO₂) - 1,103.0 lb/day, VOC - 269.0 lb/day, and CO - 4,297 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 261,960 lb/year, SO_x (as SO₂) - 57,468 lb/year, NO_x (as NO₂) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = ((a - (b x c/1,000,000)) x 1,000,000 / b) x d, where a = ammonia injection rate(lb/hr)/17(lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29(lb/lb. mol), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rules 2520, 9.3.2 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60 Subpart Da, and District Rule 4703] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District Rule 2201 and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District Rules 2201 and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [Districts Rules 2201 and 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72 and 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-2-12

EXPIRATION DATE: 02/28/2021

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #2 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-1 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NO_x, CO, and O₂. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [District Rules 1080, 4703, and 2201, 40 CFR 60.334(c), 40 CFR 64.3, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080 and 40 CFR 64.3] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District Rules 2201 and 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District Rule 2201] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rule 2201, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [District Rule 2520, 40 CFR 60.334(h)(3);and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NO_x (as NO₂) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District Rule 2201] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NO_x or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NO_x or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM₁₀ - 15.0 lb/hr, SO_x (as SO₂) - 3.6 lb/hr, NO_x (as NO₂) - 15.8 lb/hr and 2.5 ppmvd @ 15% O₂, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 12.5 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District Rules 2201, 4001, and 4703, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM₁₀ - 360.0 lb/day, SO_x (as SO₂) - 86.4 lb/day, NO_x (as NO₂) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3948.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM₁₀ - 720.0 lb/day, SO_x (as SO₂) - 172.8 lb/day, NO_x (as NO₂) - 1103.0 lb/day, VOC - 269.0 lb/day, and CO - 4,297 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 261,960 lb/year, SO_x (as SO₂) - 57,468 lb/year, NO_x (as NO₂) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = ((a - (b x c/1,000,000)) x 1,000,000 / b) x d, where a = ammonia injection rate(lb/hr)/17(lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29(lb/lb. mol), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rules 2520 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [District Rule 4703 and 40 CFR 60 Subpart Da] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703, and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District Rule 2201 and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District Rules 2201 and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [District Rules 2201, 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rule 2201 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-3-5

EXPIRATION DATE: 02/28/2021

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

FORCED DRAFT COOLING TOWER WITH 6 CELLS AND HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012]
2. Drift eliminator drift rate shall not exceed 0.0005%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. PM10 emission rate shall not exceed 11.7 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. On a weekly basis, the Permittee shall record the circulating water recirculation rate and have an independent laboratory analyze a sample of the blowdown water to determine the total dissolved solids concentration in the blowdown water. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
5. Compliance with the PM10 daily emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{circulating water recirculation rate} * \text{total dissolved solids concentration in the blowdown water} * \text{design drift rate} * \text{correction factor}$. The correction factor shall range from 0.82 for a TDS of 1,000 ppm to 0.3 for a TDS of 5,000 ppm. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of calculated PM10 emission rate and all data used in the calculations. All records shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-6-4

EXPIRATION DATE: 02/28/2021

EQUIPMENT DESCRIPTION:

240 HP CUMMINS MODEL 6CTA 8.3 F2 DIESEL-FIRED IC ENGINE DRIVING EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee shall minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. At all times, the engine and any associated air pollution control equipment and monitoring equipment shall be operated in a manner consistent with safety and good air pollution control practices for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. The PM10 emissions rate shall not exceed 0.25 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201] Federally Enforceable Through Title V Permit
7. NOx emissions shall not exceed 4.4 g/hp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 77 hours per calendar year. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rule 407 (Kern)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. The permittee shall maintain the following schedule of maintenance and inspection: Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine shall be operated and maintained according to the manufacturer's emission-related written instructions (including the after-treatment control device if any). Alternatively, a site-specific maintenance plan may be developed which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. Records of the maintenance conducted on the engine shall be maintained which demonstrate that operation and maintenance of the engine and after-treatment control device (if any) is according the facility's maintenance plan. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT

Final Title V Permit Renewal Evaluation
Elk Hills Power, LLC
S-3523

TABLE OF CONTENTS

I.	PROPOSAL	2
II.	FACILITY LOCATION	3
III.	EQUIPMENT LISTING	3
IV.	GENERAL PERMIT TEMPLATE USAGE	3
V.	SCOPE OF EPA AND PUBLIC REVIEW	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS	4
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	7
VIII.	FEDERALLY ENFORCEABLE PERMIT REQUIREMENTS	7
IX.	PERMIT SHIELD.....	15
X.	PERMIT CONDITIONS	16
XI.	ATTACHMENTS	16
A.	RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY LIST	
D.	COMMENTS RECEIVED	

TITLE V PERMIT RENEWAL EVALUATION
Cogeneration Operation

Engineer: George Heinen
Date: August 1, 2016

Facility Number: S-3523
Facility Name: Elk Hills Power, LLC
Mailing Address: PO Box 80478
Bakersfield, CA 93380-0478

Contact Name: Sonnie Pineda
Phone: (661) 765-1805

Responsible Official: Robert Bond
Title: Elk Hills Power Plant Team Leader

Project # : S-1152677
Deemed Complete: June 19, 2015

I. PROPOSAL

Elk Hills Power, LLC (EHP) was issued a Title V permit on August 31, 2006. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the renewed Title V permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions. The last Title V permit renewal was issued on 10/24/2011. This review will span from 10/24/2011 to the present.

II. FACILITY LOCATION

EHP is located at 4026 Skyline Road, Tupman, Kern County, CA.

II. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit templates:

A. *SJV-UM-0-3, Facility Wide Umbrella*

The applicant has requested to utilize template *SJV-UM-0-3, Facility Wide Umbrella*. Based on the information submitted on the Template Qualification Form, the applicant qualifies for the use of this template.

V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the proposed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the proposed permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's proposed actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate from model general permit templates and are not subject to further EPA or public review:

- Conditions 1 through 40 of the facility-wide requirements, permit unit S-3523-0

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated or Evaluated during this current renewal review interval (10/24/11 to present)

- District Rule 2020, Exemptions (amended August 18, 2011 ⇒ amended December 18, 2014)
- District Rule 2201, New and Modified Stationary Source Review Rule (amended May 21, 2011 ⇒ amended February 18, 2016)
- District Rule 4702, Internal Combustion Engines – Phase 2 (amended January 18, 2007 ⇒ November 14, 2013)
- 40 CFR 60, Subpart GG, New Source Performance Standards; Standard of Performance for Stationary Gas Turbines (amended February 27, 2014)
- 40 CFR 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (amended March 6, 2013)
- 40 CFR 64, Compliance Assurance Monitoring (CAM) (amended October 10, 1997)
- 40 CFR 82, Subpart B, Stratospheric Ozone (amended June 25, 2013)
- 40 CFR 82, Subpart F, Stratospheric Ozone (amended June 25, 2013)

B. Rules Removed during this current renewal review interval (10/24/11 to present)

None

C. Rules Added during this current renewal review interval (10/24/11 to present)

- District Rule 2410, Prevention of Significant Deterioration (adopted June 16, 2011, effective November 26, 2012)

D. Rules Not Updated during this current renewal review interval (10/24/11 to present)

- District Rule 1070, Inspections (amended December 17, 1992)
- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)
- District Rule 4101, Visible Emissions (amended February 17, 2005)
- District Rule 4102, Nuisance (amended December 17, 1992)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4202, Particulate Matter - Emission Rate (amended December 17, 1992)
- District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)
- District Rule 4601, Architectural Coatings (amended December 17, 2009)

- District Rule 4701, Internal Combustion Engines – Phase I (amended August 21, 2003)
- District Rule 4703, Stationary Gas Turbines (amended September 20, 2007)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- District Rule 8011, General Requirements (amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities (amended August 19, 2004)
- District Rule 8031, Bulk Materials (amended August 19, 2004)
- District Rule 8041, Carryout and Trackout (amended August 19, 2004)
- District Rule 8051, Open Areas (amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads (amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Area (amended September 16, 2004)
- 40 CFR 60, Subpart III, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (amended July 11, 2006)
- 40 CFR 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines (amended July 6, 2006)
- 40 CFR 61, Subpart M, National Emission Standard for Asbestos (amended September 18, 2003)
- 40 CFR 63 Subpart YYYY, National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (amended March 5, 2004)
- 40 CFR 68, Chemical Accident Prevention Provisions (amended April 9, 2004)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added

There are no new rules that are not federally enforceable being added at this time.

B. Rules Not Updated

- District Rule 4102, Nuisance (as amended December 17, 1992)

For this facility, condition #41 of the facility wide requirements S-3523-0-3 is based on District Rule 4102 listed above and is not Federally Enforceable through Title V.

- Title 17, California Code of Regulations, Section 92000 through 92540

No changes were made to these rules since the renewed Title V permit was issued, therefore, they will not be discussed any further.

VIII. FEDERALLY ENFORCEABLE PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to pertinent federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the renewed Title V permit.

A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which is specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions.

The amendments to this rule do not have any effect on current permit requirements and will therefore not be addressed in this evaluation.

B. District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

- 1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
- 2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
- 3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
- 4) Addition of any new emissions unit which is subject to District permitting requirements.
- 5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

C. District Rule 2410 – Prevention of Significant Deterioration

The prevention of significant deterioration (PSD) program is a construction permitting program for new major stationary sources and major modifications to existing major stationary sources located in areas classified as attainment or in areas that are unclassifiable for any criteria air pollutant. The provisions of this rule apply to any source and the owner or operator of any source subject to any requirement under Title 40 Code of Federal Regulations (40 CFR) Part 52.21 as incorporated into this rule.

The rule did not create new requirements, but merely transfers the authority for the 40 CFR Part 52.21 requirements to the District. Prior to adoption of this rule, that authority was vested with the USEPA. This action does not involve construction and thus does not trigger additional PSD requirements

for this source. Therefore, the facility is not subject to this rule and no further discussion is required.

D. Rule 4702 - Internal Combustion Engines

Emergency standby IC engine S-3523-6 is only subject to administrative requirements of Rule 4702 which weren't revised in the latest amendment.

There are no changes to any of the existing Rule 4702 conditions.

E. 40 CFR 60, Subpart GG - Standard of Performance for Stationary Gas Turbines

This requirement limits emissions of nitrogen oxides. Emissions shall not exceed a NO_x emission rate of 75 ppmv or 150 ppmv, depending on the unit size (at 15% O₂ with the ISO correction factor). The following analysis shows that the proposed requirement of District Rule 4703 is more stringent than 40 CFR requirements pertaining to NO_x emissions. Streamlining procedures, as documented in the following steps is utilized to substitute the proposed set of requirements for the otherwise applicable requirements.

The following table has side-by-side comparison of applicable requirements:

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Emissions Limit	Section 5.1.2 - for > 10 MW, 5 ppmv @ 15% O ₂ . (Tier II Standard Option)	60.332(a)(1) – 75 ppmv @ 15% O ₂ . (Lowest possible concentration) 60.333(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015% by volume at 15% oxygen and on a dry basis.	2.5 ppmv @ 15% O ₂ .
Work place standards	N/A	60.333(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel, which contains sulfur in excess of 0.8% by weigh (8000 ppmw).	This unit shall be fired exclusively on PUC-quality natural gas which has a total sulfur content of less than or equal to 0.75 gr/100 scf

Type of Requirement	District Rule 4703	Subpart GG, § 60.332, 60.333 and 60.334	Proposed Requirement
Monitoring	(6.2.1) Except for units subject to Section 6.2.3, for turbines with exhaust gas NO _x control devices, the owner or operator shall either install, operate, and maintain continuous emissions monitoring equipment for NO _x and oxygen, as identified in Rule 1080 (Stack Monitoring), or install and maintain APCO-approved alternate monitoring	60.334(a) The owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water injection to control NO _x emissions shall install or operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water to fuel being fired in the turbine. 60.334(b) Install, certify, maintain, operate, and quality-assure a continuous emissions monitoring system for NO _x and O ₂ . 60.334(h)(3) The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) demonstrated by representative fuel sampling data which shows that sulfur content of gas does not exceed 0.25 gr/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of Appendix D of 40 CFR part 75 is required	The owner or operator shall install, certify, maintain, operate, and quality-assure a system which continuously measures and records the exhaust gas NO _x and O ₂ concentrations. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377.
Reporting	As per District Rule 1080: Time intervals, data and magnitude of excess NO _x emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred	60.334(J) the owner or operator shall submit reports of excess emissions and monitor downtime as required under §60.7(c), periods of excess emissions that shall be reported are defined as follows: 60.334(J)(1)(iii) - An hour of excess emissions shall be any operating hour in which 4-hour rolling average NO _x concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO _x or diluent (or both). 60.334(J)(5): all reports required under §60.7(c) shall be post marked by 30 th day following the end of each calendar quarter.	The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred .
Testing	Annual Testing for nitrogen oxides (NO _x) concentrations using EPA Method 20 or 7E and oxygen (O ₂) using Method 3, 3A, or 20.	Initial NO _x performance testing using EPA method 20 or 7E and EPA method 3, 3A for O ₂ .	Annual Testing for nitrogen oxides (NO _x) concentrations using EPA Method 7E and oxygen (O ₂) using Method 3, 3A, or 20.

The District Rule 4703 requirement to limit NOx concentration to 5 ppmv @ 15% O2 is clearly more stringent than the Subpart GG emissions limit of 75 ppmv as discussed below. The draft PTO assures compliance with this requirement.

Compliance with SO_x Emission Concentration Limit - 60.333(a):

Natural gas suppliers in California (PG&E, SOCal Gas, etc.) regulate the quality of the gas as following:

- Mojave Gas Company's FERC Gas Tariff General Terms and Conditions (4/1/16) requires that delivered natural gas contain no more than 0.75 gr/100 scf total sulfur.

The California Air Resource Board (ARB), in their document Guidance for Power Plant Siting (Stationary Source Div., 6/99), also determined that 1.0 gr S/100 scf is the sulfur content of gas supplied by a utility regulated by the Public Utilities Commission (PUC).

In this case, all natural gas that is regulated enters the PUC pipeline for distribution to consumers and is tested to assure that its composition conforms to above standards. Therefore, total sulfur content of 0.75 gr/100 scf is consistent with quality of gas supplied by the utilities.

Compliance is expected as shown by the following calculations at 0.75 grain of total sulfur per 100 standard cubic feet of gas, assuming all sulfur is converted to SO₂.

$$\%S(\text{lb/lbNG}) = \left(\frac{0.75 \text{ gr}}{100 \text{ scf}} \right) \left(\frac{1 \text{ lb}}{7000 \text{ gr}} \right) \left(\frac{24.5 \text{ L}}{\text{mol NG}} \right) \left(\frac{1 \text{ mol}}{16 \text{ g}} \right) \left(\frac{454 \text{ g}}{1 \text{ lb}} \right) \left(\frac{0.035 \text{ scf}}{1 \text{ L}} \right) (100)$$

$$= 0.0026\% \text{ sulfur by weight}$$

$$\begin{aligned} \text{lb SO}_2/\text{scf gas} &= (0.000026)(1 \text{ lb}/23.8 \text{ scf gas})(64 \text{ lb SO}_2/32 \text{ lb S}) \\ &= 2.18 \text{ E-}6 \text{ lb SO}_2/\text{scf gas} \end{aligned}$$

$$\text{lb SO}_2/V_{\text{exhaust}} = (\text{lb SO}_2/\text{scf gas}) \div (\text{F factor}) (\text{Btu content of natural gas})$$

$$\left(\frac{\text{lb SO}_2}{V_{\text{exhaust}}} \right) = \frac{\left(2.18 \text{ E-}6 \frac{\text{lb SO}_2}{\text{scf gas}} \right) \left(\frac{10^6 \text{ Btu}}{\text{MMBtu}} \right)}{\left(8,578 \frac{\text{dscf}}{\text{MMBtu}} \right) \left(1000 \frac{\text{Btu}}{\text{scf}} \right)} = 2.5 \text{ E-}7 \frac{\text{lb SO}_2}{\text{dscf exhaust}}$$

$$V_{SO_2}/V_{\text{exhaust}} = nRT/P$$

where,

$$n = \text{moles } SO_2 = (3.35 \text{ E-7 lb } SO_2/\text{dscf exhaust}) / (64 \text{ lb } SO_2/\text{lb-mol})$$

$$R = \text{universal gas constant} = 10.73 \text{ psi-ft}^3/\text{lb-mol-R}$$

$$T = \text{standard temperature} = 60 \text{ }^\circ\text{F} = 520 \text{ }^\circ\text{R}$$

$$P = \text{standard pressure} = 14.7 \text{ psi}$$

$$\text{Therefore, } \left(\frac{V_{SO_2}}{V_{\text{exhaust}}} \right) = \frac{\left(\frac{2.5 \text{ E-7 lb } SO_2}{\text{dscf exhaust}} \right) \left(\frac{10.73 \text{ psi-ft}^3}{\text{lb-mole-}^\circ\text{R}} \right) (520 \text{ }^\circ\text{R})}{\left(\frac{64 \text{ lb } SO_2}{\text{lb-mol}} \right) (14.7 \text{ psi})} = 1.5 \text{ E-6 } \frac{\text{dscf}}{\text{dscf exhaust}}$$

$$= 1.5 \text{ ppmv dry}$$

Diluting it to 15% O₂

$$\text{ppmv@15\%O}_2 = \text{ppmv dry} \times \left(\frac{20.9 - 15}{20.9} \right) = 1.7 \text{ ppmv}$$

1.7 ppmv << 150 ppmv.

Compliance with 150 ppmv SO_x at 15% excess O₂ and dry standard conditions and 2,000 ppmv is assured because the unit has a fuel sulfur content of 0.75 gr/100 scf. Condition 1 of the turbine permits ensures compliance with this rule and condition.

Compliance with Sulfur Fuel Content Limit - 60.333(b):

Natural gas with fuel sulfur content of 0.3 gr/100 scf or less assures compliance with the 0.8% sulfur by weight limit of New Source Performance Standard, Subpart GG - 40 CFR Subpart 60.333(b). This standard can be converted to an expression of weight percent of sulfur in the natural gas (ng):

$$\%S(\text{lb/lb NG}) = \left(\frac{0.75 \text{ gr}}{100 \text{ scf}} \right) \left(\frac{1 \text{ lb}}{7000 \text{ gr}} \right) \left(\frac{24.5 \text{ L}}{\text{mol NG}} \right) \left(\frac{1 \text{ mol}}{16 \text{ g}} \right) \left(\frac{454 \text{ g}}{1 \text{ lb}} \right) \left(\frac{0.035 \text{ scf}}{1 \text{ L}} \right) (100)$$

$$= 0.0026\% \text{ sulfur by weight}$$

Thus natural gas with fuel sulfur content of 0.75 gr/100 scf or less assures compliance with the 0.8% sulfur by weight limit of New Source Performance Standard, Subpart GG - 40 CFR Subpart 60.333(b).

F. 40 CFR 63 Subpart ZZZZ – National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Emissions (RICE)

Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAP) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This subpart also establishes requirements to demonstrate initial and continuous compliance with the emission limitations and operating limitations.

§6585(b) states, "A major source of HAP emissions is a plant site that emits or has the potential to emit any single HAP at a rate of 10 tons (9.07 megagrams) or more per year or any combination of HAP at a rate of 25 tons (22.68 megagrams) or more per year, except that for oil and gas production facilities, a major source of HAP emissions is determined for each surface site."

§6585(c) states, "An area source of HAP emissions is a source that is not a major source."

The facility is not a major source as defined in §6585(b). Therefore, this facility is an area source of HAP emissions.

§6590(a) states, "An affected source is any existing, new, or reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand."

§6590(a)(1) defines the criteria for an existing stationary RICE as follows:

- (i) For stationary RICE with a site rating of more than 500 brake horsepower (HP) located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before December 19, 2002.
- (ii) For stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.

- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

This facility is an area source of HAP emissions. The engines at this facility have not commenced construction or reconstruction on or after June 12, 2006. Therefore, the engines at this facility meet the definition of an existing stationary RICE as defined in §6590(a)(1)(iii).

§6590(b)(3) states that the following engines do not have to meet the requirements of this subpart and of subpart A of this part:

- stationary RICE which is an existing spark ignition 4 stroke rich burn (4SRB) stationary RICE located at an area source,
- existing spark ignition 4SRB stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source, an existing spark ignition 2 stroke lean burn (2SLB) stationary RICE,
- existing spark ignition 4 stroke lean burn (4SLB) stationary RICE,
- existing compression ignition (CI) stationary RICE,
- existing emergency stationary RICE,
- existing limited use stationary RICE, or
- existing stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis

The engine at this facility is an existing emergency stationary RICE and is an existing compression ignition (CI) stationary RICE. Therefore, the engine does not have to meet the requirements of this subpart and of subpart A of this part.

G. 40 CFR Part 64 - Compliance Assurance Monitoring (CAM)

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

1. The unit must have an emission limit for the pollutant;
2. The unit must have add-on controls for the pollutant (these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers); and
3. The unit must have a pre-control potential to emit of greater than the major source thresholds.

Although this regulation was not updated during this current renewal review interval (10/24/11 to present), District Rule 2201 was recently updated. The

update to the Major Source definition in that rule could affect CAM for some facilities.

As detailed in the previous Title V permit renewal, Project S-1104061, permit units S-3523-1 and S-3523-2 were both subject to CAM requirements. Those requirements have been addressed by permit conditions 3, 4, 5, 6, 7, and 8.

Permit units S-3523-3 and S-3523-4 do not have add-on controls and therefore are not subject to CAM requirements.

The Rule 2201 amendments do not change those previous CAM determinations. Therefore, this facility's units comply with the applicable CAM requirements and no further discussion is required.

H. 40 CFR 82, Subparts B and F - Stratospheric Ozone

These regulations apply to servicing motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC). Sections of this regulation were amended in 2013, and conditions 27 and 28 of permit unit S-3523-0 assure compliance with the requirements.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

By using the model general permit template listed in Section IV of this Evaluation, the applicant has requested that a permit shield be issued for requirements addressed in the template. The basis for each permit shield is discussed in the Permit Shield section of each template.

B. Requirements not Addressed by Model General Permit Templates

Elk Hills Power, LLC is not requesting any new permit shields within this Title V renewal project. In addition, Elk Hills Power, LLC is not requesting any

changes to the existing permit shields already included in their Title V operating permits. Therefore, all of the existing permit shields will be maintained on the revised permits for this renewal project.

C. Obsolete Permit Shields From Existing Permit Requirements

There are no obsolete permit shield conditions to be removed from the permits.

X. PERMIT CONDITIONS

See Attachment B - Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility List
- D. Comments Received

ATTACHMENT A

Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-3523-0-3

EXPIRATION DATE: 02/28/2021

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rules 2010 and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 2080, and 2520] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: ELK HILLS POWER LLC

Location: 4026 SKYLINE RD, TUPMAN, CA 93276

S-3523-0-3 Aug 3 2016 7:45AM - HEINENG

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520 and 1100] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin September 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-1-12

EXPIRATION DATE: 02/28/2021

SECTION: NE35 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #1 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-2 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NOx, CO, and O2. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [District Rules 1080, 4703 and 2201, 40 CFR 60.334(c), 40 CFR 64.3, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080 and 40 CFR 64.3] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District Rules 2201 and 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District Rule 2201] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rule 2201, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [40 CFR 60.334(h)(3); 40 CFR 60.48(g)(1) and District Rule 2520] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NO_x (as NO₂) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District Rule 2201] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NO_x or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NO_x or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM₁₀ - 15.0 lb/hr, SO_x (as SO₂) - 3.6 lb/hr, NO_x (as NO₂) - 15.8 lb/hr and 2.5 ppmvd @ 15% O₂, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 12.5 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District Rules 2201, 4001, and 4703, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM₁₀ - 360.0 lb/day, SO_x (as SO₂) - 86.4 lb/day, NO_x (as NO₂) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3,948.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM₁₀ - 720.0 lb/day, SO_x (as SO₂) - 172.8 lb/day, NO_x (as NO₂) - 1,103.0 lb/day, VOC - 269.0 lb/day, and CO - 4,297 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 261,960 lb/year, SO_x (as SO₂) - 57,468 lb/year, NO_x (as NO₂) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = $((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d$, where a = ammonia injection rate (lb/hr)/17 (lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29 (lb/lb. mol)), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rules 2520, 9.3.2 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60 Subpart Da, and District Rule 4703] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District Rule 2201 and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District Rules 2201 and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [Districts Rules 2201 and 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72 and 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-2-12

EXPIRATION DATE: 02/28/2021

SECTION: NE35 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #2 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-1 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District Rule 2201] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NOx, CO, and O2. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [District Rules 1080, 4703, and 2201, 40 CFR 60.334(c), 40 CFR 64.3, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080 and 40 CFR 64.3] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District Rules 2201 and 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District Rule 2201] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District Rule 2201, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [District Rule 2520, 40 CFR 60.334(h)(3);and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NO_x (as NO₂) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District Rule 2201] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NO_x or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NO_x or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM₁₀ - 15.0 lb/hr, SO_x (as SO₂) - 3.6 lb/hr, NO_x (as NO₂) - 15.8 lb/hr and 2.5 ppmvd @ 15% O₂, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 12.5 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District Rules 2201, 4001, and 4703, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM₁₀ - 360.0 lb/day, SO_x (as SO₂) - 86.4 lb/day, NO_x (as NO₂) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3948.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM₁₀ - 720.0 lb/day, SO_x (as SO₂) - 172.8 lb/day, NO_x (as NO₂) - 1103.0 lb/day, VOC - 269.0 lb/day, and CO - 4,297 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 261,960 lb/year, SO_x (as SO₂) - 57,468 lb/year, NO_x (as NO₂) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District Rule 2201 and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = ((a - (b x c/1,000,000)) x 1,000,000 / b) x d, where a = ammonia injection rate(lb/hr)/17(lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29(lb/lb. mol), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rules 2520 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [District Rule 4703 and 40 CFR 60 Subpart Da] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703, and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District Rule 2201 and 40 CFR 60.48(g)(1)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District Rules 2201 and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [District Rules 2201, 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit
44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rule 2201 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-3-5

EXPIRATION DATE: 02/28/2021

SECTION: NE35 **TOWNSHIP:** 30S **RANGE:** 23E

EQUIPMENT DESCRIPTION:

FORCED DRAFT COOLING TOWER WITH 6 CELLS AND HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012]
2. Drift eliminator drift rate shall not exceed 0.0005%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. PM10 emission rate shall not exceed 11.7 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. On a weekly basis, the Permittee shall record the circulating water recirculation rate and have an independent laboratory analyze a sample of the blowdown water to determine the total dissolved solids concentration in the blowdown water. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
5. Compliance with the PM10 daily emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{circulating water recirculation rate} * \text{total dissolved solids concentration in the blowdown water} * \text{design drift rate} * \text{correction factor}$. The correction factor shall range from 0.82 for a TDS of 1,000 ppm to 0.3 for a TDS of 5,000 ppm. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of calculated PM10 emission rate and all data used in the calculations. All records shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-6-4

EXPIRATION DATE: 02/28/2021

EQUIPMENT DESCRIPTION:

240 HP CUMMINS MODEL 6CTA 8.3 F2 DIESEL-FIRED IC ENGINE DRIVING EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee shall minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. At all times, the engine and any associated air pollution control equipment and monitoring equipment shall be operated in a manner consistent with safety and good air pollution control practices for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. The PM10 emissions rate shall not exceed 0.25 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201] Federally Enforceable Through Title V Permit
7. NOx emissions shall not exceed 4.4 g/hp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 77 hours per calendar year. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rule 407 (Kern)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. The permittee shall maintain the following schedule of maintenance and inspection: Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine shall be operated and maintained according to the manufacturer's emission-related written instructions (including the after-treatment control device if any). Alternatively, a site-specific maintenance plan may be developed which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. Records of the maintenance conducted on the engine shall be maintained which demonstrate that operation and maintenance of the engine and after-treatment control device (if any) is according the facility's maintenance plan. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 40 CFR 63 Subpart ZZZZ, and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT B

Previous Title V Operating Permit



Permit to Operate

FACILITY: S-3523

EXPIRATION DATE: 02/29/2016

LEGAL OWNER OR OPERATOR:

ELK HILLS POWER LLC

MAILING ADDRESS:

PO BOX 460
TUPMAN, CA 93276

FACILITY LOCATION:

4026 SKYLINE RD
TUPMAN, CA 93276

FACILITY DESCRIPTION:

ELECTRIC POWER GENERATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-3523-0-2

EXPIRATION DATE: 02/29/2016

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: ELK HILLS POWER LLC
Location: 4026 SKYLINE RD, TUPMAN, CA 93276
S-3523-0-2 : Jun 20 2016 5:10PM - HEINENG

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and Rule 8011] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
 These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin September 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-1-11

EXPIRATION DATE: 02/29/2016

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #1 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-2 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NO_x, CO, and O₂. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [40 CFR 60.334(c), 40 CFR 64.3, District Rules 1080 and 4703, 6.2.1 and District NSR Rule, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 64.3 and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NOx concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District NSR Rule and District Rule 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District NSR Rule] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District NSR Rule, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [40 CFR 60.334(h)(3); 40 CFR 60.48(g)(1) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001 and 4703, 5.3.3 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NO_x (as NO₂) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District Rule 2201] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NO_x or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NO_x or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM₁₀ - 15.0 lb/hr, SO_x (as SO₂) - 3.6 lb/hr, NO_x (as NO₂) - 15.8 lb/hr and 2.5 ppmvd @ 15% O₂, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 12.5 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District NSR Rule, District Rules 4001, and 4703, 5.1.2, 5.2, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM₁₀ - 360.0 lb/day, SO_x (as SO₂) - 86.4 lb/day, NO_x (as NO₂) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3948.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM₁₀ - 720.0 lb/day, SO_x (as SO₂) - 172.8 lb/day, NO_x (as NO₂) - 1103.0 lb/day, VOC - 269.0 lb/day, and CO - 4297 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 261,960 lb/year, SO_x (as SO₂) - 57,468 lb/year, NO_x (as NO₂) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District NSR Rule] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = ((a-(bxc/1,000,000)) x 1,000,000 / b) x d, where a = ammonia injection rate(lb/hr)/17(lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29(lb/lb. mol), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval [District Rules 2520, 9.3.2 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60 Subpart Da, and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District NSR Rule] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [40 CFR 60.48(g)(1) and District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District NSR Rule and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [District NSR Rule and District Rule 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District NSR Rule and 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-2-11

EXPIRATION DATE: 02/29/2016

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #2 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-1 (503 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording non resettable fuel gas flowmeter. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NO_x, CO, and O₂. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [40 CFR 60.334(c), 40 CFR 64.3, District Rules 1080 and 4703, 6.2.1 and District NSR Rule, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
4. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 64.3 and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
5. The monitoring of CO emissions with the CEMS shall serve as a surrogate for monitoring of VOC emissions as required by 40 CFR 64 (Compliance Assurance Monitoring). Operation of the unit with CO concentration within the allowable range shall be indicative of VOC concentrations which are less than the allowed maximum. The relationship between concentration of VOC and concentration of CO shall be demonstrated at each annual source test. [40 CFR 64.3] Federally Enforceable Through Title V Permit
6. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64.7] Federally Enforceable Through Title V Permit
7. The permittee shall comply with the recordkeeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64.9] Federally Enforceable Through Title V Permit
8. If the District or EPA determine that a Quality improvement Plan is required under 40 CFR 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR part 64.8. [40 CFR Part 64.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

9. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District NSR Rule and District Rule 1080] Federally Enforceable Through Title V Permit
10. The facility shall install and maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
12. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0 and SJ-99-02] Federally Enforceable Through Title V Permit
13. Exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with 40 CFR 60.8 (e). [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
14. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
15. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
16. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
17. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District NSR Rule] Federally Enforceable Through Title V Permit
18. CTG and duct burner shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.75 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [District NSR Rule, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
19. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored at least annually using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. [40 CFR 60.334(h)(3); 40 CFR 60.48(g)(1) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Results of the CEM system shall be averaged over the applicable time period, using consecutive 15-minute sampling periods. [District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
21. Startup is defined as the period beginning with turbine initial firing until the unit meets the lb/hr and ppmv emission limits. An extended startup shall be defined as a startup that occurs after the steam turbine has been shutdown for 72 hours or more. Shutdown is defined the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Aborted shutdown is defined the period beginning with initiation of turbine shutdown and ends when the unit has ramped up and is meeting the lb/hr and ppmv emission limits. Startup durations shall not exceed three hours for a regular startup, and 7 hours for an extended startup, per occurrence. Shutdown and aborted shutdown durations shall not exceed one hour, per occurrence. [District Rules 2201, 4001 and 4703, 5.3.3 and SJ-99-02] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines' heat recovery steam generator exhausts (S-3523-1 and -2) shall not exceed any of the following: NOx (as NO2) - 400 lb and CO - 3600 lb in any one hour. If any CTG is in either startup or shutdown during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District NSR Rule] Federally Enforceable Through Title V Permit
23. During an extended startup, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 800 lb NOx or 3600 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
24. During shutdown, or aborted shutdown, of CTG, the combined emissions from both the CTG and HRSG exhausts shall not exceed either 102.5 lb NOx or 222.0 lb CO per event. [SJ-99-02] Federally Enforceable Through Title V Permit
25. Duct burning must not be employed during startup or shutdown events. [SJ-99-02] Federally Enforceable Through Title V Permit
26. Emission rates from CTG/HRSG, except during startup, shut down or aborted shutdown, shall not exceed any of the following: PM10 - 15.0 lb/hr, SOx (as SO2) - 3.6 lb/hr, NOx (as NO2) - 15.8 lb/hr and 2.5 ppmvd @ 15% O2, VOC - 4.0 lb/hr and 2.0 ppmvd @ 15% O2, CO - 12.5 lb/hr and 4 ppmvd @ 15% O2, ammonia - 10 ppmvd @ 15% O2. NOx ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmv and lb/hr limits are three-hour rolling averages. [District NSR Rule, District Rules 4001, and 4703, 5.1.2, 5.2, 40 CFR 60 Subpart Da, and SJ-99-02] Federally Enforceable Through Title V Permit
27. Emission rates from CTG/HRSG shall not exceed any of the following: PM10 - 360.0 lb/day, SOx (as SO2) - 86.4 lb/day, NOx (as NO2) - 752.0 lb/day, VOC - 184.0 lb/day, and CO - 3948.0 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Emission rates from both CTG/HRSG S-3523-1 and -2 combined shall not exceed any of the following: PM10 - 720.0 lb/day, SOx (as SO2) - 172.8 lb/day, NOx (as NO2) - 1103.0 lb/day, VOC - 269.0 lb/day, and CO - 4297 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
29. Annual emissions from both CTGs/HRSGs S-3523-1 and -2 combined calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM10 - 261,960 lb/year, SOx (as SO2) - 57,468 lb/year, NOx (as NO2) - 335,022 lb/year, VOC - 64,478 lb/year, and CO - 831,008 lb/year. [District NSR Rule and SJ-99-02] Federally Enforceable Through Title V Permit
30. Each one-hour period will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Daily emissions shall be compiled for a twenty-four hour period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions shall commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions shall be compiled from the twelve most recent calendar months. [District NSR Rule] Federally Enforceable Through Title V Permit
32. Compliance with ammonia slip limit shall be demonstrated by using the following calculation procedure: ammonia slip ppmv @ 15% O2 = $((a-(b \times c / 1,000,000)) \times 1,000,000 / b) \times d$, where a = ammonia injection rate (lb/hr)/17 (lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29 (lb/lb. mol)), c = change in measured NOx concentration ppmv at 15% O2 across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH3 CEM, the permittee must submit a monitoring plan for District review and approval [District Rules 2520, 9.3.2 and 4102] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

33. Compliance with the short term emission limits (lb/hr and ppmv @ 15% O₂) shall be demonstrated annually by District witnessed in situ sampling of exhaust gas by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rule 1081 and SJ-99-02] Federally Enforceable Through Title V Permit
34. Compliance with the startup NO_x, CO, and VOC mass emission limits shall be demonstrated for one of the CTGs (S-3523-1, or -2) at least once every five years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit
35. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60 Subpart Da, and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
36. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
37. The following test methods shall be used EPA Methods 1-4, PM₁₀: EPA Method 5 (front half and back half), NO_x: EPA Method 7E, CO: EPA Method 10, O₂: EPA Method 3, 3A, or 20, VOC: EPA Method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081, 4001, and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
38. The permittee shall maintain hourly records of NO_x, CO, and ammonia emission concentrations (ppmv @ 15% O₂), and hourly, daily, and twelve month rolling average records of NO_x and CO emissions. [District NSR Rule] Federally Enforceable Through Title V Permit
39. The permittee shall maintain records of SO_x lb/hr, lb/day, and lb/twelve month rolling average emission. SO_x emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [40 CFR 60.48(g)(1) and District NSR Rule] Federally Enforceable Through Title V Permit
40. Permittee shall maintain the following records for the CTG: occurrence, duration, and type of any startup, shutdown, or malfunction; emission measurements; total daily and annual hours of operation; and hourly quantity of fuel used. [District NSR Rule and 4703 and SJ-99-02] Federally Enforceable Through Title V Permit
41. Permittee shall maintain the following records for the continuous emissions monitoring system (CEMS): the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, maintenance, adjustments, any period of non-operation of any continuous emissions monitor and emission measurements. [District NSR Rule and District Rule 4703 and 40 CFR 60 60.7(b) and SJ-99-02] Federally Enforceable Through Title V Permit
42. Cylinder gas audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
43. The permittee shall submit a written report to the APCO for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred . [District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

44. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District NSR Rule and 2520, 9.4.2] Federally Enforceable Through Title V Permit
45. The owners and operators of each affected source shall have an Acid Rain permit and operate in compliance with all permit requirements. [40 CFR 72] Federally Enforceable Through Title V Permit
46. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
47. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
48. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 72] Federally Enforceable Through Title V Permit
49. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 72] Federally Enforceable Through Title V Permit
50. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
52. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
53. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 72. [40 CFR 72] Federally Enforceable Through Title V Permit
54. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
55. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
56. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-3-4

EXPIRATION DATE: 02/29/2016

SECTION: NE35 TOWNSHIP: 30S RANGE: 23E

EQUIPMENT DESCRIPTION:

FORCED DRAFT COOLING TOWER WITH 6 CELLS AND HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012]
2. Drift eliminator drift rate shall not exceed 0.0005%. [District NSR Rule] Federally Enforceable Through Title V Permit
3. PM10 emission rate shall not exceed 11.7 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
4. On a weekly basis, the Permittee shall record the circulating water recirculation rate and have an independent laboratory analyze a sample of the blowdown water to determine the total dissolved solids concentration in the blowdown water. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. Compliance with the PM10 daily emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{circulating water recirculation rate} * \text{total dissolved solids concentration in the blowdown water} * \text{design drift rate} * \text{correction factor}$. The correction factor shall range from 0.82 for a TDS of 1,000 ppm to 0.3 for a TDS of 5,000 ppm. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of calculated PM10 emission rate and all data used in the calculations. All records shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District NSR Rule, District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3523-6-3

EXPIRATION DATE: 02/29/2016

EQUIPMENT DESCRIPTION:

240 HP CUMMINS MODEL 6CTA 8.3 F2 DIESEL-FIRED IC ENGINE DRIVING EMERGENCY FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [40 CFR 63 Subpart ZZZZ, District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The permittee shall minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. At all times, the engine and any associated air pollution control equipment and monitoring equipment shall be operated in a manner consistent with safety and good air pollution control practices for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. The PM10 emissions rate shall not exceed 0.25 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District NSR Rule] Federally Enforceable Through Title V Permit
7. NOx emissions shall not exceed 4.4 g/hp-hr. [District NSR Rule] Federally Enforceable Through Title V Permit
8. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rule 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 77 hours per calendar year. [40 CFR 63 Subpart ZZZZ, District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [County Rule 407 (Kern)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [40 CFR 63 Subpart ZZZZ, District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. The permittee shall maintain the following schedule of maintenance and inspection: Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine shall be operated and maintained according to the manufacturer's emission-related written instructions (including the after-treatment control device if any). Alternatively, a site-specific maintenance plan may be developed which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. Records of the maintenance conducted on the engine shall be maintained which demonstrate that operation and maintenance of the engine and after-treatment control device (if any) is according the facility's maintenance plan. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [40 CFR 63 Subpart ZZZZ, District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility List

Detailed Facility Report
For Facility=3523
Sorted by Facility Name and Permit Number

ELK HILLS POWER LLC 4026 SKYLINE RD TUPMAN, CA 93276	FAC # STATUS: TELEPHONE:	S 3523 A 6617632700	TYPE: TOXIC ID:	TitleV 60305	EXPIRE ON: AREA: INSP. DATE:	02/28/2021 6 / 10/16
---	---------------------------------------	----------------------------------	---------------------------	------------------------	---	-----------------------------------

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-3523-1-12	251.5 MW electrical generation	3020-08B H	1	14,452.00	14,452.00	A	GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #1 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-2 (503 MW TOTAL PLANT NOMINAL RATING)
S-3523-2-12	251.5 MW electrical generation	3020-08B H	1	14,452.00	14,452.00	A	GE FRAME 7 MODEL PG7241FA NATURAL GAS FIRED COMBINED CYCLE GAS TURBINE ENGINE/ELECTRICAL GENERATOR #2 WITH DRY LOW NOX COMBUSTORS, 250.5 MMBTU/HR NATURAL GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, SELECTIVE CATALYTIC REDUCTION, OXIDATION CATALYST, AND STEAM TURBINE SHARED WITH S-3523-1 (503 MW TOTAL PLANT NOMINAL RATING)
S-3523-3-5	part of electrical generation unit	999-99	1	0.00	0.00	A	FORCED DRAFT COOLING TOWER WITH 6 CELLS AND HIGH EFFICIENCY DRIFT ELIMINATOR
S-3523-6-4	240 BHP diesel-fired IC engine	3020-10 C	1	264.00	264.00	A	240 HP CUMMINS MODEL 6CTA 8.3 F2 DIESEL-FIRED IC ENGINE DRIVING EMERGENCY FIRE WATER PUMP

Number of Facilities Reported: 1

ATTACHMENT D

Comments Received

The United States Environmental Protection Agency (EPA) commented that

1. The “FERC Gas Tariff General Terms and Conditions for Mojave Gas Company was last issued on April 1, 2016” and the Permit Renewal Evaluation should be revised to reflect that update.
2. The Permit Renewal Evaluation states that “the Tariff requires the natural gas to contain no more than 0.3 gr/100 scf *total sulfur*. As shown on Page 30 of the Tariff, for total sulfur the standard is $\frac{3}{4}$ of a grain or 0.75 grain per 100 cubic feet.”

District response:

The Permit Renewal Evaluation (page 11 and 12) has been revised to reflect that EPA comments. These two revisions do not affect the Evaluation’s original calculations and determinations.

Facility:	ELK HILLS POWER LLC
Facility #:	S-3523
Project #:	1152677
Project	Title V renewal
Description:	
Staff:	HEINENG

Major Application Processing Steps	Estimate	Actual Billed	Actual Non-Billed	Total
Determing Completeness	1.5	1.5	0.0	1.5
Engineer Evaluation	0	0.0	0.8	0.8
Preparing Permit	0	4.2	1.2	5.4
Miscellaneous	0.0	15.8	1.0	16.8
Hours Grand Total	1.5	21.5	3.0	24.5