



AUG 23 2016

Mr. David Rocha
Baker Commodities, Inc
P O Box 416
Kerman, CA 93630

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # C-72
Project # C-1152389**

Dear Mr. Rocha:

The Air Pollution Control Officer has issued an Authority to Construct (C-72-6-4) with a Certificate of Conformity to Baker Commodities, Inc at 16801 W Jensen Ave Kerman, CA 93630. This project is for the modification of the gasoline dispensing operation to limit the annual gasoline throughput to 18,000 gallons. Enclosed are the Authority to Construct and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permit was published on July 7, 2016. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on June 30, 2016. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Prior to operating with the modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms have been enclosed for your use. These forms may also be found on the District's website at www.valleyair.org.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. David Rocha
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email
cc: Marnie Dorsz, ES Environmental via email

Facility # C-72
BAKER COMMODITIES, INC
PO BOX 416
KERMAN, CA 93630

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit.** Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at <http://www.valleyair.org/busind/pto/ptoforms/1ptoformidx.htm>.
3. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test:** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
7. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at
any of the telephone numbers listed below.**

Seyed Sadredin

Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: C-72-6-4

ISSUANCE DATE: 08/12/2016

LEGAL OWNER OR OPERATOR: BAKER COMMODITIES, INC

MAILING ADDRESS: PO BOX 416
KERMAN, CA 93630

LOCATION: 16801 W JENSEN AVE
KERMAN, CA 93630

EQUIPMENT DESCRIPTION:

MODIFICATION OF GASOLINE DISPENSING OPERATION WITH ONE 1,000 GALLON ABOVEGROUND STORAGE TANK SERVED BY TWO-POINT PHASE I VAPOR RECOVERY SYSTEM (G-70-142-A), AND 1 FUELING POINT WITH PHASE II EXEMPT GASOLINE DISPENSING NOZZLE: REVISE THE EQUIPMENT DESCRIPTION TO INCLUDE STANDING LOSS CONTROL (SLC) AND LIMIT ANNUAL GASOLINE THROUGHPUT TO NOT EXCEED 18,000 GALLONS

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. The Phase I vapor recovery system shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Order specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rule 4621] Federally Enforceable Through Title V Permit
4. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4621] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

for El Vig

Arnaud Marjollet, Director of Permit Services

C-72-6-4 - Aug 12 2016 11:57AM -- GILLESR - Joint Inspection NOT Required

5. The storage container shall be installed, maintained, and operated such that it is leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
6. Only white paint, listed in the Executive Order specified in this permit for the Standing Loss Control System, shall be applied to the tank. The surface of the tank shall be prepared and the white paint shall be applied per manufacturer's specification. [District Rule 4621] Federally Enforceable Through Title V Permit
7. The permittee shall maintain the following records: 1) receipt of sale that demonstrates the purchase date and amount of white paint purchased, 2) record of the name of personnel applying white paint to include the date of application, surface preparation description (i.e. scraping, sanding, abrasive blasting, primer etc.), method of application (i.e. brush, roller, air/airless sprayer), average ambient temperature (degrees F) during application, and atmospheric observations during application (i.e. sunny, cloudy, rain, etc.), 3) record of the name of personnel that installed the P/V vent valve, and 4) Technical Data Sheet and/or Material Safety Data Sheet of the white paint that describes the surface preparation, application, and material safety of the white paint. [District Rule 4621] Federally Enforceable Through Title V Permit
8. The Phase I vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rule 4621] Federally Enforceable Through Title V Permit
9. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rule 4621] Federally Enforceable Through Title V Permit
10. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
11. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rule 4621] Federally Enforceable Through Title V Permit
12. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
13. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rule 4621] Federally Enforceable Through Title V Permit
14. The permittee shall perform and pass a Static Leak Test for Aboveground Tanks using ARB TP-201.3B or TP-206.3 at least once every 36 months. [District Rule 4621] Federally Enforceable Through Title V Permit
15. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
16. A person performing installation of, or maintenance on, a certified Phase I vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rule 4621] Federally Enforceable Through Title V Permit
17. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rule 4621] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

18. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rule 4621] Federally Enforceable Through Title V Permit
19. The total gasoline throughput for this operation shall not exceed 1,000 gallons per day. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Total gasoline throughput for this operation shall not exceed the following: 10,000 gallons in any consecutive 30-day period and 18,000 gallons per rolling 12-month period. If the gasoline throughput exceeds the stated limits, the permittee shall submit a complete application for an Authority to Construct (ATC) to the District within 30 days of the loss of exemption and shall install and test a certified Phase II vapor recovery system within six (6) months from the date the ATC is issued. [District Rules 2201, 4621, and 4622] Federally Enforceable Through Title V Permit
21. The permittee shall maintain daily and annual gasoline throughput records. The records shall calculate the gasoline throughput on a rolling 30-day period and a rolling 12-month period and shall be maintained on the premises as long as Phase II EVR exempt status is claimed. [District Rules 2201, 4621, and 4622] Federally Enforceable Through Title V Permit
22. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rule 4621] Federally Enforceable Through Title V Permit