



SEP 21 2016

Mr. Zac Meyer
Bakersfield City Wastewater #3
6901 McCutchen Road
Bakersfield, CA 93313

**Re: Notice of Preliminary Decision – Title V Permit Renewal
District Facility # S-3103
Project # S-1162870**

Dear Mr. Meyer:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Bakersfield City Wastewater #3 at 6901 McCutchen Road in Bakersfield, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin

Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Proposed Title V Permit Renewal Evaluation
Bakersfield City Wastewater Plant #3
S-3103**

TABLE OF CONTENTS

I.	PROPOSAL	2
II.	FACILITY LOCATION	2
III.	EQUIPMENT LISTING	2
IV.	GENERAL PERMIT TEMPLATE USAGE	3
V.	SCOPE OF EPA AND PUBLIC REVIEW	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS	3
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	5
VIII.	PERMIT REQUIREMENTS	5
IX.	PERMIT SHIELD	11
X.	PERMIT CONDITIONS	12
XI.	ATTACHMENTS	12
A.	DRAFT RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED FACILITY REPORT	

TITLE V PERMIT RENEWAL EVALUATION
Wastewater Treatment Plant

Engineer: Steve Leonard
Date: 9/07/16

Facility Number: S-3103
Facility Name: Bakersfield City Wastewater Plant #3
Mailing Address: 6901 McCutchen Rd
Bakersfield, CA 93313

Contact Name: Evette Roldan
Phone: (661) 326-3249

Responsible Official: Zac Meyer
Title: Wastewater Manager

Project # : S-1162870
Deemed Complete: 9/07/2016

I. PROPOSAL

Bakersfield City Wastewater Plant #3 was issued a Title V Operating Permit on September 30, 2012. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the issuance of the initial Title V Operating Permit.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Bakersfield City Wastewater Plant #3, facility S-3103 is located at 6901 McCutchen Road in Bakersfield, CA.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant does not propose to use any general permit templates. However, the Umbrella Permit UM-03 is currently in use and will be retained as the facility-wide conditions to ensure compliance.

V. SCOPE OF EPA AND PUBLIC REVIEW

Since the applicant is not requesting any model general permit templates, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated Since September 30, 2012

- District Rule 2020, Exemptions (amended December 18, 2014)
- District Rule 2201, New and Modified Stationary Source Review Rule (amended February 18, 2016)
- District Rule 2410, Prevention of Significant Deterioration (effective November 26, 2012)
- District Rule 4702, Internal Combustion Engines (amended November 14, 2013)
- 40 CFR 60 Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (amended July 7, 2016)
- 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Spark Ignition Internal Combustion Engines (amended February 27, 2014)
- 40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants (NESHAPS) for Stationary Reciprocating Internal Combustion Engines (amended January 30, 2013)

B. Rules Removed

No District Rules appearing on the last Title V permit renewal have been removed.

C. Rules Added Since Since September 30, 2012

No District Rules have been added since the initial Title V permit issuance.

D. Rules Not Updated Since September 30, 2012

- District Rule 1070, Inspections (amended December 17, 1992)
- District Rule 1100, Equipment Breakdown (amended December 17, 1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)

- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)
- District Rule 4101, Visible Emissions (amended February 17, 2005)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4311, Flares (amended June 18, 2009)
- District Rule 4601, Architectural Coatings (amended December 17, 2009)
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- District Rule 8011, General Requirements (amended August 19, 2004)
- District Rule 8021, Construction, Demolition, Excavation, Extraction, and Other Earthmoving Activities (amended August 19, 2004)
- District Rule 8031, Bulk Materials (amended August 19, 2004)
- District Rule 8041, Carryout and Trackout (amended August 19, 2004)
- District Rule 8051, Open Areas (amended August 19, 2004)
- District Rule 8061, Paved and Unpaved Roads (amended August 19, 2004)
- District Rule 8071, Unpaved Vehicle/Equipment Traffic Areas (amended September 16, 2004)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos
- 40 CFR Part 64, Compliance Assurance Monitoring (CAM)
- 40 CFR Part 82, Subpart F, Stratospheric Ozone

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed beyond this section.

- District Rule 4102, Nuisance (adopted May 21, 1992, amended December 17, 1992)

Condition 1 on the facility-wide permit identifies the requirements of Rule 4102.

A. Rules Added

No non-federally enforceable rules have been added.

B. Rules Not Updated

No non-federally enforceable rules have been updated.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements. Therefore, this compliance section will *address rules that have been amended or added since the issuance of the last Title V permit renewal*. In addition, several of the permits for this facility have been revised to reflect the most recent and complete conditions set forth in District Rules. Some of the equipment descriptions have been revised to reflect current District equipment description standards. This change is administrative in nature and only serves to clarify the permitted equipment. The revised equipment descriptions are listed on each individual permit.

District Rules

A. District Rule 2020, Exemptions

Rule 2020 has been amended.

This rule identifies emissions units that are not required to obtain an Authority to Construct or Permit to Operate. This rule also specifies the recordkeeping requirements to verify the exemption and outlines the compliance schedule for emissions units that lose the exemption after installation.

Condition 5 on the facility-wide permit identifies the requirements of Rule 2020.

B. District Rule 2201, New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. However, the requirements of this rule are only triggered at the time the source undergoes a modification. All applicable requirements from any NSR permit actions have already been incorporated into the current Title V permit.

C. District Rule 2410, Prevention of Significant Deterioration

District Rule 2410 has been newly adopted since this facility's initial Title V permit was issued. However, the requirements of this rule are only triggered at the time the source undergoes a modification. All applicable requirements from any PSD permit actions have already been incorporated into the current Title V permit.

D. District Rule 4702, Internal Combustion Engines

The purpose of this rule is to limit the emissions of nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion engines. This rule applies to any internal combustion (IC) engine with a rated brake horsepower of 25 or greater.

The rule was amended in November 14, 2013.

The following permit requirements ensure compliance with the amended rule:

1. S-3103-10-2: 1,199 BHP CATERPILLAR MODEL #3508TA DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
 - Conditions 5, 8 through 12, and 14 on the proposed permit comply with this rule.
2. S-3103-19-5: 1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER AND SULFATREAT FUEL GAS DRY SULFUR SCRUBBING SYSTEM SHARED WITH UNITS S-3103-13, '-14, '-15, '-16, '-17, '-18, '-20, AND '-28
 - Conditions 4, 6, 8, 10 through 17, 20, 21, and 29 on the proposed permit comply with this rule.
3. S-3103-20-5: 1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER AND SULFATREAT FUEL GAS DRY SULFUR SCRUBBING SYSTEM SHARED WITH UNITS S-3103-13, '-14, '-15, '-16, '-17, '-18, '-20, AND '-28
 - Conditions 4, 6, 8, 10 through 17, 20, 21, and 23 on the proposed permit comply with this rule.
4. S-3103-22-2: 2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 1)
 - Conditions 2, 4, 5, 6, and 11 through 14 on the proposed permit comply with this rule.

5. S-3103-23-2: 2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 2)
 - Conditions 2, 4, 5, 6, and 11 through 14 on the proposed permit comply with this rule.
6. S-3103-24-2: 2,206 BHP CATERPILLAR MODEL 3512C TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (AERATION BASIN 3)
 - Conditions 2, 4, 5, 6, and 11 through 14 on the proposed permit comply with this rule.
7. S-3103-25-2: 1,502 BHP CATERPILLAR MODEL C32 TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (HEAD WORKS)
 - Conditions 2, 4, 5, 6, and 11 through 14 on the proposed permit comply with this rule.

Federal Requirements

A. 40 CFR Part 64, Compliance Assurance Monitoring (CAM)

To be subject to CAM for a particular pollutant, an emissions unit must meet all of the following criteria:

- The unit must have an emission limit for the pollutant,
- The unit must have add-on controls for the pollutant, and
- The pre-control potential to emit for the unit must exceed major source thresholds.

CAM is not triggered for any permit units. None of the units are equipped with add on control equipment and none of the units have uncontrolled emissions limits that exceed major source thresholds.

B. 40 CFR 60 Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

Recent amendments concerning manufacturers of compression ignition engines do not effect the emergency compression ignition engines at this facility. No other amendments affect the existing compression ignited IC engines. Continued compliance is expected.

C. 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Spark Ignition Internal Combustion Engines

Recent amendments concerning manufacturers of compression ignition engines do not affect the emergency compression ignition engines at this facility. No other amendments affect the existing compression ignited IC engines. Continued compliance is expected.

D. 40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants (NESHAPS) for Stationary Reciprocating Internal Combustion Engines

Only the existing 1,199 bhp compression ignition emergency generator S-3103-10 is subject to this subpart. No other amendments affect the existing compression ignited IC engine. Continued compliance is expected.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

No general templates have been proposed. However, facility-wide conditions from umbrella permit UM-03 have been used. These contain standard permit shields.

B. Requirements not Addressed by Model General Permit Templates

No extra permit shields have been proposed or utilized for any of the existing permits.

C. Obsolete Permit Shields From Existing Permit Requirements

There are no obsolete permit shields on the permit.

X. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Facility Report

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-3103-0-2

EXPIRATION DATE: 01/31/2017

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rules 2010 and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070; 2080; and 2520] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: BAKERSFIELD CITY WASTEWATER #3
Location: 6901 MCCUTCHEN ROAD, BAKERSFIELD, CA 93313
6-3103-0-2 Sep 7 2016 3:05PM - LEONARDS

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with District Rule 2520 (6/21/01). [District Rules 2520 and 1100] Federally Enforceable Through Title V Permit
13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520] Federally Enforceable Through Title V Permit
14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520] Federally Enforceable Through Title V Permit
16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520] Federally Enforceable Through Title V Permit
17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520] Federally Enforceable Through Title V Permit
18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601] Federally Enforceable Through Title V Permit
25. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601(12/17/09). [District Rule 4601] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011]
36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520] Federally Enforceable Through Title V Permit
38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520] Federally Enforceable Through Title V Permit
39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100 (12/17/92); 2010 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
42. On September 30, 2012, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-10-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,199 BHP CATERPILLAR MODEL #3508TA DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. The engine shall be equipped with a turbocharger and with an aftercooler or intercooler. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The engine shall be operated with the fuel injection timing retarded four degrees from the manufacturer's standard recommended timing. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rule 4702 and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
10. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
11. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
14. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070, 4702, 2520, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. On and after May 3, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

16. On and after May 3, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. On and after May 3, 2013, the engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. On and after May 3, 2013, the engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. On and after May 3, 2013, the engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. On and after May 3, 2013, the permittee shall maintain records of performance tests and performance evaluations as required in §63.10(b)(2)(viii) and records of required maintenance performed on the air pollution control and monitoring equipment. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. On and after May 3, 2013, the permittee shall maintain records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-3103-12-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

ODOR CONTROL SYSTEM #1 ODOR CONTROL SYSTEM INCLUDING TWO BIOFILTER CELLS SERVING THE HEADWORKS, PRIMARY CLARIFIERS, SECONDARY CLARIFIERS, DAF THICKENERS, AERATION BASIN, AND OTHER MISCELLANEOUS SOURCES

PERMIT UNIT REQUIREMENTS

1. See facility wide permit for requirements applicable to this permit unit. [District Rule 2080] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-19-5

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER AND SULFATREAT FUEL GAS DRY SULFUR SCRUBBING SYSTEM SHARED WITH UNITS S-3103-13, '-14, '-15, '-16, '-17, '-18, '-20, AND '-28

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Total annual operating hours of digester gas fired cogeneration engines S-3103-19 and '-20 shall not exceed 17,196 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Engine shall operate according to the manufacturer's specifications. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Total sulfur content of digester gas combusted in this unit shall not exceed 20 ppmvd. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates shall not exceed any of the following: NOx (as NO2): 0.6 g/bhp-hr, PM10: 0.04 g/bhp-hr, CO: 2.5 g/bhp-hr, or VOC (as methane): 0.25 g/bhp-hr. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NOx/yr; 867 lb-SOx/yr; 2,991 lb-PM10/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
14. Source testing to measure NO_x, CO, and VOC emissions from this unit while firing digester gas shall be conducted not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
15. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
17. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. All vessel hatches and openings shall remain closed during operation of SulfaTreat H2S scrubber. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
23. No components (i.e., valves, flanges, etc.) associated with the SulfaTreat unit shall be the source of any leak greater than 10,000 ppmv (as methane) when measured at a distance no greater than 1 cm from the potential source per EPA Method 21. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Influent and effluent gas streams of SulfaTreat system shall be sampled at least monthly for H2S content of effluent gas to determine when recharging is required. [District Rule 2201] Federally Enforceable Through Title V Permit
25. During recharging of the H2S scrubber, untreated vapors shall not be introduced into the fuel system or vented to the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
26. The following test method shall be used for fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Record of H2S content of effluent gas shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-20-5

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Total annual operating hours of digester gas fired cogeneration engines S-3103-19 and '-20 shall not exceed 17,196 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Engine shall operate according to the manufacturer's specifications. [District Rule 4702] Federally Enforceable Through Title V Permit
7. Total sulfur content of digester gas combusted in this unit shall not exceed 20 ppmvd. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates shall not exceed any of the following: NO_x (as NO₂): 0.6 g/bhp-hr, PM₁₀: 0.04 g/bhp-hr, CO: 2.5 g/bhp-hr, or VOC (as methane): 0.25 g/bhp-hr. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NO_x/yr; 867 lb-SO_x/yr; 2,991 lb-PM₁₀/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
14. Source testing to measure NO_x, CO, and VOC emissions from this unit while firing digester gas shall be conducted not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
15. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
17. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
23. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-22-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 1)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 5.39 g-NOx/bhp-hr, 0.29 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.026 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-23-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 2)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 5.39 g-NOx/bhp-hr, 0.29 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115], Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.026 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-24-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,206 BHP CATERPILLAR MODEL 3512C TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (AERATION BASIN 3)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 4.97 g-NOx/bhp-hr, 0.45 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.03 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-25-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,502 BHP CATERPILLAR MODEL C32 TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (HEAD WORKS)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 4.82 g-NOx/bhp-hr, 0.19 g-CO/bhp-hr, or 0.01 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.023 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: BAKERSFIELD CITY WASTEWATER #3
Location: 0001 MCCUTCHEN ROAD, BAKERSFIELD, CA 93313
S-3103-25-2 Sep 7 2010 3:05PM - LIRONAADD

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-3103-26-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:
FERRIC CHLORIDE INJECTION SYSTEM SERVING DIGESTER TANKS

DRAFT

PERMIT UNIT REQUIREMENTS

1. Ferric chloride injection system shall be operated according to manufacturers specifications. [District Rule 2080]
Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-3103-27-2

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

ODOR CONTROL SYSTEM #2 INCLUDING ONE BIOFILTER SERVING THE SLUDGE DEWATERING BUILDING AND SLUDGE CAKE LOADING STATION

PERMIT UNIT REQUIREMENTS

1. See facility wide permit for requirements applicable to this permit unit. [District Rule 2080] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-28-4

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

16.5 MMBTU/HR FLARE INDUSTRIES ENCLOSED FLARE

DRAFT

PERMIT UNIT REQUIREMENTS

1. Flare shall be equipped with a non-resettable, totalizing flare gas volume flow meter. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
2. Flare outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311] Federally Enforceable Through Title V Permit
3. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311] Federally Enforceable Through Title V Permit
4. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311] Federally Enforceable Through Title V Permit
5. The flare's emissions rates shall not exceed any of the following: 0.06 lb-NO_x/MMBtu; 0.006 lb-SO_x (as SO₂)/MMBtu; 0.020 lb-PM₁₀/MMBtu; 0.25 lb-CO/MMBtu; or 0.0020 lb-VOC/MMBtu. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
6. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NO_x/yr; 867 lb-SO_x/yr; 2,991 lb-PM₁₀/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The flare shall only operate when both engines S-3103-19 and '-20 are shutdown for service or due to mechanical problems. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The flare shall not operate more than 3,000 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Hydrogen sulfide (H₂S) content of digester gas combusted shall not exceed 20 ppmv. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Sampling facilities shall be provided to allow for fuel gas sampling at inlet to flare. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Source testing to measure NO_x and VOC emissions from this unit shall be conducted within 60 days of initial start-up and at least once every 12 months thereafter. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
12. The results of the source test shall be submitted to the District within 45 days thereafter. [District Rules 1081, 2201, 4311] Federally Enforceable Through Title V Permit
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 30 days prior to testing. [District Rules 1081 and 4311] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

14. VOC emissions for source test purposes, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case Method 25a may be used, and analysis of halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422 "Determination of Volatile organic Compounds in Emission from Stationary Sources". [District Rule 4311] Federally Enforceable Through Title V Permit
15. NOx and O2 concentrations shall be determined by using EPA Method 3A, EPA Method 7E, or ARB 100 [District Rule 4311] Federally Enforceable Through Title V Permit
16. NOx emissions for source test purposes, in pounds per million Btu, shall be determined by using EPA Method 19 [District Rule 4311] Federally Enforceable Through Title V Permit
17. Prior to startup under the terms of the Authority to Construct and as required thereafter, the permittee shall submit a flare minimization plan (FMP) that complies with the requirements of Rule 4311 Section 6.5 to the APCO for approval. [District Rule 4311] Federally Enforceable Through Title V Permit
18. A copy of approved flare minimization plan pursuant to Rule 4311 Section 6.5 shall be maintained and made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [District Rule 4311] Federally Enforceable Through Title V Permit
19. Copies of compliance determination pursuant to 40 CFR 60.18 shall be made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [40 CFR 60.18, District Rule 4311] Federally Enforceable Through Title V Permit
20. Copies of monitoring data collected pursuant to Rule 4311 Section 5.10 shall be made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [District Rule 4311] Federally Enforceable Through Title V Permit
21. The operator of a flare subject to flare minimization plans pursuant to Section 5.8 shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Rule 4311 Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. [District Rule 4311] Federally Enforceable Through Title V Permit
22. The operator of a flare subject to flare monitoring requirements pursuant to Sections 5.10, 6.6, 6.7, 6.8, 6.9, and 6.10, as appropriate, shall submit an annual report to the APCO as specified in Rule 4311 Section 6.2.3 within 30 days following the end of each 12 month period. [District Rule 4311] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of the time and date of operation, duration of flare operation, amount of gas burned, and the purpose of the operation. [District Rules 1070, 2201, and 4311] Federally Enforceable Through Title V Permit
24. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Permittee shall maintain onsite a copy of the source test results. [District Rule 4311] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2520, and 4311] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

Permit to Operate

FACILITY: S-3103

EXPIRATION DATE: 01/31/2017

LEGAL OWNER OR OPERATOR:

BAKERSFIELD CITY WASTEWATER #3

MAILING ADDRESS:

6901 MCCUTCHEN RD.
BAKERSFIELD, CA 93313

FACILITY LOCATION:

6901 MCCUTCHEN ROAD
BAKERSFIELD, CA 93313

FACILITY DESCRIPTION:

SEWERAGE SYSTEMS

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-3103-0-1

EXPIRATION DATE: 01/31/2017

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rules 2010 and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070; 2080; and 2520] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: BAKERSFIELD CITY WASTEWATER #3
Location: 6901 MCCUTCHEN ROAD, BAKERSFIELD, CA 93313
S-3103-0-1 Sep 7 2016 1:27PM - LEONARDS

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with District Rule 2520 (6/21/01). [District Rules 2520 and 1100] Federally Enforceable Through Title V Permit
13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520] Federally Enforceable Through Title V Permit
14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520] Federally Enforceable Through Title V Permit
16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520] Federally Enforceable Through Title V Permit
17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520] Federally Enforceable Through Title V Permit
18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601] Federally Enforceable Through Title V Permit
25. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601(12/17/09). [District Rule 4601] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011]
36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520] Federally Enforceable Through Title V Permit
38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520] Federally Enforceable Through Title V Permit
39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100 (12/17/92); 2010 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
42. On September 30, 2012, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-10-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,199 BHP CATERPILLAR MODEL #3508TA DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. The engine shall be equipped with a turbocharger and with an aftercooler or intercooler. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The engine shall be operated with the fuel injection timing retarded four degrees from the manufacturer's standard recommended timing. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
7. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201,4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rule 4702 and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
10. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
11. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115 and 40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
14. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070, 4702, 2520, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. On and after May 3, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. On and after May 3, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. On and after May 3, 2013, the engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. On and after May 3, 2013, the engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. On and after May 3, 2013, the engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. On and after May 3, 2013, the permittee shall maintain records of performance tests and performance evaluations as required in §63.10(b)(2)(viii) and records of required maintenance performed on the air pollution control and monitoring equipment. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. On and after May 3, 2013, the permittee shall maintain records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63, Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-12-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

ODOR CONTROL SYSTEM #1 ODOR CONTROL SYSTEM INCLUDING TWO BIOFILTER CELLS SERVING THE HEADWORKS, PRIMARY CLARIFIERS, SECONDARY CLARIFIERS, DAF THICKENERS, AERATION BASIN, AND OTHER MISCELLANEOUS SOURCES

PERMIT UNIT REQUIREMENTS

1. See facility wide permit for requirements applicable to this permit unit. [District Rule 2080] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-19-4

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER AND SULFATREAT FUEL GAS DRY SULFUR SCRUBBING SYSTEM SHARED WITH UNITS S-3103-13, '-14, '-15, '-16, '-17, '-18, '-20, AND '-28

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Total annual operating hours of digester gas fired cogeneration engines S-3103-19 and '-20 shall not exceed 17,196 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Engine shall operate according to the manufacturer's specifications. [District Rule 4701] Federally Enforceable Through Title V Permit
7. Total sulfur content of digester gas combusted in this unit shall not exceed 20 ppmvd. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates shall not exceed any of the following: NO_x (as NO₂): 0.6 g/bhp-hr, PM₁₀: 0.04 g/bhp-hr, CO: 2.5 g/bhp-hr, or VOC (as methane): 0.25 g/bhp-hr. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NO_x/yr; 867 lb-SO_x/yr; 2,991 lb-PM₁₀/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
14. Source testing to measure NO_x, CO, and VOC emissions from this unit while firing digester gas shall be conducted not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
15. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
17. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. All vessel hatches and openings shall remain closed during operation of SulfaTreat H2S scrubber. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
23. No components (i.e., valves, flanges, etc.) associated with the SulfaTreat unit shall be the source of any leak greater than 10,000 ppmv (as methane) when measured at a distance no greater than 1 cm from the potential source per EPA Method 21. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Influent and effluent gas streams of SulfaTreat system shall be sampled at least monthly for H2S content of effluent gas to determine when recharging is required. [District Rule 2201] Federally Enforceable Through Title V Permit
25. During recharging of the H2S scrubber, untreated vapors shall not be introduced into the fuel system or vented to the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
26. The following test method shall be used for fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Record of H2S content of effluent gas shall be maintained. The records shall include identification of the equipment, date of inspection, corrective action taken, and identification of the individual performing the inspection. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-20-4

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Total annual operating hours of digester gas fired cogeneration engines S-3103-19 and '-20 shall not exceed 17,196 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Engine shall operate according to the manufacturer's specifications. [District Rule 4701] Federally Enforceable Through Title V Permit
7. Total sulfur content of digester gas combusted in this unit shall not exceed 20 ppmvd. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Emission rates shall not exceed any of the following: NO_x (as NO₂): 0.6 g/bhp-hr, PM₁₀: 0.04 g/bhp-hr, CO: 2.5 g/bhp-hr, or VOC (as methane): 0.25 g/bhp-hr. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NO_x/yr; 867 lb-SO_x/yr; 2,991 lb-PM₁₀/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. If either the NO_x or CO concentrations corrected to 15% O₂, as measured by the portable analyzer, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rule 4702] Federally Enforceable Through Title V Permit
12. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4702] Federally Enforceable Through Title V Permit
14. Source testing to measure NO_x, CO, and VOC emissions from this unit while firing digester gas shall be conducted not less than once every 24 months. [District Rule 4702] Federally Enforceable Through Title V Permit
15. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rule 4702] Federally Enforceable Through Title V Permit
17. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100. [District Rules 1081 and 4702] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
 23. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-22-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 1)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 5.39 g-NOx/bhp-hr, 0.29 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.026 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-23-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 2)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 5.39 g-NOx/bhp-hr, 0.29 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.026 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-24-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

2,206 BHP CATERPILLAR MODEL 3512C TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (AERATION BASIN 3)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 4.97 g-NOx/bhp-hr, 0.45 g-CO/bhp-hr, or 0.11 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.03 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-25-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

1,502 BHP CATERPILLAR MODEL C32 TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (HEAD WORKS)

PERMIT UNIT REQUIREMENTS

1. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 40 CFR Part 60, Subpart IIII, and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
7. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 4.82 g-NOx/bhp-hr, 0.19 g-CO/bhp-hr, or 0.01 g-VOC/bhp-hr. [District Rule 2201 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed 0.023 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102 and 13 CCR 2423 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60, Subpart IIII,] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
 13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
 14. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
-

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-26-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

FERRIC CHLORIDE INJECTION SYSTEM SERVING DIGESTER TANKS

PERMIT UNIT REQUIREMENTS

1. Ferric chloride injection system shall be operated according to manufacturers specifications. [District Rule 2080]
Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-3103-27-1

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

ODOR CONTROL SYSTEM #2 INCLUDING ONE BIOFILTER SERVING THE SLUDGE DEWATERING BUILDING AND SLUDGE CAKE LOADING STATION

PERMIT UNIT REQUIREMENTS

1. See facility wide permit for requirements applicable to this permit unit. [District Rule 2080] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3103-28-3

EXPIRATION DATE: 01/31/2017

EQUIPMENT DESCRIPTION:

16.5 MMBTU/HR FLARE INDUSTRIES ENCLOSED FLARE

PERMIT UNIT REQUIREMENTS

1. Flare shall be equipped with a non-resettable, totalizing flare gas volume flow meter. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
2. Flare outlet shall be equipped with an automatic ignition system, or, shall operate with a pilot flame present at all times when combustible gases are vented through the flare, except during purge periods for automatic-ignition equipped flares. [District Rule 4311]
3. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311] Federally Enforceable Through Title V Permit
4. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311] Federally Enforceable Through Title V Permit
5. The flare's emissions rates shall not exceed any of the following: 0.06 lb-NO_x/MMBtu; 0.006 lb-SO_x (as SO₂)/MMBtu; 0.020 lb-PM₁₀/MMBtu; 0.25 lb-CO/MMBtu; or 0.0020 lb-VOC/MMBtu. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
6. Combined annual emissions from permit units S-3103-19, '-20 and '-28 shall not exceed any one of the following: 26,726 lb-NO_x/yr; 867 lb-SO_x/yr; 2,991 lb-PM₁₀/yr; 111,360 lb-CO/yr; 11,136 lb-VOC/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The flare shall only operate when both engines S-3103-19 and '-20 are shutdown for service or due to mechanical problems. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The flare shall not operate more than 3,000 hours per calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Hydrogen sulfide (H₂S) content of digester gas combusted shall not exceed 20 ppmv. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Sampling facilities shall be provided to allow for fuel gas sampling at inlet to flare. [District Rule 1081] Federally Enforceable Through Title V Permit
11. Source testing to measure NO_x and VOC emissions from this unit shall be conducted within 60 days of initial start-up and at least once every 12 months thereafter. [District Rules 2201 and 4311] Federally Enforceable Through Title V Permit
12. The results of the source test shall be submitted to the District within 45 days thereafter. [District Rules 1081, 2201, 4311] Federally Enforceable Through Title V Permit
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 30 days prior to testing. [District Rules 1081 and 4311] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

14. VOC emissions for source test purposes, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case Method 25a may be used, and analysis of halogenated exempt compounds shall be analyzed by EPA Method 18 or ARB Method 422 "Determination of Volatile organic Compounds in Emission from Stationary Sources". [District Rule 4311] Federally Enforceable Through Title V Permit
15. NOx and O2 concentrations shall be determined by using EPA Method 3A, EPA Method 7E, or ARB 100 [District Rule 4311] Federally Enforceable Through Title V Permit
16. NOx emissions for source test purposes, in pounds per million Btu, shall be determined by using EPA Method 19 [District Rule 4311] Federally Enforceable Through Title V Permit
17. Prior to startup under the terms of the Authority to Construct and as required thereafter, the permittee shall submit a flare minimization plan (FMP) that complies with the requirements of Rule 4311 Section 6.5 to the APCO for approval. [District Rule 4311] Federally Enforceable Through Title V Permit
18. A copy of approved flare minimization plan pursuant to Rule 4311 Section 6.5 shall be maintained and made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [District Rule 4311] Federally Enforceable Through Title V Permit
- ~~19. Copies of compliance determination pursuant to 40 CFR 60.18 shall be made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [40 CFR 60.18, District Rule 4311] Federally Enforceable Through Title V Permit~~
20. Copies of monitoring data collected pursuant to Rule 4311 Section 5.10 shall be made readily available to the APCO, ARB, and EPA upon request for a minimum of 5 years. [District Rule 4311] Federally Enforceable Through Title V Permit
21. The operator of a flare subject to flare minimization plans pursuant to Section 5.8 shall submit an annual report to the APCO that summarizes all Reportable Flaring Events as defined in Rule 4311 Section 3.0 that occurred during the previous 12 month period. The report shall be submitted within 30 days following the end of the twelve month period of the previous year. [District Rule 4311] Federally Enforceable Through Title V Permit
22. The operator of a flare subject to flare monitoring requirements pursuant to Sections 5.10, 6.6, 6.7, 6.8, 6.9, and 6.10, as appropriate, shall submit an annual report to the APCO as specified in Rule 4311 Section 6.2.3 within 30 days following the end of each 12 month period. [District Rule 4311] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of the time and date of operation, duration of flare operation, amount of gas burned, and the purpose of the operation. [District Rules 1070, 2201, and 4311] Federally Enforceable Through Title V Permit
24. The permittee shall maintain all necessary records in order to show compliance with the annual shared emission limit from permit units S-3103-19, '-20 and '-28. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Permittee shall maintain onsite a copy of the source test results. [District Rule 4311]
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Facility Report

SJVUAPCD
SOUTHERN

Detailed Facility Report
For Facility=3103 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

9/11/16
3:46 pm

BAKERSFIELD CITY WASTEWATER #3
6901 MCCUTCHEEN ROAD
BAKERSFIELD, CA 93313

FAC # S 3103
STATUS: A
TELEPHONE: 6613262258

TYPE: TitleV
TOXIC ID: 60295
AREA: 31 /
INSPI. DATE: 01/17

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-3103-10-1	1,199 bhp IC Engine	3020-10 F	1	820.00	820.00	A	1,199 BHP CATERPILLAR MODEL #3508TA DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
S-3103-12-1	Miscellaneous	3020-06	1	116.00	116.00	A	ODOR CONTROL SYSTEM #1 ODOR CONTROL SYSTEM INCLUDING TWO BIOFILTER CELLS SERVING THE HEADWORKS, PRIMARY CLARIFIERS, SECONDARY CLARIFIERS, DAF THICKENERS, AERATION BASIN, AND OTHER MISCELLANEOUS SOURCES
S-3103-19-3	1,175 BHP	3020-10 F	1	820.00	820.00	A	1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER AND SULFATREAT FUEL GAS DRY SULFUR SCRUBBING SYSTEM SHARED WITH UNITS S-3103-13, -14, -15, -16, -17, -18, -20, AND -28
S-3103-20-3	1,175 BHP	3020-10 F	1	820.00	820.00	A	1,175 BHP JENBACHER MODEL JMS316 DIGESTER GAS-FIRED IC ENGINE COGENERATION SYSTEM WITH TURBOCHARGER AND AIR TO FUEL RATIO CONTROLLER
S-3103-22-1	2,937 bhp IC Engine	3020-10 F	1	820.00	820.00	A	2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 1)
S-3103-23-1	2,937 bhp IC Engine	3020-10 F	1	820.00	820.00	A	2,937 BHP CATERPILLAR MODEL 3516C TA TIER 2 CERTIFIED DIESEL FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (AERATION BLOWER 2)
S-3103-24-1	2,206 bhp IC Engine	3020-10 F	1	820.00	820.00	A	2,206 BHP CATERPILLAR MODEL 3512C TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (AERATION BASIN 3)
S-3103-25-1	1,502 bhp IC Engine	3020-10 F	1	820.00	820.00	A	1,502 BHP CATERPILLAR MODEL C32 TIER 2 CERTIFIED DIESEL FIRED IC ENGINE WITH TURBOCHARGER AND AFTER COOLER POWERING AN EMERGENCY GENERATOR (HEAD WORKS)
S-3103-26-1	Miscellaneous	3020-06	1	116.00	116.00	A	FERRIC CHLORIDE INJECTION SYSTEM SERVING DIGESTER TANKS
S-3103-27-1	Miscellaneous	3020-06	1	116.00	116.00	A	ODOR CONTROL SYSTEM #2 INCLUDING ONE BIOFILTER SERVING THE SLUDGE DEWATERING BUILDING AND SLUDGE CAKE LOADING STATION
S-3103-28-2	16.6 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	16.6 MMBTU/HR FLARE INDUSTRIES ENCLOSED FLARE

Number of Facilities Reported: 1