



DEC 29 2016

Mr. John Ludwick
Aera Energy LLC
PO Box 11164
Bakersfield, CA 93389

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)
District Facility # S-1547 and S-1548
Project # 1151973 and 1152366**

Dear Mr. Ludwick:

The Air Pollution Control Officer has issued Authorities to Construct (Authorities to Construct (ATCs) S-1547-1341-0 through '-1344-0 and S-1548-623 through '-626) with Certificates of Conformity to Aera Energy LLC at western Kern County. The project authorizes four new steam generators. Enclosed are the Authorities to Construct and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the Authority to Construct permit was published on October 26, 2016. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on October 20, 2016. No comments were received following the District's preliminary decision on this project.

Prior to operating with the modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms have been enclosed for your use. These forms may also be found on the District's website at www.valleyair.org.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Mr. John Ludwick
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

A handwritten signature in black ink, appearing to read "Arnaud Marjollet". The signature is written in a cursive style with a horizontal line underneath the name.

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email



Facility # S-1547
AERA ENERGY LLC
PO BOX 11164
BAKERSFIELD, CA 93389-1164

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit.** Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at <http://www.valleyair.org/busind/pto/ptofoms/1ptofomidx.htm>.
3. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test:** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
7. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at http://www.valleyair.org/busind/comply/compliance_forms.htm.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at
any of the telephone numbers listed below.**

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95358-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5685



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1341-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

EQUIPMENT DESCRIPTION:

100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1548-623-0)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 2,299 lb, 2nd quarter - 2,299 lb, 3rd quarter - 2,230 lb, and fourth quarter - 2,230 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOX emission reduction credits for the following quantity of emissions: 1st quarter - 936 lb, 2nd quarter - 936 lb, 3rd quarter - 937 lb, and fourth quarter - 937 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services

S-1547-1341-0 Dec 21 2016 2:18PM - EDGEHLR : Joint Inspection NOT Required

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 1,642 lb, 2nd quarter - 1,642 lb, 3rd quarter - 1,643 lb, and fourth quarter - 1,643 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 985 lb, 2nd quarter - 985 lb, 3rd quarter - 986 lb, and fourth quarter - 986 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
7. ERC Certificate Numbers S-4489-1, S-4422-2, S-1821-2, S-1032-5, and S-4424-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
10. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
16. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
17. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.007 lb-NO_x/MMBtu, 0.005 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O₂ or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
35. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
36. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
39. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1342-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

EQUIPMENT DESCRIPTION:
100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1548-624-0)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 2,299 lb, 2nd quarter - 2,299 lb, 3rd quarter - 2,230 lb, and fourth quarter - 2,230 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOX emission reduction credits for the following quantity of emissions: 1st quarter - 936 lb, 2nd quarter - 936 lb, 3rd quarter - 937 lb, and fourth quarter - 937 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services

S-1547-1342-0 : Dec 21 2016 2:10PM - EDGENILR : Joint Inspection NOT Required

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 1,642 lb, 2nd quarter - 1,642 lb, 3rd quarter - 1,643 lb, and fourth quarter - 1,643 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 985 lb, 2nd quarter - 985 lb, 3rd quarter - 986 lb, and fourth quarter - 986 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
7. ERC Certificate Numbers S-4489-1, S-4422-2, S-1821-2, S-1032-5, and S-4424-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
10. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
16. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
17. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NOx @ 3% O2 or 0.007 lb-NOx/MMBtu, 0.005 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. If either the NOx or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
35. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
36. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NOx and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
39. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1343-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

EQUIPMENT DESCRIPTION:
100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1548-625-0)


CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 2,299 lb, 2nd quarter - 2,299 lb, 3rd quarter - 2,230 lb, and fourth quarter - 2,230 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOX emission reduction credits for the following quantity of emissions: 1st quarter - 936 lb, 2nd quarter - 936 lb, 3rd quarter - 937 lb, and fourth quarter - 937 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services
S-1547-1343-0 Dec 21 2016 2:10PM - EDGEHILR : Joint Inspection NOT Required

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 1,642 lb, 2nd quarter - 1,642 lb, 3rd quarter - 1,643 lb, and fourth quarter - 1,643 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 985 lb, 2nd quarter - 985 lb, 3rd quarter - 986 lb, and fourth quarter - 986 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
7. ERC Certificate Numbers S-4489-1, S-4422-2, S-1821-2, S-1032-5, and S-4424-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
10. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
16. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
17. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NOx @ 3% O2 or 0.007 lb-NOx/MMBtu, 0.005 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
35. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
36. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
39. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1547-1344-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
KERN COUNTY, CA

EQUIPMENT DESCRIPTION:

100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1548-626-0)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 2,299 lb, 2nd quarter - 2,299 lb, 3rd quarter - 2,230 lb, and fourth quarter - 2,230 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOX emission reduction credits for the following quantity of emissions: 1st quarter - 936 lb, 2nd quarter - 936 lb, 3rd quarter - 937 lb, and fourth quarter - 937 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Sayed Sadredin, Executive Director / APCO

Claude Marjollet, Director of Permit Services

S-1547-1344-0 : Dec 21 2016 2:10PM - EDGEHILL : Joint Inspection NOT Required

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 1,642 lb, 2nd quarter - 1,642 lb, 3rd quarter - 1,643 lb, and fourth quarter - 1,643 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 985 lb, 2nd quarter - 985 lb, 3rd quarter - 986 lb, and fourth quarter - 986 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
7. ERC Certificate Numbers S-4489-1, S-4422-2, S-1821-2, S-1032-5, and S-4424-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
9. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
10. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
11. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
12. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
16. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
17. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NOx @ 3% O2 or 0.007 lb-NOx/MMBtu, 0.005 lb-PM10/MMBtu, 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
19. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
31. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

32. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
33. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
34. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
35. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
36. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
37. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
38. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
39. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
40. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



Facility # S-1548
AERA ENERGY LLC
PO BOX 11164
BAKERSFIELD, CA 93389-1164

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit.** Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at <http://www.valleyair.org/busind/pto/ptoforms/1ptoformidx.htm>.
3. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test:** Schedule and perform any required source testing. See http://www.valleyair.org/busind/comply/source_testing.htm for source testing resources.
7. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at http://www.valleyair.org/busind/comply/compliance_forms.htm.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

For assistance, please contact District Compliance staff at any of the telephone numbers listed below.

Sayed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1548-623-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: LIGHT OIL WESTERN STATIONARY SOURCE
CA

EQUIPMENT DESCRIPTION:

100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1547-1341-0)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Renaud Marjollet, Director of Permit Services

S-1548-623-0, Dec 21 2016 2:06PM - EDGEHILR : Joint Inspection NOT Required

7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
11. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
12. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.007 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 25 ppmvd CO @ 3% O₂ or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
34. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1548-624-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: LIGHT OIL WESTERN STATIONARY SOURCE
CA

EQUIPMENT DESCRIPTION:

100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1547-1342-0)

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

S-1548-624-0 Dec 21 2016 2:09PM - EDGEHLR - Joint Inspection NOT Required

7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
11. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
12. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.007 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 25 ppmvd CO @ 3% O₂ or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
34. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1548-625-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: LIGHT OIL WESTERN STATIONARY SOURCE
CA

EQUIPMENT DESCRIPTION:
100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1547-1343-0)


CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services

S-1548-625-0 Dec 21 2016 2:09PM - EDGEHLR Joint Inspection NOT Required

7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
11. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
12. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.007 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 25 ppmvd CO @ 3% O₂ or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
34. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-1548-626-0

ISSUANCE DATE: 12/21/2016

LEGAL OWNER OR OPERATOR: AERA ENERGY LLC
MAILING ADDRESS: PO BOX 11164
BAKERSFIELD, CA 93389-1164

LOCATION: LIGHT OIL WESTERN STATIONARY SOURCE
CA

EQUIPMENT DESCRIPTION:
100 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN/FIVES GLE BURNER (OR EQUIVALENT), ULTRA LOW-NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM, AND O2 CONTROLLER (ALSO PERMITTED AS S-1547-1344-0)


CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. This unit is authorized to operate at the following locations: Section 34, T28S, R21E, NE Section 33, T28S, R21E, NE Section 29, T28S, R21E, and Southern ½ Section 28, T28S, R21E [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall notify the District Compliance Division to arrange a start-up inspection at the initial location of the unit. [District Rule 1070] Federally Enforceable Through Title V Permit
5. Permittee shall notify the District Compliance Division in writing of each facility location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 1070] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Maude Marjollet, Director of Permit Services
S-1548-626-0, Dec 21 2016 2:09PM - EDGEHLR Joint Inspection NOT Required

7. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201, 4301, and 4320] Federally Enforceable Through Title V Permit
11. At least quarterly, the permittee shall monitor using the methods specified in this permit the higher heating value of each non-certified fuel supplied to this unit, or, alternatively, have the higher heating value certified by the fuel supplier. The records of higher heating value and quantity of fuel combusted shall be used to demonstrate that the rated heat input capacity of this unit, as averaged over a calendar quarter, is not exceeded. [District Rules 2201] Federally Enforceable Through Title V Permit
12. The higher heating value of each non-certified fuel shall be certified by a third party fuel supplier or determined by ASTM D1826 or D1945 in conjunction with ASTM D 3588. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
13. Except for periods of startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following limits: 6 ppmvd NO_x @ 3% O₂ or 0.007 lb-NO_x/MMBtu, 0.005 lb-PM₁₀/MMBtu, 25 ppmvd CO @ 3% O₂ or 0.0185 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4201, 4301, 4305, 4306, 4320, and 4801] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted within 60 days of initial startup and at least once every twelve (12) months thereafter. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. Fuel sulfur content shall be determined using EPA Method 11 or Method 15. [District Rule 4320] Federally Enforceable Through Title V Permit
24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320] Federally Enforceable Through Title V Permit
32. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

33. Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)] [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit
34. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit