

**NOTICE OF FINAL DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
MINOR MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued an Authority to Construct to Covanta Mendota LP at 400 Guillen Pkwy in Mendota, CA, California. This project is for the modification of a biomass and natural gas-fired circulating fluidized bed boiler to install a sodium bicarbonate injection system, with an optional activated carbon system, for compliance with MACT regulation - Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters.

No comments were received following the District's preliminary decision on this project.

The application review for Project #C-1152808 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.