

**JUN 05 2017**

Mr. Gregory Pritchett  
Chevron USA Inc  
PO Box 1392  
Bakersfield, CA 93302

**Re: Final - Authority to Construct / Certificate of Conformity (Significant Mod)  
District Facility # S-1131  
Project # 1171052**

Dear Mr. Pritchett:

The Air Pollution Control Officer has issued Authority to Construct (ATC) S-1131-1204-0 with a Certificate of Conformity to Chevron USA Inc at central Kern County. The project authorizes an IC engine/generator. Enclosed are the ATC and a copy of the notice of final action to be published approximately three days from the date of this letter.

Notice of the District's preliminary decision to issue the ATC was published on April 26, 2017. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on April 21, 2017. No comments were received following the District's preliminary decision on this project.

Prior to operating with the modifications authorized by the ATC, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms are found on the District's website at [www.valleyair.org/permits/TVforms](http://www.valleyair.org/permits/TVforms).

Seyed Sadredin  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475


**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

Mr. Gregory Pritchett  
Page 2

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



Arnaud Marjollet  
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email  
cc: Gerardo C. Rios, EPA (w/enclosure) via email



Facility # S-1131  
CHEVRON USA INC  
PO BOX 1392  
BAKERSFIELD, CA 93302

## **AUTHORITY TO CONSTRUCT (ATC)**

### **QUICK START GUIDE**

1. **Pay Invoice:** Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit.** Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at <http://www.valleyair.org/busind/pto/ptoforms/1ptoforidx.htm>.
3. **Fully Understand ATC:** Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC:** You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District:** You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test:** Schedule and perform any required source testing. See [http://www.valleyair.org/busind/comply/source\\_testing.htm](http://www.valleyair.org/busind/comply/source_testing.htm) for source testing resources.
7. **Maintain Records:** Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at [http://www.valleyair.org/busind/comply/compliance\\_forms.htm](http://www.valleyair.org/busind/comply/compliance_forms.htm).

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

**For assistance, please contact District Compliance staff at  
any of the telephone numbers listed below.**

Seyed Sadredin  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

## AUTHORITY TO CONSTRUCT

PERMIT NO: S-1131-1204-0

ISSUANCE DATE: 05/31/2017

LEGAL OWNER OR OPERATOR: CHEVRON USA INC  
MAILING ADDRESS: PO BOX 1392  
BAKERSFIELD, CA 93302

LOCATION: HEAVY OIL CENTRAL  
KERN COUNTY, CA

SECTION: NW 10 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:  
2922 HP EPA TIER 2 DIESEL-FIRED LIMITED-LIFE IC ENGINE

### CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 440 lb, 2nd quarter - 441 lb, 3rd quarter - 441 lb, and fourth quarter - 441 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 4/21/11) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. ERC Certificate Numbers C-1147-2, C-1372-2, C-966-2, S-1325-2, and S-496-2 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
5. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



Arnaud Marjollet, Director of Permit Services

S-1131-1204-0: May 31 2017 11:39AM - EDG:HLR : Joint Inspection NOT Required

6. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO-approved alternative. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
10. IC engine shall not be operated longer than 4.0 hr/day. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Total operation of the IC engine associated with this permit unit shall not exceed 40 hours without prior District approval through issuance of an Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
12. NOx emissions (referenced as NO2) shall not exceed 4.56 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
13. VOC emissions (referenced as methane) shall not exceed 0.24 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
14. CO emissions shall not exceed 2.6 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The PM10 emissions rate from the engine shall not exceed 0.15 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
16. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
17. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
18. The operator shall maintain records of the daily hours and cumulative hours of operation on a 12 month rolling average. These records shall be updated at least monthly. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
19. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit
20. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit