

Bakersfield Californian

Newspaper notice for publication in Bakersfield Californian and for posting on
valleyair.org

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permits to Dignity Health Downtown Hospital for replacing PTO S-1-3 with a 762 bhp diesel-fired emergency standby internal combustion (IC) engine powering an electrical generator, at 2215 Truxtun Ave, Bakersfield, CA.

No comments were received following the District's preliminary decision on this project.

The application review for Project # S-1171941 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 34946 FLYOVER COURT, BAKERSFIELD, CA 93308, and at any other District office. For additional information, please contact the District at (661) 392-5500.