



NOV 30 2017

Mr. David Groves
California State Prison - Avenal
PO Box 8
Avenal, CA 93204

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # C-195
Project # C-1161174**

Dear Mr. Groves:

The District has issued the Final Renewed Title V Permit for California State Prison - Avenal (see enclosure). The preliminary decision for this project was made on October 3, 2017. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95358-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Permit to Operate

FACILITY: C-195

EXPIRATION DATE: 10/31/2022

LEGAL OWNER OR OPERATOR:
MAILING ADDRESS:

CALIF STATE PRISON - AVENAL
ATTENTION: MARK SHANDOR-PLANT OPERATIONS
PO BOX 8
AVENAL, CA 93204

FACILITY LOCATION:

1 KINGS WAY
AVENAL, CA 93204

FACILITY DESCRIPTION:

CORRECTIONAL INSTITUTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin

Executive Director / APCO

Arnaud Marjollet

Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: C-195-0-3

EXPIRATION DATE: 10/31/2022

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: CALIF STATE PRISON - AVENAL
Location: 1 KINGS WAY, AVENAL, CA 93204
C-195-0-3 Nov 27 2017 1:16PM - BUSHT

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
25. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
40. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin June 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-1-10

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

2,600 KW SOLAR CENTAUR MODEL GSC-4500 GAS TURBINE, AVENAL #1, SN DCG0211, WITH UNFIRED ENERGY RECOVERY INC. MODEL 52.5-1816 THERMAL RECOVERY UNIT, AND CUSTOM BUILT RF MACDONALD SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM WITH AMMONIA INJECTION, SN W2272

PERMIT UNIT REQUIREMENTS

1. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit
2. This turbine shall not operate for more than 8,050 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This turbine shall not operate when the 21 MMBtu/hr backup boiler (C-195-2) and the other turbine (C-195-3) are both operating except for cold starts of less than 1 hour, a shutdown of less than 2 hours, and boiler testing totaling less than 24 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This turbine shall only be fired on PUC-regulated natural gas with a maximum sulfur content of 0.12% by weight as a backup fuel. [District Rules 2201, 4201, and 4801 and 40 CFR 60.333] Federally Enforceable Through Title V Permit
5. Natural gas fuel consumption for the turbine shall not exceed 879,960 scf per day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The combined total operating hours of two turbines (C-195-1 and C-195-3) when operating concurrently with two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) shall not exceed 2,601 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Daily hours of concurrent operation with the two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) shall be maintained. [District Rule 2520] Federally Enforceable Through Title V Permit
8. The exhaust NO_x concentrations shall not exceed 9 ppmvd @ 15% O₂ or 1.1 lb/hr, averaged over a 3-hour period, except during the thermal stabilizing period or reduced load period, as defined in District Rule 4703. [District Rules 2201 and Rule 4703 and 40 CFR 60.332(c)] Federally Enforceable Through Title V Permit
9. The exhaust CO concentration shall not exceed 130.0 ppmvd @ 15% O₂ or 10.00 lb/hr, averaged over a 3-hour period, except during the thermal stabilizing period or reduced load period, as defined in District Rule 4703. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
10. Ammonia (NH₃) emissions shall not exceed either of the following limits: 1.28 lb/hr or 10 ppmvd @ 15% O₂ (based on a 1-hour rolling average). [District Rule 2201] Federally Enforceable Through Title V Permit
11. Daily emissions shall not exceed any of the following: 122.6 lb-SO_x/day, 36.0 lb-PM₁₀/day, or 120.0 lb-VOC (NMHC)/day. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
12. Permittee shall perform a source test to measure NO_x and CO emissions (ppmvd @ 15% O₂ and lb/hr) at least once every twelve months. [District Rules 1081 and 4703, 6.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The following test methods shall be used: NO_x - EPA Method 7E or 20, CO - EPA Method 10 or 10B, O₂ - EPA Method 3, 3A, or 20, and ammonia - BAAQMD Method ST-1B. NO_x test results shall be corrected to ISO standard conditions as defined in 40 CFR Part 60 Subpart GG Section 60.335. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. The request to utilize EPA approved alternative source testing methods must be submitted in writing and written approval received from the District prior to the submission of the source test plan. [District Rules 1081 and 4703, 6.4.1, 6.4.2, & 6.4.3, and 40 CFR 60.335] Federally Enforceable Through Title V Permit
16. The HHV and LHV of the fuel combusted shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703] Federally Enforceable Through Title V Permit
17. Ammonia shall be injected whenever the selective catalytic reduction system catalyst temperature exceeds the minimum ammonia injection temperature recommended by the manufacturer. [District Rules 2201 and 4703 and 40 CFR 64] Federally Enforceable Through Title V Permit
18. During initial performance testing, the ammonia injection rate shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emission limitations stated in this permit. The minimum ammonia injection rates demonstrated during the initial performance test to result in compliance with the NO_x emission limits shall be imposed as a condition in the Permit to Operate. [40 CFR 60.334(f)(3)] Federally Enforceable Through Title V Permit
19. If the ammonia injection rate is less than the minimum ammonia injection rate demonstrated during the initial compliance test, the permittee shall return the ammonia injection rate above the minimum ammonia injection rate established during compliance testing as soon as possible, but no longer than 8 hours after detection. If the ammonia injection rate is not returned above the minimum ammonia injection rate established during compliance testing within 8 hours, the permittee shall notify the District within the following 1 hour and conduct a source test within 60 days of the first exceedance to demonstrate compliance with the applicable emission limits at the reduced ammonia injection rate. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4703 and 40 CFR 64] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NO_x (as NO₂), CO, and O₂ weekly. If compliance with NO_x and CO emission is demonstrated for eight (8) consecutive weeks, then the monitoring frequency shall be reduced to monthly. If deviations are observed in two consecutive months, monitoring shall revert to weekly until 8 consecutive weeks show no deviations. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within one (1) day of restarting the unit unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the week if on a weekly monitoring schedule. [District Rules 2201 and 4703 and 40 CFR 60.334 and 40 CFR 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. If the NO_x and/or CO concentrations, as measured by the permittee with a portable analyzer, exceed the permitted emission limits, the permittee shall notify the District and return the NO_x and CO concentrations to the permitted emission limits as soon as possible but no longer than eight (8) hours after detection. If the permittee's portable analyzer readings continue to exceed the permitted emission limits after eight (8) hour, the permittee shall notify the District within the following one (1) hour, and conduct a certified source test within 60 days to demonstrate compliance with permitted emissions limits. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
22. This unit shall be fired exclusively on PUC-regulated natural gas and the PUC-regulated natural gas shall have a total sulfur content of less than or equal to 1.0 gr/100 scf. [District Rules 2201 and 4801 and 40 CFR 60.333(b)] Federally Enforceable Through Title V Permit
23. The sulfur fuel content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If the sulfur fuel content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a sulfur fuel content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
24. Compliance with the ammonia emission limit shall be demonstrated at least once per month, concurrently with the NO_x stack concentration readings, utilizing one of the following procedures: 1) The permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. 2) The permittee may utilize a District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. The permittee shall submit a detailed calculation protocol or monitoring plan for District Approval at least 60 days prior to the commencement of operation. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
25. The facility shall maintain a daily record of the ammonia injection rate and SCR catalyst inlet temperature. [District Rule 2201 and 40 CFR 64] Federally Enforceable Through Title V Permit
26. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods or thermal stabilizing periods, total hours of operation, and the amount and type of fuel consumed. [District Rule 4703] Federally Enforceable Through Title V Permit
27. Source testing to determine compliance with the NO_x, CO and NH₃ emission rates (ppmvd @ 15% O₂) shall be conducted at least once every 12 months. [District Rules 2201 and 4703 and 40 CFR 60.335(a)] Federally Enforceable Through Title V Permit
28. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
29. Permittee shall record fuel consumption, fuel type, and sulfur content of fuel. Records shall be retained for at least five years and shall be made available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. The owner or operator shall maintain the gas quality characteristics in a current, valid purchase contract, tariff sheet, or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 10 grains/100 scf or less. [District Rules 2520, 9.3.2 and 4301 and 40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

31. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate, not to exceed one hour. [District Rule 4703, 3.19] Federally Enforceable Through Title V Permit
32. Thermal Stabilization Period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
33. The duration of each startup or shutdown event shall not exceed two hours. Start-up and shutdown emissions shall be counted toward all applicable emission limits. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
34. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
35. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
36. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
37. Particulate matter emissions shall not exceed 0.1 grains/scf @ 12% CO₂. [District Rule 4301] Federally Enforceable Through Title V Permit
38. The owner or operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-2-11

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

19.959 MMBTU/HR MOHAWK NATURAL GAS-FIRED BOILER WITH A POWER FLAME MODEL #NVC10-G-30 LOW NOX BURNER

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
4. On and after July 1, 2012, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit
5. This boiler shall not be fired when both gas turbines (permit units C-195-1 and C-195-3) are operating except for cold start-up of less than 1 hour, a shutdown of less than 3 hours, or during boiler testing not to exceed a total of 24 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. This boiler shall not operate when both 25.1 MMBtu/hr boilers (permit units C-195-12 and C-195-13) are operating. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The maximum annual heat input of the unit shall not exceed 555.6 MMBtu based on a rolling 12 consecutive month period. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The unit shall only be fired on PUC-regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
9. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of natural gas combusted in the unit shall be installed, utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Emissions rates from the natural gas-fired unit shall not exceed any of the following limits: 9 ppmv NO_x @ 3% O₂ or 0.011 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 100 ppmv CO @ 3% O₂ or 0.074 lb-CO/MMBtu, or 10 ppmv VOC @ 3% O₂ or 0.004 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Records of monthly and annual heat input of the unit shall be maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-3-10

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

2,600 KW SOLAR CENTAUR MODEL CSC-4500 GAS TURBINE, AVENAL #2, SN DCG02010, WITH UNFIRED ENERGY RECOVERY INC. MODEL 52.5-1416 THERMAL RECOVERY UNIT, AND CUSTOM BUILT RF MACDONALD SELECTIVE CATALYTIC (SCR) SYSTEM WITH AMMONIA INJECTION, SN W2274

PERMIT UNIT REQUIREMENTS

1. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit
2. This turbine shall not operate for more than 8,050 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This turbine shall not operate when the 21 MMBtu/hr backup boiler (C-195-2) and the other turbine (C-195-3) are both operating except for cold starts of less than 1 hour, a shutdown of less than 2 hours, and boiler testing totaling less than 24 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This turbine shall only be fired on PUC-regulated natural gas with a maximum sulfur content of 0.12% by weight as a backup fuel. [District Rules 2201, 4201, and 4801 and 40 CFR 60.333] Federally Enforceable Through Title V Permit
5. Natural gas fuel consumption for the turbine shall not exceed 879,960 scf per day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The combined total operating hours of two turbines (C-195-1 and C-195-3) when operating concurrently with two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) shall not exceed 2,601 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Daily hours of concurrent operation with the two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) shall be maintained. [District Rule 2520] Federally Enforceable Through Title V Permit
8. The exhaust NO_x concentrations shall not exceed 9 ppmvd @ 15% O₂ or 1.1 lb/hr, averaged over a 3-hour period, except during the thermal stabilizing period or reduced load period, as defined in District Rule 4703. [District Rules 2201 and 4703 and 40 CFR 60.332(c)] Federally Enforceable Through Title V Permit
9. The exhaust CO concentration shall not exceed 130.0 ppmvd @ 15% O₂ or 10.00 lb/hr, averaged over a 3-hour period, except during the thermal stabilizing period or reduced load period, as defined in District Rule 4703. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
10. Ammonia (NH₃) emissions shall not exceed either of the following limits: 1.28 lb/hr or 10 ppmvd @ 15% O₂ (based on a 1-hour rolling average). [District Rule 2201] Federally Enforceable Through Title V Permit
11. Daily emissions shall not exceed any of the following: 122.6 lb-SO_x/day, 36.0 lb-PM₁₀/day, or 120.0 lb-VOC (NMHC)/day. [District Rules 2201 and 4301] Federally Enforceable Through Title V Permit
12. Permittee shall perform a source test to measure NO_x and CO emissions (ppmvd @ 15% O₂ and lb/hr) at least once every twelve months. [District Rules 1081 and 4703, 6.3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The following test methods shall be used: NO_x - EPA Method 7E or 20, CO - EPA Method 10 or 10B, O₂ - EPA Method 3, 3A, or 20, and ammonia - BAAQMD Method ST-1B. NO_x test results shall be corrected to ISO standard conditions as defined in 40 CFR Part 60 Subpart GG Section 60.335. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. The request to utilize EPA approved alternative source testing methods must be submitted in writing and written approval received from the District prior to the submission of the source test plan. [District Rules 1081 and 4703, 6.4.1, 6.4.2, & 6.4.3 and 40 CFR 60.335] Federally Enforceable Through Title V Permit
16. The HHV and LHV of the fuel combusted shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [District Rule 4703] Federally Enforceable Through Title V Permit
17. Ammonia shall be injected whenever the selective catalytic reduction system catalyst temperature exceeds the minimum ammonia injection temperature recommended by the manufacturer. [District Rules 2201 and 4703 and 40 CFR 64] Federally Enforceable Through Title V Permit
18. During initial performance testing, the ammonia injection rate shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emission limitations stated in this permit. The minimum ammonia injection rates demonstrated during the initial performance test to result in compliance with the NO_x emission limits shall be imposed as a condition in the Permit to Operate. [40 CFR 60.334(f)(3)] Federally Enforceable Through Title V Permit
19. If the ammonia injection rate is less than the minimum ammonia injection rate demonstrated during the initial compliance test, the permittee shall return the ammonia injection rate above the minimum ammonia injection rate established during compliance testing as soon as possible, but no longer than 8 hours after detection. If the ammonia injection rate is not returned above the minimum ammonia injection rate established during compliance testing within 8 hours, the permittee shall notify the District within the following 1 hour and conduct a source test within 60 days of the first exceedance to demonstrate compliance with the applicable emission limits at the reduced ammonia injection rate. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4703 and 40 CFR 64] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NO_x (as NO₂), CO, and O₂ weekly. If compliance with NO_x and CO emission is demonstrated for eight (8) consecutive weeks, then the monitoring frequency shall be reduced to monthly. If deviations are observed in two consecutive months, monitoring shall revert to weekly until 8 consecutive weeks show no deviations. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within one (1) day of restarting the unit unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the week if on a weekly monitoring schedule. [District Rules 2201 and 4703 and 40 CFR 60.334 and 40 CFR 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

21. If the NO_x and/or CO concentrations, as measured by the permittee with a portable analyzer, exceed the permitted emission limits, the permittee shall notify the District and return the NO_x and CO concentrations to the permitted emission limits as soon as possible but no longer than eight (8) hours after detection. If the permittee's portable analyzer readings continue to exceed the permitted emission limits after eight (8) hour, the permittee shall notify the District within the following one (1) hour, and conduct a certified source test within 60 days to demonstrate compliance with permitted emissions limits. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
22. This unit shall be fired exclusively on PUC-regulated natural gas and the PUC-regulated natural gas shall have a total sulfur content of less than or equal to 1.0 gr/100 scf. [District Rules 2201 and 4801 and 40 CFR 60.333(b)] Federally Enforceable Through Title V Permit
23. The sulfur fuel content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If the sulfur fuel content is less than 1.0 gr/100 scf for 8 consecutive weeks, then the monitoring frequency shall be every 6 months. If any six-month monitoring tests result in a sulfur fuel content exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
24. Compliance with the ammonia emission limit shall be demonstrated at least once per month, concurrently with the NO_x stack concentration readings, utilizing one of the following procedures: 1) The permittee may utilize a continuous in-stack ammonia monitor to verify compliance with the ammonia emissions limit. 2) The permittee may utilize a District-approved calculation method using measured surrogate parameters to determine the daily ammonia emissions in ppmvd @ 15% O₂. The permittee shall submit a detailed calculation protocol or monitoring plan for District Approval at least 60 days prior to the commencement of operation. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
25. The facility shall maintain a daily record of the ammonia injection rate and SCR catalyst inlet temperature. [District Rule 2201 and 40 CFR 64] Federally Enforceable Through Title V Permit
26. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods or thermal stabilizing periods, total hours of operation, and the amount and type of fuel consumed. [District Rule 4703] Federally Enforceable Through Title V Permit
27. Source testing to determine compliance with the NO_x, CO and NH₃ emission rates (ppmvd @ 15% O₂) shall be conducted at least once every 12 months. [40 CFR 60.335(a) and District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
28. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
29. Permittee shall record fuel consumption, fuel type, and sulfur content of fuel. Records shall be retained for at least five years and shall be made available for District inspection upon request. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
30. The owner or operator shall maintain the gas quality characteristics in a current, valid purchase contract, tariff sheet, or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 10 grains/100 scf or less. [District Rule 2520, 9.3.2, District Rule 4301, and 40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

31. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate, not to exceed one hour. [District Rule 4703, 3.19] Federally Enforceable Through Title V Permit
32. Thermal Stabilization Period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
33. The duration of each startup or shutdown event shall not exceed two hours. Start-up and shutdown emissions shall be counted toward all applicable emission limits. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
34. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
35. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703] Federally Enforceable Through Title V Permit
36. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
37. Particulate matter emissions shall not exceed 0.1 grains/scf @ 12% CO₂. [District Rule 4301] Federally Enforceable Through Title V Permit
38. The owner or operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-4-4

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

WOODWORKING OPERATION SERVED BY TORIT MODEL 30 CYCLONE DUST COLLECTOR, SN 224053, WITH TORIT CABINET-TYPE BAGHOUSE

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Visible emissions from the exhaust of the dust collector serving the woodworking operation shall not equal or exceed 5% opacity for a period or periods aggregating more than three minutes in any one hour. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Dust collector exhaust fan(s) shall be switched on prior to the start-up of any woodworking equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All ducting and control equipment shall be in good working order to prevent fugitive particulate emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All filters shall be properly maintained and must be in place during the woodworking operation(s). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Each dust collector cleaning frequency and duration shall be adjusted to optimize the control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Replacement filters numbering at least 10% of the total number of filters in the largest dust collector using each type of filter shall be maintained on the premises. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM10 emissions from the dust collector shall not exceed 0.005 gr/dscf. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
11. Records of all maintenance of the dust collector, including all change outs of filter media, shall be maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
12. All records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-6-4

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

WOODWORKING OPERATION SERVED BY TORIT MODEL 30 FM CYCLONE DUST COLLECTOR, SERIES 30-15 WITH BAGHOUSE

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Visible emissions from the exhaust of the dust collector serving the woodworking operation shall not equal or exceed 5% opacity for a period or periods aggregating more than three minutes in any one hour. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Dust collector exhaust fan(s) shall be switched on prior to the start-up of any woodworking equipment. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All ducting and control equipment shall be in good working order to prevent fugitive particulate emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All filters shall be properly maintained and must be in place during the woodworking operation(s). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Each dust collector cleaning frequency and duration shall be adjusted to optimize the control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Replacement filters numbering at least 10% of the total number of filters in the largest dust collector using each type of filter shall be maintained on the premises. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM10 emissions from the dust collector shall not exceed 0.005 gr/dscf. [District Rules 2201 and 4201] Federally Enforceable Through Title V Permit
11. Records of all maintenance of the dust collector, including all change outs of filter media, shall be maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
12. All records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-8-3

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

WOODWORKING OPERATION SERVED BY DONALDSON "TORIT" DUST COLLECTOR MODEL 30, #250077, WITH 24" CYCLONE AND FABRIC FILTER BAGHOUSE

PERMIT UNIT REQUIREMENTS

1. Material removed from dust collector(s) shall be disposed of in a manner preventing entrainment into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
3. PM10 emissions shall not exceed 20 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-9-5

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

AUTOMOTIVE, METAL PARTS/PRODUCTS, AND WOOD PRODUCTS PAINT SPRAYING OPERATION WITH HVLP SPRAY GUN, RELY-ON PAINT SPRAY BOOTH, I.D. #IF121010, WITH DRY AIR FILTERS AND ENCLOSED GUN CLEANER, AND 0.4 MMBTU/HR DRYING OVEN

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. No coatings, solvents, or additives containing chromium compounds shall be used. [CH&SC 41700]
4. VOC emissions from all coating operations shall not exceed 40 pounds per day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. VOC emissions from all metal parts and products coating operations shall not exceed 14.0 pounds per day for the entire facility. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Wood products coating application operations shall use a total of less than 20 gallons of coating per year. [District Rules 2201 and Rule 4606] Federally Enforceable Through Title V Permit
7. All painting, including application of primer, shall be conducted inside the booth with filters in place, fan(s) operating, and doors closed. [District Rule 2201] Federally Enforceable Through Title V Permit
8. During metal parts and products coating, only HVLP, electrostatic, electrodeposition, flow, roll, dip, brush or continuous coating application equipment shall be used, and the application equipment shall be operated in accordance with the manufacturer's recommendations. [District Rule 4603] Federally Enforceable Through Title V Permit
9. During wood product coating, only HVLP, electrostatic, brush, dip, flow, or roll coating application equipment shall be used, and the application equipment shall be operated in accordance with the manufacturer's recommendations. [District Rule 4606] Federally Enforceable Through Title V Permit
10. During motor vehicle and mobile equipment coating, only HVLP, electrostatic, brush, dip, or roll coating application equipment, or other application equipment approved by the District in writing, shall be used. All application equipment shall be operated in accordance with the manufacturer's recommendations. [District Rule 4612] Federally Enforceable Through Title V Permit
11. If an HVLP spray gun is used, the operator must demonstrate that the spray gun operates between 0.1 and 10 pounds per square inch, gauge, (psig) air atomizing pressure, measured dynamically at the center of the air cap and at the air horns. For a gun permanently labeled HVLP by the manufacturer, a satisfactory demonstration shall either be in the form of manufacturer's published technical information or by a demonstration of the operation of the gun using an air pressure tip gauge from the manufacturer of the gun. For a gun not permanently labeled HVLP by the manufacturer, a satisfactory demonstration shall be based on manufacturer's published technical material and by a demonstration of the operation of the gun using an air pressure tip gauge from the manufacturer of the gun. [District Rules 4603, 4606, and 4612] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. VOC content of any coatings as applied, excluding water and exempt compounds, used for any metal parts or product shall not exceed any of the following limits, except as allowed elsewhere in this permit: baked coating 275 g/l (2.3 lb/gal), air-dried coating: 340 g/l (2.8 lb/gal), air-dried dip coating of steel joists with coating viscosity, as applied, of more than 45.6 centistokes at 78 degrees F or an average dry-film thickness of greater than 2.0 millimeters: 340 g/l (2.8 lb/gal), air-dried dip coating of steel joists with coating viscosity, as applied, of less than or equal to 45.6 centistokes at 78 degrees F or an average dry-film thickness of less than or equal to 2.0 millimeters: 400 g/l (3.32 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
13. VOC content of air-dried specialty coatings as applied, excluding water and exempt compounds, used for metal parts or product shall not exceed any of the following limits: camouflage 420 g/l (3.5 lb/gal), extreme performance: 420 g/l (3.5 lb/gal), heat resistant: 420 g/l (3.5 lb/gal), high gloss: 420 g/l (3.5 lb/gal), high performance architectural: 420 g/l (3.5 lb/gal), high temperature: 420 g/l (3.5 lb/gal), metallic coating: 420 g/l (3.5 lb/gal), pretreatment coating: 420 g/l (3.5 lb/gal), touch up and repair coating: 420 g/l (3.5 lb/gal), silicone release: 420 g/l (3.5 lb/gal), solar absorbent: 420 g/l (3.5 lb/gal), and solid film lubricant: 880 g/l (7.3 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
14. VOC content of air-dried specialty coatings as applied, excluding water and exempt compounds used for large appliance parts or products coating operations, or metal furniture coating operations at a stationary source with VOC emissions greater than three (3) tons of VOC per 12 month rolling period, before consideration of controls shall not exceed any of the following limits: general, one component: 275 g/l (2.3 lb/gal), general, multi-component: 340 g/l (2.8 lb/gal), extreme high gloss: 340 g/l (2.8 lb/gal), extreme performance: 420 g/l (3.5 lb/gal), heat resistant: 420 g/l (3.5 lb/gal), metallic: 420 g/l (3.5 lb/gal), pretreatment coating: 420 g/l (3.5 lb/gal), and solar absorbent: 420 g/l (3.5 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
15. VOC content of plastic parts and products coating operations as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits: general one-component: 280 g/l (2.3 lb/gal), general multi-component: 420 g/l (3.5 lb/gal), electric dissipating coatings and shock-free coatings: 800 g/l (6.7 lb/gal), extreme performance for 2-pack coating: 420 g/l (3.5 lb/gal), metallic: 420 g/l (3.5 lb/gal), military specification for 1 pack coating: 340 g/l (2.8 lb/gal), military specification for 2-pack coating: 420 g/l (3.5 lb/gal), mold-seal: 760 g/l (6.3 lb/gal), multi-colored coatings 680 g/l (5.7 lb/gal), optical coatings: 800 g/l (6.7 lb/gal), and vacuum-metalizing: 800 g/l (6.7 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
16. VOC content of automotive/transportation plastic parts and products coating operations as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits for high baked coatings - interior and exterior: flexible primer: 540 g/l (4.5 lb/gal), non-flexible primer: 420 g/l (3.5 lb/gal), basecoat: 520 g/l (4.3 lb/gal), clearcoat: 480 g/l (4.0 lb/gal), and non-basecoat/clearcoat: 520 g/l (4.3 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
17. VOC content of automotive/transportation plastic parts and products coating operations as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits for low bake/air-dried coatings - exterior parts: primers: 580 g/l (4.8 lb/gal), basecoat: 600 g/l (5.0 lb/gal), clearcoat: 540 g/l (4.5 lb/gal), and non-basecoat/clearcoat: 600 g/l (5.0 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

18. VOC content of automotive/transportation plastic parts and products coating operations as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits for low bake/air-dried coatings - interior parts: 600 g/l (5.0 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
19. VOC content of automotive/transportation plastic parts and products coating operations as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits for touch-up and repair coatings: 620 g/l (5.2 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
20. VOC content of business machine plastic parts and product coatings as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits: Primer: 350 g/l (2.9 lb/gal), topcoat: 350 g/l (2.9 lb/gal), texture coat: 350 g/l (2.9 lb/gal), fog coat: 260 g/l (2.2 lb/gal), and touch-up and repair: 350 g/l (2.9 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
21. VOC content of pleasure craft coatings as applied, excluding water and at a stationary source with all VOC emissions from metal parts and products, plastic parts and products, automotive/transportation and business machine plastic parts and products, and pleasure craft coating operation, including related cleaning activities greater than 2.7 tons of VOC per 12-month rolling period before consideration of controls shall not exceed any of the following limits: extreme high gloss topcoat: 490 g/l (4.1 lb/gal), high gloss topcoat: 420 g/l (3.5 lb/gal), pretreatment wash primer: 780 g/l (6.5 lb/gal), finish primer surfacer: 420 g/l (3.5 lb/gal), high build primer surfacer: 340 g/l (2.8 lb/gal), aluminum substrate antifoulant coating 560 g/l (4.7 lb/gal), other substrate antifoulant coating: 330 g/l (2.8 lb/gal), and all other pleasure craft surface coatings for metal or plastic: 420 g/l (3.5 lb/gal). [District Rule 4603] Federally Enforceable Through Title V Permit
22. An operator of large appliance parts and products, and metal furniture coating operations shall: store all VOC-containing coatings, thinners, cleaning materials, and waste materials in closed non-absorbent and non-leaking containers, keeping the containers closed except when specifically in use; close mixing vessels that contain VOC coatings and other materials, except when specifically in use; minimize spill of any VOC-containing materials and clean up spills immediately; and convey VOC-containing materials in closed containers or pipes. [District Rule 4603] Federally Enforceable Through Title V Permit
23. An operator of metal parts products coating operations, plastic parts and products coating operations, automotive/transportation and business machine plastic parts and products coating operations and pleasure craft coating operations shall: store all VOC-containing coatings, thinners, cleaning materials, and waste materials in closed non-absorbent and non-leaking containers, keeping the containers closed except when specifically in use; close mixing vessels that contain VOC coatings and other materials, except when specifically in use; minimize spill of any VOC-containing materials and clean up spills immediately; and convey VOC-containing materials in closed containers or pipes. [District Rule 4603] Federally Enforceable Through Title V Permit
24. VOC content of coatings as applied, excluding water and exempt compounds, used for wood product, shall not exceed any of the following limits: clear topcoat 275 g/l (2.3 lb/gallon), filler 275 g/l (2.3 lb/gallon), high-solids stains 240 g/l (2.0 lb/gallon), ink 500 g/l (4.2 lb/gallon), mold-seal coating 750 g/l (6.3 lb/gallon), multi-colored coating 275 g/l (2.3 lb/gallon), pigmented coating 275 g/l (2.3 lb/gallon), sanding sealer 275 g/l (2.3 lb/gallon). [District Rule 4606] Federally Enforceable Through Title V Permit
25. VOC content of coatings as applied, excluding water and exempt compounds, used for wood product, shall not exceed any of the following limits: low-solids stain 120 g/l (1.0 lb/gallon), stripper 350 g/l (2.9 lb/gallon). [District Rule 4606] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. VOC content of strippable booth coating shall not exceed 450 g/l (3.8 lb/gallon) as applied, excluding water and exempt compounds. [District Rule 4606] Federally Enforceable Through Title V Permit
27. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts, and thinners shall be stored in closed, non-absorbent and non-leaking containers. The containers shall remain closed at all times except when depositing or removing the contents of the containers or when the container is empty. [District Rules 4603, 4606, and 4612] Federally Enforceable Through Title V Permit
28. For solvent cleaning operations other than for bug and tar removal, the permittee shall not use solvents that have VOC content greater than 25 g/l (0.21 lb/gal) of cleaning material. [District Rules 4603, 4606, and 4612] Federally Enforceable Through Title V Permit
29. For bug and tar removal, the permittee shall not use any material other than bug and tar remover regulated under the Consumer Products Regulation (California Code of Regulations Section 94507 et seq.). [District Rule 4612] Federally Enforceable Through Title V Permit
30. The VOC Regulatory content of coatings, as applied shall not exceed any of the following limits: adhesion promoter 540 g/l (4.5 lb/gal), clear coating 250 g/l (2.1 lb/gal), color coating 420 g/l (3.5 lb/gal), multi-color coating 680 g/l (5.7 lb/gal), pretreatment coating 660 g/l (5.5 lb/gal), primer 250 g/l (2.1 lb/gal), primer sealer 250 g/l (2.1 lb/gal), single-stage coating 340 g/l (2.8 lb/gal), temporary protective coating 60 g/l (0.5 lb/gal), underbody coating 430 g/l (3.6 lb/gal), uniform finish coating 540 g/l (4.5 lb/gal), and any other coating type 250 g/l (2.1 lb/gal). The VOC Regulatory content for coatings shall be defined as the VOC in grams per liter of coating (or pounds per gallon of coating), excluding water and exempt compounds. [District Rule 4612] Federally Enforceable Through Title V Permit
31. For metal parts and products coatings, the permittee shall maintain a current list of coatings and solvents in use which contains all of the coating data necessary to evaluate compliance, including the following information: mix ratio of components used, VOC content and specific chemical constituents of coatings as applied, and VOC content and specific chemical constituents of solvents used for surface preparation and cleanup. [District Rule 4603] Federally Enforceable Through Title V Permit
32. For motor vehicle and mobile equipment coatings, the permittee shall maintain and have available at all times the following: a current list of all coatings used that includes the material name and manufacturer, application method, coating type and mix ratio specific to the coating, and the VOC Actual for Coatings and VOC Regulatory for Coatings as applied; current manufacturer specification sheets, material safety data sheets (MSDS), technical data sheets, or air quality data sheets, which list the VOC Actual for Coatings and VOC Regulatory for Coatings of each ready-to-spray coating and automotive coating components; and purchase records identifying the coating type, name, and volume of coatings bought. [District Rule 4612] Federally Enforceable Through Title V Permit
33. Permittee shall maintain daily records of the following: quantity and type of coatings and solvents used, mix ratios (by volume) of components added to each coating, volume of coatings applied, VOC content of each coating as applied, VOC content of each solvent and for dip coating operations, the viscosity (cSt) of coatings. [District Rules 2520, 9.3.2, 4603, 4606, and 4612] Federally Enforceable Through Title V Permit
34. Permittee shall keep the following records for solvent cleaning activities: quantity of solvent used, manufacturers product data sheet or MSDS of solvents used, the solvent's name and manufacturer, VOC content of solvents in g/l or lb/gal, the mix ratio and VOC content of the batch when the solvent is a mixture of different materials blended by the permittee and the type of cleaning activity for which each solvent is used. [District Rules 2520, 9.3.2, 4603, 4606, and 4612] Federally Enforceable Through Title V Permit
35. Records shall be retained on-site for a minimum of five years and made available for District inspection upon request. [District Rules 1070, 2520, 9.4.2, 4603, 4606, and 4612] Federally Enforceable Through Title V Permit
36. There shall be no visible emissions from the stack of the paint booth. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
37. The permittee shall maintain on a daily basis, records of visible emissions from the paint booth. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-10-3

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

1,608 BHP (INTERMITTENT) DETROIT MODEL 16V-149TIB DIESEL-FIRED EMERGENCY STANDBY IC ENGINE
POWERING AN ELECTRICAL GENERATOR (COGENERATION FACILITY, BUILDING 940)

PERMIT UNIT REQUIREMENTS

1. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Injection timing shall be retarded at least 4 degrees from standard setting. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rules 2201 and 4702 and 17 CCR 93115 and 40 CFR 63.6625(f)] Federally Enforceable Through Title V Permit
4. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 2201 and 4702 and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. Emissions from the engine shall not exceed any of the following limits: 81.5 lb/day for PM10, 594.3 lb/day for NOx, 79 lb/day for SOx, 257.3 lb/day for CO, or 95.1 lb/day for VOC. [District Rules 2201 and 4301 and 17 CCR 93115] Federally Enforceable Through Title V Permit
10. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 2520, 9.4.2 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520, 9.4.2 and 4702, and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-12-11

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

25.1 MMBTU/HR CLEAVER BROOKS MODEL CB200-600, 150# PACKAGED FIRE-TUBE NATURAL GAS-FIRED BOILER, SN L92694, WITH POWERFLAME NCV11CBR-G-30, SN 020620564 LOW-NOX BURNER, AND O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. Concurrent operation of two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) and two 2,600 kW turbines (C-195-1 and C-195-3) shall not exceed 2,601 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201, 4320, and 4801] Federally Enforceable Through Title V Permit
4. Emissions from the natural gas-fired unit shall not exceed any of the following limits: 7 ppmvd NOx @ 3% O2 or 0.008 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.014 lb-PM10/MMBtu, 100 ppmvd CO @ 3% O2 or 0.074 lb-CO/MMBtu, or 0.004 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320 [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Daily records of hours of concurrent operation of two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) and two 2,600 kW turbines (C-195-1 and C-195-3) shall be maintained. [District Rule 1070] Federally Enforceable Through Title V Permit
15. Copies of all fuel invoices, gas purchase contract, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. Operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.4.2 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
16. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-13-11

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

25.1 MMBTU/HR CLEAVER BROOKS MODEL CB200-600, 150# PACKAGED FIRE-TUBE NATURAL GAS-FIRED BOILER, SN L92695, WITH POWERFLAME NCV11CBR-G-30, SN 020620563 LOW-NOX BURNER AND O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. Concurrent operation of two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) and two 2,600 kW turbines (C-195-1 and C-195-3) shall not exceed 2,601 hours per year. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The unit shall only be fired on PUC-quality natural gas. [District Rules 2201, 4320, and 4801] Federally Enforceable Through Title V Permit
4. Emissions from the natural gas-fired unit shall not exceed any of the following limits: 7 ppmvd NO_x @ 3% O₂ or 0.008 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.014 lb-PM₁₀/MMBtu, 100 ppmvd CO @ 3% O₂ or 0.074 lb-CO/MMBtu, or 0.004 lb-VOC/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
7. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
12. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Daily records of hours of concurrent operation of two 25.1 MMBtu/hr boilers (C-195-12 and C-195-13) and two 2,600 kW turbines (C-195-1 and C-195-3) shall be maintained. [District Rule 1070] Federally Enforceable Through Title V Permit
15. Copies of all fuel invoices, gas purchase contract, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. Operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.4.2 and 40 CFR 60.48c(g)] Federally Enforceable Through Title V Permit
16. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-16-2

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

395 BHP (INTERMITTENT) CUMMINS MODEL QSM11-G1 TIER 2 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
3. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rules 2201 and 4702 and 17 CCR 93115 and 40 CFR 63.6625(f)] Federally Enforceable Through Title V Permit
4. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [District Rules 2201 and 4702 and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. NOx emissions shall not exceed 3.94 g/hp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. The PM10 emissions rate shall not exceed 0.07 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rule 2201 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 2520, 9.4.2 and 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
19. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
22. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2520, 9.4.2 and 4702 and 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: C-195-17-5

EXPIRATION DATE: 10/31/2022

EQUIPMENT DESCRIPTION:

GASOLINE DISPENSING OPERATION WITH ONE 12,000 SPLIT (8,000 GALLONS GASOLINE/4,000 GALLONS DIESEL) HOOVER VAULT ABOVEGROUND STORAGE TANK SERVED BY MORRISON BROTHERS PHASE I ENHANCED VAPOR RECOVERY (EVR) SYSTEM (VR-402-B), STANDING LOSS CONTROL (VR-301-E), AND 1 FUELING POINT WITH 1 GASOLINE DISPENSING NOZZLE SERVED BY BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-194)

PERMIT UNIT REQUIREMENTS

1. The Phase I, Phase II, and Standing Loss Control Vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621 and 4622 and CH&SC 41950] Federally Enforceable Through Title V Permit
2. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 4622] Federally Enforceable Through Title V Permit
3. The storage container(s) shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
4. The Phase I and Phase II vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
5. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
6. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
7. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. Upon identification of any major defects, the permittee shall tag "Out-of-Order" all dispensing equipment for which vapor recovery has been impaired. Tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defective equipment has been repaired, replaced, or adjusted, as necessary. In the case of defects identified by the District, tagged equipment shall be rendered inoperable, and the tag shall not be removed until the District has been notified of the repairs, and the District has either reinspected the system or authorized the tagged equipment for use. [District Rule 4622] Federally Enforceable Through Title V Permit
9. The permittee shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with the requirements of this permit. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) copies of all vapor recovery performance tests; 2) all applicable ARB Executive Orders, Approval Letters, and District Permits; 3) the manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 4) system and/or component testing requirements, including test schedules and passing criteria for each of the standard tests required by this permit (the owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements), and 5) additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622] Federally Enforceable Through Title V Permit
10. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
11. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
12. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 2) the hoses are not torn, flattened or crimped; 3) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 4) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622] Federally Enforceable Through Title V Permit
13. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622] Federally Enforceable Through Title V Permit
14. The gasoline throughput for this permit unit shall not exceed 657,000 gallons in any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

16. The permittee shall perform and pass a Static Leak Test "Determination of Static Pressure Performance of Vapor Recovery Systems at Gasoline Dispensing Facilities with Aboveground Tanks" in accordance with the Executive Order specified in this permit for the Phase I Vapor Recovery System at least once every 12 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
17. For certified Phase II vapor recovery systems with liquid removal devices, the permittee shall perform and pass an ARB TP-201.6C Liquid Removal Test whenever the liquid in the vapor path exceeds 100 ml of liquid, or as required by the applicable ARB Executive Order. The amount of liquid in the vapor path shall be measured by lowering the gasoline dispensing nozzle into a container until such time that no more liquid drains from the nozzle. The amount of liquid drained into the container shall be measured using a graduated cylinder or graduated beaker. The vapor path shall be inspected according to the monitoring frequency as determined by monthly gasoline throughput. [District Rule 4622] Federally Enforceable Through Title V Permit
18. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
19. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
20. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
21. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
22. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rule 4622] Federally Enforceable Through Title V Permit
23. The permittee shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name and applicable certification numbers of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622] Federally Enforceable Through Title V Permit
24. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622] Federally Enforceable Through Title V Permit
25. The permittee shall maintain monthly and annual gasoline throughput records. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
26. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
27. The District shall be notified within 24 hours of the facility's pass/fail status after the performance of each test. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.