

DEC 13 2017

Mr. Bill Davidson
TRC Operating Company, Inc.
805 Black Gold Ct.
Taft, CA 93268

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: S-2622
Project Number: S-1162386

Dear Mr. Davidson:

The District has issued the Final Renewed Title V Permit for TRC Operating Company, Inc. (see enclosure). The preliminary decision for this project was made on October 17, 2017. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Facility # S-2622
TRC OPERATION CO INC
PO BOX 227
TAFT, CA 93268

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93728-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Permit to Operate

FACILITY: S-2622

EXPIRATION DATE: 05/31/2022

LEGAL OWNER OR OPERATOR:
MAILING ADDRESS:

TRC OPERATION CO INC
PO BOX 227
TAFT, CA 93268

FACILITY LOCATION:

HEAVY OIL WESTERN
CA

FACILITY DESCRIPTION:

CRUDE OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-2622-0-3

EXPIRATION DATE: 05/31/2022

FACILITY-WIDE REQUIREMENTS

1. Facilities S-3088 and S-2622 are included in the same stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
2. To maintain status as a small producer, permittee's crude oil production shall average less than 6000 bbl/day from all operations within Kern County and permittee shall not engage in refining, transporting, or marketing of refined petroleum products. [District Rule 2080] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
5. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
6. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160] Federally Enforceable Through Title V Permit
7. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, and 2020] Federally Enforceable Through Title V Permit
8. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 2080; and 2520] Federally Enforceable Through Title V Permit
9. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
10. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040]

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: TRC OPERATION CO INC
Location: HEAVY OIL WESTERN, CA
S-2022-0-3 : Dec 11 2017 10:32AM - KLEVANNND

11. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520] Federally Enforceable Through Title V Permit
13. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520] Federally Enforceable Through Title V Permit
14. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 1100] Federally Enforceable Through Title V Permit
15. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520] Federally Enforceable Through Title V Permit
16. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
17. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520] Federally Enforceable Through Title V Permit
18. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520] Federally Enforceable Through Title V Permit
19. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520] Federally Enforceable Through Title V Permit
20. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520] Federally Enforceable Through Title V Permit
23. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
25. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
26. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601] Federally Enforceable Through Title V Permit
27. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
28. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601] Federally Enforceable Through Title V Permit
29. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520] Federally Enforceable Through Title V Permit
30. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
31. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
32. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8021 and 8011] Federally Enforceable Through Title V Permit
33. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8031 and 8011] Federally Enforceable Through Title V Permit
34. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8041 and 8011] Federally Enforceable Through Title V Permit
35. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8051 and 8011] Federally Enforceable Through Title V Permit
36. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rule 8061 and Rule 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rule 8071 and Rule 8011] Federally Enforceable Through Title V Permit
38. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
39. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520] Federally Enforceable Through Title V Permit
40. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520] Federally Enforceable Through Title V Permit
41. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520] Federally Enforceable Through Title V Permit
42. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
43. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
44. On September 30, 2012, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-1-11

EXPIRATION DATE: 05/31/2022

SECTION: NE21 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

25.2 MMBTU/HR C.E. NATCO GAS-FIRED STEAM GENERATOR #19 WITH DIFFUSER PLATE AND FLUE GAS RECIRCULATION (CYMRIC OHIO LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct (ATC) for such modifications, except for changes specified in the conditions below. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District at least seven calendar days prior to the designation of this permit unit as a dormant emissions unit or an active emissions unit. [District Rule 1070]
3. When designated as a dormant emissions unit the fuel supply line shall be physically disconnected from the emissions unit. [District Rule 4306] Federally Enforceable Through Title V Permit
4. When designated as a dormant emissions unit, the permittee shall not be required to perform source testing or monitoring requirements otherwise required by this permit. [District Rule 4306] Federally Enforceable Through Title V Permit
5. A source test to demonstrate compliance with the NOx and CO emission limits shall be performed within 60 days of recommencing operation of the dormant emissions unit. [District Rule 4306] Federally Enforceable Through Title V Permit
6. This unit may not be operated after the applicable compliance schedule from Rule 4320, unless a valid ATC is obtained that approves the changes allowing this unit to comply with the applicable requirements of Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
7. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081] Federally Enforceable Through Title V Permit
8. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
9. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
10. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
11. This unit is authorized to burn vapors from the vapor control system listed in permit S-2622-7. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emissions rates from this unit shall not exceed any of the following limits: 15 ppmv NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, 0.003 lb-SOx/MMBtu, 0.008 lb-PM10/MMBtu, 200 ppmv CO @ 3% O2 or 0.148 lb-CO/MMBtu, or 0.006 lb-VOC/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
14. Upon recommencing operation, if either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
15. Upon recommencing operation, all alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
16. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
18. Upon recommencing operation, source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
22. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
27. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
28. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit
29. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-5-5

EXPIRATION DATE: 05/31/2022

SECTION: NE21 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

TEOR OPERATION INCLUDING 12 UNCONTROLLED CYCLIC WELLS

PERMIT UNIT REQUIREMENTS

1. All wells authorized by this permit shall be located more than 1000 feet from any existing well vent vapor recovery system operated by the company. [District Rule 4401] Federally Enforceable Through Title V Permit
2. Permittee shall maintain with the permit a current well roster and such roster shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-11-12

EXPIRATION DATE: 05/31/2022

SECTION: NE22 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

14.5 MMBTU/HR GAS-FIRED STEAM GENERATOR WITH DIFFUSER PLATE AND FLUE GAS RECIRCULATION
(MIDWAY-PREMIER LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct (ATC) for such modifications, except for changes specified in the conditions below. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District at least seven calendar days prior to the designation of this permit unit as a dormant emissions unit or an active emissions unit. [District Rule 1070]
3. When designated as a dormant emissions unit the fuel supply line shall be physically disconnected from the emissions unit. [District Rule 4306] Federally Enforceable Through Title V Permit
4. When designated as a dormant emissions unit, the permittee shall not be required to perform source testing or monitoring requirements otherwise required by this permit. [District Rule 4306] Federally Enforceable Through Title V Permit
5. A source test to demonstrate compliance with the NO_x and CO emission limits shall be performed within 60 days of recommencing operation of the dormant emissions unit. [District Rule 4306] Federally Enforceable Through Title V Permit
6. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 16, 1993). [District Rule 1081]
7. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. The unit shall only be fired on natural gas or vapor recovery gas from S-2622-7. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Emissions from the natural gas-fired unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.003 lb-SO_x/MMBtu, 0.008 lb-PM₁₀/MMBtu, 48 ppmvd CO @ 3% O₂ or 0.036 lb-CO/MMBtu, or 0.006 lb-VOC/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. Upon recommencing operation, the permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
13. Upon recommencing operation, if either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
14. Upon recommencing operation, all alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
15. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
16. Upon recommencing operation, source testing to measure NO_x and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
17. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
18. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
21. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

22. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
23. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, and 4306] Federally Enforceable Through Title V Permit
26. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
27. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit
28. On and after July 1, 2012, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-17-6

EXPIRATION DATE: 05/31/2022

SECTION: NE22 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

62.5 MMBTU/HR C.E. NATCO NATURAL GAS FIRED STEAM GENERATOR (#59 DIS# 22456-79) WITH MAGNA FLAME GLE LOW NOX BURNER AND O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
7. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Emissions from this unit shall not exceed any of the following limits: 15 ppmvd NO_x @ 3% O₂ or 0.018 lb-NO_x/MMBtu, 0.00285 lb-SO_x/MMBtu, 0.0076 lb-PM₁₀/MMBtu, 47.5 ppmvd CO @ 3% O₂ or 0.035 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
11. Steam generator shall be fired on natural gas and/or TEOR gas from S-2622-7 with a sulfur content of no greater than 1.0 gr-S/100 scf or pre-treated using a sulfa-treat (or equivalent) system for 95% control of SO_x emissions. [District Rules 2201, 4320 and 4801] Federally Enforceable Through Title V Permit
12. When complying with sulfur emission limits by fuel analysis, each fuel source shall be tested at startup and annually thereafter for sulfur content. Gas analyses shall be performed using EPA Method 11 or Method 15. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
14. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. Source testing to measure NO_x and CO emissions from this unit while fired on vapor control/TEOR gas from S-2622-7 shall be conducted within 60 days of initial start-up. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. If the unit is fired on noncertified gaseous fuel and compliance with SO_x emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520] Federally Enforceable Through Title V Permit
27. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520; 4305; and 4351] Federally Enforceable Through Title V Permit
28. Permittee shall maintain accurate records of sulfur content of gas combusted in steam generator and shall make such records readily available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NO_x emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NO_x emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit
32. On and after July 1, 2010, the permittee shall submit an analysis showing the fuel's sulfur content at least once every year. Valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy this requirement, provided they establish the fuel parameters mentioned above. [District Rule 4320] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate,

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-18-3

EXPIRATION DATE: 05/31/2022

SECTION: NE21 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR, WITH O2 CONTROLLER, FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. No modification(s) to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
3. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
4. When natural gas fired, emission rates shall not exceed any of the following: PM10: 0.014 lb/MMBtu, SO_x (as SO₂): 0.002 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu, VOC: 0.003 lb/MMBtu, CO: 47.5 ppmv @ 3% O₂. [District Rules 2201 and 4305] Federally Enforceable Through Title V Permit
5. When TEOR gas fired, overall emission rates shall not exceed any of the following: PM10: 0.015 lb/MMBtu, SO_x (as SO₂): 0.015 lb/MMBtu, NO_x (as NO₂): 0.036 lb/MMBtu, VOC: 0.003 lb/MMBtu, CO: 47.5 ppmv @ 3% O₂. [District Rules 2201 and 4305] Federally Enforceable Through Title V Permit
6. Only natural gas or a combination of natural gas and scrubbed non-condensable gas shall be used as fuel in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A fuel gas scrubber shall be utilized as required to meet SO_x limits when TEOR gas is burned. [District Rule 2201] Federally Enforceable Through Title V Permit
8. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
9. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NO_x and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NO_x emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.). [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 4305] Federally Enforceable Through Title V Permit
11. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rule 4305] Federally Enforceable Through Title V Permit
12. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rule 4305] Federally Enforceable Through Title V Permit
13. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. [District Rule 4305] Federally Enforceable Through Title V Permit
14. The acceptable range of positions of the atmospheric combustion air control valve and fuel firing rates shall be established by testing emissions from this unit or other representative units, as approved by the District. The acceptable ranges shall be maintained during operation at levels for which compliance with applicable NOx and CO emission rates have been demonstrated through source testing. [District Rule 4305] Federally Enforceable Through Title V Permit
15. The atmospheric combustion air control valve position and fuel firing rates shall be recorded at least on a weekly basis. [District Rule 4305] Federally Enforceable Through Title V Permit
16. If the atmospheric combustion air control valve position or fuel firing rate deviate from the acceptable range for more than 20 minutes, the steam generator shall be automatically shutdown. [District Rule 4305] Federally Enforceable Through Title V Permit
17. The acceptable range of atmospheric combustion air control valve position shall be documented for each steam generator in a District approved plan. Permittee shall maintain a copy of the current plan with the steam generator permit. [District Rule 4305] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of the weekly atmospheric combustion air control valve position and fuel firing rate. The records must also include a description of any corrective action taken to return the atmospheric combustion air control valve position and fuel firing rate to the acceptable range. Permittee shall maintain records of steam generator automatic shutdown and corrective action taken prior to restarting the unit. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Within two hours after a continuous period in which fuel flow to the unit has been shut off for 30 minutes or longer the atmospheric combustion air control valve and fuel firing rate shall be returned to the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit
20. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305] Federally Enforceable Through Title V Permit
21. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305] Federally Enforceable Through Title V Permit
22. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
26. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-19-3

EXPIRATION DATE: 05/31/2022

SECTION: NE21 **TOWNSHIP:** 29S **RANGE:** 21E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#134, DIS# 28716-83) WITH O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4305. [District Rule 4305] Federally Enforceable Through Title V Permit
2. No modification(s) to this unit shall be performed without an Authority to Construct for the modification(s), except for changes specified in condition 3 below. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: PM10: 0.015 lb/MMBtu, SOx (as SO2): 0.015 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2, VOC: 0.003 lb/MMBtu, or CO: 50 ppmv @3% O2. [District Rules 2201 and District Rule 4305] Federally Enforceable Through Title V Permit
5. Only natural gas or a combination of natural gas and scrubbed non-condensable gas shall be used as fuel in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. A fuel gas scrubber shall be utilized as required to meet SOx limits when TEOR gas is burned. [District Rule 2201] Federally Enforceable Through Title V Permit
7. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
8. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.). [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
9. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rule 4305] Federally Enforceable Through Title V Permit
11. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rule 4305] Federally Enforceable Through Title V Permit
12. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. [District Rule 4305] Federally Enforceable Through Title V Permit
13. The acceptable range of positions of the atmospheric combustion air control valve and fuel firing rates shall be established by testing emissions from this unit or other representative units, as approved by the District. The acceptable ranges shall be maintained during operation at levels for which compliance with applicable NOx and CO emission rates have been demonstrated through source testing. [District Rule 4305] Federally Enforceable Through Title V Permit
14. The atmospheric combustion air control valve position and fuel firing rates shall be recorded at least on a weekly basis. [District Rule 4305] Federally Enforceable Through Title V Permit
15. If the atmospheric combustion air control valve position or fuel firing rate deviate from the acceptable range for more than 20 minutes, the steam generator shall be automatically shutdown. [District Rule 4305] Federally Enforceable Through Title V Permit
16. The acceptable range of atmospheric combustion air control valve position shall be documented for each steam generator in a District approved plan. Permittee shall maintain a copy of the current plan with the steam generator permit. [District Rule 4305] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of the weekly atmospheric combustion air control valve position and fuel firing rate. The records must also include a description of any corrective action taken to return the atmospheric combustion air control valve position and fuel firing rate to the acceptable range. Permittee shall maintain records of steam generator automatic shutdown and corrective action taken prior to restarting the unit. [District Rule 4305] Federally Enforceable Through Title V Permit
18. Within two hours after a continuous period in which fuel flow to the unit has been shut off for 30 minutes or longer the atmospheric combustion air control valve and fuel firing rate shall be returned to the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305] Federally Enforceable Through Title V Permit
20. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305] Federally Enforceable Through Title V Permit
22. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
25. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2622-20-3

EXPIRATION DATE: 05/31/2022

SECTION: NE21 TOWNSHIP: 29S RANGE: 21E

EQUIPMENT DESCRIPTION:

DORMANT 62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#168, DIS# 28639-82) WITH O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4305. [District Rule 4305] Federally Enforceable Through Title V Permit
2. No modification(s) to this unit shall be performed without an Authority to Construct for the modification(s), except for changes specified in condition 3 below. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The fuel supply line shall be physically disconnected from this unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: PM10: 0.015 lb/MMBtu, SOx (as SO2): 0.015 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2, VOC: 0.003 lb/MMBtu, or CO: 50 ppmv @3% O2. [District Rules 2201 and District Rule 4305] Federally Enforceable Through Title V Permit
5. Only natural gas or a combination of natural gas and scrubbed non-condensable gas shall be used as fuel in this steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. A fuel gas scrubber shall be utilized as required to meet SOx limits when TEOR gas is burned. [District Rule 2201] Federally Enforceable Through Title V Permit
7. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
8. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.). [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
9. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

10. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rule 4305] Federally Enforceable Through Title V Permit
11. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rule 4305] Federally Enforceable Through Title V Permit
12. Emissions from this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (12/16/93), of three 30-minute test runs for NOx and CO. [District Rule 4305] Federally Enforceable Through Title V Permit
13. The acceptable range of positions of the atmospheric combustion air control valve and fuel firing rates shall be established by testing emissions from this unit or other representative units, as approved by the District. The acceptable ranges shall be maintained during operation at levels for which compliance with applicable NOx and CO emission rates have been demonstrated through source testing. [District Rule 4305] Federally Enforceable Through Title V Permit
14. The atmospheric combustion air control valve position and fuel firing rates shall be recorded at least on a weekly basis. [District Rule 4305] Federally Enforceable Through Title V Permit
15. If the atmospheric combustion air control valve position or fuel firing rate deviate from the acceptable range for more than 20 minutes, the steam generator shall be automatically shutdown. [District Rule 4305] Federally Enforceable Through Title V Permit
16. The acceptable range of atmospheric combustion air control valve position shall be documented for each steam generator in a District approved plan. Permittee shall maintain a copy of the current plan with the steam generator permit. [District Rule 4305] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of the weekly atmospheric combustion air control valve position and fuel firing rate. The records must also include a description of any corrective action taken to return the atmospheric combustion air control valve position and fuel firing rate to the acceptable range. Permittee shall maintain records of steam generator automatic shutdown and corrective action taken prior to restarting the unit. [District Rule 4305] Federally Enforceable Through Title V Permit
18. Within two hours after a continuous period in which fuel flow to the unit has been shut off for 30 minutes or longer the atmospheric combustion air control valve and fuel firing rate shall be returned to the acceptable range. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305] Federally Enforceable Through Title V Permit
20. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305] Federally Enforceable Through Title V Permit
22. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SO_x (lb/MMBtu) - EPA Method 6 or ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H₂S and mercaptans, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588. [District Rules 1081 and 4305] Federally Enforceable Through Title V Permit
25. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.