



JUL 09 2018

Mr. Shams Hasan
E&B Natural Resources
3000 James Road
Bakersfield, CA 93308

Re: Proposed ATC / Certificate of Conformity (Significant Mod)
Facility Number: S-1624
Project Number: S1182344

Dear Mr. Hasan:

Enclosed for your review is the District's analysis of an application for Authority to Construct for the facility identified above. You requested that a Certificate of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. The project authorizes three new steam generators.

After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authority to Construct with a Certificate of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authority to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (559) 230-5900.

Thank you for your cooperation in this matter.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators,
 and Process Heaters Greater than 5.0 MMBtu/hr (10/16/08)
Rule 4801 Sulfur Compounds (12/17/92)
CH&SC 41700 Health Risk Assessment
CH&SC 42301.6 School Notice
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA
Guidelines

III. Project Location

The equipment will be located in the Conoco lease within the SW/4 of Section 33, Township 27S, Range 27E in E&B's Heavy Oil Central stationary source. The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

An aerial photo of the Conoco site is included in **Attachment II**.

IV. Process Description

In TEOR operations, steam generators are used to produce steam which is injected into the production zone to reduce the viscosity of the crude oil and pressurize the oil-bearing strata, thereby facilitating oil flow to producing wells. Produced fluids are then piped to surface facilities for processing and temporary storage.

Production from wells initially enters a gas/liquid separator. Liquid from the gas/liquid separator enters wash tanks for separation into oil, gas and water. Separated oil is stored in stock tanks prior to custody transfer.

Project

The facility will install three new 85 MMBtu/hr natural/waste gas-fired steam generators. The project results in an increase in combustion emissions of NO_x, SO_x PM₁₀, and CO. Combustion VOC emissions are mitigated with cancellation of tank PTO S-1624-70-2.

V. Equipment Listing

Pre-Project Equipment Description:

S-1624-70-2: 1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK, GRIMES #5

Proposed Modifications:

S-1624-328-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR
 WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS
 RECIRCULATION (EB24 - CONOCO LEASE)

- S-1624-329-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB25 - CONOCO LEASE)
- S-1624-330-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB26 - CONOCO LEASE)

Post Project Equipment Description:

- S-1624-328-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB24 - CONOCO LEASE)
- S-1624-329-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB25 - CONOCO LEASE)
- S-1624-330-0: 85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB26 - CONOCO LEASE)

VI. Emission Control Technology Evaluation

Emissions from natural gas-fired steam generators include NO_x, CO, VOC, PM₁₀, and SO_x.

NO_x is the major pollutant of concern when burning natural gas. NO_x formation is either due to thermal fixation of atmospheric nitrogen in the combustion air (thermal NO_x) or due to conversion of chemically bound nitrogen in the fuel (fuel NO_x). Due to the low fuel nitrogen content of natural gas, nearly all NO_x emissions are thermal NO_x. Formation of thermal NO_x is affected by four furnace zone factors: (1) nitrogen concentration, (2) oxygen concentration, (3) peak temperature, and (4) time of exposure at peak temperature.

Low-NO_x burners reduce NO_x formation by producing lower flame temperatures (and longer flames) than conventional burners. Low-NO_x burners delay the mixing of fuel and air by introducing the fuel (or sometimes air) in multiple stages. In the first stage, the air-fuel mixture is fuel-rich in which the oxygen is consumed in reactions with the fuel, thereby limiting excess oxygen available to react with nitrogen to produce thermal NO_x.

The combustion zones in the secondary and tertiary stages are maintained in a fuel-lean environment. The excess air in these stages helps to reduce the flame temperature, which in turn minimizes the reaction between excess oxygen and nitrogen. The North American burner incorporates patented internal mixing elements that premix the fuel and air prior to combustion in the reaction zone. By completing a majority of the combustion in the burner reaction chamber, the low emissions of the burner are protected from process influences.

Flue gas recirculation (FGR) reduces NO_x emissions by recirculating a percentage of the exhaust gas back into the windbox. This reduces the oxygen concentration in the air-fuel mixture

and regulates the combustion process, lowering the combustion temperature. The lowered availability of oxygen in conjunction with lowered combustion temperature reduces the formation of NO_x.

Tank S-1624-70 is equipped with a pressure-vacuum (PV) relief vent valve set to within 10% of the maximum allowable working pressure of the tank. The PV-valve reduces VOC wind induced emissions from the tank vent.

VII. General Calculations

A. Assumptions

- The maximum operating schedule is 24 hours per day, 8,760 hr/year

Steam Generators:

- Maximum heat input rating = 85 MMBtu/hr (each steam generator)
- F-Factor for Natural Gas @ 60°F: 8,578 dscf/MMBtu
- Gas Molar Vol 60 °F = $10.7316 \text{ psia ft}^3/\text{lbmol R} \times 519.67 \text{ R}/(14.696 \text{ psia/atm})$
= 378.61 ft³/lbmol
- Natural Gas Heating Value = 1,000 Btu/scf

Tank S-1624-70:

- Throughput = one turnover/day (District practice for tanks without a throughput limit)
- TVP limit = 0.5 psia (PTO)
- Volume = 1,000 bbls
- Variable level operation

B. Emission Factors

Pollutant	Steam Generators Emission Factors (EF)		Source
NO _x	0.0062 lb-NO _x /MMBtu	5 ppmvd NO _x (@ 3%O ₂)	Proposed
SO _x	0.00285 lb SO ₂ /MMBtu	1.0 gr S/100 scf	Proposed
PM ₁₀	*0.0035 lb-PM ₁₀ /MMBtu		Proposed
CO	0.0185 lb-CO/MMBtu	25 ppmv CO @3% O ₂	BACT
VOC	0.0055 lb-VOC/MMBtu	13 ppmv VOC @3% O ₂	Proposed & AP-42 (07/98) Table 1.4-2

*The District has determined that steam generators fired solely on PUC quality natural gas have PM₁₀ emissions no greater than 0.003 lb-PM₁₀/ MMBtu. The applicant has conservatively proposed to use 0.0035 lb-PM₁₀/ MMBtu.

The PE for tank S-1624-70 is based on the results from the District's Microsoft Excel spreadsheets for Tank Emissions - Fixed Roof Crude Oil less than 26° API.

C. Calculations

1. Pre-Project Potential to Emit (PE1)

Since the steam generator is a new emissions unit, PE1 = 0 for all pollutants.

Tank S-1624-70 PE1	
Daily Emissions (lb/day)	Annual Emissions (lb/year)
52.3	19,082

See emission calculations in **Attachment III**.

2. Post Project Potential to Emit (PE2)

Tank S-1624-70 PE2	
Daily Emissions (lb/day)	Annual Emissions (lb/year)
0.0	0

The PE2 for each pollutant is calculated with the following equation:

- $PE2 = EF \text{ (lb/MMBtu)} \times \text{Heat Input (MMBtu/hr)} \times \text{Op. Sched. (hr/day or hr/year)}$

S-1624-328-0 thru '-330-0 (each)

Pollutant	Daily PE2			
	EF2 (lb/MMBtu)	Heat Input (MMBtu/hr)	Operating Schedule (hr/day)	Daily PE2 (lb/day)
NO _x	0.006	85	24	12.6
SO _x	0.00285	85	24	5.8
PM ₁₀	0.0035	85	24	7.1
CO	0.019	85	24	37.7
VOC	0.0055	85	24	11.2

Pollutant	Annual PE2			
	EF2 (lb/MMBtu)	Heat Input (MMBtu/hr)	Operating Schedule (hr/year)	Annual PE2 (lb/year)
NO _x	0.006	85	8,760	4,617
SO _x	0.00285	85	8,760	2,122
PM ₁₀	0.0035	85	8,760	2,606
CO	0.019	85	8,760	13,775
VOC	0.0055	85	8,760	4,095

Emissions profiles are included in **Attachment IV**.

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

The SSPE1 calculated below is the SSPE2 for project 1173781 (finalized 3/5/18) which did not include permit units having only VOC emissions as facility emissions exceed Offset and Major Source Thresholds for VOC emissions (> 20,000 lb/yr).

SSPE1 (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
S-1624-13	2,650	3,445	1,590	71,306	>> 20,000
S-1624-25	1,418	516	1,289	129	
S-1624-26	1,850	673	1,682	168	
S-1624-174	2,117	402	1,465	14,235	
S-1624-215	1,927	3,445	1,831	17,827	
S-1624-218	8,078	339	950	43,956	
S-1624-220	4,542	2,122	2,606	27,550	
S-1624-221	4,542	2,122	2,606	27,550	

SSPE1 (lb/year)					
S-1624-222	4,542	2,122	2,606	27,550	
S-1624-223	4,542	2,122	2,606	27,550	
S-1624-224	4,542	2,122	2,606	27,550	
S-1624-238	28,470	1,560	4,161	45,990	
S-1624-239	2,409	3,635	1,664	16,206	
S-1624-254	4,542	2,122	2,606	27,550	
S-1624-255	4,542	2,122	2,606	27,550	
S-1624-270	2,502	699	294	13,616	
S-1624-284	4468	2122	2606	13552	
S-1624-285	4468	2122	2606	13552	
S-1624-288	4,617	2,122	2,606	13,775	
S-1624-293	4617	2122	2606	13,775	
S-1624-295	4,617	2,122	2,234	13,775	
S-1624-307	4,617	2,122	2,606	13,775	
S-1624-308	4,617	2,122	2,606	13,775	
S-1624-317	4,617	2,122	2,606	13,775	
S-1624-318	4,617	2,122	2,606	13,775	
S-1624-70	0	0	0	0	19,082
SSPE1	124,470	48,666	56,250	539,812	> 20,000

4. Post Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE1	124,470	48,666	56,250	539,812	>> 20,000
S-1624-328	4,617	2,122	2,606	13,775	4,095
S-1624-329	4,617	2,122	2,606	13,775	4,095
S-1624-330	4,617	2,122	2,606	13,775	4,095
S-1624-70	0	0	0	0	0
SSPE2	138,321	55,032	64,068	581,137	> 20,000

5. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source

- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)						
	NO _x	SO _x	PM ₁₀	PM _{2.5}	CO	VOC
SSPE1	124,470	48,666	56,250	56,250	539,812	> 20,000
SSPE2	138,321	55,032	64,068	64,068	581,137	> 20,000
Major Source Threshold	20,000	140,000	140,000	140,000	200,000	20,000
Major Source?	Yes	No	No	No	Yes	Yes

Note: PM2.5 assumed to be equal to PM10

This source is an existing Major Source for NO_x, CO and VOC emissions and will remain a so. No change in other pollutants are proposed or expected as a result of this project.

Rule 2410 Major Source Determination:

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination (tons/year)						
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀
Estimated Facility PE before Project Increase				>250		
PSD Major Source Thresholds	250	250	250	250	250	250
PSD Major Source ? (Y/N)				Y		

As shown above, the facility is an existing PSD major source for at least one pollutant.

6. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,

- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201.

Since steam generators S-1624-328-0 and '330-0 are new emissions units, BE = PE1 = 0 for all pollutants.

a. BE VOC

Tank S-1624-70:

Pursuant to Rule 2201, a Clean Emissions Unit is defined as an emissions unit that is "equipped with an emissions control technology with a minimum control efficiency of at least 95% or is equipped with emission control technology that meets the requirements for achieved-in-practice BACT as accepted by the APCO during the five years immediately prior to the submission of the complete application.

Tank S-1624-70 is equipped with a PV-vent set to within 10% of maximum allowable pressure, which meets the requirements for achieved-in-practice BACT. Therefore, BE = PE1.

7. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is not a major source for SOx and PM10, this project does not constitute an SB 288 major modification for these air contaminants.

Since this facility is a major source for NOx and VOC the project's PE2 is compared to the SB 288 Major Modification Thresholds in the following table in order to determine if the SB 288 Major Modification calculation is required.

SB 288 Major Modification Thresholds			
Pollutant	Project PE2 (lb/year)	Threshold (lb/year)	SB 288 Major Modification Calculation Required?
NO _x	13,851	50,000	N
VOC	12,285	50,000	N

Since none of the SB 288 Major Modification Thresholds are surpassed with this project, this project does not constitute an SB 288 Major Modification.

8. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

The determination of Federal Major Modification is based on a two-step test. For the first step, only the emission *increases* are counted. Emission decreases may not cancel out the increases for this determination.

Since this facility is not a major source for SO_x and PM₁₀, this project does not constitute an SB 288 major modification for these air contaminants.

Step 1

For new emissions units, the increase in emissions is equal to the PE2 for each new unit included in this project.

The project's combined total emission increases are compared to the Federal Major Modification Thresholds in the following table.

Federal Major Modification Thresholds for Emission Increases			
Pollutant	Total Emissions Increases (lb/yr)	Thresholds (lb/yr)	Federal Major Modification?
NO _x	13,851	0	Y
VOC	12,285	0	Y

Since there is an increase in NO_x and VOC emissions, this project constitutes a Federal Major Modification. Federal Offset quantities are calculated below.

Federal Offset Quantities:

The Federal offset quantity is only calculated only for the pollutants for which the project is a Federal Major Modification. The Federal offset quantity is the sum of the annual emission changes for all new and modified emission units in a project calculated as the potential to emit after the modification (PE2) minus the actual emissions (AE) during the baseline period for each emission unit times the applicable federal offset ratio. There are no special calculations performed for units covered by an SLC.

NOx		Federal Offset Ratio	1.5
Permit No.	Actual Emissions (lb/year)	Potential Emissions (lb/year)	Emissions Change (lb/yr)
S-1624-328-0	0	4,617	4,617
S-1624-329-0	0	4,617	4,617
S-1624-330-0	0	4,617	4,617
Net Emission Change (lb/year):			13,851
Federal Offset Quantity: (NEC * 1.5)			20,777

VOC		Federal Offset Ratio	1.5
Permit No.	Actual Emissions (lb/year)	Potential Emissions (lb/year)	Emissions Change (lb/yr)
S-1624-328-0	0	4,095	4,095
S-1624-329-0	0	4,095	4,095
S-1624-329-0	0	4,095	4,095
Net Emission Change (lb/year):			12,285
Federal Offset Quantity: (NEC * 1.5)			18,428

9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

Rule 2410 applies to any pollutant regulated under the Clean Air Act, except those for which the District has been classified nonattainment.

I. Project Location Relative to Class 1 Area

As demonstrated in the “PSD Major Source Determination” Section above, the facility was determined to be a existing PSD Major Source. Because the project is not located within 10 km (6.2 miles) of a Class 1 area – modeling of the emission increase is not required to determine if the project is subject to the requirements of Rule 2410.

II. Project Emission Increase – Significance Determination

a. Evaluation of Calculated Post-project Potential to Emit for New or Modified Emissions Units vs PSD Significant Emission Increase Thresholds

As a screening tool, the post-project potential to emit from all new and modified units is compared to the PSD significant emission increase thresholds, and if the total potentials to emit from all new and modified units are below the applicable thresholds, no further PSD analysis is needed.

PSD Significant Emission Increase Determination: Potential to Emit (tons/year)					
	NO ₂	SO ₂	CO	PM	PM ₁₀
Total PE from New and Modified Units	6.9	3.2	20.7	3.9	3.9
PSD Significant Emission Increase Thresholds	40	40	100	25	15
PSD Significant Emission Increase?	No	No	No	No	No

As demonstrated above, because the post-project total potentials to emit from all new and modified emission units are below the PSD significant emission increase thresholds, this project is not subject to the requirements of Rule 2410 and no further discussion is required.

10. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. The steam generators are new permit units and therefore, QNEC = PE_{2/4} for NO_x, SO, PM₁₀, CO and VOC.

QNEC

	NO _x	SO _x	PM ₁₀	CO	VOC
S-1624-328	4,617/4 = 1054.25	2122/4 = 530.5	2,606/4 = 651.5	13,775/4 = 3,443.75	4095/4 = 1023.75
S-1624-329	1054.25	530.5	651.5	3,443.75	1023.75
S-1624-330	1054.25	530.5	651.5	3,443.75	1023.75

VIII. Compliance Determination

Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,

- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an Adjusted Increase in Permitted Emissions (AIPE) exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

a. New emissions units – PE > 2 lb/day

As seen in Section VII.C.2 above, the applicant is proposing to install new steam generators each with a PE greater than 2 lb/day for NO_x, SO_x, PM₁₀, CO, and VOC. Therefore BACT for new units with PE > 2 lb/day purposes is triggered for NO_x, SO_x, PM₁₀, CO, and VOC.

b. Relocation of emissions units – PE > 2 lb/day

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore BACT is not triggered.

c. Modification of emissions units – AIPE > 2 lb/day

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore BACT is not triggered.

d. SB 288/Federal Major Modification

As discussed in Sections VII.C.7 and VII.C.8 above, this project does constitute a Federal Major Modification for NO_x and VOC emissions. Therefore BACT is triggered for NO_x for and VOC all emissions units in the project for which there is an emission increase.

2. BACT Guideline

BACT Guideline 1.2.1, applies to the oilfield steam generators greater \geq 20 MMBtu/hr. [Oilfield Steam Generator ($>$ or \geq 20 MMBtu/hr)] (See **Attachment V**)

3. Top-Down BACT Analysis

Per Permit Services Policies and Procedures for BACT, a Top-Down BACT analysis shall be performed as a part of the application review for each application subject to the BACT requirements pursuant to the District's NSR Rule.

Pursuant to the attached Top-Down BACT Analysis (see **Attachment VI**), BACT has been satisfied with the following:

NO_x: 5 ppmvd @ 3% O₂

SO_x and PM₁₀: gaseous fuel treated such that the sulfur content does not exceed 1 gr of sulfur compounds (as S) per 100 dscf
 CO: 25 ppmvd or less @ 3% O₂
 VOC: Gaseous fuel

B. Offsets

1. Offset Applicability

Offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals or exceeds the offset threshold levels in Table 4-1 of Rule 2201.

The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE2	138,321	55,032	64,068	581,137	> 20,000
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets calculations required?	Yes	Yes	Yes	Yes	Yes

2. Quantity of Offsets Required

As seen above, the SSPE2 is greater than the offset thresholds for NO_x, PM₁₀, CO, and VOC emissions; therefore offset calculations will be required for this project.

Per Sections 4.7.1 and 4.7.3, the quantity of offsets in pounds per year is calculated as follows for sources with an SSPE1 greater than the offset threshold levels before implementing the project being evaluated.

Offsets Required (lb/year) = (Σ[PE2 – BE] + ICCE) x DOR, for all new or modified emissions units in the project,

Where,

PE2 = Post Project Potential to Emit, (lb/year)

BE = Baseline Emissions, (lb/year)

ICCE= Increase in Cargo Carrier Emissions, (lb/year)

DOR = Distance Offset Ratio, determined pursuant to Section 4.8

BE = Pre-project Potential to Emit for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, Located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE)

The facility is proposing to install new emissions units; therefore their Baseline Emissions are equal to zero. There are no increases in cargo carrier emissions; therefore offsets can be determined as follows:

Offsets Required (lb/year) = $(\sum[PE2 - BE]) \times DOR$

NO_x Offset Calculations

Offsets Required (lb/year) = $([PE2 - BE]) \times DOR$

PE2 = 4,617 lb/year (each steam generator)
BE = 0 lb/year

The project is a Federal Major Modification for NO_x and therefore the offset ratio for NO_x is 1.5:1.

Offsets Required (lb/year) = $([4,617 - 0]) \times DOR$
= $4,617 \times 1.5$
= 6,926 lb-NO_x/year (each steam generator)

Calculating the appropriate quarterly emissions to be offset is as follows (each steam generator):

<u>Pollutant</u>	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
NO _x	1731.5	1731.5	1731.5	1731.5

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X + 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore, the appropriate quarterly emissions to be offset are as follows (each steam generator):

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1624-328-0	1731	1731	1732	1732
S-1624-329-0	1731	1731	1732	1732
S-1624-330-0	1731	1731	1732	1732
Total	5,193	5,193	5,196	5,196

The applicant has stated that the facility plans to purchase the following amounts from S-4334-2:

Certificate	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-4334-2	95,700	98,089	100,530	100,530

As seen above, the facility has proposed sufficient credits to fully offset the quarterly NOx emission increases associated with S-1624-328-0 thru '-330-0.

Proposed Rule 2201 (offset) Conditions

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender NOx emission reduction credits for the following quantity of emissions: 1st quarter – 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,732 lb, and fourth quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- {GC# 1983} ERC Certificate Number S-4334-2 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

SOx Offset Calculations

The quantity of offsets in pounds per year for SO_x is calculated as follows for sources with an SSPE1 less than the offset threshold levels before implementing the project being evaluated.

$$\text{Offsets Required (lb/year)} = [(\text{SSPE2} - \text{ROT} + \text{ICCE}) \times \text{DOR}]$$

Where,

- SSPE2 = Post Project Stationary Source Potential to Emit
- ROT = Respective Offset Threshold, for the respective pollutant
- ICCE = Increase in Cargo Carrier Emissions
- DOR = Distance Offset Ratio, determined pursuant to Section 4.8

$$\text{Offsets Required (lb/year)} = [(\text{SSPE2} - \text{ROT} + \text{ICCE}) \times \text{DOR}]$$

- SSPE2 (SO_x) = 55,032 lb/year
- Offset threshold (NO_x) = 54,750 lb/year
- ICCE = 0 lb/year

The approved distance offset ratio is 1.5:1 because the emission reductions originated greater than 15 miles for the proposed units.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= [(55,032 - 54,750 + 0) \times 1.5] \\ &= 282 \times 1.5 \\ &= 423 \text{ lb SO}_x\text{/year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (423 \text{ lb SO}_x\text{/year}) \div (4 \text{ quarters/year}) \\ &= 105.75 \text{ lb/qtr} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

<u>Pollutant</u>	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
PM10	105	106	106	106

Therefore, the appropriate quarterly emissions to be offset are as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1634-328	105	106	106	106
S-1624-329	105	106	106	106
S-1624-320	105	106	106	106
Total	315	318	318	318

The applicant has stated that the facility plans to purchase the following amounts from S-4758-5:

Certificate	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-4758-5	7,327	7,104	7,923	6,884

As seen above, the facility has proposed sufficient credits to fully offset the quarterly SOx emission increases associated with S-1624-328-0 thru '-330.

PM10 Offset Calculations

Offsets Required (lb/year) = ((PE2 – BE)) x DOR

PE2 = 2,606 lb/year

BE = 0 lb/year

The approved distance offset ratio is 1.5:1 because the emission reductions originated greater than 15 miles for the proposed units.

Offsets Required (lb/year) = ((2,606 – 0)) x DOR
 = 2,606 x 1.5
 = 3,909 lb-PM10/year (each steam generator)

Calculating the appropriate quarterly emissions to be offset is as follows:

<u>Pollutant</u>	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
PM10	977.25	977.25	977.25	977.25

Therefore, the appropriate quarterly emissions to be offset are as follows:

	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-1634-328	977	977	977	978
S-1624-329	977	977	977	978
S-1624-320	977	977	977	978
Total	2,931	2,931	2,931	2,934

The applicant has stated that the facility plans to purchase the following amounts from S-4758-5:

Certificate	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
S-4758-5	7,327	7,104	7,923	6,884

Note PM10 may be offset using SOx at an interpollutant offset ratio of 1.0 tons SOx/ton PM10 by District policy APR 1430. As seen above, the facility has proposed sufficient credits to fully offset the quarterly PM10 emission increases associated with S-1624-328-0 thru '-330.

Proposed Rule 2201 (offset) Conditions

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter – 977 lb, 2nd quarter – 977 lb, 3rd quarter – 977 lb, and fourth quarter – 978 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- {GC# 1983} ERC Certificate Number S-4758-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

CO Offset Calculations

CO offsets are triggered by CO emissions in excess of 200,000 lb/year for the facility. However, pursuant to Section 4.6.1, "Emission Offsets shall not be required for the following: increases in carbon monoxide in attainment areas if the applicant demonstrates to the satisfaction of the APCO, that the Ambient Air Quality Standards are not violated in the areas to be affected, and such emissions will be consistent with Reasonable Further Progress, and will not cause or contribute to a violation of Ambient Air Quality Standards (AAQS)."

The Technical Services Section of the San Joaquin Valley Unified Air Pollution Control District performed a CO modeling run, using the EPA AERMOD air dispersion model, to determine if the CO emissions would exceed the State and Federal AAQS. Modeling of the worst case 1 hour and 8 hour CO impacts were performed. These values were added to the worst case ambient concentration (background) measured and compared to the ambient air quality standards. Results of the modeling are presented in Appendix E.

This modeling demonstrates that the proposed increase in CO emissions will not cause a violation of the CO ambient air quality standards. Therefore, the increase in CO emissions is exempt from offsets pursuant to Section 6.4.1.

VOC Offset Calculations

Offsets Required (lb/year) = $([PE2 - BE]) \times DOR$

As calculated in Section VII.C.6 above, the BE for tank S-1624-70 equals its PE1 since the unit is a Clean Emissions Unit.

PE2 = 12,285 lb/year (three steam generators)
PE2 = 0 lb/year (tank S-1624-70)
BE = 19,082 lb/year (tank S-1624-70)

$$\begin{aligned}\text{Offsets Required (lb/year)} &= (12,285 + 0 - 19,082) \times \text{DOR} \\ &= -6,797 \times \text{DOR} \\ &= 0 \text{ lb VOC/year}\end{aligned}$$

As demonstrated in the calculation above, the amount of offsets is zero. Therefore, VOC offsets will not be required for this project.

C. Public Notification

1. Applicability

Public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed,
- d. Any project with an SSPE of greater than 20,000 lb/year for any pollutant, and/or
- e. Any project which results in a Title V significant permit modification

a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications

New Major Sources are new facilities, which are also Major Sources. Since this is not a new facility, public noticing is not required for this project for New Major Source purposes.

As demonstrated in Sections VII.C.7 and VII.C.8, this project is a Federal Major Modification. Therefore, public noticing for Federal Major Modification purposes is required.

b. PE > 100 lb/day

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. As seen in Section VII.C.2 above, this project does not include a new emissions unit which has daily emissions greater than 100 lb/day for any pollutant, therefore public noticing for PE > 100 lb/day purposes is not required.

c. Offset Threshold

The SSPE1 and SSPE2 are compared to the offset thresholds in the following table.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO _x	124,470	138,321	20,000 lb/year	No
SO _x	48,666	55,032	54,750 lb/year	No
PM ₁₀	56,250	64,068	29,200 lb/year	No
CO	539,812	581,137	200,000 lb/year	No
VOC	> 20,000	> 20,000	20,000 lb/year	No

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

d. SSIPE > 20,000 lb/year

Public notification is required for any permitting action that results in a SSIPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSIPE = SSPE2 – SSPE1. The SSIPE is compared to the SSIPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO _x	124,470	138,321	13,851	20,000 lb/year	No
SO _x	48,666	55,032	6,366	20,000 lb/year	No
PM ₁₀	56,250	64,068	7,818	20,000 lb/year	No
CO	539,812	581,137	41,325	20,000 lb/year	Yes
VOC			<0	20,000 lb/year	No

As demonstrated above, the SSIPE for CO is greater than 20,000 lb/year; therefore public noticing for SSIPE purposes is required.

e. Title V Significant Permit Modification

As shown in the Discussion of Rule 2520 below, this project constitutes a Title V significant modification. Therefore, public noticing for Title V significant modifications is required for this project.

2. Public Notice Action

As discussed above, public noticing is required for this project for NO_x and VOC emissions triggering a Federal Major Modification and a CO IPE greater than 20,000 lb/year. Therefore, public notice documents will be submitted to the California Air

Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

D. Daily Emission Limits (DELs)

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

Proposed Rule 2201 (DEL) Conditions:

The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100 scf. [District Rules 2201 and 4320]

Emission rates shall not exceed any of the following: NO_x (as NO_x): 5 ppmvd @ 3% O₂ or 0.0062 lb/MMBtu; SO_x: 0.00285 lb/MMBtu; PM₁₀: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O₂ or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320]

E. Compliance Assurance

1. Source Testing

This unit is subject to District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*. Source testing requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

1. Monitoring

As required by District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to monitoring requirements. Monitoring requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

2. Recordkeeping

As required by District Rule 4320, *Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr*, this unit is subject to recordkeeping requirements. Recordkeeping requirements, in accordance with District Rule 4320, will be discussed in Section VIII, *District Rule 4320*, of this evaluation.

The following permit condition will be listed on permit as follows:

S-1624-328-0 thru '-330-0:

- Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] N
- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)]

4. Reporting

No reporting is required to demonstrate compliance with Rule 2201.

F. Ambient Air Quality Analysis (AAQA)

An AAQA shall be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis. Refer to **Attachment VII** of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO_x, CO, and SO_x. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO_x, CO, or SO_x.

The proposed location is in a non-attainment area for the state's PM₁₀ as well as federal and state PM_{2.5} thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM₁₀ and PM_{2.5}.

G. Compliance Certification

Section 4.15.2 of this Rule requires the owner of a new Major Source or a source undergoing a Federal Major Modification to demonstrate to the satisfaction of the District that all other Major Sources owned by such person and operating in California are in compliance or are on a schedule for compliance with all applicable emission limitations and standards. As discussed in Section VIII above, this facility is a new major source and this project does constitute a Federal Major Modification, therefore this requirement is applicable. E&B's compliance certification is included in **Attachment VIII**.

H. Alternate Siting Analysis

The current project occurs at an existing facility. The applicant proposes to install steam generators.

Since the project will provide steam to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.

Rule 2410 Prevention of Significant Deterioration

As shown in Section VII.C.9 above, this project does not result in a new PSD major source or PSD major modification. No further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a "permit amendment that does not qualify as a minor permit modification or administrative amendment."

Minor permit modifications are not Title I modifications as defined in this rule. This project triggers a Federal Major Modification, as a result, the proposed project constitutes a Significant Modification to the Title V Permit. E&Bs Title V Compliance Certification form is included in Attachment VIII.

Rule 4001 New Source Performance Standards (NSPS)

40 CFR Part 60 Subpart Dc Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. 40 CFR Part 60, Subpart Dc applies to Small Industrial-Commercial-Institutional Steam Generators between 10 MMBtu/hr and 100 MMBtu/hr (post-6/9/89 construction, modification or, reconstruction). Subpart Dc has standards for SO_x and PM₁₀. The 85 MMBtu/hr steam generators are subject to Subpart Dc requirements.

60.42c – Standards for Sulfur Dioxide

Since coal is not combusted by the steam generators in this project, the requirements of this section are not applicable.

60.43c – Standards for Particulate Matter

The steam generators do not fired on coal, combust mixtures of coal with other fuels, combust wood, combust mixtures of wood with other fuels, or oil; therefore, it will not be subject to the requirements of this section.

60.44c – Compliance and Performance Tests Methods and Procedures for Sulfur Dioxide.

Since the steam generators in this project are not subject to the sulfur dioxide requirements of this subpart, no testing to show compliance is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

60.45c – Compliance and Performance Test Methods and Procedures for Particulate Matter

Since the steam generators in this project are not subject to the particulate matter requirements of this subpart, no testing to show compliance is required. Therefore, the requirements of this section are not applicable to the steam generator in this project.

60.46c – Emission Monitoring for Sulfur Dioxide

Since the steam generators in this project is not subject to the sulfur dioxide requirements of this subpart, no monitoring is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

60.47c – Emission Monitoring for Particulate Matter

Since the steam generators in this project is not subject to the particulate matter requirements of this subpart, no monitoring is required. Therefore, the requirements of this section are not applicable to the steam generators in this project.

60.48c – Reporting and Recordingkeeping Requirements

Section 60.48c (a) states that the owner or operator of each affected facility shall submit notification of the date of construction or reconstruction, anticipated startup, and actual startup, as provided by §60.7 of this part. This notification shall include:

- (1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

The design heat input capacity and type of fuel combusted at the facility will be listed on the unit's equipment description. No conditions are required to show compliance with this requirement.

- (2) If applicable, a copy of any Federally enforceable requirement that limits the annual capacity factor for any fuel mixture of fuels under §60.42c or §40.43c.

This requirement is not applicable since the unit is not subject to §60.42c or §40.43c.

- (3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

The facility has not proposed an annual capacity factor; therefore one will not be required.

- (4) Notification if an emerging technology will be used for controlling SO₂ emissions. The Administrator will examine the description of the control device and will determine whether the technology qualifies as an emerging technology. In making this determination, the Administrator may require the owner or operator of the affected facility to submit additional information concerning the control device. The affected facility is subject to the provisions of §60.42c(a) or (b)(1), unless and until this determination is made by the Administrator

This requirement is not applicable since the unit will not be equipped with an emerging technology used to control SO₂ emissions.

District Rule 4001, §3.0 defines the Administrator as the APCO of the District. The following condition ensures compliance:

- Permittee shall submit notification to the District of the date of construction, anticipated startup, and actual startup. Notifications shall be postmarked no later than 30 days after construction and 15 days after actual startup. The notifications shall include the design heat input and identification of fuels for this permit unit. [40 CFR 60.48c (a)]

Section 60.48c (g) states that the owner or operator of each affected facility shall record and maintain records of the amounts of each fuel combusted during each day. The following conditions will be added to the permit to ensure compliance with this section.

- A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)]
- Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)]

Section 60.48c (i) states that all records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record. District Rule 4320 requires that records be kept for five years. Compliance is ensured with the following condition:

- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, 4320, and 40 CFR 60.48c (i)]

Therefore, compliance with the requirements of this rule is expected.

Rule 4101 Visible Emissions

Rule 4101 states that no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 (or 20% opacity). As the steam generators are fired solely on natural gas, visible emissions are not expected to exceed Ringelmann 1 or 20% opacity. Also, based on past inspections of the facility continued compliance is expected.

Rule 4102 Nuisance

Rule 4102 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 – *Risk Management Policy for Permitting New and Modified Sources* specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than one. According to the Technical Services Memo for this project (**Attachment VII**), the total facility prioritization score including this project was greater than one. Therefore, an HRA was required to determine the short-term acute and long-term chronic exposure from this project.

The cancer risk for this project is shown below:

RMR Summary						
Units	Prioritization Score	Acute Hazard Index	Chronic Hazard Index	Maximum Individual Cancer Risk	T-BACT Required?	Special Permit Requirements?
Unit 328-0 (NG Steam Generator)	0.08	0.00	0.00	1.08E-08	No	Yes
Unit 329-0 (NG Steam Generator)	0.08	0.00	0.00	1.07E-08	No	Yes
Unit 330 (NG Steam Generator)	0.08	0.00	0.00	1.07E-08	No	Yes
Project Totals	0.24	0.00	0.00	3.22E-08		
Facility Totals	>1	0.70	0.03	1.69E-05		

Discussion of T-BACT

BACT for toxic emission control (T-BACT) is required if the cancer risk exceeds one in one million. As demonstrated above, T-BACT is not required for this project because the HRA indicates that the risk is not above the District’s thresholds for triggering T-BACT requirements; therefore, compliance with the District’s Risk Management Policy is expected.

Proposed Permit Requirements

To ensure that human health risks will not exceed District allowable levels; the following shall be included as requirements for:

Unit # 328-0, 329-0, & 330-0

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction.

Rule 4201 Particulate Matter Concentration

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

F-Factor for NG: 8,578 dscf/MMBtu at 60 °F
PM₁₀ Emission Factor: 0.005 lb-PM₁₀/MMBtu
Percentage of PM as PM₁₀ in Exhaust: 100%
Exhaust Oxygen (O₂) Concentration: 3%

$$\text{Excess Air Correction to F Factor} = \frac{20.9}{(20.9 - 3)} = 1.17$$

$$GL = \left(\frac{0.0035 \text{ lb-PM}}{\text{MMBtu}} \times \frac{7,000 \text{ grain}}{\text{lb-PM}} \right) / \left(\frac{8,578 \text{ ft}^3}{\text{MMBtu}} \times 1.17 \right)$$

$$GL = 0.002 \text{ grain / dscf} < 0.1 \text{ grain / dscf}$$

Therefore, compliance with the requirements of this rule is expected.

California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

Rule 4305 Boilers, Steam Generators and Process Heaters – Phase 2

Pursuant to Rule 4305, Section 2.0, the proposed new unit will be subject to Rule 4305. Also, the proposed new unit will also be subject to Rule 4306. Since emissions limits of Rule 4306 and all other requirements are equivalent to or more stringent than Rule 4305 requirements, compliance with Rule 4320 requirements will satisfy requirements of Rule 4305.

Rule 4306 Boilers, Steam Generators and Process Heaters – Phase 3

Pursuant to Rule 4306, Section 2.0, the proposed unit will be subject to Rule 4306. Also, the proposed unit will also be subject to Rule 4320. Since emissions limits of Rule 4320 and all other requirements are equivalent to or more stringent than Rule 4306 requirements, compliance with Rule 4320 requirements will satisfy requirements of Rule 4306.

Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr

This rule limits NO_x, CO, SO₂ and PM₁₀ emissions from boilers, steam generators and process heaters rated greater than 5 MMBtu/hr. This rule also provides a compliance option of payment of fees in proportion to the actual amount of NO_x emitted over the previous year.

The steam generators are rated at greater than 5 MMBtu/hr heat input. Therefore this rule applies.

Section 5.1 NOx Emission Limits

Section 5.1 states that an operator of a unit(s) subject to this rule shall comply with all applicable requirements of the rule and one of the following, on a unit-by-unit basis:

- Operate the unit to comply with the emission limits specified in Sections 5.2 and 5.4; or
- Pay an annual emissions fee to the District as specified in Section 5.3 and comply with the control requirements specified in Section 5.4; or
- Comply with the applicable Low-use Unit requirements of Section 5.5.

Section 5.2.1 states that on and after the indicated Compliance Deadline units shall not be operated in a manner which exceeds the applicable NO_x limit specified in Table 1 of this rule.

The units have a maximum heat input of 85.0 MMBtu/hr; therefore, the applicable emission limit category Section 5.2, Table 1, Category C.2 from District Rule 4320 applies as follows:

C. Oilfield Steam Generators			
Category	NO _x Limit	Authority to Construct	Compliance Deadline
2. Units with a total rated heat input >20.0 MMBtu/hr	a) Standard Schedule 7 ppmv or 0.008 lb/MMBtu; or	July 1, 2009	July 1, 2010
	b) Staged Enhanced Schedule Initial Limit 9 ppmv or 0.011 lb/MMBtu; and	July 1, 2011	July 1, 2012
	Final Limit 5 ppmv or 0.0062 lb/MMBtu	January 1, 2013	January 1, 2014

E&B has proposed to comply with Rule 4320 by limiting the burner to 5 ppm-NO_x @ 3% O₂ (or 0.0062 lb-NO_x/MMBtu). The following condition will be listed on the ATCs to ensure compliance:

- Emission rates shall not exceed any of the following: NO_x (as NO_x): 5 ppmvd @ 3% O₂ or 0.0062 lb/MMBtu; SO_x: 0.00285 lb/MMBtu; PM₁₀: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O₂ or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320]

Section 5.4 Particulate Matter Control Requirements

5.4.1 To limit particulate matter emissions, an operator shall comply with one of the following requirements:

- 5.4.1.1 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall fire units exclusively on PUC-quality natural gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases;

5.4.1.2 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall limit fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet; or

5.4.1.3 On and after the applicable NO_x Compliance Deadline specified in Section 5.2 Table 1, operators shall install and properly operate an emission control system that reduces SO₂ emissions by at least 95% by weight; or limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% O₂.

5.4.1.4 Notwithstanding the compliance deadlines indicated in Sections 5.4.1.1 through 5.4.1.3, refinery units, which require modification of refinery equipment to reduce sulfur emissions, shall be in compliance with the applicable requirement in Section 5.4.1 no later than July 1, 2013.

E&B has addressed the particulate matter requirement by proposing to fire the unit on fuel with a sulfur content to no more than one (1) grain of total sulfur per one hundred (100) standard cubic feet.

- *The unit shall only be fired on natural gas with a maximum sulfur content of 1 gr S/100 scf. [District Rules 2201 and 4320] N*

Compliance with section 5.4 is expected.

Section 5.6 Startup and Shutdown Provisions

Section 5.6 states that on and after the full compliance deadline specified in Section 5.0, the applicable emission limits of Sections 5.2 Table 1 and 5.5.2 shall not apply during start-up or shutdown provided an operator complies with the requirements specified in Sections 5.6.1 through 5.6.5.

Emissions during start-up and shutdown will not be subject to the emission limits in Sections 5.2 and 5.2.2. The following conditions will be listed on the ATCs:

- E&B is not proposing low use status and does not request addition of startup or shutdown provisions.

Section 5.7 Monitoring Provisions

Section 5.7.1 requires that permit units subject to District Rule 4320, Section 5.2 shall both install and maintain an operational APCO approved Continuous Emission Monitoring System (CEMS) for NO_x, CO and O₂, or implement an APCO-approved alternate monitoring.

E&B proposes to use Alternate Monitoring Scheme A (pursuant to District Policy SSP-1105), which requires that monitoring of NO_x, CO, and O₂ exhaust concentrations shall be conducted at least once per month (in which a source test is not performed) using a portable analyzer. The following conditions will be incorporated into the ATCs to ensure compliance with the requirements of the proposed alternate monitoring plan:

- {4063} The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need

not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]

- {4064} If either the NOX or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320]
- {4065} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320]
- {4066} The permittee shall maintain records of: (1) the date and time of NOX, CO, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NOX and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320]

Section 5.7.6 requires operators complying with Sections 5.4.1.1 or 5.4.1.2 to provide an annual fuel analysis to the District unless a more frequent sampling and reporting period is included in the Permits to Operate. Sulfur analysis shall be performed in accordance with the test methods in Section 6.2.

- When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rule 4320]

The following condition will be listed on the ATCs to ensure compliance with the reporting section of this requirement:

- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320]

Section 5.8 Compliance Determination

Section 5.8.1 requires that the operator of any unit shall have the option of complying with either the applicable heat input (lb/MMBtu), emission limits or the concentration (ppmv) emission limits specified in Section 5.2. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling).

Therefore, the following condition will be listed on the ATCs as follows:

- {2976} The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]

Section 5.8.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0.

Therefore, the following permit condition will be listed on the ATCs as follows:

- {2972} All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. *For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation.* [District Rules 4305, 4306, and 4320]

Section 5.8.4 requires that for emissions monitoring pursuant to Sections 5.7.1 and 6.3.1 using a portable NO_x analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period.

Therefore, the following permit condition will be listed on the ATCs as follows:

- {4065} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320]

Section 5.8.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. Therefore, the following permit condition will be listed on the ATCs as follows:

- {2980} For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320]

Section 6.1 Recordkeeping

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.5 shall be maintained for five calendar years and shall be made available to the APCO and EPA upon

request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule.

A permit condition will be listed on the ATCs as follows:

- All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320]

Section 6.2, Test Methods

Section 6.2 identifies the following test methods as District-approved source testing methods for the pollutants listed:

Pollutant	Units	Test Method Required
NO _x	ppmv	EPA Method 7E or ARB Method 100
NO _x	lb/MMBtu	EPA Method 19
CO	ppmv	EPA Method 10 or ARB Method 100
Stack Gas O ₂	%	EPA Method 3 or 3A, or ARB Method 100
Stack Gas Velocities	ft/min	EPA Method 2
Stack Gas Moisture Content	%	EPA Method 4
Oxides of sulfur		EPA Method 6C, EPA Method 8, or ARB Method 100
Total Sulfur as Hydrogen Sulfide (H ₂ S) Content		EPA Method 11 or EPA Method 15, as appropriate.
Sulfur Content of Liquid Fuel		ASTM D 6920-03 or ASTM D 5453-99

The following permit condition will be listed on the ATCs as follows:

- The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities - EPA Method 2; Stack gas moisture content - EPA Method 4; SO_x - EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content - EPA Method 11 or 15; and fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2201, 4305, 4306, 4320] N

Section 6.3, Compliance Testing

Section 6.3.1 requires that this unit be tested to determine compliance with the applicable requirements of section 5.1 and 5.2.3 not less than once every 12 months. Upon demonstrating compliance on two consecutive compliance source tests, the following source test may be deferred for up to thirty-six months.

The following permit conditions will be listed on the ATCs:

- A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 220, 4305, 4306 and 4320]
- Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 4306 and 4320]
- The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]

Section 7.0, Compliance Schedule

Section 7.0 identifies the dates by which the operator shall submit an application for an ATC and the date by which the owner shall demonstrate compliance with this rule.

The unit will be in compliance with the emissions limits listed in Table 1, Section 5.2 of this rule, and periodic monitoring and source testing as required by District Rule 4320. Therefore, requirements of the compliance schedule, as listed in Section 7.0 of District Rule 4320, are satisfied. No further discussion is required.

Conclusion

Conditions will be incorporated into the permit in order to ensure compliance with each section of this rule. Therefore, compliance with District Rule 4320 requirements is expected.

Rule 4351 Boilers, Steam Generators and Process Heaters – Phase 1

This rule applies to boilers, steam generators, and process heaters at NO_x Major Sources that are not located west of Interstate 5 in Fresno, Kings, or Kern counties. The facility is a NO_x Major Sources is located east of Interstate five. Therefore this rule applies. Since emissions limits of Rule 4320 and all other requirements are equivalent to, or more stringent, than Rule 4351 requirements, compliance with Rule 4320 requirements will satisfy requirements of Rule 4351.

Rule 4801 Sulfur Compounds

A person shall not discharge into the atmosphere sulfur compounds, which would exist as a liquid or gas at standard conditions, exceeding in concentration at the point of discharge: 0.2 % by volume calculated as SO₂, on a dry basis averaged over 15 consecutive minutes. As the combustion equipment associated with this project will be fired on PUC quality natural gas, compliance with the requirements of this rule is expected.

California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

Greenhouse Gas (GHG) Significance Determination

Oil and gas operations in Kern County must comply with the *Kern County Zoning Ordinance – 2015 (C) Focused on Oil and Gas Local Permitting*. In 2015, Kern County revised the Kern County Zoning Ordinance Focused on Oil and Gas Activities (Kern Oil and Gas Zoning Ordinance) in regards to future oil and gas exploration, and drilling and production of hydrocarbon resource projects occurring within Kern County.

Kern County served as lead agency for the revision to their ordinance under the California Environmental Quality Act (CEQA), and prepared an Environmental Impact Report (EIR) that was certified on November 9, 2015. The EIR evaluated and disclosed to the public the environmental impacts associated with the growth of oil and gas exploration in Kern County, and determined that such growth will result in significant GHG impacts in the San Joaquin Valley. As such, the EIR included mitigation measures for GHG.

The District is a Responsible Agency for the project because of its discretionary approval power over the project via its Permits Rule (Rule 2010) and New Source Review Rule

(Rule 2201), (CEQA Guidelines §15381). As a Responsible Agency, the District is limited to mitigating or avoiding impacts for which it has statutory authority. The District does not have statutory authority for regulating GHGs. The District has determined that the applicant is responsible for implementing GHG mitigation measures imposed in the EIR by the Kern County for the Kern County Zoning Ordinance.

District CEQA Findings

The proposed project is located in Kern County and is thus subject to the Kern County Zoning Ordinance – 2015 (C) Focused on Oil and Gas Local Permitting. The Kern County Zoning Ordinance was developed by the Kern County Planning Agency as a

comprehensive set of goals, objectives, policies, and standards to guide development, expansion, and operation of oil and gas exploration within Kern County.

In 2015, Kern County revised their *Kern County Zoning Ordinance* in regards to exploration, drilling and production of hydrocarbon resources projects. Kern County, as the lead agency, is the agency that will enforce the mitigation measures identified the EIR, including the mitigation requirements of the Oil and Gas ERA. As a responsible agency the District complies with CEQA by considering the EIR prepared by the Lead Agency, and by reaching its own conclusion on whether and how to approve the project involved (CCR §15096). The District has reviewed the EIR prepared by Kern County, the Lead Agency for the project, and finds it to be adequate. The District also prepared a full findings document. The full findings document, *California Environmental Quality Act (CEQA) Statement of Findings for the Kern County Zoning Ordinance EIR* contains the details of the District's findings regarding the Project. The District's implementation of the Kern Zoning Ordinance and its EIR applies to ATC applications received for any new/modified equipment used in oil/gas production in Kern County, including new wells. The full findings applies to the Project and the Project's related activity equipment(s) is covered under the Kern Zoning Ordinance. To reduce project related impacts on air quality, the District evaluates emission controls for the project such as Best Available Control Technology (BACT) under District Rule 2201 (New and Modified Stationary Source Review). In addition, the District is requiring the applicant to surrender emission reduction credits (ERC) for stationary source emissions above the offset threshold.

Thus, the District concludes that through a combination of project design elements, permit conditions, and the Oil and Gas ERA, the project will be fully mitigated to result in no net increase in emissions. Pursuant to CCR §15096, prior to project approval and issuance of ATCs the District prepared findings.

Indemnification Agreement/Letter of Credit Determination

According to District Policy APR 2010 (CEQA Implementation Policy), when the District is the Lead or Responsible Agency for CEQA purposes, an indemnification agreement and/or a letter of credit may be required. The decision to require an indemnity agreement and/or a letter of credit is based on a case-by-case analysis of a particular project's potential for litigation risk, which in turn may be based on a project's potential to generate public concern, its potential for significant impacts, and the project proponent's ability to pay for the costs of litigation without a letter of credit, among other factors.

The revision to the *Kern County Zoning Ordinance* went through an extensive public process that included a Notice of Preparation, a preparation of an EIR, scoping meetings, and public hearings. The process led to the certification of the final EIR and approval of the revised *Kern County Zoning Ordinance* in November 2015 by the Kern County Board of Supervisors. As mentioned above, the proposed project will be fully mitigated and will result in no net increase in emissions. In addition, the proposed project is not located at a facility of concern; therefore, an Indemnification Agreement and/or a Letter of Credit will not be required for this project in the absence of expressed public concern.

IX. Recommendation

Compliance with all applicable rules and regulations is expected. Pending a successful Public Noticing period, issue ATCs subject to the permit conditions on the attached draft ATCs in **Attachment IX**.

X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
S-1624-328-0 thru '330-0	3020-02 H	85 MMBtu/hr	\$1128.00

Attachments

- I: PTO S-1624-70-2
- II: Aerial Photo of Site
- III: Tank Emissions Calculations
- IV: Emissions Profiles
- V: BACT Guideline
- VI: BACT Analysis
- VII: HRA /AAQA Modelling
- VIII: Title V and Statewide Compliance Documents
- IX: Draft ATCs

Attachment I
PTO S-1624-70-2

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1624-70-2

EXPIRATION DATE: 06/30/2021

SECTION: 32 TOWNSHIP: 27S RANGE: 27E

EQUIPMENT DESCRIPTION:

1,000 BBL FIXED ROOF PETROLEUM STORAGE TANK, GRIMES #5

PERMIT UNIT REQUIREMENTS

1. When this tank is not operated (dormant for Rule 4623), all liquids shall be removed and the produced crude oil inlet line shall be physically disconnected. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Results of TVP test on material introduced to this tank upon reactivation shall be submitted to the District within 60 days of recommencing operation of this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
3. Permittee shall notify the District at least seven (7) calendar days prior to recommencing operation. [District Rule 1070] Federally Enforceable Through Title V Permit
4. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1 through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623] Federally Enforceable Through Title V Permit
5. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rules 2201 and 4623] Federally Enforceable Through Title V Permit
6. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank in order to maintain exemption from the rule. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
8. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
10. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit


PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

12. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Attachment II Aerial Photo of Site



Attachment III Tank Emissions Calculations

Tank Input Data	
permit number (S-xxxx-xx-xx)	-70
facility tank I.D.	#5
nearest city {1: Bakersfield, 2: Fresno, 3: Stockton}	1
tank ROC vapor pressure (psia)	0.5
liquid bulk storage temperature, Tb (°F)	100
is this a constant-level tank? {yes, no}	no
will flashing losses occur in this tank (only if first-line tank)? {yes, no}	no
breather vent pressure setting range (psi)	0.06
diameter of tank (feet)	21.5
capacity of tank (bbl)	1,000
conical or dome roof? {c, d}	c
shell height of tank (feet)	16
average liquid height (feet)	9
are the roof and shell the same color? {yes,no}	yes
For roof:	
color {1:Spec Al, 2:Diff Al, 3:Light, 4:Med, 5:Red, 6:White}	4
condition {1: Good, 2: Poor}	1
-----This row only used if shell is different color from roof-----	4
-----This row only used if shell is different color from roof-----	1

Liquid Input Data	A	B
maximum daily fluid throughput (bbl)		1,000
maximum annual fluid throughput (bbl)	365,000	365,000
-----This row only used if flashing losses occur in this tank-----		100
-----This row only used if flashing losses occur in this tank-----		36,500
molecular weight, Mw (lb/lb-mol)		100

Calculated Values	A	B
daily maximum ambient temperature, T _{ax} (°F)		77.65
daily minimum ambient temperature, T _{an} (°F)		53.15
daily total solar insolation factor, I (Btu/ft ² -day)		1648.9
atmospheric pressure, P _a (psia)		14.47
water vapor pressure at daily maximum liquid surface temperature (T _{lx}), P _{vx} (psia)	99.0	0.9259
water vapor pressure at daily minimum liquid surface temperature (T _{ln}), P _{vn} (psia)	88.2	0.6653
water vapor pressure at average liquid surface temperature (T _{la}), P _{va} (psia)	93.6	0.7903
roof outage, H _{ro} (feet)		0.2240
vapor space volume, V _v (cubic feet)		2622.66
paint factor, alpha		0.68
vapor density, W _v (lb/cubic foot)		0.0084
daily vapor temperature range, delta T _v (degrees Rankine)		49.04
vapor space expansion factor, K _e		0.1032

Results	lb/year	lb/day
Standing Storage Loss	832	2.28
Working Loss	18,250	50.00
Flashing Loss	N/A	N/A
Total Uncontrolled Tank VOC Emissions	19,082	52.3

Summary Table	
Permit Number	-70
Facility Tank I.D.	#5
Tank capacity (bbl)	1,000
Tank diameter (ft)	21.5
Tank shell height (ft)	16
Conical or Dome Roof	Conical
Maximum Daily Fluid Throughput (bbl/day)	1,000
Maximum Annual Fluid Throughput (bbl/year)	365,000
Maximum Daily Oil Throughput (bbl/day)	N/A
Maximum Annual Oil Throughput (bbl/year)	N/A
Total Uncontrolled Daily Tank VOC Emissions (lb/day)	52.3
Total Uncontrolled Annual Tank VOC Emissions (lb/year)	19,082

Attachment IV Emissions Profiles

Permit #: S-1624-328-0	Last Updated
Facility: E&B NATURAL RESOURCES MGMT	06/16/2018 EDGEHILR

Equipment Pre-Baselined: NO

	<u>NOX</u>	<u>SOX</u>	<u>PM10</u>	<u>CO</u>	<u>VOC</u>
Potential to Emit (lb/Yr):	4617.0	2122.0	2606.0	13775.0	4095.0
Daily Emis. Limit (lb/Day)	12.6	5.8	7.1	37.7	11.2
Quarterly Net Emissions Change (lb/Qtr)					
Q1:	1154.0	530.0	651.0	3443.0	1023.0
Q2:	1154.0	530.0	651.0	3444.0	1024.0
Q3:	1154.0	531.0	652.0	3444.0	1024.0
Q4:	1155.0	531.0	652.0	3444.0	1024.0
Check if offsets are triggered but exemption applies	N	N	N	N	N
Offset Ratio	1.5	1.5	1.5		
Quarterly Offset Amounts (lb/Qtr)					
Q1:	1731.0	105.0	977.0		
Q2:	1731.0	106.0	977.0		
Q3:	1732.0	106.0	977.0		
Q4:	1732.0	106.0	978.0		

Permit #: S-1624-329-0	Last Updated
Facility: E&B NATURAL RESOURCES MGMT	06/16/2018 EDGEHILR

Equipment Pre-Baselined: NO

	<u>NOX</u>	<u>SOX</u>	<u>PM10</u>	<u>CO</u>	<u>VOC</u>
Potential to Emit (lb/Yr):	4717.0	2122.0	2606.0	13775.0	4095.0
Daily Emis. Limit (lb/Day)	12.6	5.8	7.1	37.7	11.2
Quarterly Net Emissions Change (lb/Qtr)					
Q1:	1154.0	530.0	651.0	3443.0	1023.0
Q2:	1154.0	530.0	651.0	3444.0	1024.0
Q3:	1154.0	531.0	652.0	3444.0	1024.0
Q4:	1155.0	531.0	652.0	3444.0	1024.0
Check if offsets are triggered but exemption applies	N	N	N	N	N
Offset Ratio	1.5	1.5	1.5		
Quarterly Offset Amounts (lb/Qtr)					
Q1:	1731.0	105.0	977.0		
Q2:	1731.0	106.0	977.0		
Q3:	1732.0	106.0	977.0		
Q4:	1732.0	106.0	978.0		

Permit #: S-1624-330-0	Last Updated
Facility: E&B NATURAL RESOURCES MGMT	06/16/2018 EDGEHILR

Equipment Pre-Baselined: NO

	<u>NOX</u>	<u>SOX</u>	<u>PM10</u>	<u>CO</u>	<u>VOC</u>
Potential to Emit (lb/Yr):	4617.0	2122.0	2606.0	13775.0	4095.0
Daily Emis. Limit (lb/Day)	12.6	5.8	7.1	37.7	11.2
Quarterly Net Emissions Change (lb/Qtr)					
Q1:	1154.0	530.0	651.0	3443.0	1023.0
Q2:	1154.0	530.0	651.0	3444.0	1024.0
Q3:	1154.0	531.0	652.0	3444.0	1024.0
Q4:	1155.0	531.0	652.0	3444.0	1024.0
Check if offsets are triggered but exemption applies	N	N	N	N	N
Offset Ratio	1.5	1.5	1.5		
Quarterly Offset Amounts (lb/Qtr)					
Q1:	1731.0	105.0	977.0		
Q2:	1731.0	106.0	977.0		
Q3:	1732.0	106.0	977.0		
Q4:	1732.0	106.0	978.0		

Attachment V BACT Guideline

San Joaquin Valley
Unified Air Pollution Control District

Best Available Control Technology (BACT) Guideline 1.2.1*

Last Update: 03/24/2014

Oilfield Steam Generator (> or =20 MMBtu/hr)

Pollutant	Achieved in Practice or contained in the SIP	Technologically Feasible	Alternate Basic Equipment
VOC	Gaseous fuel		
SOx	Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO2 scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO2 @ 3% O2		
PM10	Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO2 scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emission rate of 9 ppmvd SO2 @ 3% O2		
NOx	<ul style="list-style-type: none"> •Units rated 85 MMBtu/hr and fired solely on PUC quality natural gas: 6 ppmvd @ 3% O2; or •Units firing on > or = 50% PUC quality natural gas; commercial propane; and/or LPG: 7 ppmvd @ 3% O2, except units rated 85 MMBtu/hr and fired solely on PUC quality natural gas; or •Units firing on <50% PUC quality natural gas; commercial propane; and/or LPG: 9 ppmvd @ 3% O2 	5 ppmvd @ 3% O2	
CO	25 ppmvd @ 3% O2		

**San Joaquin Valley
Unified Air Pollution Control District**

CO2e

FEDERAL BACT
=====

FEDERAL BACT
=====

FEDERAL BACT
=====

Federal BACT (40CFR52.21 (b)(23)) for Sources Subject to District Rule 2410 (Prevention of Significant Deterioration)

Variable frequency drive high efficiency electrical motors driving the blower; and
•When firing on ≥50% PUC quality natural gas, commercial propane, and/or LPG: a convection section with at least 235 square feet of heat transfer surface area per MMBtu/hr (HHV) of maximum rated heat input (verified by manufacturer or independent engineering/construction firm) or an overall thermal efficiency rating of 88% (verified by manufacturer or independent engineering/construction firm); or,

•When firing on <50% PUC quality natural gas, commercial propane, and/or LPG: split flow dual pass water feed configuration, a convection section having at least 128 square feet of heat transfer surface area per MMBtu/hr (HHV) of maximum rated heat input (verified by the manufacturer or independent engineering/construction firm) and at least six inches of castable refractory or an overall thermal efficiency rating of at least 85% (verified by manufacturer or independent engineering/construction firm);

Variable frequency drive high efficiency electrical motors driving the blower; and,
•When firing on ≥50% PUC quality natural gas, commercial propane, and/or LPG: a convection section with at least 235 square feet of heat transfer surface area per MMBtu/hr (HHV) of maximum rated heat input (verified by manufacturer or independent engineering/construction firm) or an overall thermal efficiency rating of 88% (verified by manufacturer or independent engineering/construction firm); or,

•When firing on <50% PUC quality natural gas, commercial propane, and/or LPG: split flow dual pass water feed configuration, a convection section having at least 128 square feet of heat transfer surface area per MMBtu/hr (HHV) of maximum rated heat input (verified by the manufacturer or independent engineering/construction firm) and at least six inches of castable refractory or an overall thermal efficiency rating of at least 85% (verified by manufacturer or independent engineering/construction firm);

Or other emission reduction technique determined on a case by case basis that meets the requirements of 40

1.2.1

San Joaquin Valley
Unified Air Pollution Control District

CFR52.21(b)(23)

BACT is the most stringent control technique for the emissions unit and class of source. Control techniques that are not achieved in practice or contained in a state implementation plan must be cost effective as well as feasible. Economic analysis to demonstrate cost effectiveness is required for all determinations that are not achieved in practice or contained in an EPA approved State Implementation Plan.

***This is a Summary Page for this Class of Source**

Attachment VI BACT Analysis

Top Down BACT Analysis for Steam Generators

For the steam generator, BACT is required for NO_x, SO_x, PM₁₀, CO, and VOC.

Top-Down BACT Analysis for NO_x Emissions

a. Step 1 - Identify All Possible Control Technologies

From the SJVUAPCD BACT Clearinghouse, Guideline 1.2.1, Oilfield Steam Generator (≥ 20 MMBtu/hr), 4th quarter 2014, identifies BACT for NO_x emissions as follows:

Pollutant	Achieved in Practice or contained in SIP	Technologically Feasible	Alternate Basic Equipment
NO _x	<ul style="list-style-type: none"> • Units rated 85 MMBtu/hr and fired solely on PUC quality natural gas: 6 ppmvd @ 3% O₂; or • Units firing on > 50% PUC quality natural gas, commercial propane, and/or LPG: 7 ppmvd @ 3% O₂, except units rated 85 MMBtu/hr and fired solely on PUC quality natural gas; or • Units firing on < 50% PUC quality natural gas, commercial propane, and/or LPG: 9 ppmvd @ 3% O₂ 	5 ppmvd @ 3% O ₂	

Step 2 - Eliminate Technologically Infeasible Options

None of the above listed technologies are technologically infeasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

1. 5 ppmvd @ 3% O₂ (Technologically Feasible)
2. Units rated 85 MMBtu/hr and fired solely on PUC quality natural gas: 6 ppmvd @ 3% O₂ (Achieved in Practice)

3. Units firing on > 50% PUC quality natural gas, commercial propane, and/or LPG: 7 ppmvd @ 3% O₂, except units rated 85 MMBtu/hr and fired solely on PUC quality natural gas (Achieved in Practice)
4. Units firing on < 50% PUC quality natural gas, commercial propane, and/or LPG: 9 ppmvd @ 3% O₂ (Achieved in Practice)

Step 4 - Cost Effectiveness Analysis

The applicant has proposed to limit the NO_x emissions of the steam generator in this project to 5 ppmv @ 3% O₂; therefore a cost effective analysis is not required.

Step 5 - Select BACT

BACT for NO_x emissions from the oilfield steam generator is 5 ppmvd @ 3% O₂. The applicant has proposed to install a steam generator with a NO_x limit of 5 ppmvd @ 3% O₂; therefore, BACT for NO_x emissions is satisfied.

Top Down BACT Analysis for SO_x and PM₁₀ Emissions

Step 1 - Identify all control technologies

From the SJVUAPCD BACT Clearinghouse, Guideline 1.2.1, Oilfield Steam Generator (≥ 20 MMBtu/hr), 4th quarter 2014, identifies BACT for SO_x and PM₁₀ emissions as follows:

Pollutant	Achieved in Practice or contained in SIP	Technologically Feasible	Alternate Basic Equipment
SO _x and PM ₁₀	Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO ₂ scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emissions rate of 9 ppmvd SO ₂ @ 3% O ₂		

Step 2 - Eliminate Technologically Infeasible Options

None of the above listed technologies are technologically infeasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

- 1) Fired on PUC quality natural gas, commercial propane, and/or commercial LPG; or gaseous fuel treated to remove 95% by weight of sulfur compounds; or treated such that the sulfur content of all fuel streams combined does not exceed 1 gr of sulfur compounds (as S) per 100 dscf; or use of a continuously operating SO₂ scrubber and either achieve 95% by weight control of sulfur compounds or achieve an emissions rate of 9 ppmvd SO₂ @ 3% O₂ (Achieved in Practice)

Step 4 - Cost Effectiveness Analysis

The applicant has proposed to use natural/waste/TEOR/produced gas fuel with a sulfur content no more than 1 grains/100 scf for the steam generator, which meets the most stringent emission requirements of BACT. Therefore, BACT is satisfied and a cost effective analysis does not need to be performed.

Step 5 - Select BACT

The applicant has proposed the use of natural/waste/TEOR/produced gas with a sulfur content not to exceed 1 gr-S/100 scf. This proposal is selected as BACT for SO_x and PM₁₀ emissions; therefore, BACT for SO_x and PM₁₀ emissions is satisfied.

Top Down BACT Analysis for CO Emissions

Step 1 - Identify All Possible CO Control Technologies

From the SJVUAPCD BACT Clearinghouse, Guideline 1.2.1, Oilfield Steam Generator (≥ 20 MMBtu/hr), 4th quarter 2014, identifies BACT for CO emissions as follows:

Pollutant	Achieved in Practice or contained in SIP	Technologically Feasible	Alternate Basic Equipment
CO	25 ppmvd @ 3% O ₂		

Step 2 - Eliminate Technologically Infeasible Options

None of the above listed technologies are technologically infeasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

- 1) 25 ppmvd @ 3% O₂ (Achieved-In-Practice)

Step 4 - Cost Effectiveness Analysis

The applicant has proposed to limit the CO emissions of the steam generator in this project to 25 ppmv @ 3% O₂. Since the applicant has chosen the most effective control technology in step 3, a cost effectiveness analysis is not required.

Step 5 - Select BACT

BACT for CO emissions from the oilfield steam generator is 25 ppmvd @ 3% O₂. The applicant has proposed to install a steam generator with a CO limit of 25 ppmvd @ 3% O₂; therefore, BACT for CO emissions is satisfied.

Top Down BACT Analysis for VOC Emissions

Step 1 - Identify All Possible VOC Control Technologies

From the SJVUAPCD BACT Clearinghouse, Guideline 1.2.1, Oilfield Steam Generator (\geq 20 MMBtu/hr), 4th quarter 2014, identifies BACT for VOC emissions as follows:

Pollutant	Achieved in Practice or contained in SIP	Technologically Feasible	Alternate Basic Equipment
VOC	Gaseous fuel		

Step 2 - Eliminate Technologically Infeasible Options

None of the above listed technologies are technologically infeasible.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

- 2) Gaseous fuel (Achieved-In-Practice)

Step 4 - Cost Effectiveness Analysis

The applicant has proposed the use of natural/waste/TEOR/produced gas fuel for the steam generator in this project. Since the applicant has chosen the most effective control technology in step 3, a cost effectiveness analysis is not required.

Step 5 - Select BACT

BACT for VOC emissions from the oilfield steam generator is gaseous fuel. The applicant has proposed natural/waste/TEOR/produced gas fuel; therefore BACT for VOC emissions is satisfied.

Attachment VII HRA /AAQA Modelling

San Joaquin Valley Air Pollution Control District Risk Management Review

To: Dan Klevann – Permit Services
 From: Eddie Arredondo – Technical Services
 Date: June 12, 2018
 Facility Name: E&B Natural Resources
 Location: T27S, R27E, SW33
 Application #(s): S-1624-328, 329-0, & 330-0
 Project #: S-1182344

A. RMR SUMMARY

RMR Summary						
Units	Prioritization Score	Acute Hazard Index	Chronic Hazard Index	Maximum Individual Cancer Risk	T-BACT Required?	Special Permit Requirements?
Unit 328-0 (NG Steam Generator)	0.08	0.00	0.00	1.08E-08	No	Yes
Unit 329-0 (NG Steam Generator)	0.08	0.00	0.00	1.07E-08	No	Yes
Unit 330-0 (NG Steam Generator)	0.08	0.00	0.00	1.07E-08	No	Yes
Project Totals	0.24	0.00	0.00	3.22E-08		
Facility Totals	>1	0.70	0.03	1.69E-05		

Proposed Permit Requirements

To ensure that human health risks will not exceed District allowable levels; the following shall be included as requirements for:

Unit # 328-0, 329-0, & 330-0

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction.

B. RMR REPORT

I. Project Description

Technical Services received a request on June 5, 2018, to perform a Risk Management Review for a proposed installation of three new 85MMBtu/hr natural gas/waste gas-fired steam generators (Conoco Lease) and surrender tank '70 to net VOC emissions.

II. Analysis

Toxic emissions for this proposed unit were derived from data in the 1992 Radian Corporation report to WSPA, and input into the San Joaquin Valley APCD's Hazard Assessment and Reporting Program (SHARP). In accordance with the District's Risk Management Policy for Permitting New and Modified Sources (APR 1905, May 28, 2015), risks from the proposed unit's toxic emissions were prioritized using the procedure in the 1990 CAPCOA Facility Prioritization Guidelines. The prioritization score for this proposed facility was greater than 1.0 (see RMR Summary Table). Therefore, a refined health risk assessment was required. The AERMOD model was used, with the parameters outlined below and meteorological data for 2010-2014 from Bakersfield to determine the dispersion factors (i.e., the predicted concentration or X divided by the normalized source strength or Q) for a receptor grid. These dispersion factors were input into the SHARP Program, which then used the Air Dispersion Modeling and Risk Tool (ADMRT) of the Hot Spots Analysis and Reporting Program Version 2 (HARP 2) to calculate the chronic and acute hazard indices and the carcinogenic risk for the project.

The following parameters were used for the review:

Analysis Parameters Unit 328-0, 329-0, & 330-0 (Each)			
Source Type	Point	Location Type	Rural
Stack Height (m)	6.09	Closest Receptor (m)	304
Stack Diameter. (m)	1.06	Type of Receptor	Residential
Stack Exit Velocity (m/s)	17.37	Max Hours per Year	8760
Stack Exit Temp. (°K)	388	Fuel Type	NG
Fuel Usage (mmscf/hr)	0.085	Fuel Usage (mmscf/yr)	745

Technical Services performed modeling for criteria pollutants CO, NO_x, SO_x, and PM₁₀ with the emission rates below:

Unit #	NO_x (Lbs.)		SO_x (Lbs.)		CO (Lbs.)		PM₁₀ (Lbs.)	
	Hr.	Yr.	Hr.	Yr.	Hr.	Yr.	Hr.	Yr.
328-0	0.51	4468	0.24	2122	1.57	13775	0.30	2606
329-0	0.51	4468	0.24	2122	1.57	13775	0.30	2606
330-0	0.51	4468	0.24	2122	1.57	13775	0.30	2606

The results from the Criteria Pollutant Modeling are as follows:

Criteria Pollutant Modeling Results*

	Background Site	1 Hour	3 Hours	8 Hours	24 Hours	Annual
CO	Bakersfield-Muni (2016)	Pass	X	Pass	X	X
NO _x	Bakersfield-California (2016)	Pass ¹	X	X	X	Pass
SO _x	Fresno – Garland (2016)	Pass	Pass	X	Pass	Pass
PM ₁₀	Bakersfield-California (2016)	X	X	X	Pass ²	Pass ²
PM _{2.5}	Bakersfield-Southeast (2015)	X	X	X	Pass ³	Pass ³

*Results were taken from the attached PSD spreadsheet.

¹The project was compared to the 1-hour NO₂ National Ambient Air Quality Standard that became effective on April 12, 2010 using the District's approved procedures

²The criteria pollutants are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2).

³The court has vacated EPA's PM_{2.5} SILs. Until such time as new SIL values are approved, the District will use the corresponding PM₁₀ SILs for both PM₁₀ and PM_{2.5} analyses.

III. Conclusion

The acute and chronic indices are below 1.0 and the cancer risk factor associated with the each unit is less than 1.0 in a million. **In accordance with the District's Risk Management Policy, the project is approved without Toxic Best Available Control Technology (T-BACT).**

To ensure that human health risks will not exceed District allowable levels; the permit requirements listed on page 1 of this report must be included for this proposed unit.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

IV. Attachments

- A. RMR request from the project engineer
- B. Additional information from the applicant/project engineer
- C. Prioritization score w/ toxic emissions summary
- D. Facility Summary

Attachment VIII
Title V and Statewide Compliance Documents

**San Joaquin Valley
Unified Air Pollution Control District
TITLE V MODIFICATION - COMPLIANCE CERTIFICATION FORM**

I. TYPE OF PERMIT ACTION (Check appropriate box)

- SIGNIFICANT PERMIT MODIFICATION ADMINISTRATIVE AMENDMENT
 MINOR PERMIT MODIFICATION

COMPANY NAME: E&B NATURAL RESOURCES MGMT.	FACILITY ID: S-1624
1. Type of Organization: <input checked="" type="checkbox"/> Corporation <input type="checkbox"/> Sole Ownership <input type="checkbox"/> Government <input type="checkbox"/> Partnership <input type="checkbox"/> Utility	
2. Owner's Name: E&B NATURAL RESOURCES MGMT.	
3. Agent to the Owner: SHAMS HASAN, HSE MANAGER	

II. COMPLIANCE CERTIFICATION (Read each statement carefully and initial all circles for confirmation):

- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will continue to comply with the applicable federal requirement(s).
- Based on information and belief formed after reasonable inquiry, the equipment identified in this application will comply with applicable federal requirement(s) that will become effective during the permit term, on a timely basis.
- Corrected information will be provided to the District when I become aware that incorrect or incomplete information has been submitted.
- Based on information and belief formed after reasonable inquiry, information and statements in the submitted application package, including all accompanying reports, and required certifications are true accurate and complete.

I declare, under penalty of perjury under the laws of the state of California, that the forgoing is correct and true:



Signature of Responsible Official

SHAMS HASAN

Name of Responsible Official (please print)

HSE MANAGER

Title of Responsible Official (please print)

05-25-2018

Date

May 24, 2018

Mr. Leonard Scandura
Manager of Permit Services
San Joaquin Valley Unified APCD
34946 Flyover Court
Bakersfield, CA 93308

Subject: Steam Generator - Compliance Certification – EB24, EB25 & EB26

Dear Mr. Scandura:

I hereby certify that all major Stationary Sources owned or operated by such person (or by any entity controlling, controlled by, or under common control with such person) in California, which are subject to emission limitations, are in compliance or on a schedule for compliance with all applicable emission limitations and standards.


Alternative siting analysis is required for any project, which constitutes a New Major Source or a Federal Major Modification.

The current project occurs at existing facilities. The applicant proposes to operate a steam generator to thermally enhance existing wells at the site.

Since the project will provide thermal enhancement to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.



Signature



Title

Attachment IX Draft ATCs

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-1624-328-0

LEGAL OWNER OR OPERATOR: E&B NATURAL RESOURCES MGMT
MAILING ADDRESS: ATTN: SHAMS HASAN
3000 JAMES ROAD
BAKERSFIELD, CA 93308

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: SW33 TOWNSHIP: T27S RANGE: R27E

EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB24 - CONOCO LEASE)

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Permit S-1624-70 shall be canceled upon implementation of this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOx emission reduction credits for the following quantity of emissions: 1st quarter - 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,732 lb, and fourth quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

DRAFT

Arnaud Marjolle, Director of Permit Services

S-1624-328-0 Jun 18 2018 8:21AM - EDGEMLR : Joint Inspection NOT Required

5. ERC Certificate Number S-4334-2 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 977 lb, 2nd quarter - 977 lb, 3rd quarter - 977 lb, and fourth quarter - 978 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. SOx ERCs may be used to offset PM10 at an interpollutant ratio of 1:1. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOx emission reduction credits for the following quantity of emissions: 1st quarter - 105 lb, 2nd quarter - 106 lb, 3rd quarter - 106 lb, and fourth quarter - 106 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
8. ERC Certificate Number S-4758-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
10. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
11. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
12. Particulate matter emissions shall not exceed 0.1 grain/dscf at operating conditions, nor 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following: NO_x (as NO_x): 5 ppmvd @ 3% O₂ or 0.0062 lb/MMBtu; SO_x: 0.00285 lb/MMBtu; PM₁₀: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O₂ or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
16. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
17. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities - EPA Method 2; Stack gas moisture content - EPA Method 4; SO_x - EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content - EPA Method 11 or 15; and fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2201, 4305, 4306, 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. If the NO_x or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the applicable emission limit, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NO_x, CO, and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the PTO, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

29. Shorter time periods for demonstration of compliance after startup or re-ignition may be approved by the APCO by submittal of appropriate technical justification upon implementation of this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
30. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
32. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
33. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320 and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-1624-329-0

LEGAL OWNER OR OPERATOR: E&B NATURAL RESOURCES MGMT
MAILING ADDRESS: ATTN: SHAMS HASAN
3000 JAMES ROAD
BAKERSFIELD, CA 93308

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: SW33 TOWNSHIP: T27S RANGE: R27E

EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB25 - CONOCO LEASE)

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Permit S-1624-70 shall be canceled upon implementation of this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOx emission reduction credits for the following quantity of emissions: 1st quarter - 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,732 lb, and fourth quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

DRAFT

Arnaud Marjolle, Director of Permit Services

S-1624-329-0 - Jun 10 2016 8:21AM - EDGEHLR - Joint Inspection NOT Required

5. ERC Certificate Number S-4334-2 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 977 lb, 2nd quarter - 977 lb, 3rd quarter - 977 lb, and fourth quarter - 978 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. SOx ERCs may be used to offset PM10 at an interpollutant ratio of 1:1. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOx emission reduction credits for the following quantity of emissions: 1st quarter - 105 lb, 2nd quarter - 106 lb, 3rd quarter - 106 lb, and fourth quarter - 106 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
8. ERC Certificate Number S-4758-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
10. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
11. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
12. Particulate matter emissions shall not exceed 0.1 grain/dscf at operating conditions, nor 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following: NOx (as NOx): 5 ppmvd @ 3% O2 or 0.0062 lb/MMBtu; SOx: 0.00285 lb/MMBtu; PM10: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O2 or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
16. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
17. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities - EPA Method 2; Stack gas moisture content - EPA Method 4; SO_x - EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content - EPA Method 11 or 15; and fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2201, 4305, 4306, 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. If the NO_x or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the applicable emission limit, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NO_x, CO, and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the PTO, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT
CONDITIONS CONTINUE ON NEXT PAGE

29. Shorter time periods for demonstration of compliance after startup or re-ignition may be approved by the APCO by submittal of appropriate technical justification upon implementation of this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
30. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
32. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
33. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320 and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-1624-330-0

LEGAL OWNER OR OPERATOR: E&B NATURAL RESOURCES MGMT

MAILING ADDRESS: ATTN: SHAMS HASAN
3000 JAMES ROAD
BAKERSFIELD, CA 93308

LOCATION: HEAVY OIL CENTRAL
CA

SECTION: SW33 TOWNSHIP: T27S RANGE: R27E

EQUIPMENT DESCRIPTION:

85 MMBTU/HR NATURAL GAS/WASTE GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN LE-85 BURNER AND FLUE GAS RECIRCULATION (EB26 - CONOCO LEASE)

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Permit S-1624-70 shall be canceled upon implementation of this ATC. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOx emission reduction credits for the following quantity of emissions: 1st quarter - 1,731 lb, 2nd quarter - 1,731 lb, 3rd quarter - 1,732 lb, and fourth quarter - 1,732 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director, APCO

DRAFT

Arnaud Marjollet, Director of Permit Services

S-1624-330-0 Jun 18 2018 @ 2:14AM - EDGEHILL : Job: Inspection NOT Required

5. ERC Certificate Number S-4334-2 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 977 lb, 2nd quarter - 977 lb, 3rd quarter - 977 lb, and fourth quarter - 978 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. SOx ERCs may be used to offset PM10 at an interpollutant ratio of 1:1. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOx emission reduction credits for the following quantity of emissions: 1st quarter - 105 lb, 2nd quarter - 106 lb, 3rd quarter - 106 lb, and fourth quarter - 106 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
8. ERC Certificate Number S-4758-5 (or certificates split from these certificates) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
10. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
11. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
12. Particulate matter emissions shall not exceed 0.1 grain/dscf at operating conditions, nor 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
13. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
14. The unit shall only be fired on natural gas with a maximum sulfur content of 1.0 gr S/100 scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed any of the following: NO_x (as NO_x): 5 ppmvd @ 3% O₂ or 0.0062 lb/MMBtu; SO_x: 0.00285 lb/MMBtu; PM₁₀: 0.0035 lb/MMBtu; CO: 25 ppmvd @ 3% O₂ or 0.0185 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
16. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rule 4320] Federally Enforceable Through Title V Permit
17. A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities - EPA Method 2; Stack gas moisture content - EPA Method 4; SO_x - EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content - EPA Method 11 or 15; and fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2201, 4305, 4306, 4320] Federally Enforceable Through Title V Permit
22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
24. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. If the NO_x or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the applicable emission limit, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NO_x, CO, and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the PTO, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

29. Shorter time periods for demonstration of compliance after startup or re-ignition may be approved by the APCO by submittal of appropriate technical justification upon implementation of this AIC. [District Rule 2201] Federally Enforceable Through Title V Permit
30. PUC quality natural gas is any gaseous fuel where the sulfur content is no more than one-fourth (0.25) grain of hydrogen sulfide per one hundred (100) standard cubic feet, no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet, and at least 80% methane by volume. [District Rule 4320] Federally Enforceable Through Title V Permit
31. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
32. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, permittee shall demonstrate compliance at least annually. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
33. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain daily records of the type and quantity of fuel combusted by the steam generator. [District Rule 2201 and 40 CFR 60.48c (g)] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320 and 40 CFR 60.48c (i)] Federally Enforceable Through Title V Permit

DRAFT