

SEP 11 2018

Steve Shehadey  
Bar 20 Dairy Biogas LLC  
PO Box 1231  
Fresno, CA 93715

**Re: Notice of Preliminary Decision - Authority to Construct**  
**Facility Number: C-9169**  
**Project Number: C-1170986**

Dear Mr. Shehadey:

Enclosed for your review and comment is the District's analysis of Bar 20 Dairy Biogas LLC's application for an Authority to Construct for the installation of a covered anaerobic treatment lagoon with an associated digester gas collection system and two 1,412 bhp digester gas-fired IC engines powering electrical generators, at 24387 W Whitesbridge Ave, Kerman.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice period, the District intends to issue the Authority to Construct. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions regarding this matter, please contact Mr. John Yoshimura of Permit Services at (559) 230-5887.

Sincerely,



Arnaud Marjollet  
Director of Permit Services

AM:jy

Enclosures

cc: Tung Le, CARB (w/ enclosure) via email  
Neil Black, CalBioEnergy (w/ enclosure) via email  
Ross Buckenham, CalBioEnergy (w/ enclosure) via email

**Seyed Sadredin**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95358-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

Fresno Bee

Newspaper notice for publication in Fresno Bee and for posting on valleyair.org

---

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Bar 20 Dairy Biogas LLC for the installation of a covered anaerobic treatment lagoon with an associated digester gas collection system and two 1,412 bhp digester gas-fired IC engines powering electrical generators, at 24387 W Whitesbridge Ave, Kerman.

The analysis of the regulatory basis for this proposed action, Project # C-1170986, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by [DATE] to [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) or **ARNAUD MARJOLLET, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**AVISO DE UNA DECISIÓN PRELIMINAR  
PARA LA PROPUESTA EMISIÓN DE  
UNA AUTORIDAD PARA CONSTRUIR**

POR EL PRESENTE SE NOTIFICA que El Distrito Unificado para el Control de la Contaminación del Aire del Valle de San Joaquín (el Distrito del Aire) está solicitando comentarios públicos en la propuesta emisión de una Autoridad para Construir a Bar 20 Dairy Biogas LLC para la instalación de una laguna de tratamiento anaeróbico cubierta con un sistema de recolección de gas digester y dos motores de combustión interna de gas de 1,412 bhp apoderando generadores eléctricos, en 24387 W Whitesbridge Ave, Kerman.

El análisis de la base regulatoria para esta acción propuesta, Número del Proyecto # C-1170986, está disponible para la inspección pública en [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000. Comentarios por escrito acerca de este proyecto deben ser sometidos o con matasellos antes del <DATE> a [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) o a **ARNAUD MARJOLLET, DIRECTOR DEL DEPARTAMENTO DE PERMISOS, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Bar 20 Dairy Biogas LLC for the installation of a covered anaerobic treatment lagoon with an associated digester gas collection system and two 1,412 bhp digester gas-fired IC engines powering electrical generators, at 24387 W Whitesbridge Ave, Kerman.

The analysis of the regulatory basis for this proposed action, Project # C-1170986, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by [DATE] to [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) or **ARNAUD MARJOLLET, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

Fresno Bee

Newspaper notice for publication in Fresno Bee and for posting on valleyair.org

---

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Bar 20 Dairy Biogas LLC for the installation of a covered anaerobic treatment lagoon with an associated digester gas collection system and two 1,412 bhp digester gas-fired IC engines powering electrical generators, at 24387 W Whitesbridge Ave, Kerman.

The analysis of the regulatory basis for this proposed action, Project # C-1170986, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by [DATE] to [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) or **ARNAUD MARJOLLET, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**AVISO DE UNA DECISIÓN PRELIMINAR  
PARA LA PROPUESTA EMISIÓN DE  
UNA AUTORIDAD PARA CONSTRUIR**

POR EL PRESENTE SE NOTIFICA que El Distrito Unificado para el Control de la Contaminación del Aire del Valle de San Joaquín (el Distrito del Aire) está solicitando comentarios públicos en la propuesta emisión de una Autoridad para Construir a Bar 20 Dairy Biogas LLC para la instalación de una laguna de tratamiento anaeróbico cubierta con un sistema de recolección de gas digester y dos motores de combustión interna de gas de 1,412bhp apoderando generadores eléctricos, en 24387 W Whitesbridge Ave, Kerman.

El análisis de la base regulatoria para esta acción propuesta, Número del Proyecto # C-1170986, está disponible para la inspección pública en [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000. Comentarios por escrito acerca de este proyecto deben ser sometidos o con matasellos antes del <DATE> a [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) o a **ARNAUD MARJOLLET, DIRECTOR DEL DEPARTAMENTO DE PERMISOS, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

**NOTICE OF PRELIMINARY DECISION  
FOR THE PROPOSED ISSUANCE OF  
AN AUTHORITY TO CONSTRUCT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Unified Air Pollution Control District solicits public comment on the proposed issuance of Authority to Construct to Bar 20 Dairy Biogas LLC for the installation of a covered anaerobic treatment lagoon with an associated digester gas collection system and two 1,412 bhp digester gas-fired IC engines powering electrical generators, at 24387 W Whitesbridge Ave, Kerman.

The analysis of the regulatory basis for this proposed action, Project # C-1170986, is available for public inspection at [http://www.valleyair.org/notices/public\\_notices\\_idx.htm](http://www.valleyair.org/notices/public_notices_idx.htm) and at any District office. For additional information, please contact the District at (559) 230-6000. Written comments on this project must be sent or postmarked by [DATE] to [publicnotices@valleyair.org](mailto:publicnotices@valleyair.org) or **ARNAUD MARJOLLET, DIRECTOR OF PERMIT SERVICES, SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726.**

# San Joaquin Valley Air Pollution Control District

## Authority to Construct Application Review

Installation of Digester System and Two Digester Gas-Fired IC Engines with SCR

Facility Name:	Bar 20 Dairy Biogas LLC	Date:	May 31, 2018
Mailing Address:	PO Box 1231 Fresno, CA 93715	Engineer:	John Yoshimura
Contact Person:	Steve Shehadey	Lead Engineer:	Joven Refuerzo
Telephone:	(559) 266-5054		
E-Mail:	shehadeys@aol.com		
Application #s:	C-9169-1-0, '-2-0, and '-3-0		
Project #:	C-1170986		
Deemed Complete:	May 18, 2017		

---

### I. Proposal

Bar 20 Dairy Biogas LLC has requested Authority to Construct (ATC) permits to construct a new 36,000,000 gallon (equivalent to 570' x 505' x 21.5') covered below ground anaerobic treatment lagoon with an associated digester gas collection system (ATC C-9169-1-0) and install two 1,412 bhp digester gas-fired IC engines each powering a 1,000 kW electrical generator (ATCs C-9169-2-0 and '-3-0). The proposed anaerobic treatment lagoon will be equipped with a H<sub>2</sub>S removal system; each proposed engine will be equipped with a selective catalytic reduction (SCR) system with urea (ammonia) injection for emissions control. The new digester system and engines powering electrical generators will be constructed at Bar 20 Partners LTD (C-5203), in an area of the existing dairy east of the existing cow housing areas and south of the existing storage pond weeping wall. Bar 20 Partners LTD will send manure from the dairy to the anaerobic digester located on the dairy site. The digester system will produce renewable biogas that will be used to fuel the IC engine generator sets.

The following is a summary of some of the information provided by the applicant. The proposed digester system and IC engines at the site will be installed, operated, maintained, repaired, and replaced if necessary by Bar 20 Dairy Biogas LLC. The responsibility of the dairy (Bar 20 Partners LTD) will be limited to providing the manure feedstock and disposing of the effluent, which the dairy already must do for compliance with water quality regulations. Bar 20 Dairy Biogas LLC will not be involved at all in the dairy's primary activity, which is the production of milk. Bar 20 Dairy Biogas LLC will sell all of the electricity generated to the utility grid and will not provide any electricity directly to Bar 20 Partners LTD. Because the dairy and the proposed digester system and digester gas-fired IC engines powering electrical generators at the site will have different two-digit Standard Industrial Classification (SIC) codes (Industry Group 24: Dairy Farms for Bar 20 Partners LTD vs. Industry Group 49: Electric, Gas, And Sanitary Services for the IC engine generator sets), pursuant to Section 3.37 of District Rule 2201, the proposed digester system and digester gas-fired IC engine will not be part of the dairy agricultural stationary source. Therefore, Bar 20 Dairy Biogas LLC and Bar 20 Partners LTD are separate stationary sources and the proposed digester system and IC engines will be permitted as a non-agricultural stationary source.

## II. Applicable Rules

Rule 2201	New and Modified Stationary Source Review Rule (2/18/16)
Rule 2410	Prevention of Significant Deterioration (6/16/11)
Rule 2520	Federally Mandated Operating Permits (6/21/01)
Rule 4001	New Source Performance Standards (4/14/99)
Rule 4002	National Emission Standards for Hazardous Air Pollutants (5/20/04)
Rule 4101	Visible Emissions (2/17/05)
Rule 4102	Nuisance (12/17/92)
Rule 4201	Particulate Matter Concentration (12/17/92)
Rule 4701	Internal Combustion Engines – Phase 1 (8/21/03)
Rule 4702	Internal Combustion Engines (11/14/13)
Rule 4801	Sulfur Compounds (12/17/92)
CH&SC 41700	Health Risk Assessment
CH&SC 42301.6	School Notice
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)	
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines	

## III. Project Location

The facility is located at 24387 W Whitesbridge Ave in Kerman, CA. The equipment is not located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

## IV. Process Description

### C-9169-1-0 (Anaerobic Digester System)

An anaerobic digester is a sealed basin or tank that is designed to accelerate and control the decomposition of organic matter by microorganisms in the absence of oxygen. The process of anaerobic decomposition results in the conversion of organic compounds in the substrate into methane (CH<sub>4</sub>), carbon dioxide (CO<sub>2</sub>), and water rather than intermediate Volatile Organic Compounds (VOCs). The gas generated by this process is known as biogas, waste gas, or digester gas. In addition to methane and carbon dioxide, digester gas may also contain small amounts of Nitrogen (N<sub>2</sub>), Oxygen (O<sub>2</sub>), Hydrogen Sulfide (H<sub>2</sub>S), and Ammonia (NH<sub>3</sub>). Digester gas may also include trace amounts of various VOCs that remain from incomplete digestion of the volatile solids in the incoming substrate. Because digester gas is mostly composed of methane, the main component of natural gas, the gas produced in the digester can be cleaned to remove H<sub>2</sub>S and other impurities and used as fuel.

The proposed anaerobic digester system will be designed to process the manure generated by the cattle at Bar 20 Partners LTD dairy. The manure will be flushed from the cow housing areas at the dairy to a solid separation system (weeping wall) prior to the digester system. This pre-digester mechanical separation system will remove fibrous solids from the manure. After the separation system, the liquid manure will gravity flow into the proposed covered anaerobic lagoon digester. The liquid effluent from the covered lagoon digester will be pumped to the existing storage ponds at the dairy for use to irrigate and fertilize adjacent cropland.

The proposed digester system will consist of a covered anaerobic treatment lagoon digester. The covered anaerobic treatment lagoon digester will process the liquid fraction from the dairy manure solid separation system. The digester will have the following approximate dimensions: 570 ft long by 505 ft wide at the top, with an average depth of 21.5 ft, and a side slope (run/rise) of 2.0. The volume of the digester (not including freeboard) will be approximately 5,247,942 ft<sup>3</sup> (~36,000,000 gal). The digester will basically operate at ambient temperatures; however, the digester will utilize heat from the engines to warm the substrate to promote more efficient anaerobic digestion. The bottom and the walls of the new lagoon will be lined with a system of high-density polyethylene (HDPE) membranes and a gas collection system will be installed. The new lagoon will be fitted with HDPE covers. The gas collection system will consist of perforated piping under the HDPE covers at the perimeter of the covered lagoon.

The digester will utilize an air/oxygen injection system for removal of H<sub>2</sub>S from the digester gas. The continuous injection of controlled quantities of air under the digester cover increases the amount of oxygen in the space under the digester cover and in the surface layer of the digester liquid, which facilitates oxidation of sulfides in the digester gas and surface of the liquid to elemental sulfur and water. Injection of air/oxygen also promotes biological removal of H<sub>2</sub>S from the digester gas by facilitating the establishment of sulfur oxidizing microorganisms, such as Thiobacillus species, which have the ability to grow under various environmental conditions and oxidize H<sub>2</sub>S to elemental sulfur.

The digester gas will be captured by the covered the lagoon gas collection system and will be piped to the gas conditioning system for polishing to remove additional H<sub>2</sub>S and removal of moisture. The gas will then be sent to the engines for use as fuel to generate electricity for sale to the utility and to produce heat for the digester system. When the gas cannot be used in the engines, the digester gas will collect under the lagoon cover. As the gas collects under the lagoon cover, the pressure in the digesters will rise. In rare emergency situations when the gas cannot be combusted in the engines for an extended period, the pressure will cause the relief valves to open and release the digester gas, composed primarily of methane and carbon dioxide, into the atmosphere. As the pressure decreases, the gas relief valves will automatically close and normal operation will proceed.

The applicant has indicated that the biogas produced by the covered lagoon digesters will be composed of approximately 60-70% methane and 30-40% carbon dioxide. Because the proposed digester system will be able to store the biogas for extended periods under the covers of the lagoon digesters and the proposed engines at the Bar 20 Partners LTD dairy (Facility C-5203) on the dairy will have more than sufficient capacity to combust all of gas generated, no flare is being proposed for this digester installation at this facility.

#### C-9169-2-0 and -3-0 (IC Engines)

The applicant is proposing to install two 1,412 bhp Caterpillar model G3516 A+ lean-burn digester gas-fired IC engines. Each engine will be equipped with an SCR system and will power a 1,000 kW generator. The electricity generated by this operation will be sold to the utility grid. The engines will be permitted to operate up to 24 hr/day and 8,760 hr/year. The engines will be permitted to operate up to 24 hours per day and 120 hours per year during the commissioning period (the time allowed during initial startup of the engine to perform testing, adjustment, tuning, and calibration of the IC engine without full operation of the SCR system and/or oxidation catalyst) in the first year and up to 24 hours per day and 8,760 hours per year after the commissioning period.



## V. Equipment Listing

- C-9169-1-0: DIGESTER GAS OPERATION CONSISTING OF A 36,000,000 GALLON (EQUIVALENT TO 570'X505'X21.5') ANAEROBIC DIGESTER LAGOON WITH AN AIR/OXYGEN INJECTION SYSTEM FOR H<sub>2</sub>S CONTROL AND A GAS COLLECTION AND HANDLING SYSTEM SERVED BY A H<sub>2</sub>S SCRUBBER
- C-9169-2-0: 1,412 BHP CATERPILLAR MODEL G3516 A+ DIGESTER GAS-FIRED LEAN-BURN IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM POWERING AN ELECTRICAL GENERATOR
- C-9169-3-0: 1,412 BHP CATERPILLAR MODEL G3516 A+ DIGESTER GAS-FIRED LEAN-BURN IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM POWERING AN ELECTRICAL GENERATOR


## VI. Emission Control Technology Evaluation

### C-9169-1 (Anaerobic Digester System)

As described above, the covered anaerobic treatment digester lagoon will utilize an air/oxygen injection system for removal of H<sub>2</sub>S from the digester gas. The continuous injection of controlled quantities of air under the lagoon covers increases the amount of oxygen in the space under the digester covers and the surface layer of the liquid in the covered lagoon digester, which facilitates oxidation of sulfides in the digester gas and in the liquid surface to elemental sulfur and water. The sulfur dissolves in the liquid in the digester and can be removed from the digester system by deposition and filtration. Injection of air/oxygen also promotes biological removal of H<sub>2</sub>S from the digester gas by facilitating the establishment of sulfur oxidizing microorganisms, such as Thiobacillus species, which have the ability to grow under various environmental conditions and oxidize H<sub>2</sub>S to elemental sulfur and sulfates that can be removed from the digester system. Use of air/oxygen injection to remove H<sub>2</sub>S from digester gas has been shown to have higher effectiveness in covered lagoon digesters because the large areas under the lagoon covers facilitate contact with the digester gas and lagoon surface, which enables improved oxidation and biological reduction of sulfides.

For final polishing, the digester gas will be sent through an iron sponge H<sub>2</sub>S scrubber to remove H<sub>2</sub>S from the gas prior to combustion in the proposed engines.

An iron sponge scrubber is comprised of vessel(s) containing iron sponge, which consists of a hydrated form of iron oxide infused onto wood shavings. The wood shavings serve only as a carrier for the iron oxide powder. Iron oxide infused into the wood surface will not wash off or migrate with the gas. As the gas passes through the iron sponge material, the H<sub>2</sub>S is removed by the following chemical reaction producing black iron sulfide and water:



For the iron sponge to perform effectively, it must be maintained within a defined range of sufficient moisture content. This requirement is typically satisfied if the gas is saturated with water vapor, as is frequently the case with digester gas. If the iron sponge becomes dry, it can be re-wet and remain effective. The iron sponge reaction is not pressure sensitive.

Specially treated activated carbon can also be used to remove H<sub>2</sub>S from gas streams. H<sub>2</sub>S will be adsorbed as the gas flows through the activated carbon bed. Activated carbon has a large number of pores, which greatly increase the surface area for adsorption. Contaminants in the gas diffuse into these pores and are retained on the carbon surface due to both chemical and physical forces. Activated carbon used for the removal of H<sub>2</sub>S is usually treated with chemical bases to increase the holding capacity for H<sub>2</sub>S.

The proposed scrubber will consist of enclosed vessels filled with iron sponge and/or treated activated carbon. The digester gas will flow through the scrubber and then to a dryer and chiller to remove moisture. For continuous operation, there will be a secondary unit that will be brought online at specified times or when monitoring indicates that the primary unit is nearing saturation. Valves can be arranged so either bed can operate while the other is serviced. The useful life of the iron sponge and activated carbon vessels will vary depending on the inlet concentration of H<sub>2</sub>S, the flow rate, and the mass in the vessels. Before a scrubber is completely spent, it must be regenerated or replaced. Spent iron sponge or activated carbon vessels will be sent to a regeneration facility or to an appropriate disposal facility.

The proposed scrubber will be capable of reducing H<sub>2</sub>S concentrations in the digester gas to 40 ppmv or less. Reducing the H<sub>2</sub>S concentration in the gas will minimize SO<sub>x</sub> emissions from combustion and will also reduce the maintenance requirements for the engine and will protect catalysts from masking, plugging, and poisoning.

#### C-9169-2-0 and -3-0 (IC Engines)

The proposed engines will be equipped with:

- Turbocharger
- Aftercooler
- Air/Fuel Ratio or an O<sub>2</sub> Controller
- Lean Burn Technology
- Positive Crankcase Ventilation (PCV) or 90% efficient control device
- Selective Catalytic Reduction (SCR)

The turbocharger reduces the NO<sub>x</sub> emission rate from the engines by increasing the efficiency and promoting more complete burning of the fuel.

The aftercooler functions in conjunction with the turbocharger to reduce the inlet air temperature. By reducing the inlet air temperature, the peak combustion temperature is lowered, which reduces the formation of thermal NO<sub>x</sub>.

The fuel/air ratio controller (oxygen controller) is used to maintain the amount of oxygen in the exhaust stream to optimize engine operation and catalyst function.

Lean burn technology increases the volume of air in the combustion process and therefore increases the heat capacity of the mixture. This technology also incorporates improved swirl patterns to promote thorough air/fuel mixing. This in turn lowers the combustion temperature and reduces NO<sub>x</sub> formation.

The PCV system reduces crankcase VOC and PM<sub>10</sub> emissions by at least 90% over an uncontrolled crankcase vent.

A Selective Catalytic Reduction (SCR) system operates as an external control device where flue gases and a reagent, in this case urea, are passed through an appropriate catalyst. Urea, will be injected upstream of the catalyst where it is converted to ammonia. The ammonia is used to reduce NO<sub>x</sub>, over the catalyst bed, to form elemental nitrogen and other by-products. The use of a catalyst typically reduces the NO<sub>x</sub> emissions by up to 90%.

Additionally, prior to being combusted in the engine, the digester gas will be treated in a gas conditioning system to reduce the H<sub>2</sub>S such that the sulfur content will not exceed 40 ppmv as H<sub>2</sub>S.

## **VII. General Calculations**

### **A. Assumptions**

- PM emissions from the handling of separated solids for the digester system are considered negligible because of the high moisture content of separated manure solids.
- All emissions from the manure processed in the digester system will be allocated to the liquid manure handling system at Bar 20 Partners LTD because the manure for the digester system will be taken from the flush system at Bar 20 Partners LTD and the effluent from the digester system will be used by Bar 20 Partners LTD.
- The proposed digester system will reduce potential VOC emissions from manure generated by the cattle at Bar 20 Partners LTD dairy. Manure that is currently stored in five uncovered storage ponds will instead be placed in the enclosed digester vessel at the Bar 20 Dairy Biogas facility, thereby decreasing volatilization of compounds from the manure. In a digester, most VOCs present will be converted to methane (an exempt compound) and carbon dioxide further reducing the potential for VOC emissions. Because results of dairy digester analyses have indicated negligible to very low VOC content (less than 1% by weight), fugitive VOC emissions from the digester system are assumed to be negligible, consistent with District Policy SSP 2015. During operation, the digester gas will be directed to the engines where the gas will be combusted resulting in the oxidation of gaseous hydrocarbons into carbon dioxide and water. Therefore, VOC emissions from the digester system are considered negligible.
- Higher Heating Value (HHV) for Digester Gas: 700 Btu/scf (proposed by the applicant, based on 70% methane content, also used in other similar District projects)
- Typical EPA F-factor for digester gas: 9,100 dscf/MMBtu (Estimated based on previous source tests and District practice)
- MMBtu/hr to bhp conversion 392.75 bhp-hr/MMBtu (per AP-42, Appendix A)
- Average sulfur content of the scrubbed digester gas: 40 ppmv as H<sub>2</sub>S (per applicant)
- Molar Specific Volume = 379.5 scf/lb-mol (60°F)

- Molecular weights:  
NO<sub>x</sub> (as NO<sub>2</sub>) = 46 lb/lb-mol      CO = 28 lb/lb-mol      NH<sub>3</sub> = 17 lb/lb-mol  
VOC (as CH<sub>4</sub>) = 16 lb/lb-mol      SO<sub>x</sub> (as SO<sub>2</sub>) = 64.06 lb/lb-mol
- Efficiency of engine = 30% (District practice)
- A commissioning period to perform testing, adjustment, tuning, and calibration of the IC engines without full operation of the SCR systems will be allowed during initial startup of the engines. The duration of the commissioning period shall last no more than 120 hours of operation of the engine without the SCR system installed and operating at its maximum efficiency (proposed by the applicant)
- The engines will be allowed to operate up to 120 hours during the initial installation and testing period for commissioning purposes only during the first year of operation.
- During normal operation the engines will operate 24 hours/day and 8,760 hours per year (proposed by the applicant)
- Ammonia slip from SCR = 10 ppm (proposed by the applicant)

## **B. Emission Factors**

### C-9169-2-0 and '3-0 (IC Engines)

#### Emission Factors during the Commissioning Period:

The commissioning period precedes normal operation of a power plant. Activities conducted during the commissioning period typically include: checking all mechanical, electrical, and control systems for the units and related equipment; confirming the performance measures specified for the equipment; test firing the units; and tuning of the units and the generators. The early stages of commissioning are conducted prior to the installation of the emission control equipment to prevent its damage. In accordance with EPA's guidance, the commissioning period is considered the final phase of the construction process rather than initial startup of the equipment.<sup>1</sup> Therefore, other than quantifying emissions for New and Modified Source Review (NSR), source-specific emission limitations from applicable rules and regulations are generally not effective until completion of the commissioning period. Because emission control devices are not in place and functioning during commissioning, higher emission limits are required during this time.

---

<sup>1</sup> See US EPA Implementation Question and Answer Document for National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines and New Source Performance Standards for Stationary Compression Ignition and Spark Ignition Internal Combustion Engines, April 2, 2013, Question 39 (<http://www.epa.gov/ttn/atw/rice/20120717riceqaupdate.pdf>)

<b>Emission Factors for Digester Gas-Fired Engines (Commissioning Period)</b>			
<b>Pollutant</b>	<b>g/bhp-hr</b>	<b>ppmvd (@ 15%O<sub>2</sub>)</b>	<b>Source</b>
NO <sub>x</sub>	1.0	72 ppmvd	Proposed by Applicant and Engine/Catalyst Manufacturer
SO <sub>x</sub>	0.04	40 ppmvd in fuel gas	BACT Requirement/Mass Balance Equation on Following Page
PM <sub>10</sub>	0.10	--	Proposed by Applicant and Engine Catalyst Manufacturer
CO	4.85		Proposed by Applicant and Engine Catalyst Manufacturer
VOC	1.0		Proposed by Applicant and Engine/Catalyst Manufacturer
NH <sub>3</sub>	0.06	10 ppmvd	Proposed by the Applicant, See Conversion on the Following Page

Emission Factors during Normal Operation after the Commissioning Period:

The emission factors for NO<sub>x</sub>, CO, and VOC from the proposed engines during normal operation were proposed by the applicant and supported by information provided by the engines manufacturer. The emission factors for NO<sub>x</sub> and VOC were required as BACT. The emission factors for SO<sub>x</sub>, PM<sub>10</sub>, and ammonia slip during normal operation are the same as the emission factors presented above for during the commissioning period. The unit conversions (from ppmvd to g/bhp-hr) for the emission factors are also shown below.

<b>Emission Factors for Digester Gas-Fired Engines (Normal Operation)</b>			
<b>Pollutant</b>	<b>g/bhp-hr</b>	<b>ppmvd (@ 15%O<sub>2</sub>)</b>	<b>Source</b>
NO <sub>x</sub>	0.15	11 ppmvd	BACT Requirement; Proposed by Applicant
SO <sub>x</sub>	0.04	40 ppmvd in fuel gas	BACT Requirement
PM <sub>10</sub>	0.10	--	Proposed by Applicant
CO	0.65	78 ppmvd	Proposed by Applicant
VOC	0.10	21 ppmvd as CH <sub>4</sub>	BACT Requirement
NH <sub>3</sub>	0.06	10 ppmvd	Proposed by Applicant

NO<sub>x</sub> – 0.15 g/bhp-hr as proposed by the applicant

$$0.15 \frac{\text{g NO}_x}{\text{bhp-hr}} \times \frac{1 \text{ lb}}{453.59 \text{ g}} \times \frac{1 \text{ hp-hr}}{2,545 \text{ Btu}} \times \frac{0.33 \text{ Btu}_{\text{out}}}{1 \text{ Btu}_{\text{in}}} \times \frac{10^6 \text{ Btu}}{1 \text{ MMBtu}} = 0.0429 \frac{\text{lb NO}_x}{\text{MMBtu}}$$

$$0.0429 \frac{\text{lb NO}_x}{\text{MMBtu}} \times \frac{(20.9 - 15)\% \text{ O}_2}{20.9\% \text{ O}_2} \times \frac{1 \text{ MMBtu}}{9,100 \text{ ft}^3} \times \frac{379.5 \text{ ft}^3}{\text{lb-mole}} \times \frac{\text{lb-mole}}{46 \text{ lb NO}_x} \times \frac{10^6 \text{ ppmvd}}{1} = 11.0 \text{ ppmvd NO}_x \text{ @ } 15\% \text{ O}_2$$

SO<sub>x</sub> – 40 ppmvd H<sub>2</sub>S @ 15% O<sub>2</sub> in fuel gas

$$\frac{40 \text{ ft}^3 \text{ H}_2\text{S}}{10^6 \text{ ft}^3} \times \frac{32.06 \text{ lb S}}{\text{lb-mol H}_2\text{S}} \times \frac{\text{lb-mole}}{379.5 \text{ ft}^3} \times \frac{64.06 \text{ lb SO}_2}{32.06 \text{ lb S}} \times \frac{\text{ft}^3}{700 \text{ Btu}} \times \frac{10^6 \text{ Btu}}{\text{MMBtu}} = 0.00965 \frac{\text{lb SO}_x}{\text{MMBtu}}$$

$$0.00965 \frac{\text{lb SO}_x}{\text{MMBtu}} \times \frac{\text{MMBtu}}{392.75 \text{ bhp-hr}} \times \frac{\text{Btu}_{\text{in}}}{0.30 \text{ Btu}_{\text{out}}} \times \frac{453.59 \text{ g}}{\text{lb}} = 0.04 \frac{\text{g-SO}_x}{\text{bhp-hr}}$$

CO – 0.65 g/bhp-hr as proposed by the applicant

$$0.65 \frac{\text{g CO}}{\text{bhp-hr}} \times \frac{1\text{ lb}}{453.59\text{ g}} \times \frac{1\text{ hp-hr}}{2,545\text{ Btu}} \times \frac{0.33\text{ Btu}_{\text{out}}}{1\text{ Btu}_{\text{in}}} \times \frac{10^6\text{ Btu}}{1\text{ MMBtu}} = 0.185 \frac{\text{lb CO}}{\text{MMBtu}}$$

$$0.185 \frac{\text{lb CO}}{\text{MMBtu}} \times \frac{(20.9 - 15)\% \text{ O}_2}{20.9\% \text{ O}_2} \times \frac{1\text{ MMBtu}}{9,100\text{ ft}^3} \times \frac{379.5\text{ ft}^3}{\text{lb-mole}} \times \frac{\text{lb-mole}}{28\text{ lb CO}} \times \frac{10^6\text{ ppmv}}{1} = 78\text{ ppmvd CO @ 15\% O}_2$$

VOC – 0.10 g/bhp-hr

$$0.10 \frac{\text{g VOC}}{\text{bhp-hr}} \times \frac{1\text{ lb}}{453.59\text{ g}} \times \frac{1\text{ hp-hr}}{2,545\text{ Btu}} \times \frac{0.33\text{ Btu}_{\text{out}}}{1\text{ Btu}_{\text{in}}} \times \frac{10^6\text{ Btu}}{1\text{ MMBtu}} = 0.0286 \frac{\text{lb VOC}}{\text{MMBtu}}$$

$$0.0286 \frac{\text{lb VOC}}{\text{MMBtu}} \times \frac{(20.9 - 15)\% \text{ O}_2}{20.9\% \text{ O}_2} \times \frac{1\text{ MMBtu}}{9,100\text{ ft}^3} \times \frac{379.5\text{ ft}^3}{\text{lb-mole}} \times \frac{\text{lb-mole}}{16\text{ lb VOC}} \times \frac{10^6\text{ ppmv}}{1} = 21\text{ ppmvd VOC @ 15\% O}_2$$

NH<sub>3</sub> – 10 ppmvd @ 15% O<sub>2</sub> as proposed by the Applicant

$$\frac{10\text{ ft}^3 \text{ NH}_3}{10^6\text{ ft}^3} \times \frac{9,100\text{ ft}^3}{\text{MMBtu}} \times \frac{17\text{ lb NH}_3}{\text{lb-mole}} \times \frac{20.9}{20.9 - 15} \times \frac{1\text{ lb-mole}}{379.5\text{ ft}^3} \times \frac{\text{MMBtu}}{392.75\text{ bhp-hr}} \times \frac{453.6\text{ g}}{\text{lb}} \times \frac{\text{Btu}_{\text{in}}}{0.30\text{ Btu}_{\text{out}}} = 0.06 \frac{\text{g-NH}_3}{\text{bhp-hr}}$$

**C. Calculations**

**1. Pre-Project Potential to Emit (PE1)**

Since these are new emissions units, PE1 = 0 for all pollutants.

**2. Post Project Potential to Emit (PE2)**

**C-9169-1-0 (Anaerobic Digester System)**

As explained above, the digester system will be composed of a sealed lagoon that will reduce VOC emissions from the manure and will have negligible fugitive emissions; therefore, VOC emissions from the manure will only be attributed to Bar 20 Partners LTD dairy for manure prior to entering the digester system and when returned to Bar 20 Partners LTD dairy and emissions from the digester system are considered negligible.

**C-9169-2-0 and '3-0 (Digester Gas-Fired Engines)**

Daily PE2 for Each Engine during the Commissioning Period

Daily PE during the commissioning period for each of the proposed engines is calculated in the table below:

$$\text{PE2 (lb/day)} = [\text{EF (g/bhp-hr)} \times \text{Rating (bhp)} \times 24 \text{ (hr/day)}] / 453.6 \text{ (g/lb)}$$

Daily PE During the Commissioning Period (C-9169-2-0 and '-3-0)								
NO <sub>x</sub>	1.0	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>74.7</b> (lb/day)
SO <sub>x</sub>	0.04	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>3.0</b> (lb/day)
PM <sub>10</sub>	0.1	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>7.5</b> (lb/day)
CO	4.85	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>362.3</b> (lb/day)
VOC	1.0	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>74.7</b> (lb/day)
NH <sub>3</sub>	0.06	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>4.5</b> (lb/day)

Daily PE2 for the Engines after Completion of the Commissioning Period:

Daily PE for each of the proposed engines after completion of the commissioning periods is calculated in the table below:

$$PE2 \text{ (lb/day)} = [EF \text{ (g/bhp-hr)} \times \text{Rating (bhp)} \times 24 \text{ (hr/day)}] / 453.6 \text{ (g/lb)}$$

Daily PE After the Commissioning Period (Normal Operation) (C-9169-2-0 and '-3-0)								
NO <sub>x</sub>	0.15	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>11.2</b> (lb/day)
SO <sub>x</sub>	0.04	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>3.0</b> (lb/day)
PM <sub>10</sub>	0.10	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>7.5</b> (lb/day)
CO	0.65	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>48.6</b> (lb/day)
VOC	0.10	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>7.5</b> (lb/day)
NH <sub>3</sub>	0.06	(g/bhp-hr) x	1,412	(bhp) x	24	(hr/day) ÷	453.59 (g/lb) =	<b>4.5</b> (lb/day)

Maximum Annual PE2 for Each Engine Including the Commissioning Periods

As discussed above, the proposed engine will be allowed to operate up to 120 hours for commissioning during the first year of operation. The maximum annual PE for the engine will be calculated based on the maximum hours of operation during the commissioning period and the remaining hours during normal operation.

Annual PE2 During the Commissioning Period (C-9169-2-0 and '-3-0)								
NO <sub>x</sub>	1.0	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>374</b> (lb/yr)
SO <sub>x</sub>	0.04	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>15</b> (lb/yr)
PM <sub>10</sub>	0.1	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>37</b> (lb/yr)
CO	4.85	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>1,812</b> (lb/yr)
VOC	1.0	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>374</b> (lb/yr)
NH <sub>3</sub>	0.06	(g/bhp-hr) x	1,412	(bhp) x	120	(hr) ÷	453.59 (g/lb) =	<b>22</b> (lb/yr)

Annual PE2 After the Commissioning Period (Normal Operation) (C-9169-2-0 and '-3-0)								
NO <sub>x</sub>	0.15	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>4,034</b> (lb/yr)
SO <sub>x</sub>	0.04	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>1,076</b> (lb/yr)
PM <sub>10</sub>	0.10	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>2,690</b> (lb/yr)
CO	0.65	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>17,482</b> (lb/yr)
VOC	0.10	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>2,690</b> (lb/yr)
NH <sub>3</sub>	0.06	(g/bhp-hr) x	1,412	(bhp) x	8,640	(hr) ÷	453.59 (g/lb) =	<b>1,614</b> (lb/yr)

**Maximum Daily and Annual PE2 during First Year, Including Commissioning**

Maximum Post-Project Daily and Annual PE2				
Pollutant	Daily (lb/day)	During Commissioning (lb/year)	After Commissioning (lb/year)	Total (lb/year)
NO <sub>x</sub>	74.7	374	4,034	4,408
SO <sub>x</sub>	3.0	15	1,076	1,091
PM <sub>10</sub>	7.5	37	2,690	2,727
CO	362.3	1,812	17,482	19,294
VOC	74.7	374	2,690	3,064
NH <sub>3</sub>	4.5	22	1,614	1,636

**Annual PE2 for the Engines after Commissioning**

The annual PE2 for the engine following the commissioning period is calculated as follows:

Annual PE2 After Year 1 with no Commissioning (Normal Operation)									
NO <sub>x</sub>	0.15	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	4,090	(lb/yr)
SO <sub>x</sub>	0.04	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	1,091	(lb/yr)
PM <sub>10</sub>	0.10	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	2,727	(lb/yr)
CO	0.65	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	17,725	(lb/yr)
VOC	0.10	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	2,727	(lb/yr)
NH <sub>3</sub>	0.06	(g/bhp·hr) x	1,412	(bhp) x	8,760	(hr) ÷	453.59 (g/lb) =	1,636	(lb/yr)

**3. Pre-Project Stationary Source Potential to Emit (SSPE1)**

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

Since this is a new facility, there are no valid ATCs, PTOs, or ERCs at the Stationary Source; therefore, the SSPE1 is equal to zero.

**4. Post Project Stationary Source Potential to Emit (SSPE2)**

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site. Since the operation, including commissioning, is higher than normal operation emissions, it will be used for NSR purposes.



Post-Project Stationary Source Potential to Emit [SSPE2] (lb/year)						
	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC	NH <sub>3</sub>
C-9169-1-0	0	0	0	0	0	0
C-9169-2-0	4,408	1,091	2,727	19,294	3,064	1,636
C-9169-3-0	4,408	1,091	2,727	19,294	3,064	1,636
<b>Post-Project SSPE (SSPE2)</b>	<b>8,816</b>	<b>2,182</b>	<b>5,454</b>	<b>38,588</b>	<b>6,128</b>	<b>3,272</b>

## 5. Major Source Determination

### Rule 2201 Major Source Determination

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)						
	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	PM <sub>2.5</sub>	CO	VOC
SSPE1	0	0	0	0	0	0
SSPE2	8,816	2,182	5,454	5,454	38,588	6,128
Major Source Threshold	20,000	140,000	140,000	140,000	200,000	20,000
Major Source?	No	No	No	No	No	No

Note: PM<sub>2.5</sub> assumed to be equal to PM<sub>10</sub>

As seen in the table above, the facility is not an existing Major Source and is not becoming a Major Source as a result of this project.

### Rule 2410 Major Source Determination

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination (tons/year)						
	NO <sub>2</sub>	VOC	SO <sub>2</sub>	CO	PM	PM <sub>10</sub>
Estimated Facility PE before Project Increase	0	0	0	0	0	0
PSD Major Source Thresholds	250	250	250	250	250	250
PSD Major Source ?	N	N	N	N	N	N

As shown above, the facility is not an existing PSD major source for any regulated NSR pollutant expected to be emitted at this facility.

## 6. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Pursuant to District Rule 2201, BE = PE1 for:

- Any unit located at a non-Major Source,
- Any Highly-Utilized Emissions Unit, located at a Major Source,
- Any Fully-Offset Emissions Unit, located at a Major Source, or
- Any Clean Emissions Unit, located at a Major Source.

otherwise,

BE = Historic Actual Emissions (HAE), calculated pursuant to District Rule 2201.

As shown in Section VII.C.5 above, the facility is not a Major Source for any pollutant.

Therefore BE = PE1.

Since these are new emissions units, BE = PE1 = 0 for all pollutants.

### **7. SB 288 Major Modification**

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is not a Major Source for any of the pollutants addressed in this project, this project does not constitute an SB 288 major modification.

### **8. Federal Major Modification**

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

Since this facility is not a Major Source for any pollutants, this project does not constitute a Federal Major Modification.

### **9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination**

Rule 2410 applies to any pollutant regulated under the Clean Air Act, except those for which the District has been classified nonattainment. The pollutants which must be addressed in the PSD applicability determination for sources located in the SJV and which are emitted in this project are: (See 52.21 (b) (23) definition of significant)

- NO<sub>2</sub> (as a primary pollutant)
- SO<sub>2</sub> (as a primary pollutant)
- CO
- PM
- PM<sub>10</sub>

- Hydrogen sulfide (H<sub>2</sub>S)<sup>2</sup>
- Total reduced sulfur (including H<sub>2</sub>S)<sup>2</sup>

### I. Project Emissions Increase - New Major Source Determination

The post-project potentials to emit from all new and modified units are compared to the PSD major source thresholds to determine if the project constitutes a new major source subject to PSD requirements.

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(i). The PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination: Potential to Emit (tons/year)						
	NO <sub>2</sub>	VOC	SO <sub>2</sub>	CO	PM	PM <sub>10</sub>
Total PE from New and Modified Units	4.4	3.1	1.1	19.3	2.7	2.7
PSD Major Source threshold	250	250	250	250	250	250
New PSD Major Source?	N	N	N	N	N	N

As shown in the table above, the potential to emit for the project, by itself, does not exceed any PSD major source threshold. Therefore Rule 2410 is not applicable and no further analysis is required.

### 10. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. Detailed QNEC calculations are included in Appendix E.

## VIII. Compliance Determination

### Rule 2201 New and Modified Stationary Source Review Rule

#### A. Best Available Control Technology (BACT)

##### 1. BACT Applicability

BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions\*:

- Any new emissions unit with a potential to emit exceeding two pounds per day,

<sup>2</sup> Because the facility is not included in the specific source categories listed in 40 CFR 51.165, for PSD purposes only non-fugitive emissions from the engine exhaust stack must be addressed for this project. Although the sulfur (primarily H<sub>2</sub>S) in the fuel will be converted almost entirely to SO<sub>x</sub> during combustion, the maximum possible amount of H<sub>2</sub>S and total reduced sulfur compounds from the engine stack can be calculated by assuming that all sulfur in the fuel is emitted as H<sub>2</sub>S. Based on the fuel sulfur limit of 40 ppmv as H<sub>2</sub>S, the maximum possible H<sub>2</sub>S emission factor for the engine is calculated to be 0.04 g-H<sub>2</sub>S/bhp, resulting in a total maximum of 0.55 tpy H<sub>2</sub>S from the exhaust stack of the engine. This is well below the applicable PSD threshold of 250 tpy.

- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an AIPE exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

\*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

**a. New emissions units – PE > 2 lb/day**

**C-9169-1-0 (Anaerobic Digester System)**

As explained above, the digester system will consist of a sealed lagoon that will reduce VOC emissions from the liquid manure at the dairy and emissions from the digester system are considered negligible. Therefore, BACT for new units with PE > 2 lb/day purposes is not required for the digester system.

**C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)**

As seen in Section VII.C.2 above, the proposed engines will have a PE greater than 2.0 lb/day for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, CO, and VOC. Therefore, BACT is triggered for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, and VOC. However, BACT is not triggered for CO since the SSPE2 for CO is not greater than 200,000 lbs/year, as demonstrated in Section VII.C.5 of this document.

**b. Relocation of emissions units – PE > 2 lb/day**

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore, BACT is not triggered for relocation of an emissions unit.

**c. Modification of emissions units – AIPE > 2 lb/day**

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore, BACT is not triggered for a modification of a unit.

**d. SB 288/Federal Major Modification**

As discussed in Sections VII.C.7 and VII.C.8 above, this project does not constitute an SB 288 and/or Federal Major Modification. Therefore BACT is not triggered for Major Modification purposes.

**2. BACT Guideline**

**C-9169-2-0 and '-2-0 (Digester Gas-Fired IC Engines)**

BACT Guideline 3.3.15, applies to the proposed digester gas-fired IC engines. [Waste Gas-Fired IC Engines] (See Appendix B)

### 3. Top-Down BACT Analysis

Per Permit Services Policies and Procedures for BACT, a Top-Down BACT analysis shall be performed as a part of the application review for each application subject to the BACT requirements pursuant to the District's NSR Rule.

Pursuant to the Top-Down BACT Analysis (See Appendix C), BACT has been satisfied with the following:

- NO<sub>x</sub>: NO<sub>x</sub> emissions ≤ 0.15 g/bhp-hr
- SO<sub>x</sub>: Fuel sulfur content ≤ 40 ppmv (as H<sub>2</sub>S)
- PM<sub>10</sub>: Fuel sulfur content ≤ 40 ppmv (as H<sub>2</sub>S)
- VOC: VOC emissions ≤ 0.10 g/bhp-hr

The following conditions will be placed on the ATCs to ensure compliance with the BACT requirements during normal operation:

- This engine shall be fired on digester gas fuel only. [District Rule 2201]
- After the commissioning period, emissions from this IC engine shall not exceed any of the following limits: 0.15 g-NO<sub>x</sub>/bhp-hr (equivalent to 11 ppmvd NO<sub>x</sub> @ 15% O<sub>2</sub>), NO<sub>x</sub> referenced as NO<sub>2</sub>; 0.10 g-PM<sub>10</sub>/bhp-hr; 0.65 g-CO/bhp-hr (equivalent to 210 ppmvd CO @ 15% O<sub>2</sub>); or 0.10 g-VOC/bhp-hr (equivalent to 21 ppmvd VOC @ 15% O<sub>2</sub>), VOC referenced as CH<sub>4</sub>. [District Rules 2201 and 4702]
- The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]

## B. Offsets

### 1. Offset Applicability

Offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals to or exceeds the offset threshold levels in Table 4-1 of Rule 2201.

The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO <sub>x</sub>	SO <sub>x</sub>	PM <sub>10</sub>	CO	VOC
SSPE2	8,816	2,182	5,454	38,588	6,128
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets triggered?	No	No	No	No	No

### 2. Quantity of Offsets Required

As seen above, the SSPE2 is not greater than the offset thresholds for all the pollutants; therefore offset calculations are not necessary and offsets will not be required for this project.

## C. Public Notification

### 1. Applicability

Public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed,
- d. Any project with an SSPE of greater than 20,000 lb/year for any pollutant, and/or
- e. Any project which results in a Title V significant permit modification

#### a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications

New Major Sources are new facilities, which are also Major Sources. As shown in Section VII.C.5 above, the SSPE2 is not greater than the Major Source threshold for any pollutant. Therefore, public noticing is not required for this project for new Major Source purposes.

As demonstrated in Sections VII.C.7 and VII.C.8, this project does not constitute an SB 288 or Federal Major Modification; therefore, public noticing for SB 288 or Federal Major Modification purposes is not required.

#### b. PE > 100 lb/day

The PE2 for these new units are compared to the daily PE Public Notice thresholds in the following table:

<b>PE &gt; 100 lb/day Public Notice Thresholds</b>			
<b>Pollutant</b>	<b>PE2 (lb/day)</b>	<b>Public Notice Threshold</b>	<b>Public Notice Triggered?</b>
NO <sub>x</sub>	74.7	100 lb/day	No
SO <sub>x</sub>	3.0	100 lb/day	No
PM <sub>10</sub>	7.5	100 lb/day	No
CO	362.3	100 lb/day	Yes
VOC	74.7	100 lb/day	No
NH <sub>3</sub>	4.5	100 lb/day	No

Therefore, public noticing for PE > 100 lb/day purposes is required.

#### c. Offset Threshold

The SSPE1 and SSPE2 are compared to the offset thresholds in the following table.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO <sub>x</sub>	0	8,816	20,000 lb/year	No
SO <sub>x</sub>	0	2,182	54,750 lb/year	No
PM <sub>10</sub>	0	5,454	29,200 lb/year	No
CO	0	38,588	200,000 lb/year	No
VOC	0	6,128	20,000 lb/year	No

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

**d. SSIPE > 20,000 lb/year**

Public notification is required for any permitting action that results in a SSIPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSIPE = SSPE2 – SSPE1. The SSIPE is compared to the SSIPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE2 (lb/year)	SSPE1 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO <sub>x</sub>	8,816	0	8,816	20,000 lb/year	No
SO <sub>x</sub>	2,182	0	2,182	20,000 lb/year	No
PM <sub>10</sub>	5,454	0	5,454	20,000 lb/year	No
CO	38,588	0	38,588	20,000 lb/year	Yes
VOC	6,128	0	6,128	20,000 lb/year	No
NH <sub>3</sub>	3,272	0	3,272	20,000 lb/year	No

As demonstrated above, the SSIPE for CO was greater than 20,000 lb/year; therefore public noticing for SSIPE purposes is required.

**e. Title V Significant Permit Modification**

Since this facility does not have a Title V operating permit, this change is not a Title V significant Modification, and therefore public noticing is not required.

**2. Public Notice Action**

As discussed above, public noticing is required for this project for CO emissions in excess of 100 lb/day and an increase of over 20,000 lb/year. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be published in a local newspaper of general circulation prior to the issuance of the ATC for this equipment.

#### **D. Daily Emission Limits (DELs)**

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

##### **Proposed Rule 2201 (DEL) Conditions for the Digester System (C-9169-1-0)**

As stated above, the digester system will reduce emissions from the manure produced by cattle at Bar 20 LTD dairy. The following conditions will be placed on the ATC permit to ensure that fugitive emissions from the digester system will be negligible and that the air/oxygen injection system is operated to minimize H<sub>2</sub>S:

- All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants. [District Rule 2201]
- The digester system shall be designed to allow gas generated to be stored for more than 24 hours prior to venting in the event that the gas cannot be combusted in digester gas-fired engines or sent to another device with a VOC control efficiency of at least 95% by weight as determined by the APCO. [District Rule 2201]
- The air/oxygen injection system shall be maintained and operated in accordance with the supplier's recommendations to minimize the concentration of hydrogen sulfide (H<sub>2</sub>S) in the digester gas. [District Rule 2201]
- The VOC content of the digester gas produced by the digester system shall not exceed 10% by weight. [District Rule 2201]

##### **Proposed Rule 2201 (DEL) Conditions for the Digester Gas-Fired Engines (C-9169-2-0 and '3-0)**

###### **Proposed Rule 2201 (DEL) Conditions for Engines during both Commissioning and Normal Operation**

- This engine shall be fired on digester gas fuel only. [District Rule 2201]
- The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]
- This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 2201 and 4702]
- Ammonia (NH<sub>3</sub>) emissions from this engine shall not exceed 10 ppmvd @ 15% O<sub>2</sub>. [District Rules 2201 and 4102]
- All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants into the atmosphere. [District Rule 2201]

###### **Proposed Rule 2201 (DEL) Conditions during Commissioning Period**

For the proposed digester gas-fired IC engines, the DELs for NO<sub>x</sub>, SO<sub>x</sub>, PM<sub>10</sub>, CO, and VOC are stated in the form of maximum emission factors (g/bhp-hr), the maximum engine



horsepower rating (1,412 bhp), and maximum number of hours allowed for commissioning activities. The following conditions will be placed on the permit as a mechanism to ensure compliance.

- The owner/operator shall minimize the emissions from the engine to the maximum extent possible during the commissioning period. [District Rule 2201]
- Commissioning activities are defined as, but not limited to, all adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable operation of the reciprocating IC engine, emission control equipment, and associated electrical delivery systems. [District Rule 2201]
- Commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when the engine is first fired, whichever occurs first. The commissioning period shall terminate when the initial engine tuning has completed and the engine is available for commercial operation. The total duration of the commissioning period for this engine shall not exceed 120 hours of operation of the engine. [District Rule 2201]
- The total number of firing hours of this unit without abatement of emissions by the SCR system and oxidation catalyst shall not exceed 120 hours during the commissioning period. Such operation of this unit without abatement shall be limited to discrete commissioning activities that can only be properly executed without the SCR system or oxidation catalyst. Upon completion of these activities, the permittee shall provide written notice to the District and the unused balance of the 120 firing hours without abatement shall expire. [District Rule 2201]
- Emission rates from this engine unit during the commissioning period shall not exceed any of the following limits: 1.0 g-NO<sub>x</sub>/bhp-hr, 0.1 g-PM<sub>10</sub>/bhp-hr, 4.85 g-CO/bhp-hr, or 1.0 g-VOC/bhp-hr. [District Rule 2201]
- At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the engine shall be tuned to minimize emissions. [District Rule 2201]
- At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the Selective Catalytic Reduction (SCR) system and oxidation catalyst shall be installed, adjusted, and operated to minimize emissions from this unit. [District Rule 2201]
- The permittee shall submit a summary of activities to be performed during the commissioning period to the District at least two weeks prior to the first firing of this engine. The summary shall include a list of each commissioning activity, the anticipated duration of each activity in hours, and the purpose of the activity. The activities described shall include, but are not limited to, the tuning of the engine, the installation and operation of the SCR system, the installation, calibration, and testing of emissions monitors, and any activities requiring the firing of this unit without abatement by the SCR system. [District Rule 2201]

#### Proposed Rule 2201 (DEL) Conditions during Normal Operation

- After the commissioning period, emissions from this IC engine shall not exceed any of the following limits: 0.15 g-NO<sub>x</sub>/bhp-hr (equivalent to 11 ppmvd NO<sub>x</sub> @ 15% O<sub>2</sub>), NO<sub>x</sub> referenced as NO<sub>2</sub>; 0.10 g-PM<sub>10</sub>/bhp-hr; 0.65 g-CO/bhp-hr (equivalent to 210 ppmvd

CO @ 15% O<sub>2</sub>); or 0.10 g-VOC/bhp-hr (equivalent to 21 ppmvd VOC @ 15% O<sub>2</sub>), VOC referenced as CH<sub>4</sub>. [District Rules 2201 and 4702]

## E. Compliance Assurance

### 1. Source Testing

#### C-9169-1-0 (Anaerobic Digester System)

Pursuant to District Policy APR 1705, source testing of this unit is not required to demonstrate compliance with Rule 2201.

#### C-9169-2-0 and -3-0 (Digester Gas-Fired IC Engine)

In accordance with District Policy APR 1705, source testing for NO<sub>x</sub>, CO and VOC emissions from the digester gas fired IC engines served by a catalyst control system (including SCR and an oxidation catalyst) shall be conducted initially and at least once every 24 months thereafter. In addition, in order to assure compliance with the ammonia slip limit from the SCR system, source testing of the ammonia emissions will also be required initially and at least once every 24 months thereafter.

For PM<sub>10</sub> emissions, the applicant has proposed to use an emission factor from AP-42, Section 2.4, which is applicable to municipal solid waste landfills. The digester gas fired in these engines should have a similar makeup to that of gas generated by a landfill. However, in order to assure that the engines are able to demonstrate compliance with the proposed PM<sub>10</sub> emission factor, initial source testing will be required.

The engine is not served by any control devices for PM<sub>10</sub> emissions. Therefore, it is not expected that the PM<sub>10</sub> emissions will change much over time as long as the quality of the gas combusted in this unit remains fairly consistent. The facility will be required to monitor the sulfur content of the digester gas combusted in this unit at least once per quarter. The results of this quarterly monitoring should demonstrate that the quality of the gas combusted is consistent. Therefore, ongoing periodic source testing for PM<sub>10</sub> emissions will not be required.

The following conditions will be placed on the permits to ensure compliance:

- Source testing to measure NO<sub>x</sub>, CO, VOC, PM<sub>10</sub>, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted within 60 days upon end of the commissioning period. [District Rules 1081, 2201, and 4702]
- Source testing to measure NO<sub>x</sub>, CO, VOC, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]
- For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO<sub>x</sub>, CO, VOC, and NH<sub>3</sub> concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 2201 and 4702]
- The following methods shall be used for source testing: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100; CO (ppmv) - EPA Method 10 or ARB Method 100; VOC (ppmv) - EPA Method 18, 25A or 25B or ARB Method 100; stack gas oxygen - EPA

Method 3 or 3A or ARB Method 100; stack gas velocity - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; PM10 (filterable and condensable) - EPA Method 201 and 202, EPA Method 201a and 202, or ARB Method 5 in combination with 501; NH3 - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4702]

- {109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
- The results of each source test shall be submitted to the District within 60 days after completion of the source test. [District Rule 1081]
- The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO<sub>x</sub>, CO, and O<sub>2</sub> analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Emission Monitoring and Testing. [District Rule 1081]

## 2. Monitoring

### C-9169-1-0 (Anaerobic Digester System)

No monitoring of this unit is required to demonstrate compliance with Rule 2201.

### C-9169-2-0 and -3-0 (Digester Gas-Fired IC Engine)

The proposed digester gas-fired engines are subject to District Rule 4702 - Internal Combustion Engines. Section 5.8.1 of District Rule 4702 requires engines rated at least 1,000 bhp that can operate more than 2,000 hour per calendar year or equipped with external control devices to install, operate, and maintain an APCO-approved alternate monitoring plan. Section 5.8.9 of District Rule 4702 requires monitoring of NO<sub>x</sub> emissions at least once every calendar quarter for a non-agricultural spark-ignited IC engine. However, Section 6.5.3 of District Rule 4702 requires monthly monitoring for engines equipped with non-certified control devices in order to demonstrate compliance with the emission limits in District Rule 4702. Therefore, monthly monitoring of NO<sub>x</sub>, CO, and O<sub>2</sub> concentrations in accordance pre-approved alternate monitoring plan "A" will be required. Since the engine will be equipped with SCR, quarterly monitoring of ammonia slip will also be required. The following conditions will be placed on the permits to ensure compliance:

- The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if 2 consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly

monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]

- The permittee shall monitor and record the stack concentration of NH<sub>3</sub> at least once every calendar quarter in which a source test is not performed. NH<sub>3</sub> monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last quarter. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4102]
- If the NO<sub>x</sub>, CO, or NH<sub>3</sub> concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the allowable emission concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 2201 and 4702]
- {3787} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

In addition, Section 5.10.1 of District Rule 4702 requires an annual analysis of the sulfur content of engine fuel. Because of the variable content of digester gas, additional monitoring of the fuel sulfur content will be required. The following conditions will be placed on the permits to ensure compliance:

- Fuel sulfur content analysis shall be performed at least annually using EPA Method 11 or EPA Method 15, as appropriate. Records of the fuel sulfur content analysis shall be maintained and provided to the District upon request. [District Rules 2201 and 4702]
- The sulfur content of the digester gas used to fuel the engine shall be monitored and recorded at least once every calendar quarter in which a fuel sulfur analysis is not performed. If quarterly monitoring shows a violation of the fuel sulfur content limit of this permit, monthly monitoring will be required until six consecutive months of monitoring show compliance with the fuel sulfur content limit. Once compliance with the fuel sulfur content limit is shown for six consecutive months, then the monitoring

frequency may return to quarterly. Monitoring of the sulfur content of the digester gas fuel shall not be required if the engine does not operate during that period. Records of the results of monitoring of the digester gas fuel sulfur content shall be maintained. [District Rules 2201 and 4702]

- Monitoring of the digester gas sulfur content shall be performed using gas detection tubes calibrated for H<sub>2</sub>S; a digital analyzer approved for gaseous fuel analysis; a continuous fuel gas monitor that meets the requirements specified in SCAQMD Rule 431.1, Attachment A; District-approved source test methods, including EPA Method 15, ASTM Method D1072, D4084, and D5504; District-approved in-line H<sub>2</sub>S monitors; or an alternative method approved by the District. Prior to utilization of in-line monitors to demonstrate compliance with the digester gas sulfur content limit of this permit, the permittee shall submit details of the proposed monitoring system, including the make, model, and detection limits, to the District and obtain District approval for the proposed monitor(s). [District Rules 2201 and 4702]

### **3. Recordkeeping**

Recordkeeping is required to demonstrate compliance with the offset, public notification and daily emission limit requirements of Rule 2201. The following recordkeeping conditions will be listed on the permits:

#### C-9169-1-0 (Anaerobic Digester System)

- All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 1070 and 2201]

#### C-9169-2-0 and -3-0 (Digester Gas-Fired IC Engines)

- The SCR catalyst shall be maintained and replaced in accordance with the recommendations of the catalyst manufacturer or emission control supplier. Records of catalyst maintenance and replacement shall be maintained. [District Rules 2201 and 4702]
- Air-to-fuel ratio controller(s) shall be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times. [District Rule 2201]
- The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, O<sub>2</sub>, and NH<sub>3</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub>, CO, and NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, (5) the method of determining the NH<sub>3</sub> emission concentration, and (6) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 2201]
- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of fuel used during commissioning period(s), the type and quantity of fuel used during normal operation, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or

volumetric fuel flow meter or other APCO approved-device. [District Rules 2201 and 4702]

- Records of any analyzer(s) installed or utilized to monitor methane, oxygen, and hydrogen sulfide shall be maintained and shall be made available for District inspection upon request. [District Rule 2201]
- The permittee shall record total operating time of the engine in hours during the commissioning period. [District Rule 2201]
- {4051} The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
- All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 2201 and 4702]

#### **4. Reporting**

No reporting is required to demonstrate compliance with District Rule 2201.

#### **F. Ambient Air Quality Analysis (AAQA)**

An AAQA shall be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis. Refer to Appendix C of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO<sub>x</sub>, CO, and SO<sub>x</sub>. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO<sub>x</sub>, CO, or SO<sub>x</sub>.

The proposed location is in a non-attainment area for the state's PM<sub>10</sub> as well as federal and state PM<sub>2.5</sub> thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM<sub>10</sub> and PM<sub>2.5</sub>.

#### **Rule 2410 Prevention of Significant Deterioration**

As shown in Section VII.C.9 above, this project does not result in a new PSD major source or PSD major modification. No further discussion is required.

#### **Rule 2520 Federally Mandated Operating Permits**

Since this facility's potential emissions do not exceed any major source thresholds of Rule 2201, this facility is not a major source, and Rule 2520 does not apply.

#### **Rule 4001 New Source Performance Standards (NSPS)**

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR) and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60.

#### **40 CFR 60 Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines**

The purpose of 40 CFR 60 Subpart JJJJ is to establish New Source Performance Standards to reduce emissions of NO<sub>x</sub>, SO<sub>x</sub>, PM, CO, and VOC from new stationary spark ignition (SI) internal combustion (IC) engines.

Pursuant to Section 60.4230, compliance with this subpart is required for owners and operators of stationary SI IC engines that commence construction after June 12, 2006, where the stationary SI ICE are manufactured: (a) on or after July 1, 2007, for engines with a maximum engine power greater than or equal to 500 HP (except lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP); (b) on or after January 1, 2008, for lean burn engines with a maximum engine power greater than or equal to 500 HP and less than 1,350 HP; (c) on or after July 1, 2008, for engines with a maximum engine power less than 500 HP; or (d) on or after January 1, 2009, for emergency engines with a maximum engine power greater than 19 KW (25 HP).

The proposed engines (C-9169-2-0 and '-3-0) are 1,412 bhp SI ICE that will be constructed after June 12, 2006 and manufactured after July 1, 2007; therefore, the engines are subject to this subpart. However, the District has not been delegated the authority to implement 40 CFR 60, Subpart JJJJ for non-Major Sources; therefore, the requirements from this subpart will not be included in the permit. However, the applicant will be responsible for compliance with the applicable requirements of this regulation.

#### **Rule 4002 National Emission Standards for Hazardous Air Pollutants (NESHAPs)**

This rule incorporates NESHAPs from Part 63, Chapter 1, Title 40, Code of Federal Regulations (CFR) and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 63.

#### **40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)**

40 CFR 63 Subpart ZZZZ establishes national emission limitations and operating limitations for hazardous air pollutants (HAPs) emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. A major source of HAP emissions is a facility that has the potential to emit any single HAP at a rate of 10 tons/year or greater or any combinations of HAPs at a rate of 25 tons/year or greater. An area source of HAPs is a facility is not a major source of HAPs.

Pursuant to Section 63.6590(c), an affected source that is a new or reconstructed stationary Reciprocating Internal Combustion Engine (RICE) located at an area source must meet the requirements of 40 CFR 63, Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart IIII, for compression ignition engines or 40 CFR 60, Subpart JJJJ, for spark ignition engines and no further requirements apply for such engines under this part.

As with 40 CFR 60, Subpart JJJJ, the District has not been delegated the authority to implement 40 CFR 63, Subpart ZZZZ for non-Major Sources; therefore, no requirements from this subpart will be included in the permit. However, the applicant will be responsible for compliance with the applicable requirements of this regulation.

### Rule 4101 Visible Emissions

Rule 4101 states that no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 or 20% opacity.

The following condition will be listed on the permits to ensure compliance:

- {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]

### Rule 4102 Nuisance

Rule 4102 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

### California Health & Safety Code 41700 (Health Risk Assessment)

District Policy APR 1905 – *Risk Management Policy for Permitting New and Modified Sources* specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than one. According to the Technical Services Memo for this project (Appendix D), the total facility prioritization score including this project was greater than one. Therefore, an HRA was required to determine the short-term acute and long-term chronic exposure from this project. Since there is no emissions from the digester system, an HRA was not required for unit C-9169-1-0.

The cancer risk for this project is shown below:

HRA Summary		
Unit	Cancer Risk	T-BACT Required
C-9169-2-0	0.042 per million	No
C-9169-3-0	0.042 per million	No

### Discussion of T-BACT

BACT for toxic emission control (T-BACT) is required if the cancer risk exceeds one in one million. As demonstrated above, T-BACT is not required for this project because the HRA indicates that the risk is not above the District's thresholds for triggering T-BACT requirements; therefore, compliance with the District's Risk Management Policy is expected.

District policy APR 1905 also specifies that the increase in emissions associated with a proposed new source or modification not have acute or chronic indices, or a cancer risk



greater than the District's significance levels (i.e. acute and/or chronic indices greater than 1 and a cancer risk greater than 20 in a million). As outlined by the HRA Summary in Appendix D of this report, the emissions increases for this project was determined to be less than significant. The following condition will be listed on the permits as a mechanism to ensure compliance with this requirement.

C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)

- The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]

**Rule 4201 Particulate Matter Concentration**

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)

$$0.031 \frac{g}{hp \cdot hr} \times \frac{1hp \cdot hr}{2,545Btu} \times \frac{10^6 Btu}{9,100dscf} \times \frac{0.33Btu_{out}}{1Btu_{in}} \times \frac{15.43grain}{g} = 0.007 \frac{grain}{dscf}$$

Since 0.007 grain/dscf is less than 0.1 grain/dscf, compliance with this rule is expected. The following condition will be listed on the proposed ATC permits to ensure compliance:

- {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]

**Rule 4701 Internal Combustion Engines – Phase I**

C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)

The purpose of this rule is to limit the emissions of nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), and volatile organic compounds (VOC) from internal combustion (IC) engines.

The requirements of Rule 4702 are equivalent or more stringent than the requirements of this Rule. Since the proposed IC engines are subject to both Rules 4701 and 4702, compliance with Rule 4702 is sufficient to demonstrate compliance with this rule.

**Rule 4702 Internal Combustion Engines**

C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)

The purpose of this rule is to limit the emissions of nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compounds (VOC), and sulfur oxides (SO<sub>x</sub>) from IC engines.

This rule applies to any internal combustion engine with a rated brake horsepower of 25 brake horsepower or greater.

Section 5.2.1 requires that the operator of a spark-ignited non-agricultural internal combustion engine rated > 50 bhp shall not operate it in such a manner that results in emissions exceeding the limits in Table 1 of Rule 4702 until such time that the engine has demonstrated compliance with emission limits in Table 2 of Rule 4702 pursuant to the compliance deadlines in Section

7.5. In lieu of complying with Table 1 emission limits, the operator of a spark-ignited engine shall comply with the applicable emission limits pursuant to Section 8.0.

The proposed new engines are required to immediately comply with the emission limits contained in Table 2 since the applicable compliance dates have passed (except for an operator with at least 12 existing engines at one stationary source); therefore, the emissions limits in Table 1 of Rule 4702 are not applicable to the proposed engines.

Section 5.2.2 requires that on and after the compliance schedule specified in Section 7.5, the operator of a spark-ignited non-agricultural internal combustion engine rated > 50 bhp shall comply with all the applicable requirements of the rule and the requirements of Section 5.2.2.1, 5.2.2.2, or 5.2.2.3, on an engine-by-engine basis.

Section 5.2.2.1 requires that on and after the compliance schedule specified in Section 7.5, the operator of a spark-ignited engine that is used exclusively in non-agricultural operations shall comply with Sections 5.2.2.1.1 through 5.2.2.1.3 on an engine-by-engine basis:

- 5.2.2.1.1 NO<sub>x</sub>, CO, and VOC emission limits pursuant to Table 2;
- 5.2.2.1.2 SO<sub>x</sub> control requirements of Section 5.7, pursuant to the deadlines specified in Section 7.5; and
- 5.2.2.1.3 Monitoring requirements of Section 5.10, pursuant to the deadlines specified in Section 7.5.

Section 5.2.2.2 allows that in lieu of complying with the NO<sub>x</sub> emission limit requirement of Section 5.2.2.1.1, an operator may pay an annual fee to the District, as specified in Section 5.6, pursuant to Section 7.6. As shown below, the applicant is proposing to comply with the NO<sub>x</sub> emission limit requirement of Table 2 as required by Section 5.2.2.1.1; therefore, no further discussion is required.

Section 5.2.2.3 allows that in lieu of complying with the NO<sub>x</sub>, CO, and VOC limits of Table 2 on an engine-by-engine basis, an operator may elect to implement an alternative emission control plan pursuant to Section 8.0. As shown below, the applicant is proposing to comply with the NO<sub>x</sub>, CO, and VOC emission limit requirements of Table 2; therefore, no further discussion is required.

<b>Rule 4702, Table 2 Emission Limits/Standards for Spark-Ignited IC Engines rated &gt;50 bhp Used in Non-Agricultural Operations</b>			
(Emission Limits are effective according to the compliance schedule specified in Rule 4702, Section 7.5.)			
<b>Engine Type</b>	<b>NO<sub>x</sub> Emission Limit (ppmv @ 15% O<sub>2</sub>, dry)</b>	<b>CO Emission Limit (ppmv @ 15% O<sub>2</sub>, dry)</b>	<b>VOC Emission Limit (ppmv @ 15% O<sub>2</sub>, dry)</b>
1. a. Rich-Burn, Waste Gas Fueled	50 ppmv	2,000 ppmv	250 ppmv
1. b. Rich-Burn, Cyclic Loaded, Field Gas Fueled	50 ppmv	2,000 ppmv	250 ppmv
1. c. Rich-Burn, Limited Use	25 ppmv	2,000 ppmv	250 ppmv
1. d. Rich-Burn, Not Listed Above	11 ppmv	2,000 ppmv	250 ppmv
2. a. Lean-Burn, 2-Stroke, Gaseous Fueled, >50 bhp & <100 bhp	75 ppmv	2,000 ppmv	750 ppmv
2. b. Lean-Burn, Limited Use	65 ppmv	2,000 ppmv	750 ppmv
2. c. Lean-Burn Engine used for gas compression	65 ppmv or 93% reduction	2,000 ppmv	750 ppmv
2. d. Waste Gas Fueled	65 ppmv or 90% reduction	2,000 ppmv	750 ppmv
2. e. Lean-Burn, Not Listed Above	11 ppmv	2,000 ppmv	750 ppmv

The proposed engines will be operated as a separate stationary source than the dairy farm, and the District has determined that the engines are non-agricultural IC engines. The proposed engines are fired on digester gas and do not satisfy the definition of waste gas; therefore, the engine is required to comply with the following emissions limits from Table 2, Row 2.e: 11 ppmvd NO<sub>x</sub>, 2,000 ppmvd CO, and 750 ppmvd VOC (all measured @ 15% O<sub>2</sub>)

Therefore, the following previously proposed condition will be listed on the permits to ensure compliance:

- After the commissioning period, emissions from this IC engine shall not exceed any of the following limits: 0.15 g-NO<sub>x</sub>/bhp-hr (equivalent to 11 ppmvd NO<sub>x</sub> @ 15% O<sub>2</sub>), NO<sub>x</sub> referenced as NO<sub>2</sub>; 0.10 g-PM<sub>10</sub>/bhp-hr; 0.65 g-CO/bhp-hr (equivalent to 210 ppmvd CO @ 15% O<sub>2</sub>); or 0.10 g-VOC/bhp-hr (equivalent to 21 ppmvd VOC @ 15% O<sub>2</sub>), VOC referenced as CH<sub>4</sub>. [District Rules 2201 and 4702]

Section 5.2.3 applies to spark-ignited engines used exclusively in agricultural operations. As stated above, the proposed engines will be operated as part of a separate non-agricultural stationary source; therefore, Section 5.2.3 does not apply to the proposed engines.

Section 5.2.4 applies to certified compression-ignited engines. The proposed engines are not a compression-ignited engine; therefore, Section 5.2.4 does not apply to the proposed engines.

Section 5.2.5 applies to non-certified compression-ignited engines. The proposed engines are not a compression-ignited engine; therefore, Section 5.2.5 does not apply to the proposed engine.

Section 5.3 requires that all continuous emission monitoring systems (CEMS) emissions measurements shall be averaged over a period of 15 consecutive minutes. Any 15-consecutive minute block average CEMS measurement exceeding the applicable emission limits of this rule shall constitute a violation of this rule. The proposed engines will not have CEMS installed; therefore this section of the Rule is not applicable.

Section 5.4 specifies procedures to calculate percent emission reductions if percent emission reductions are used to comply with the NO<sub>x</sub> emission limits of Section 5.2. The use of percent emission reductions to comply with Section 5.2 is not being proposed for the engines under this project; therefore, this section of the Rule is not applicable.

Section 5.5 requires the operator of an internal combustion engine that uses percent emission reduction to comply with the NO<sub>x</sub> emission limits of Section 5.2 shall provide an accessible inlet and outlet on the external control device or the engine as appropriate for taking emission samples and as approved by the APCO. The use of percent emission reductions to comply with Section 5.2 is not being proposed for the engines under this project; therefore, this section of the Rule is not applicable.

Section 5.6 specifies procedures that operators of non-agricultural spark-ignited IC engines who elect to comply under Section 5.2.2.2 must use for calculation of the annual emissions fee. The applicant has proposed that the engines comply with the applicable emission limits of Table 2 of District Rule 4702; therefore, payment of annual emissions fees for the engines are not required and this section of the Rule is not applicable.

Section 5.7 requires that on and after the compliance schedule specified in Section 7.5, operators of non-agricultural spark-ignited engines and non-agricultural compression-ignited engines shall comply shall comply with Sections 5.7.1, 5.7.2, 5.7.3, 5.7.4, 5.7.5, or 5.7.6:

- 5.7.1 Operate the engine exclusively on PUC-quality natural gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases; or
- 5.7.2 Limit gaseous fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic feet; or
- 5.7.3 Use California Reformulated Gasoline for gasoline-fired spark-ignited engines; or
- 5.7.4 Use California Reformulated Diesel for compression-ignited engines; or
- 5.7.5 Operate the engine on liquid fuel that contains no more than 15 ppm sulfur, as determined by the test method specified in Section 6.4.6; or
- 5.7.6 Install and properly operate an emission control system that reduces SO<sub>2</sub> emissions by at least 95% by weight as determined by the test method specified in Section 6.4.6.

To satisfy BACT, the average sulfur content of the digester gas fuel for the engines will be limited to 40 ppmv or 0.04 g/bhp-hr (approximately equal to 0.8 grains sulfur per 100 standard cubic feet<sup>3</sup>). The following condition will be listed on the proposed engine permits to ensure compliance:

- The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]

Section 5.8 requires that the operator of a non-agricultural spark-ignited IC engine subject to the requirements of Section 5.2 or any engine subject to the requirements of Section 8.0 shall comply with the following requirements of Sections 5.8.1 – 5.8.11:

Section 5.8.1 stipulates that for each engine with a rated brake horsepower of 1,000 bhp or greater and which is allowed to operate more than 2,000 hours per calendar year, or with an external emission control device, shall either install, operate, and maintain continuous monitoring equipment for NO<sub>x</sub>, CO, and oxygen, as identified in Rule 1080 (Stack Monitoring), or install, operate, and maintain APCO-approved alternate monitoring. The monitoring system may be a continuous emissions monitoring system (CEMS), a parametric emissions monitoring system (PEMS), or an alternative monitoring system approved by the APCO. APCO-approved alternate monitoring shall consist of one or more of the following:

- 5.8.1.1 Periodic NO<sub>x</sub> and CO emission concentrations,
- 5.8.1.2 Engine exhaust oxygen concentration,
- 5.8.1.3 Air-to-fuel ratio,
- 5.8.1.4 Flow rate of reducing agents added to engine exhaust,
- 5.8.1.5 Catalyst inlet and exhaust temperature,
- 5.8.1.6 Catalyst inlet and exhaust oxygen concentration, or
- 5.8.1.7 Other operational characteristics.

The applicant has proposed to comply with this section of the Rule by proposing a pre-approved alternate emissions monitoring plan that specifies that the permittee perform periodic monitoring of NO<sub>x</sub>, CO, and O<sub>2</sub> emissions concentrations as specified in District Policy SSP-1810, dated 4/29/04. Therefore, the following condition will be placed on the permit to ensure compliance:

- The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed

<sup>3</sup>

$$0.04 \frac{g}{hp \cdot hr} \times \frac{39275 hp \cdot hr}{MMBtu} \times \frac{MMBtu}{9,100 dscf} \times \frac{0.363 Btu_{out}}{1 Btu_{in}} \times \frac{15.43 grain}{g} = 0.008 \frac{grain}{dscf}$$

within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]

Section 5.8.2 requires that for each non-agricultural spark-ignited IC engine not subject to Section 5.8.1, the operator shall monitor operational characteristics recommended by the engine manufacturer or emission control system supplier, and approved by the APCO. The proposed engines will be subject to Section 5.8.1; therefore this section is not applicable.

Section 5.8.3 requires that for each engine with an alternative monitoring system, the operator shall submit to, and receive approval from the APCO, adequate verification of the alternative monitoring system's acceptability. The proposed engines include a pre-approved alternate emissions monitoring plan that specifies that the permittee perform periodic NO<sub>x</sub>, CO, and O<sub>2</sub> emissions concentrations as specified in District Policy SSP-1810, dated 4/29/04. Therefore, this section is satisfied.

Section 5.8.4 requires that for each engine with an APCO approved CEMS, operate the CEMS in compliance with the requirements of 40 Code of Federal Regulations (CFR) Part 51, 40 CFR Parts 60.7 and 60.13 (except subsection h), 40 CFR Appendix B (Performance Specifications), 40 CFR Appendix F (Quality Assurance Procedures), and applicable provisions of Rule 1080 (Stack Monitoring). The proposed engines will not have CEMS installed; therefore, this section of the Rule is not applicable.

Section 5.8.5 requires that each engine have the data gathering and retrieval capabilities of an installed monitoring system described in Section 5.8 approved by the APCO. As stated above, the proposed engines include an alternate emissions monitoring plan that has been pre-approved by the APCO. Therefore, this section is satisfied.

Section 5.8.6 requires that for each non-agricultural spark-ignited IC engine, the operator shall install and operate a nonresettable elapsed operating time meter. In lieu of installing a nonresettable time meter, the operator may use an alternative device, method, or technique in determining operating time provided that the alternative is approved by the APCO. The operator shall maintain and operate the required meter in accordance with the manufacturer's instructions. The applicant has proposed a nonresettable elapsed operating time meter for the engines in this project. Therefore, the following condition will be placed on the permits to ensure compliance:

- This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 2201 and 4702]

Section 5.8.7 requires that for each engine, the operator shall implement the Inspection and Monitoring (I&M) plan submitted to and approved by the APCO pursuant to Section 6.5. The applicant has submitted an I&M program with this ATC application and the requirements of this plan will be explained in detail in the section that covers Section 6.5 of this Rule.

Section 5.8.8 requires that for each engine, the operator shall collect data through the I&M plan in a form approved by the APCO. The applicant has submitted an I&M program and the

requirements of this plan will be explained in detail in the section that covers Section 6.5 of this Rule.

Section 5.8.9 requires for each non-agricultural spark-ignited IC engine, the operator shall use a portable NO<sub>x</sub> analyzer to take NO<sub>x</sub> emission readings to verify compliance with the emission requirements of Section 5.2 or Section 8.0 during each calendar quarter in which a source test is not performed. If an engine is operated less than 120 calendar days per calendar year, the operator shall take one NO<sub>x</sub> emission reading during the calendar year in which a source test is not performed and the engine is operated. All emission readings shall be taken with the engine operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate or Permit-Exempt Equipment Registration. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. All NO<sub>x</sub> emissions readings shall be reported to the APCO in a manner approved by the APCO. NO<sub>x</sub> emission readings taken pursuant to this section shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive minute sample reading or by taking at least five (5) readings evenly spaced out over the 15 consecutive-minute period. Therefore, the following conditions will be placed on the permits to ensure compliance:

- The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
- {3787} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]

Section 5.8.10 specifies that the APCO shall not approve an alternative monitoring system unless it is documented that continued operation within ranges of specified emissions related performance indicators or operational characteristics provides a reasonable assurance of compliance with applicable emission limits and that the operator shall source test over the proposed range of surrogate operating parameters to demonstrate compliance with the applicable emission standards. The proposed permits for the engines includes a pre-approved alternate emissions monitoring plan that requires periodic NO<sub>x</sub>, CO, and O<sub>2</sub> emissions concentrations. Therefore, this section is satisfied.

Section 5.8.11 requires that for each non-agricultural spark-ignited IC engine subject to the Alternate Emission Control Plan (AECPP) of Section 8.0, the operator shall install and operate a

nonresettable fuel meter. The use of an Alternate Emission Control Plan to comply with Section 5.2 is not being proposed for the proposed engines; therefore this section of the Rule is not applicable.

Section 5.9 specifies monitoring requirements for all other engines that are not subject to the requirements of Section 5.8. The proposed engines are subject to the requirements of Section 5.8; therefore this section of the Rule is not applicable.

Section 5.10 specifies SO<sub>x</sub> Emissions Monitoring Requirements. On and after the compliance schedule specified in Section 7.5, an operator of a non-agricultural IC engine shall comply with the following requirements:

- 5.10.1 An operator of an engine complying with Sections 5.7.2 or 5.7.5 shall perform an annual sulfur fuel analysis in accordance with the test methods in Section 6.4. The operator shall keep the records of the fuel analysis and shall provide it to the District upon request,
- 5.10.2 An operator of an engine complying with Section 5.7.6 by installing and operating a control device with at least 95% by weight SO<sub>x</sub> reduction efficiency shall submit for approval by the APCO the proposed the key system operating parameters and frequency of the monitoring and recording not later than July 1, 2013, and
- 5.10.3 An operator of an engine complying with Section 5.7.6 shall perform an annual source test unless a more frequent sampling and reporting period is included in the Permit-to-Operate. Source tests shall be performed in accordance with the test methods in Section 6.4.

The following condition will be listed on the proposed permits to ensure compliance:

- Fuel sulfur content analysis shall be performed at least annually using EPA Method 11 or EPA Method 15, as appropriate. Records of the fuel sulfur analysis shall be maintained and provided to the District upon request. [District Rules 2201 and 4702]

Section 5.11 requires operators of engines used exclusively in agricultural operations that are not required to have a Permit-to-Operate pursuant to California Health and Safety Code Section 42301.16 but are required to comply with Section 5.2 of Rule 4702 shall register such engines pursuant to Rule 2250 (Permit-Exempt Equipment Registration). The proposed engines are required to have a District Permit to Operate; therefore this section of the Rule is not applicable.

Section 6.1 requires that the operator of an engine subject to the requirements of Rule 4702 shall submit to the APCO an approvable emission control plan of all actions to be taken to satisfy the emission requirements of Section 5.2 and the compliance schedules of Section 7.0. If there is no change to the previously-approved emission control plan, the operator shall submit a letter to the District indicating that the previously approved plan is still valid.

Section 6.1.1 specifies that the requirement to submit an emission control plan shall apply to the following engines:

- 6.1.1.1 Engines that have been retrofitted with an exhaust control device, except those certified per Section 9.0;



- 6.1.1.2 Engines subject to Section 8.0;
- 6.1.1.3 An agricultural spark-ignited engine that is subject to the requirements of Section 8.0;
- 6.1.1.4 An agricultural spark-ignited engine that has been retrofitted with a catalytic emission control and is not subject to the requirements of Section 8.0.

Section 6.1.2 specifies that the emission control plan shall contain the following information, as applicable for the engine:

- 6.1.2.1 Permit-to-Operate number, Authority-to-Construct number, or Permit-Exempt Equipment Registration number,
- 6.1.2.2 Engine manufacturer,
- 6.1.2.3 Model designation and engine serial number,
- 6.1.2.4 Rated brake horsepower,
- 6.1.2.5 Type of fuel and type of ignition,
- 6.1.2.6 Combustion type: rich-burn or lean-burn,
- 6.1.2.7 Total hours of operation in the previous one-year period, including typical daily operating schedule,
- 6.1.2.8 Fuel consumption (cubic feet for gas or gallons for liquid) for the previous one-year period,
- 6.1.2.9 Stack modifications to facilitate continuous in-stack monitoring and to facilitate source testing,
- 6.1.2.10 Type of control to be applied, including in-stack monitoring specifications,
- 6.1.2.11 Applicable emission limits,
- 6.1.2.12 Documentation showing existing emissions of NO<sub>x</sub>, VOC, and CO, and
- 6.1.2.13 Date that the engine will be in full compliance with this rule.

Section 6.1.3 requires that the emission control plan shall identify the type of emission control device or technique to be applied to each engine and a construction/removal schedule, or shall provide support documentation sufficient to demonstrate that the engines are in compliance with the emission requirements of this rule.

Section 6.1.4 requires that for an engine being permanently removed from service, the emission control plan shall include a letter of intent pursuant to Section 7.2. The applicant has submitted all the required information for Section 6.1 in the application for the engines evaluated under this project.

Section 6.2.1 requires that the operator of an engine subject to the requirements of Section 5.2 shall maintain an engine operating log to demonstrate compliance with Rule 4702. This information shall be retained for a period of at least five years, shall be readily available, and be made available to the APCO upon request. The engine operating logs shall include, on a monthly basis, the following information:

- 6.2.1.1 Total hours of operation,
- 6.2.1.2 Type of fuel used,
- 6.2.1.3 Maintenance or modifications performed,
- 6.2.1.4 Monitoring data,
- 6.2.1.5 Compliance source test results, and
- 6.2.1.6 Any other information necessary to demonstrate compliance with this rule.

6.2.1.7 For an engine subject to Section 8.0, the quantity (cubic feet of gas or gallons of liquid) of fuel used on a daily basis.

The following condition will be placed on the permits to ensure compliance:

- The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201 and 4702]

Section 6.2.2 requires that the data collected pursuant to the requirements of Section 5.8 and Section 5.9 shall be maintained for at least five years, shall be readily available, and made available to the APCO upon request.

The following previously presented condition will be listed on the permits to ensure compliance:

- All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 2201 and 4702]

Section 6.2.3 requires that an operator claiming an exemption under Section 4.2 or Section 4.3 shall maintain annual operating records. The applicant is not claiming an exemption for the proposed engines under Section 4.2 or Section 4.3; therefore, this section does not apply.

Section 6.3 requires that the operator of an engine subject to the emission limits in Section 5.2 or the requirements of Section 8.2, shall comply with the compliance testing requirements of Section 6.3.

Section 6.3.1 specifies that the requirements of Section 6.3.2 through Section 6.3.4 shall apply to the following engines:

- 6.3.1.1 Engines that have been retrofitted with an exhaust control device, except those certified per Section 9.0;
- 6.3.1.2 Engines subject to Section 8.0;
- 6.3.1.3 An agricultural spark-ignited engine that is subject to the requirements of Section 8.0;
- 6.3.1.4 An agricultural spark-ignited engine that has been retrofitted with a catalytic emission control and is not subject to the requirements of Section 8.0.

Section 6.3.2 requires demonstration of compliance with applicable limits, ppmv or percent reduction, in accordance with the test methods in Section 6.4, as specified below:

- 6.3.2.1 By the applicable date specified in Section 5.2, and at least once every 24 months thereafter, except for an engine subject to Section 6.3.2.2.

- 6.3.2.2 By the applicable date specified in Section 5.2 and at least once every 60 months thereafter, for an agricultural spark-ignited engine that has been retro-fitted with a catalytic emission control device.
- 6.3.2.3 A portable NO<sub>x</sub> analyzer may be used to show initial compliance with the applicable limits/standards in Section 5.2 for agricultural spark-ignited engines, provided the criteria specified in Sections 6.3.2.3.1 to 6.3.2.3.5 are met, and a source test is conducted in accordance with Section 6.3.2 within 12 months from the required compliance date.

The following conditions will be included in the permits to ensure compliance:

- Source testing to measure NO<sub>x</sub>, CO, VOC, PM<sub>10</sub>, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted within 60 days upon end of the commissioning period. [District Rules 1081, 2201, and 4702]
- Source testing to measure NO<sub>x</sub>, CO, VOC, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]

Section 6.3.3 requires the operator to conduct emissions source testing with the engine operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate or Permit-Exempt Equipment Registration. For emissions source testing performed pursuant to Section 6.3.2 for the purpose of determining compliance with an applicable standard or numerical limitation, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC shall be reported as methane. VOC, NO<sub>x</sub>, and CO concentrations shall be reported in ppmv, corrected to 15 percent oxygen. For engines that comply with a percent reduction limit, the percent reduction of NO<sub>x</sub> emissions shall also be reported. The following conditions will be included in the permits to ensure compliance:

- {3791} Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
- For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO<sub>x</sub>, CO, VOC, and NH<sub>3</sub> concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 2201 and 4702]

Section 6.3.4 requires that in addition to other information, the source test protocol shall describe which critical parameters will be measured and how the appropriate range for these parameters shall be established. The range for these parameters shall be incorporated into the I&M plan.

Section 6.3.5 specifies that engines that are limited by Permit-to-Operate or Permit-Exempt Equipment Registration condition to be fueled exclusively with PUC quality natural gas shall not be subject to the reoccurring source test requirements of Section 6.3.2 for VOC emissions. The proposed engines will be fueled by digester gas; therefore, this section does not apply.

Section 6.3.6 specifies requirements for spark-ignited engines for testing a unit or units that represent a specified group of units, in lieu of compliance with the applicable requirements of Section 6.3.2. Testing of representative units is not being proposed for the engines; therefore, this section does not apply.

Section 6.4 requires that the compliance with the requirements of Section 5.2 shall be determined, as required, in accordance with the following test procedures or any other method approved by EPA and the APCO:

- 6.4.1 Oxides of nitrogen - EPA Method 7E, or ARB Method 100.
- 6.4.2 Carbon monoxide - EPA Method 10, or ARB Method 100.
- 6.4.3 Stack gas oxygen - EPA Method 3 or 3A, or ARB Method 100.
- 6.4.4 Volatile organic compounds - EPA Method 25A or 25B, or ARB Method 100. Methane and ethane, which are exempt compounds, shall be excluded from the result of the test.
- 6.4.5 Operating horsepower determination - any method approved by EPA and the APCO.
- 6.4.6 SO<sub>x</sub> Test Methods
  - 6.4.6.1 Oxides of sulfur – EPA Method 6C, EPA Method 8, or ARB Method 100.
  - 6.4.6.2 Determination of total sulfur as hydrogen sulfide (H<sub>2</sub>S) content – EPA Method 11 or EPA Method 15, as appropriate.
  - 6.4.6.3 Sulfur content of liquid fuel – American Society for Testing and Materials (ASTM) D 6920-03 or ASTM D 5453-99.
  - 6.4.6.4 The SO<sub>x</sub> emission control system efficiency shall be determined using the following:  
% Control Efficiency =  $[(C_{SO_2, \text{inlet}} - C_{SO_2, \text{outlet}}) / C_{SO_2, \text{inlet}}] \times 100$   
Where:  
C<sub>SO<sub>2</sub>, inlet</sub> = concentration of SO<sub>x</sub> (expressed as SO<sub>2</sub>) at the inlet side of the SO<sub>x</sub> emission control system, in lb/Dscf  
C<sub>SO<sub>2</sub>, outlet</sub> = concentration of SO<sub>x</sub> (expressed as SO<sub>2</sub>) at the outlet side of the SO<sub>x</sub> emission control system, in lb/Dscf
- 6.4.7 The Higher Heating Value (hhv) of the fuel shall be determined by one of the following test methods:
  - 6.4.7.1 ASTM D 240-02 or ASTM D 3282-88 for liquid hydrocarbon fuels.
  - 6.4.7.2 ASTM D 1826-94 or ASTM 1945-96 in conjunction with ASTM D 3588-89 for gaseous fuel.

The following conditions will be listed on the permits to ensure compliance:

- The following methods shall be used for source testing: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100; CO (ppmv) - EPA Method 10 or ARB Method 100; VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100; stack gas oxygen - EPA Method 3 or 3A or ARB Method 100; stack gas velocity - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; PM<sub>10</sub> (filterable and condensable) - EPA Method 201 and 202, EPA Method 201a and 202, or ARB Method 5 in combination with Method 501; NH<sub>3</sub> - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4702]

- Fuel sulfur content analysis shall be performed at least annually using EPA Method 11 or EPA Method 15, as appropriate. Records of the fuel sulfur content analysis shall be maintained and provided to the District upon request. [District Rules 2201 and 4702]
- The Higher Heating Value (HHV) of the fuel gas shall be determined using ASTM D1826, ASTM 1945 in conjunction with ASTM D3588, or an alternative method approved by the District. [District Rules 2201 and 4702]

Section 6.5 requires that the operator of an engine that is subject to the requirements of Section 5.2 or the requirements of Section 8.0 shall submit to the APCO for approval, an Inspection & Maintenance (I&M) plan that specifies all actions to be taken to satisfy the requirements of Sections 6.5.1 through Section 6.5.9 and the requirements of Section 5.8. The actions to be identified in the I&M plan shall include, but are not limited to, the information specified below. If there is no change to the previously approved I&M plan, the operator shall submit a letter to the District indicating that previously approved plan is still valid.

Section 6.5.1 specifies that the I&M plan requirements of Sections 6.5.2 through Section 6.5.9 shall apply to the following engines:

- 6.5.1.1 Engines that have been retrofitted with an exhaust control device, except those certified per Section 9.0;
- 6.5.1.2 Engines subject to Section 8.0;
- 6.5.1.3 An agricultural spark-ignited engine that is subject to the requirements of Section 8.0.
- 6.5.1.4 An agricultural spark-ignited engine that has been retrofitted with a catalytic emission control and is not subject to the requirements of Section 8.0.

The proposed engine will be equipped with an SCR system for control of NO<sub>x</sub> and oxidation catalyst for control of CO and VOC. Therefore, the requirements of Sections 6.5.2 through 6.5.9 are applicable to the engines.

Section 6.5.2 requires procedures requiring the operator to establish ranges for control equipment parameters, engine operating parameters, and engine exhaust oxygen concentrations that source testing has shown result in pollutant concentrations within the rule limits.

Section 6.5.3 requires procedures for monthly inspections as approved by the APCO. The applicable control equipment parameters and engine operating parameters will be inspected and monitored monthly in conformance with a regular inspection schedule in the I&M plan.

Section 6.5.4 requires procedures for the corrective actions on the noncompliant parameter(s) that the operator will take when an engine is found to be operating outside the acceptable range for control equipment parameters, engine operating parameters, and engine exhaust NO<sub>x</sub>, CO, VOC, or oxygen concentrations.

Section 6.5.5 requires procedures for the operator to notify the APCO when an engine is found to be operating outside the acceptable range for control equipment parameters, engine operating parameters, and engine exhaust NO<sub>x</sub>, CO, VOC, or oxygen concentrations.

Section 6.5.6 requires procedures for and corrective maintenance performed for the purpose of maintaining an engine in proper operating condition. The applicant has proposed that the engines will be operated and maintained per the manufacturer's specifications.

Section 6.5.7 requires procedures and a schedule for using a portable NO<sub>x</sub> analyzer to take NO<sub>x</sub> emission readings pursuant to Section 5.8.9.

Section 6.5.8 requires procedures for collecting and recording required data and other information in a form approved by the APCO including, but not limited to, data collected through the I&M plan and the monitoring systems described in Sections 5.8.1 and 5.8.2. Data collected through the I&M plan shall have retrieval capabilities as approved by the APCO.

#### NO<sub>x</sub> Emissions

In order to satisfy the I & M requirements for NO<sub>x</sub> emissions, the applicant has proposed to perform the following:

1. The applicant will take periodic NO<sub>x</sub> emission concentration measurements with a portable analyzer at least once every calendar quarter.
2. To ensure that NO<sub>x</sub> emissions concentrations are not being exceeded between periodic NO<sub>x</sub> portable analyzer measurements, the applicant is proposing to determine a correlation between the SCR system's reagent injection rate and NO<sub>x</sub> emissions. The appropriate ranges for each operating load will be established during initial source testing and will be monitored at least once per month.

Therefore, the following conditions will be listed on the permits to ensure compliance:

- During initial performance testing, the SCR system reagent injection rate shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable SCR system reagent injection rate(s) demonstrated during the initial performance test that result in compliance with the NO<sub>x</sub> emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]
- If the SCR system reagent injection rate is outside of the established acceptable range, the permittee shall return the SCR system reagent injection rate to within the established acceptable range as soon as possible, but no longer than 8 hours after detection. If the SCR system reagent injection rate is not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of NO<sub>x</sub> and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of NO<sub>x</sub> and O<sub>2</sub> shall continue until the operator can show that the SCR system reagent injection rate is returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
- The permittee shall monitor and record the SCR system reagent injection rate and the engine operating load at least once per month. [District Rule 4702]
- The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during

quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]

- The permittee shall monitor and record the stack concentration of NH<sub>3</sub> at least once every calendar quarter in which a source test is not performed. NH<sub>3</sub> monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last quarter. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4102]
- If the NO<sub>x</sub>, CO, or NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]

#### CO and VOC Emissions

In order to satisfy the I & M requirements for CO and VOC emissions, the applicant has proposed to perform the following:

1. The applicant will take periodic CO emission concentration measurements with a portable analyzer at least once every calendar quarter. Per the catalyst manufacturer, if the oxidation catalyst is controlling CO emissions, it should also be achieving the desired removal efficiency for VOC emissions. Therefore, quarterly emission concentration measurements with a portable analyzer for VOC emissions will not be required.
2. To ensure that CO and VOC emissions concentrations are not being exceeded between periodic CO emission concentration measurements, the applicant is proposing to determine a correlation between the catalyst control system inlet exhaust temperature and back pressure. The appropriate ranges for each operating load will be established during initial source testing and will be monitored at least once per month.

Therefore, the following conditions will be listed on the permits to ensure compliance:

- During initial performance testing, the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system shall be

monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable inlet temperature and back pressure demonstrated during the initial compliance test that result in compliance with the CO and VOC emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]

- The permittee shall monitor and record the inlet temperature to the SCR system, the back pressure of the exhaust upstream of the catalyst control system, and the engine operating load at least once per month. [District Rule 4702]
- If the inlet temperature to the catalyst control system and/or the back pressure of the exhaust upstream of the catalyst control system is outside of the established acceptable ranges established during the initial compliance test, the permittee shall return the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system back to the acceptable range as soon as possible, but no longer than 8 hours after detection. If the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of CO and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of CO and O<sub>2</sub> shall continue until the operator can show that the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
- The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
- If the NO<sub>x</sub>, CO, or NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]



Section 6.5.9 specifies procedures for revising the I&M plan. The I&M plan shall be updated to reflect any change in operation. The I&M plan shall be updated prior to any planned change in operation. An engine operator that changes significant I&M plan elements must notify the District no later than seven days after the change and must submit an updated I&M plan to the APCO no later than 14 days after the change for approval. The date and time of the change to the I&M plan shall be recorded in the engine operating log. For new engines and modifications to existing engines, the I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit-to-Operate or Permit-Exempt Equipment Registration. The operator of an engine may request a change to the I&M plan at any time. The applicant has proposed to comply with the I&M plan modification requirements per this section of the Rule. The following condition will be listed on the permits to ensure compliance:

- {3212} The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]

Section 7.0 specifies the schedules for compliance with the general requirements of Section 5.0 and the Alternative Emission Control Plan (AECPP) option of Section 8.0. The proposed engine will be required to comply with the applicable sections of District Rule 4702 upon initial startup of the equipment; therefore, compliance with this section is expected.

Section 8.0 specifies requirements for use of an Alternative Emission Control Plan (AECPP) to comply with the NO<sub>x</sub> emission requirements of Section 5.2 for a group of engines. The use of an Alternate Emission Control Plan to comply with Section 5.2 is not being proposed for the proposed engines; therefore, this section of the Rule is not applicable.

Section 9.0 specifies requirements for certification of exhaust control systems for compliance with District Rule 4702. Certification under this section for the exhaust control systems for the proposed engines are not currently being proposed; therefore, this section of the Rule is not applicable at this time.

#### Conclusion

As shown above, the proposed engine will satisfy all the requirements of Rule 4702. Therefore, the engines will be in compliance as of the date of initial operation and the following conditions will be added to the permits to ensure continued compliance:

- {4261} This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
- {3203} This engine shall be operated within the ranges that the source testing has shown result in pollution concentrations within the emissions limits as specified on this permit. [District Rule 4702]

## Rule 4801 Sulfur Compounds

### C-9169-2-0 and '-3-0 (Digester Gas-Fired IC Engines)

The purpose of this District Rule 4801 is to limit the emissions of sulfur compounds. The limit is that sulfur compound emissions (as SO<sub>2</sub>) shall not exceed 0.2% by volume. Using the ideal gas equation, the sulfur compound emissions are calculated as follows:

$$\text{Volume of SO}_x \text{ as (SO}_2\text{)} = (n \times R \times T) \div P$$

Where:

n = moles SO<sub>x</sub>

T (standard temperature) = 60 °F or 520 °R

R (universal gas constant) =  $\frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot \text{°R}}$

To demonstrate compliance with the sulfur compound emission limit of Rule 4801, the maximum sulfur compound emissions from the engines will be calculated using the maximum sulfur content allowed for the digester gas, which is 40 ppmv, equivalent to 0.00965 lb-SO<sub>x</sub>/MMBtu.

$$0.0113 \frac{\text{lb}}{\text{MMBtu}} \times \frac{1 \text{ MMBtu}}{9,100 \text{ scf}_{\text{exhaust}}} \times \frac{1 \text{ lb} \cdot \text{mol}}{64 \text{ lb} \cdot \text{SO}_2} \times \frac{10.73 \text{ psi} \cdot \text{ft}^3}{\text{lb} \cdot \text{mol} \cdot \text{°R}} \times \frac{520 \text{ °R}}{14.7 \text{ psi}} \times 1,000,000 \text{ ppm} = 7.4 \text{ ppmv}$$

Since 7.4 ppmv is ≤ 2000 ppmv, the engines are expected to comply with Rule 4801. The following condition will be placed on the ATC permits to ensure compliance:

- The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]

## California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

## California Environmental Quality Act (CEQA)

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;
- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and

- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

### **Greenhouse Gas (GHG) Significance Determination**

#### District is a Responsible Agency

It is determined that another agency has prepared an environmental review document for the project. The District is a Responsible Agency for the project because of its discretionary approval power over the project via its Permits Rule (Rule 2010) and New Source Review Rule (Rule 2201), (CEQA Guidelines §15381). As a Responsible Agency, the District is limited to mitigating or avoiding impacts for which it has statutory authority. The District does not have statutory authority for regulating greenhouse gas emissions. The District has determined that the applicant is responsible for implementing greenhouse gas mitigation measures, if any, imposed by the Lead Agency.

#### **District CEQA Findings**

The County of Fresno (County) is the public agency having principal responsibility for approving the project. As such, the County served as the Lead Agency (CCR §15367). In approving the project, the Lead Agency prepared and adopted a Mitigated Negative Declaration. The Lead agency filed a Notice of Determination, stating that the environmental document was adopted pursuant to the provisions of CEQA and concluding that the project would not have a significant effect on the environment.

The District is a Responsible Agency for the project because of its discretionary approval power over the project via its Permits Rule (Rule 2010) and New Source Review Rule (Rule 2201), (CCR §15381). As a Responsible Agency the District complies with CEQA by considering the environmental document prepared by the Lead Agency, and by reaching its own conclusion on whether and how to approve the project (CCR §15096).

The District has considered the Lead Agency's environmental document and finds that it adequately characterizes the project's potential impact on air quality. In addition, all feasible and cost-effective control measures to reduce potential impacts on air quality resulting from project related stationary source emissions have been applied to the project. Furthermore, the District has conducted an engineering evaluation of the project, this document, which demonstrates that Stationary Source emissions from the project would be reduced. Thus, the District finds that through a combination of project design elements, compliance with applicable District rules and regulations, and compliance with District air permit conditions, project specific stationary source emissions would be reduced to lessen the impacts on air quality. The District does not have authority over any of the other project impacts and has, therefore, determined that no additional findings are required (CEQA Guidelines §15096(h)).

#### **Indemnification Agreement/Letter of Credit Determination**

According to District Policy APR 2010 (CEQA Implementation Policy), when the District is the Lead or Responsible Agency for CEQA purposes, an indemnification agreement and/or a letter of credit may be required. The decision to require an indemnity agreement and/or a letter of credit is based on a case-by-case analysis of a particular project's potential for

litigation risk, which in turn may be based on a project's potential to generate public concern, its potential for significant impacts, and the project proponent's ability to pay for the costs of litigation without a letter of credit, among other factors.

The criteria pollutant emissions and toxic air contaminant emissions associated with the proposed project are not significant, and there is minimal potential for public concern for this particular type of facility/operation. Therefore, an Indemnification Agreement and/or a Letter of Credit will not be required for this project in the absence of expressed public concern.

**IX. Recommendation**

Compliance with all applicable rules and regulations is expected. Pending a successful NSR Public Noticing period, issue ATCs C-9169-1-0, '-2-0, and '-3-0 subject to the permit conditions on the attached draft ATCs in Appendix A.

**X. Billing Information**

<b>Annual Permit Fees</b>			
<b>Permit Number</b>	<b>Fee Schedule</b>	<b>Fee Description</b>	<b>Annual Fee</b>
C-9169-1-0	3020-10-F	Digester System – Misc.	\$116.00
C-9169-2-0	3020-10-F	1,412 bhp digester-fired IC engine	\$820.00
C-9169-3-0	3020-10-F	1,412 bhp digester-fired IC engine	\$820.00

**Appendixes**

- A: Draft ATCs
- B: BACT Guideline
- C: Top Down BACT Analysis
- D: HRA/AAQA Summary
- E: Quarterly Net Emissions Change

**APPENDIX A**  
**Draft ATCs**

San Joaquin Valley  
Air Pollution Control District

**AUTHORITY TO CONSTRUCT**

**ISSUANCE DATE: DRAFT**

**PERMIT NO:** C-9169-1-0

**LEGAL OWNER OR OPERATOR:** BAR 20 DAIRY BIOGAS LLC  
**MAILING ADDRESS:** C/O/ CALIFORNIA BIOENERGY LLC  
2828 ROUTH STREET, STE 500  
DALLAS, TX 75201

**LOCATION:** 24387 WEST WHITESBRIDGE AVE  
KERMAN, CA 93630

**EQUIPMENT DESCRIPTION:**

DIGESTER GAS OPERATION CONSISTING OF A 36,000,000 GALLON (EQUIVALENT TO 570'X505'X21.5') ANAEROBIC DIGESTER LAGOON WITH AN AIR/OXYGEN INJECTION SYSTEM FOR H<sub>2</sub>S CONTROL AND A GAS COLLECTION AND HANDLING SYSTEM SERVED BY A H<sub>2</sub>S SCRUBBER

**CONDITIONS**

1. {271} All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201]
2. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. The digester system shall be designed to allow gas generated to be stored for more than 24 hours prior to venting in the event that the gas cannot be combusted in digester gas-fired engines or sent to another device with a VOC control efficiency of at least 95% by weight as determined by the APCO. [District Rule 2201]
4. The air/oxygen injection system shall be maintained and operated in accordance with the supplier's recommendations to minimize the concentration of hydrogen sulfide (H<sub>2</sub>S) in the digester gas. [District Rule 2201]
5. The VOC content of the digester gas produced by the digester system shall not exceed 10% by weight. [District Rule 2201]
6. All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rule 1070]

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

C-9169-1-0 Sep 7 2016 2:54PM - YOSHIMUJ Joint Inspection NOT Required

San Joaquin Valley  
Air Pollution Control District

**AUTHORITY TO CONSTRUCT**

ISSUANCE DATE: DRAFT

PERMIT NO: C-9169-2-0

LEGAL OWNER OR OPERATOR: BAR 20 DAIRY BIOGAS LLC  
MAILING ADDRESS: C/O/ CALIFORNIA BIOENERGY LLC  
2828 ROUTH STREET, STE 500  
DALLAS, TX 75201

LOCATION: 24387 WEST WHITESBRIDGE AVE  
KERMAN, CA 93630

**EQUIPMENT DESCRIPTION:**

1,412 BHP CATERPILLAR MODEL G3516 A+ DIGESTER GAS-FIRED LEAN-BURN IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM POWERING AN ELECTRICAL GENERATOR

**CONDITIONS**

1. All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants. [District Rule 2201]
2. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. {4261} This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
7. {3203} This engine shall be operated within the ranges that the source testing has shown result in pollution concentrations within the emissions limits as specified on this permit. [District Rule 4702]
8. This engine shall be fired on digester gas fuel only. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

C-9169-2-0 Jun 5 2018 11:38AM - YOSHIMUJ Joint Inspection NOT Required

9. The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]
10. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 2201 and 4702]
11. The owner/operator shall minimize the emissions from the engine to the maximum extent possible during the commissioning period. [District Rule 2201]
12. Commissioning activities are defined as, but not limited to, all adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable operation of the reciprocating IC engine, emission control equipment, and associated electrical delivery systems. [District Rule 2201]
13. Commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when the engine is first fired, whichever occurs first. The commissioning period shall terminate when the initial engine tuning has completed and the engine is available for commercial operation. The total duration of the commissioning period for this engine shall not exceed 120 hours of operation of the engine. [District Rule 2201]
14. The total number of firing hours of this unit without abatement of emissions by the SCR system and oxidation catalyst shall not exceed 120 hours during the commissioning period. Such operation of this unit without abatement shall be limited to discrete commissioning activities that can only be properly executed without the SCR system or oxidation catalyst. Upon completion of these activities, the permittee shall provide written notice to the District and the unused balance of the 120 firing hours without abatement shall expire. [District Rule 2201]
15. At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the engine shall be tuned to minimize emissions. [District Rule 2201]
16. At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the Selective Catalytic Reduction (SCR) system and oxidation catalyst shall be installed, adjusted, and operated to minimize emissions from this unit. [District Rule 2201]
17. The permittee shall submit a summary of activities to be performed during the commissioning period to the District at least two weeks prior to the first firing of this engine. The summary shall include a list of each commissioning activity, the anticipated duration of each activity in hours, and the purpose of the activity. The activities described shall include, but are not limited to, the tuning of the engine, the installation and operation of the SCR system, the installation, calibration, and testing of emissions monitors, and any activities requiring the firing of this unit without abatement by the SCR system. [District Rule 2201]
18. Emission rates from this engine unit during the commissioning period shall not exceed any of the following limits: 1.0 g-NO<sub>x</sub>/bhp-hr, 0.1 g-PM<sub>10</sub>/bhp-hr, 4.85 g-CO/bhp-hr, or 1.0 g-VOC/bhp-hr. [District Rule 2201]
19. The permittee shall record total operating time of the engine in hours during the commissioning period. [District Rule 2201]
20. After the commissioning period, emissions from this IC engine shall not exceed any of the following limits: 0.15 g-NO<sub>x</sub>/bhp-hr (equivalent to 11 ppmvd NO<sub>x</sub> @ 15% O<sub>2</sub>), NO<sub>x</sub> referenced as NO<sub>2</sub>; 0.10 g-PM<sub>10</sub>/bhp-hr; 0.65 g-CO/bhp-hr (equivalent to 210 ppmvd CO @ 15% O<sub>2</sub>); or 0.10 g-VOC/bhp-hr (equivalent to 21 ppmvd VOC @ 15% O<sub>2</sub>), VOC referenced as CH<sub>4</sub>. [District Rules 2201 and 4702]
21. The SCR catalyst shall be maintained and replaced in accordance with the recommendations of the catalyst manufacturer or emission control supplier. Records of catalyst maintenance and replacement shall be maintained. [District Rules 2201 and 4702]
22. Air-to-fuel ratio controller(s) shall be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times. [District Rule 2201]
23. Ammonia (NH<sub>3</sub>) emissions from this engine shall not exceed 10 ppmvd @ 15% O<sub>2</sub>. [District Rules 2201 and 4102]
24. Source testing to measure NO<sub>x</sub>, CO, VOC, PM<sub>10</sub>, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted within 60 days upon end of the commissioning period. [District Rules 1081, 2201, and 4702]

DRAFT  
CONDITIONS CONTINUE ON NEXT PAGE



25. Source testing to measure NO<sub>x</sub>, CO, VOC, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]
26. Fuel sulfur content analysis shall be performed at least annually using EPA Method 11 or EPA Method 15, as appropriate. Records of the fuel sulfur content analysis shall be maintained and provided to the District upon request. [District Rules 2201 and 4702]
27. {3791} Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO<sub>x</sub>, CO, VOC, and NH<sub>3</sub> concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 2201 and 4702]
29. The following methods shall be used for source testing: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100; CO (ppmv) - EPA Method 10 or ARB Method 100; VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100; stack gas oxygen - EPA Method 3 or 3A or ARB Method 100; stack gas velocity - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; PM<sub>10</sub> (filterable and condensable) - EPA Method 201 and 202, EPA Method 201a and 202, or ARB Method 5 in combination with Method 501; NH<sub>3</sub> - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4702]
30. The Higher Heating Value (HHV) of the fuel gas shall be determined using ASTM D1826, ASTM 1945 in conjunction with ASTM D3588, or an alternative method approved by the District. [District Rules 2201 and 4702]
31. {109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
32. The results of each source test shall be submitted to the District within 60 days after completion of the source test. [District Rule 1081]
33. The sulfur content of the digester gas used to fuel the engine shall be monitored and recorded at least once every calendar quarter in which a fuel sulfur analysis is not performed. If quarterly monitoring shows a violation of the fuel sulfur content limit of this permit, monthly monitoring will be required until six consecutive months of monitoring show compliance with the fuel sulfur content limit. Once compliance with the fuel sulfur content limit is shown for six consecutive months, then the monitoring frequency may return to quarterly. Monitoring of the sulfur content of the digester gas fuel shall not be required if the engine does not operate during that period. Records of the results of monitoring of the digester gas fuel sulfur content shall be maintained. [District Rules 2201 and 4702]
34. Monitoring of the digester gas sulfur content shall be performed using gas detection tubes calibrated for H<sub>2</sub>S; a digital analyzer approved for gaseous fuel analysis; a continuous fuel gas monitor that meets the requirements specified in SCAQMD Rule 431.1, Attachment A; District-approved source test methods, including EPA Method 15, ASTM Method D1072, D4084, and D5504; District-approved in-line H<sub>2</sub>S monitors; or an alternative method approved by the District. Prior to utilization of in-line monitors to demonstrate compliance with the digester gas sulfur content limit of this permit, the permittee shall submit details of the proposed monitoring system, including the make, model, and detection limits, to the District and obtain District approval for the proposed monitor(s). [District Rules 2201 and 4702]
35. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO<sub>x</sub>, CO, and O<sub>2</sub> analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Emission Monitoring and Testing. [District Rule 1081]

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

36. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
37. The permittee shall monitor and record the stack concentration of NH<sub>3</sub> at least once every calendar quarter in which a source test is not performed. NH<sub>3</sub> monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last quarter. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4102]
38. If the NO<sub>x</sub>, CO, or NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]
39. {3787} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]
40. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, O<sub>2</sub>, and NH<sub>3</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub>, CO, and NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, (5) the method of determining the NH<sub>3</sub> emission concentration, and (6) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2201 and 4702]
41. The permittee shall monitor and record the SCR system reagent injection rate and the engine operating load at least once per month. [District Rule 4702]
42. During initial performance testing, the SCR system reagent injection rate shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable SCR system reagent injection rate(s) demonstrated during the initial performance test that result in compliance with the NO<sub>x</sub> emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

43. If the SCR system reagent injection rate is outside of the established acceptable range, the permittee shall return the SCR system reagent injection rate to within the established acceptable range as soon as possible, but no longer than 8 hours after detection. If the SCR system reagent injection rate is not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of NO<sub>x</sub> and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of NO<sub>x</sub> and O<sub>2</sub> shall continue until the operator can show that the SCR system reagent injection rate is returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
44. During initial performance testing, the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable inlet temperature and back pressure demonstrated during the initial compliance test that result in compliance with the CO and VOC emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]
45. The permittee shall monitor and record the inlet temperature to the SCR system, the back pressure of the exhaust upstream of the catalyst control system, and the engine operating load at least once per month. [District Rule 4702]
46. If the inlet temperature to the catalyst control system and/or the back pressure of the exhaust upstream of the catalyst control system is outside of the established acceptable ranges established during the initial compliance test, the permittee shall return the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system back to the acceptable range as soon as possible, but no longer than 8 hours after detection. If the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of CO and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of CO and O<sub>2</sub> shall continue until the operator can show that the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
47. {3212} The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]
48. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of fuel used during commissioning period(s), the type and quantity of fuel used during normal operation, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201 and 4702]
49. {4051} The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
50. Records of any analyzer(s) installed or utilized to monitor methane, oxygen, and hydrogen sulfide shall be maintained and shall be made available for District inspection upon request. [District Rule 2201]
51. All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 2201 and 4702]

DRAFT

San Joaquin Valley  
Air Pollution Control District

**AUTHORITY TO CONSTRUCT**

ISSUANCE DATE: DRAFT  
**DRAFT**

**PERMIT NO:** C-9169-3-0

**LEGAL OWNER OR OPERATOR:** BAR 20 DAIRY BIOGAS LLC  
**MAILING ADDRESS:** C/O/ CALIFORNIA BIOENERGY LLC  
2828 ROUTH STREET, STE 500  
DALLAS, TX 75201

**LOCATION:** 24387 WEST WHITESBRIDGE AVE  
KERMAN, CA 93630

**EQUIPMENT DESCRIPTION:**  
1,412 BHP CATERPILLAR MODEL G3516 A+ DIGESTER GAS-FIRED LEAN-BURN IC ENGINE WITH A SELECTIVE CATALYTIC REDUCTION (SCR) SYSTEM POWERING AN ELECTRICAL GENERATOR

**CONDITIONS**

1. All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants. [District Rule 2201]
2. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. {14} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
4. {15} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
5. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. {4261} This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702]
7. {3203} This engine shall be operated within the ranges that the source testing has shown result in pollution concentrations within the emissions limits as specified on this permit. [District Rule 4702]
8. This engine shall be fired on digester gas fuel only. [District Rule 2201]

CONDITIONS CONTINUE ON NEXT PAGE

**YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT.** This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

**Arnaud Marjolle, Director of Permit Services**

C-9169-3-0 Jun 5 2018 11:38AM - YOSHIMUJ Joint Inspection NOT Required

9. The sulfur content of the digester gas used as fuel in this engine shall not exceed 40 ppmv as H<sub>2</sub>S. The applicant may utilize an averaging period of up to 24 hours in length for demonstration of compliance with the fuel sulfur content limit. [District Rules 2201, 4102, 4702, and 4801]
10. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 2201 and 4702]
11. The owner/operator shall minimize the emissions from the engine to the maximum extent possible during the commissioning period. [District Rule 2201]
12. Commissioning activities are defined as, but not limited to, all adjustment, tuning, and calibration activities recommended by the equipment manufacturers and the construction contractor to ensure safe and reliable operation of the reciprocating IC engine, emission control equipment, and associated electrical delivery systems. [District Rule 2201]
13. Commissioning period shall commence when all mechanical, electrical, and control systems are installed and individual system startup has been completed, or when the engine is first fired, whichever occurs first. The commissioning period shall terminate when the initial engine tuning has completed and the engine is available for commercial operation. The total duration of the commissioning period for this engine shall not exceed 120 hours of operation of the engine. [District Rule 2201]
14. The total number of firing hours of this unit without abatement of emissions by the SCR system and oxidation catalyst shall not exceed 120 hours during the commissioning period. Such operation of this unit without abatement shall be limited to discrete commissioning activities that can only be properly executed without the SCR system or oxidation catalyst. Upon completion of these activities, the permittee shall provide written notice to the District and the unused balance of the 120 firing hours without abatement shall expire. [District Rule 2201]
15. At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the engine shall be tuned to minimize emissions. [District Rule 2201]
16. At the earliest feasible opportunity, in accordance with the recommendations of the equipment supplier and the construction contractor, the Selective Catalytic Reduction (SCR) system and oxidation catalyst shall be installed, adjusted, and operated to minimize emissions from this unit. [District Rule 2201]
17. The permittee shall submit a summary of activities to be performed during the commissioning period to the District at least two weeks prior to the first firing of this engine. The summary shall include a list of each commissioning activity, the anticipated duration of each activity in hours, and the purpose of the activity. The activities described shall include, but are not limited to, the tuning of the engine, the installation and operation of the SCR system, the installation, calibration, and testing of emissions monitors, and any activities requiring the firing of this unit without abatement by the SCR system. [District Rule 2201]
18. Emission rates from this engine unit during the commissioning period shall not exceed any of the following limits: 1.0 g-NO<sub>x</sub>/bhp-hr, 0.1 g-PM<sub>10</sub>/bhp-hr, 4.85 g-CO/bhp-hr, or 1.0 g-VOC/bhp-hr. [District Rule 2201]
19. The permittee shall record total operating time of the engine in hours during the commissioning period. [District Rule 2201]
20. After the commissioning period, emissions from this IC engine shall not exceed any of the following limits: 0.15 g-NO<sub>x</sub>/bhp-hr (equivalent to 11 ppmvd NO<sub>x</sub> @ 15% O<sub>2</sub>), NO<sub>x</sub> referenced as NO<sub>2</sub>; 0.10 g-PM<sub>10</sub>/bhp-hr; 0.65 g-CO/bhp-hr (equivalent to 210 ppmvd CO @ 15% O<sub>2</sub>); or 0.10 g-VOC/bhp-hr (equivalent to 21 ppmvd VOC @ 15% O<sub>2</sub>), VOC referenced as CH<sub>4</sub>. [District Rules 2201 and 4702]
21. The SCR catalyst shall be maintained and replaced in accordance with the recommendations of the catalyst manufacturer or emission control supplier. Records of catalyst maintenance and replacement shall be maintained. [District Rules 2201 and 4702]
22. Air-to-fuel ratio controller(s) shall be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times. [District Rule 2201]
23. Ammonia (NH<sub>3</sub>) emissions from this engine shall not exceed 10 ppmvd @ 15% O<sub>2</sub>. [District Rules 2201 and 4102]
24. Source testing to measure NO<sub>x</sub>, CO, VOC, PM<sub>10</sub>, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted within 60 days upon end of the commissioning period. [District Rules 1081, 2201, and 4702]

DRAFT  
CONDITIONS CONTINUE ON NEXT PAGE

25. Source testing to measure NO<sub>x</sub>, CO, VOC, and ammonia (NH<sub>3</sub>) emissions from this unit shall be conducted at least once every 24 months. [District Rules 1081, 2201, and 4702]
26. Fuel sulfur content analysis shall be performed at least annually using EPA Method 11 or EPA Method 15, as appropriate. Records of the fuel sulfur content analysis shall be maintained and provided to the District upon request. [District Rules 2201 and 4702]
27. {3791} Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rule 4702]
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. NO<sub>x</sub>, CO, VOC, and NH<sub>3</sub> concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 2201 and 4702]
29. The following methods shall be used for source testing: NO<sub>x</sub> (ppmv) - EPA Method 7E or ARB Method 100; CO (ppmv) - EPA Method 10 or ARB Method 100; VOC (ppmv) - EPA Method 18, 25A or 25B, or ARB Method 100; stack gas oxygen - EPA Method 3 or 3A or ARB Method 100; stack gas velocity - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4; PM<sub>10</sub> (filterable and condensable) - EPA Method 201 and 202, EPA Method 201a and 202, or ARB Method 5 in combination with Method 501; NH<sub>3</sub> - BAAQMD ST-1B or SCAQMD Method 207-1. Alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [District Rules 1081 and 4702]
30. The Higher Heating Value (HHV) of the fuel gas shall be determined using ASTM D1826, ASTM 1945 in conjunction with ASTM D3588, or an alternative method approved by the District. [District Rules 2201 and 4702]
31. {109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]
32. The results of each source test shall be submitted to the District within 60 days after completion of the source test. [District Rule 1081]
33. The sulfur content of the digester gas used to fuel the engine shall be monitored and recorded at least once every calendar quarter in which a fuel sulfur analysis is not performed. If quarterly monitoring shows a violation of the fuel sulfur content limit of this permit, monthly monitoring will be required until six consecutive months of monitoring show compliance with the fuel sulfur content limit. Once compliance with the fuel sulfur content limit is shown for six consecutive months, then the monitoring frequency may return to quarterly. Monitoring of the sulfur content of the digester gas fuel shall not be required if the engine does not operate during that period. Records of the results of monitoring of the digester gas fuel sulfur content shall be maintained. [District Rules 2201 and 4702]
34. Monitoring of the digester gas sulfur content shall be performed using gas detection tubes calibrated for H<sub>2</sub>S; a digital analyzer approved for gaseous fuel analysis; a continuous fuel gas monitor that meets the requirements specified in SCAQMD Rule 431.1, Attachment A; District-approved source test methods, including EPA Method 15, ASTM Method D1072, D4084, and D5504; District-approved in-line H<sub>2</sub>S monitors; or an alternative method approved by the District. Prior to utilization of in-line monitors to demonstrate compliance with the digester gas sulfur content limit of this permit, the permittee shall submit details of the proposed monitoring system, including the make, model, and detection limits, to the District and obtain District approval for the proposed monitor(s). [District Rules 2201 and 4702]
35. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO<sub>x</sub>, CO, and O<sub>2</sub> analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Emission Monitoring and Testing. [District Rule 1081]

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

36. The permittee shall monitor and record the stack concentration of NO<sub>x</sub>, CO, and O<sub>2</sub> at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall be performed not less than once every month for 12 months if two consecutive deviations are observed during quarterly monitoring. Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month if on a monthly monitoring schedule, or within the last quarter if on a quarterly monitoring schedule. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4702]
37. The permittee shall monitor and record the stack concentration of NH<sub>3</sub> at least once every calendar quarter in which a source test is not performed. NH<sub>3</sub> monitoring shall be conducted utilizing District approved gas-detection tubes or a District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last quarter. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2201 and 4102]
38. If the NO<sub>x</sub>, CO, or NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, as measured by the portable analyzer or the District-approved ammonia monitoring equipment, exceed the respective permitted emissions concentration(s), the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 8 hours of operation after detection. If the portable analyzer or ammonia monitoring equipment readings continue to exceed the permitted emissions concentration(s) after 8 hours of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2201 and 4702]
39. {3787} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rule 4702]
40. The permittee shall maintain records of: (1) the date and time of NO<sub>x</sub>, CO, O<sub>2</sub>, and NH<sub>3</sub> measurements, (2) the O<sub>2</sub> concentration in percent and the measured NO<sub>x</sub>, CO, and NH<sub>3</sub> concentrations corrected to 15% O<sub>2</sub>, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, (5) the method of determining the NH<sub>3</sub> emission concentration, and (6) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 2201 and 4702]
41. The permittee shall monitor and record the SCR system reagent injection rate and the engine operating load at least once per month. [District Rule 4702]
42. During initial performance testing, the SCR system reagent injection rate shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable SCR system reagent injection rate(s) demonstrated during the initial performance test that result in compliance with the NO<sub>x</sub> emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

43. If the SCR system reagent injection rate is outside of the established acceptable range, the permittee shall return the SCR system reagent injection rate to within the established acceptable range as soon as possible, but no longer than 8 hours after detection. If the SCR system reagent injection rate is not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of NO<sub>x</sub> and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of NO<sub>x</sub> and O<sub>2</sub> shall continue until the operator can show that the SCR system reagent injection rate is returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
44. During initial performance testing, the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system shall be monitored concurrently with each testing run to establish acceptable values and ranges that provide a reasonable assurance of ongoing compliance with the emissions limitations stated in this permit. Acceptable values and ranges shall be established for each load that the engine is expected to operate at, in a minimum of 10% increments (e.g. 70%, 80%, and 90%). The acceptable inlet temperature and back pressure demonstrated during the initial compliance test that result in compliance with the CO and VOC emission limits shall be imposed as a condition in the final Permit to Operate. [District Rule 4702]
45. The permittee shall monitor and record the inlet temperature to the SCR system, the back pressure of the exhaust upstream of the catalyst control system, and the engine operating load at least once per month. [District Rule 4702]
46. If the inlet temperature to the catalyst control system and/or the back pressure of the exhaust upstream of the catalyst control system is outside of the established acceptable ranges established during the initial compliance test, the permittee shall return the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system back to the acceptable range as soon as possible, but no longer than 8 hours after detection. If the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are not returned to within acceptable range within 8 hours, the permittee shall notify the District within the following 1 hour and begin monitoring and recording the stack concentration of CO and O<sub>2</sub> at least once every month. Monthly monitoring of the stack concentration of CO and O<sub>2</sub> shall continue until the operator can show that the inlet temperature to the catalyst control system and the back pressure of the exhaust upstream of the catalyst control system are returned to operating within the acceptable ranges specified within this permit. [District Rule 4702]
47. {3212} The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702]
48. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of fuel used during commissioning period(s), the type and quantity of fuel used during normal operation, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201 and 4702]
49. {4051} The permittee shall record the total time the engine operates, in hours per calendar year. [District Rule 2201]
50. Records of any analyzer(s) installed or utilized to monitor methane, oxygen, and hydrogen sulfide shall be maintained and shall be made available for District inspection upon request. [District Rule 2201]
51. All records shall be maintained and retained for a minimum of five (5) years, and shall be made available for District inspection upon request. All records may be maintained and submitted in an electronic format approved by the District. [District Rules 2201 and 4702]

DRAFT



**APPENDIX B**  
**BACT Guideline**

**SJVAPCD Best Available Control Technology (BACT) Guideline 3.3.15\***  
 Last Update: XX/XX/2013

**Waste Gas-Fired IC Engine\*\***

Pollutant	Achieved in Practice or contained in SIP	Technologically Feasible	Alternate Basic Equipment
NO <sub>x</sub>	0.15 g/bhp-hr (lean-burn engine with SCR, rich-burn engine with 3-way catalyst, or other equivalent)		1. Fuel Cells (<0.05 lb/MW-hr) 2. Microturbines (<9 ppmv @ 15% O <sub>2</sub> ) 3. Gas Turbine (<9 ppmv @ 15% O <sub>2</sub> ) (Note: gas turbines only ABE for projects ≥ 3 MW)
SO <sub>x</sub>	Sulfur content of fuel gas ≤ 40 ppmv (as H <sub>2</sub> S) (dry absorption, wet absorption, chemical H <sub>2</sub> S reduction, water scrubber, or equivalent) (may be averaged up to 24 hours for compliance)		
PM <sub>10</sub>	Sulfur content of fuel gas ≤ 40 ppmv (as H <sub>2</sub> S)		
CO	2.0 g/bhp-hr		1. Fuel Cells (<0.10 lb/MW-hr) 2. Microturbines (<60 ppmv @ 15% O <sub>2</sub> ) 3. Gas Turbine (<60 ppmv @ 15% O <sub>2</sub> ) (Note: gas turbines only ABE for projects ≥ 3 MW)
VOC	0.10 g/bhp-hr (lean burn and positive crankcase ventilation (PCV) or a 90% efficient crankcase control device or equivalent)		Fuel Cells (<0.02 lb-VOC/MW-hr as CH <sub>4</sub> )

\*\* For the purposes of this determination, waste gas is a gas produced from the digestion of material excluding municipal sources such as waste water treatment plants, landfills, or any source where siloxane impurities are a concern.

BACT is the most stringent control technique for the emissions unit and class of source. Control techniques that are not achieved in practice or contained in a state implementation plan must be cost effective as well as feasible. Economic analysis to demonstrate cost effectiveness is required for all determinations that are not achieved in practice or contained in an EPA approved State Implementation Plan.

**\*This is a Summary Page for this Class of Source - Permit Specific BACT Determinations on Next Pages**

**APPENDIX C**  
**Top Down BACT Analysis**

## Top-Down BACT Analyses for the Digester Gas-Fired Engine

As stated above, the information from the existing District BACT Guideline 3.3.15 for Waste Gas-Fired IC Engines will be utilized for the BACT analysis for the proposed engine.

### I. BACT Analysis for NO<sub>x</sub> Emissions:

#### a. Step 1 - List all control technologies

- 1) NO<sub>x</sub> emissions ≤ 0.15 g/bhp-hr = 10 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub><sup>4</sup> (lean-burn engine with SCR, rich-burn engine with 3-way catalyst, or other equivalent) (Achieved in Practice)
- 2) Fuel Cell (≤ 0.05 lb/MW-hr = 1.1 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub><sup>5</sup>) (Alternate Basic Equipment)
- 3) Microturbine (< 9 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)
- 4) Gas Turbine (< 9 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)

#### Description of Control Technologies

##### 1) NO<sub>x</sub> emissions ≤ 0.15 g/bhp-hr (10 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Selective Catalytic Reduction (SCR) or equivalent) (Achieved in Practice)

A Selective Catalytic Reduction (SCR) system operates as an external control device where flue gases and a reagent (e.g. urea or ammonia) are passed through an appropriate catalyst. The reagent is used to reduce NO<sub>x</sub>, over the catalyst bed, to form elemental nitrogen, water vapor, and other by-products. The use of a catalyst typically reduces the NO<sub>x</sub> emissions by up to 90%.

##### 2) Fuel Cell (≤ 0.05 lb- NO<sub>x</sub>/MW-hr) (Alternate Basic Equipment)

Fuel cells use an electrochemical process to produce a direct electric current without the combustion of fuel. Fuel cells use externally supplied reactant gases (hydrogen and oxygen) that are combined in a catalytic process. Like a battery, the electric potential generated by a fuel cell is accessed by connecting an external load to the anode and cathode plates of the fuel cell. Because the fuel for a fuel cell is supplied externally, it does not run down like a battery. However, the fuel cell stack must be periodically replaced because of deactivation of catalytic materials contained in the fuel cell, which results in reduced conversion efficiencies. Since fuel cells require pure hydrogen gas

$$^4 \frac{0.15 \text{ g NO}_x}{\text{bhp} - \text{hr}} \times \frac{\text{MMBtu}}{9,100 \text{ dscf}} \times \frac{30\%}{1} \times \frac{1 \text{ lb} - \text{mol}}{46 \text{ lb}} \times \frac{20.9 - 15}{20.9} \times \frac{379.5 \text{ dscf}}{1 \text{ lb mol}} \times \frac{393.75 \text{ bhp} - \text{hr}}{\text{MMBtu}} \times \frac{\text{lb}}{453.6 \text{ g}} = 10 \text{ ppmv @ 15 \% O}_2$$

$$^5 \frac{0.05 \text{ lb NO}_x}{\text{MW} - \text{hr}} \times \frac{\text{MW}}{1,341 \text{ bhp}} \times \frac{\text{MMBtu}}{9,100 \text{ dscf}} \times \frac{30\%}{1} \times \frac{1 \text{ lb} - \text{mol}}{46 \text{ lb}} \times \frac{20.9 - 15}{20.9} \times \frac{379.5 \text{ dscf}}{1 \text{ lb mol}} \times \frac{393.75 \text{ bhp} - \text{hr}}{\text{MMBtu}} = 1.1 \text{ ppmv @ 15 \% O}_2$$

for fuel, hydrocarbons used to power fuel cells must be purified and reformed prior to use. The reformation process can occur in an external fuel processor or through internal reforming in the fuel cell. Both molten carbonate fuel cells and solid oxide fuel cells can internally reform the hydrocarbon fuel to hydrogen for use in the fuel cell. Additionally, these high temperature fuel cells are tolerant of CO<sub>2</sub> that is found in digester gas.

Fuel cells have recently been commercialized and offer the advantages of high efficiency, nearly negligible emissions, and very quiet power generation. The greatest deterrent to increased use of fuel cells is the significantly higher expense when compared to other generation technologies. These higher costs include the initial capital expense and, for digester gas installations, the increased ongoing expenses associated with the extensive cleanup required to remove contaminants that can poison fuel cell catalysts. Although this expense can be substantial, digester gas -fueled fuel cells have been installed at some wastewater treatment plants and fuel cells have also been fueled with other types of biogas (e.g. landfill gas and brewery wastewater gas).

### **3) Gas Turbine (< 9 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)**

Gas turbines are internal combustion engines that operate on the Brayton (Joule) combustion cycle rather than the Otto combustion cycle used in reciprocating internal combustion engines or the diesel cycle for diesel engines. In the Brayton cycle the air flow and fuel injection are steady, and the different parts of the cycle occur continuously within different components of the system. In a gas turbine, fuel is continually injected into the combustion chamber or combustor and air is constantly drawn into the turbine and compressed. All elements of the Brayton cycle occur simultaneously in a gas turbine.

Gas turbines are one of the cleanest means of generating electricity. With the use of lean pre-mixed combustion or catalytic exhaust cleanup, NO<sub>x</sub> emissions from large gas-fired turbines are generally in the single-digit ppmv range. These levels are generally for natural gas-fired units but they are considered technologically feasible for digester gas -fired units.

Gas turbines are available in sizes ranging from 500 kW - 25 MW. Based on contacts with turbine suppliers, biogas-fired turbines used to produce electricity are expected to be available in the size range of 2 - 7 MW. According to Solar Turbines, the smaller digester gas -fired turbines are no longer actively produced or marketed since this size range is generally covered by other generation technologies such as reciprocating IC engines and microturbines.

### **4) Microturbine (< 9 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)**

Microturbines are small gas turbines rated between 25 kW and 500 kW that burn gaseous and liquid fuels to generate electricity or provide mechanical power. Microturbines were developed from turbocharger technologies found in large trucks and the turbines in aircraft auxiliary power units. Microturbines can be operated on a wide variety of fuels, including natural gas, liquefied petroleum gas, gasoline, diesel, landfill gas, and digester gases. According to the California Air Resources Board (ARB), there

were approximately 200 digester gas -fired microturbines operating in California as of the year 2006.<sup>6</sup> Microturbines generally have electrical efficiencies of 25 - 30%; however, the electrical efficiency of larger microturbines ( $\geq 200$  kW) can range from 30 - 33%. Microturbine manufacturers include Capstone Microturbines and FlexEnergy.

Microturbines without add-on controls can meet very stringent emission limits and have significantly lower emissions of NO<sub>x</sub>, CO, and VOC than uncontrolled reciprocating engines because most microturbines operating on gaseous fuels utilize lean premixed (dry low NO<sub>x</sub>, or DLN) combustion technology. Microturbines manufacturers will generally guarantee NO<sub>x</sub> emissions of 9 - 15 ppmv @ 15% O<sub>2</sub>. However, several emission tests performed on digester gas -fired microturbines have demonstrated even lower emissions. A small number of dairy digester gas-fired microturbines have been installed<sup>7</sup>, including Twin Birch Dairy and New Hope Farm View dairy and Twin Birch Dairy in New York, and den Dulk Dairy in Michigan.

The proposed project is for a large waste gas to energy facility and, although larger microturbines have recently become available, several microturbines (at least 5) would still be required to replace each engine. The applicant states that when they investigated microturbines they found that there were difficulties related to the loss of power and efficiency because of heat de-rating in warmer climates and the very high pressure requirement and parasitic load, which increased overall costs. In addition, a different applicant for digester gas projects recently permitted by the District (Projects S-1143770 and S-1143771) indicated that when they investigated microturbines they found that they could not secure the necessary financing for a waste gas to energy project of this size using microturbines and that the major microturbines vendors were unable to secure the debt. Although microturbines may not currently be a practical option for this particular project, they will be considered in the cost analysis below.

## **b. Step 2 - Eliminate technologically infeasible options**

### Option 3 - Gas Turbine ( $\leq 9$ ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)

Option 3, Gas Turbine, was determined to be infeasible for the proposed project because the available information indicates that the principal suppliers of gas turbines (Solar Turbines, Allison, and General Electric) do not currently produce or market waste gas-fired gas turbines rated less than 3 MW since this size range is generally covered by other generation technologies such as reciprocating IC engines and microturbines.

The cost information given in the US EPA Combined Heat and Power Partnership Catalog of CHP Technologies<sup>8</sup> (March 2015) and the SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]<sup>9</sup> (October 5, 2015) also supports that gas turbines rated approximately 3 MW are not generally available. The

---

<sup>6</sup> "Staff Report: Initial Statement of Reasons for Proposed Amendments to the Distributed Generation Certification Regulation" (9/1/2006), Cal EPA - ARB, Executive Summary Pg. ii (<http://www.arb.ca.gov/regact/dg06/dgisor.pdf>)

<sup>7</sup> See EPA AgStar Program "AgStar Project Profiles", <http://www2.epa.gov/agstar/agstar-project-profiles>

<sup>8</sup> US EPA Combined Heat and Power Partnership "Catalog of CHP Technologies" (March 2015)  
<http://www.epa.gov/chp/catalog-chp-technologies>

<sup>9</sup> SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] (October 5, 2015)  
<http://www.cpuc.ca.gov/WorkArea/DownloadAsset.aspx?id=7889>

smallest turbine for which the US EPA Combined Heat and Power Partnership Catalog of CHP Technologies provides cost information is 3,304 kW and the smallest turbine for which the SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] provides cost information is 2,500 kW.

The proposed project would require a gas turbine rated 1,000 kW, which is below the range that is currently being marketed by turbine manufacturers; therefore, gas turbines are not considered feasible for this particular project and will be eliminated from consideration at this time.

**c. Step 3 - Rank remaining options by control effectiveness**

- 1) Fuel Cell ( $\leq 0.05$  lb/MW-hr  $\approx 1.5$  ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)
- 2) Digester gas-fueled microturbines (Alternate Basic Equipment)
- 3) NO<sub>x</sub> emissions  $\leq 0.15$  g/bhp-hr (lean-burn engine with SCR, rich-burn engine with 3-way catalyst, or other equivalent) (Achieved in Practice)

**d. Step 4 - Cost Effectiveness Analysis**

Pursuant to Section IX.D of District Policy APR 1305 – BACT Policy, a cost effectiveness analysis is required for the options that have not been determined to be achieved in practice. In accordance with the District's Revised BACT Cost Effectiveness Thresholds Memo (5/14/08), to determine the cost effectiveness of particular technologically feasible control options or alternate equipment options, the amount of emissions resulting from each option will be quantified and compared to the District Standard Emissions allowed by the District Rule that is applicable to the particular unit. The emission reductions will be equal to the difference between the District Standard Emissions and the emissions resulting from the particular option being evaluated.

The District has determined that the proposed digester gas-fueled IC engines are non-agricultural IC engines. The lean burn, digester gas-fired, engines are subject to the following emission limits for non-agricultural, lean burn, waste gas fueled IC engines contained in District Rule 4702, Section 5.2.2, Table 2, 2.e: 11 ppmvd NO<sub>x</sub>, 2,000 ppmvd CO, and 750 ppmvd VOC (all measured @ 15% O<sub>2</sub>). The proposed digester engine is also subject to the New Source Performance Standards (NSPS) for IC Engines contained in 40 CFR 60 Subpart JJJJ, which includes a VOC emissions limit of 1.0 g/bhp-hr (or 80 ppmv @ 15% O<sub>2</sub> reported as propane) for landfill and digester gas-fired IC engines. Therefore, the District Standard Emissions used for the BACT cost analysis below for the proposed engine will be based on the emission limits contained in these applicable regulations.

Option 1: Fuel Cells ( $\leq 0.05$  lb/MW-hr  $\approx 1.5$  ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>) (Alternate Basic Equipment)

Because fuel cells have reduced NO<sub>x</sub> and VOC emissions in comparison to a reciprocating IC engine, a Multi-Pollutant Cost Effectiveness Threshold (MCET) will be

used to determine if this option is cost-effective. The following cost analysis will examine if the replacement of the proposed engine with a fuel cell is cost effective even when the additional operation costs of a fuel cell are not considered.

### Assumptions

- Digester Gas F-Factor: 9,100 dscf/MMBtu (dry, adjusted to 60 °F)
- Higher Heating Value for Dairy Digester Gas: 700 Btu/scf
- Molar Specific Volume = 379.5 scf/lb-mol (at 60°F)
- Price for electricity: \$127.72/MW-hr (*based on the California Bioenergy Market Adjusting Tariff (BioMAT) initial contract price offered by Investor Owned Utilities (PG&E, SCE, and SDG&E)*<sup>10</sup> beginning June 1, 2016)
- MMBtu/hr to bhp conversion: 392.75 (per AP-42, Appendix A)
- Btu to kW-hr conversion: 3,413 Btu/kW-hr (per AP-42, Appendix A)
- The initial capital costs and the operation costs for the digester gas-fueled IC engine and fuel cell will be based on information given in the US EPA Combined Heat and Power Partnership Catalog of CHP Technologies<sup>8</sup> and the SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]<sup>9</sup>
- Because the US EPA Combined Heat and Power Partnership Catalog of CHP Technologies only provides cost information for natural gas-fueled engines and fuel cells, additional capital costs for the use of digester gas are taken from the SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]<sup>9</sup>

### Assumptions for the Proposed Digester Gas-Fired IC Engines

- The engines will operate at full load for 24 hours/day and 8,760 hours/year
- Typical thermal efficiencies for IC engines range from 30-35%. A worst case thermal efficiency of 30% will be used.
- The maximum total daily heating value of the digester gas used by the engine will be: 287.6 MMBtu/day ( $1,412 \text{ bhp}_{out}/\text{engine} \times 1 \text{ bhp}_{in}/0.30 \text{ bhp}_{out} \times 1 \text{ MMBtu}_{in}/392.75 \text{ bhp}_{in}\text{-hr} \times 24 \text{ hr}/\text{day}$ )
- The maximum total annual heating value for of the digester gas used by the engine will be: 104,979 MMBtu/year ( $1,412 \text{ bhp}_{out}/\text{engine} \times 1 \text{ bhp}_{in}/0.30 \text{ bhp}_{out} \times 1 \text{ MMBtu}_{in}/392.75 \text{ bhp}_{in}\text{-hr} \times 8,760 \text{ hr}/\text{year}$ )
- Estimated purchase and installation cost for CHP IC engine rated approximately 1,028 kW without add-on air pollution control equipment: \$1,223/kW (*average of interpolated values from US EPA Combined Heat and Power Partnership Catalog of CHP Technologies on page 2-15 and SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] on page A-33*)

<sup>10</sup> See: <http://www.pge.com/en/b2b/energysupply/wholesaleelectricssuppliersolicitation/BioMAT/index.page>, <https://scebiomat.accionpower.com/biomat/home.asp>, and <http://www.sdge.com/procurement/bioenergy-market-adjusting-tariff-bio-mat>



- Additional capital investment for digester gas conditioning and cleanup for the engine: \$387/kW (*SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]*)
- Total Installation Cost for digester-fueled IC engine rated 1,028 kW: \$1,610/kW
- Estimated operation costs for CHP IC engine rated 1,028 kW without add-on air pollution control costs: \$0.028/kW-hr (*average of interpolated values from US EPA Combined Heat and Power Partnership Catalog of CHP Technologies on page 2-17 and SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] on page A-33*)
- The SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] indicates that biogas conditioning/cleanup costs are highly dependent on the quantity of biogas being processed and contaminants being removed and that the differences in clean-up costs for digester gas-fired IC engines, microturbines, and gas turbines “reflect the greater rigor in the removal of the hydrogen sulfide”. The digester gas used to fuel the engine must be limited to a sulfur content of no more than 40 ppmv as H<sub>2</sub>S to satisfy BACT for SO<sub>x</sub>. Because required level of sulfur removal is adequate for use in the engine, there will be no increase in operating costs related to cleaning the digester gas for use in the engine.
- Rule 4702 NO<sub>x</sub> emission limit for non-agricultural, lean burn IC engines: 65 ppmv @ 15% O<sub>2</sub> = 0.2540 lb/MMBtu
- Rule 4702 VOC emission limit for non-agricultural, lean burn IC engines: 750 ppmv @ 15% O<sub>2</sub> as CH<sub>4</sub> = 1.0193 lb/MMBtu
- 40 CFR 60 Subpart JJJJ VOC emission limit for landfill and digester gas-fired IC engines: 1.0 g/bhp-hr (or 80 ppmv @ 15% O<sub>2</sub> reported as propane)

#### Assumptions for Fuel Cell System

- Net electrical efficiency for a molten carbonate fuel cell (MCFC): 45% (*US EPA Combined Heat and Power Partnership Catalog of CHP Technologies gives efficiencies of 47% for a 300 kW MCFC and 42.5% for a 1,400 kW MCFC*)
- Size of fuel cell system needed to replace the proposed engine: 1,581 kW (estimated based on 287.6 MMBtu/day and 45% efficiency<sup>11</sup>)
- Estimated Purchase and Installation Cost for Molten Carbonate Fuel Cell: \$4,474/kW (*Average of the two costs for largest Molten Carbonate Fuel Cells given in US EPA Combined Heat and Power Partnership document Catalog of CHP Technologies on page 6-16 and SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report] on page A-13; The U.S. Department of Energy Federal energy management Program (FEMP) document “Fuel Cells and Renewable Energy” (last updated 12-1-2014 and available at: <http://www.wbdg.org/resources/fuelcell.php>) states, “Installation costs of a fuel cell system can range from \$5,000/kW to \$10,000/kW.” Therefore, this estimate may be actually too low based on the recently reported costs for fuel cell power plants, such as the “Bloom Box”.*)

---

<sup>11</sup>  $\frac{287.6 \text{ MMBtu}}{\text{day}} \times \frac{\text{kW} \cdot \text{hr}}{3,410 \text{ Btu}} \times \frac{10^6 \text{ Btu}}{\text{MMBtu}} \times \frac{\text{day}}{24 \text{ hrs}} \times 45\% = 1,581 \text{ kW}$

- Additional capital investment for digester gas conditioning and cleanup for the fuel cell: \$563/kW (*SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]*)
- Total Installation Cost for digester gas-fueled fuel cells rated  $\geq 1,200$  kW (the larger the capacity, the cheaper the cost) will be used: \$5,037/kW
- Typical operation costs for natural gas-fueled fuel cells, including stack replacement costs: \$0.04/kW-hr (*SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]*)
- Additional operational costs for digester gas conditioning and cleanup for large fuel cells: \$0.15/kW-hr (*SGIP 2015 Self-Generation Incentive Program Cost Effectiveness Study [Final Report]*)
- Total Operation Cost for digester gas-fueled fuel cells rated  $\geq 1,200$  kW: \$0.19/kW-hr
- Unlike the proposed engines, a high-temperature fuel cell power plant must primarily operate at steady state conditions; there would not be the ability to store gas to generate more electricity during peak hours, which is the current business plan of the applicant. Because the price paid for electricity is greater during peak hours and less during other times, the price paid for electricity generated by a fuel cell power plant would be less. This would require the operator to alter their plans of operation and result in less revenue per kW-hr of electricity generated potentially offsetting the revenue from increased power generating capacity because of the higher efficiency of a fuel cell power plant. For more conservative analysis, the difference in the cost of peak and off-peak electricity was not considered in this comparison.

#### Capital Cost

The estimated increased incremental capital cost for replacement of the proposed engines with a fuel cell is calculated based on the difference in cost of a fuel cell power plant and the proposed IC engines.

The incremental capital cost for replacement of the proposed IC engines with a fuel cell power plant is calculated as follows:

$$(1,581 \text{ kW} \times \$5,037/\text{kW}) - (1,028 \text{ kW} \times \$1,610/\text{kW}) = \$6,308,417$$

#### Annualized Capital Cost

Pursuant to District Policy APR 1305, section X (11/09/99), the incremental capital cost for the purchase of the fuel cell system will be spread over the expected life of the system using the capital recovery equation. The expected life of the entire system will be estimated at 10 years. A 10% interest rate is assumed in the equation and the assumption will be made that the equipment has no salvage value at the end of the ten-year cycle.

$$A = [P \times i(1+i)^n]/[(1+i)^n - 1]$$

Where: A = Annual Cost  
P = Present Value  
i = Interest Rate (10%)

N = Equipment Life (10 years)

A =  $[\$6,308,417 \times 0.1(1.1)^{10}]/[(1.1)^{10}-1]$   
= **\$1,028,272/year**

### Annual Costs

#### Annual Operation and Maintenance Cost

The annual operation and maintenance costs for each option are calculated as follows:

#### Proposed 1,000 IC kW Engine

8,760,000 kW-hr/yr x \$0.028/kW-hr = \$245,280/year

#### Fuel Cells (Alternate Equipment)

12,435,500 kW-hr/yr x \$0.19/kW-hr = \$2,362,745/year

#### Annual Costs of Increased Maintenance

\$2,362,745/yr - \$245,280/yr = \$2,117,465/year

#### Total Increased Annual Costs for Fuel Cell as an Alternative to the Proposed Engine

\$1,028,272/year + \$2,362,745/year = **\$3,391,017/year**

### Emission Reductions

#### NO<sub>x</sub> and VOC Emission Factors

Pursuant to the District's Revised BACT Cost Effectiveness Thresholds Memo (5/14/08), District Standard Emissions that will be used to calculate the emission reductions from alternative equipment.

The District Standard Emissions for NO<sub>x</sub> emissions from the engines will be based on the NO<sub>x</sub> emission limit for non-agricultural, lean burn IC engines from District Rule 4702, Section 5.2.1, Table 1, 2. e. The District Standard Emissions for VOC emissions from the engines will be based on the New Source Performance Standard (NSPS) VOC emission limit for landfill and digester gas-fired IC engines from 40 CFR 60 Subpart JJJJ, since this limit is more stringent than the applicable emission limit in District Rule 4702.

The following emissions factors will be used for the cost analysis:

#### District Standard Emissions

0.165 lb-NO<sub>x</sub>/MMBtu (11 ppmv NO<sub>x</sub> @ 15% O<sub>2</sub>)

0.111 lb-VOC/MMBtu (75 ppmv VOC @ 15% O<sub>2</sub>)

### Emissions from Fuel Cells as Alternative Equipment

0.016 lb-NO<sub>x</sub>/MMBtu (0.05 lb-NO<sub>x</sub>/MW-hr)  
0.006 lb-VOC/MMBtu (0.02 lb-VOC/MW-hr)

### Emission Reductions

#### Each Proposed Engine Compared to Fuel Cells based on District Standard Emission Reductions

##### NO<sub>x</sub> Emission Reductions (65 ppmv @ 15% O<sub>2</sub> → 0.05 lb-NO<sub>x</sub>/MW-hr)

104,979 MMBtu/year x (0.165 lb-NO<sub>x</sub>/MMBtu – 0.016 lb-NO<sub>x</sub>/MMBtu)  
= 15,642 lb-NO<sub>x</sub>/year (7.8 ton-NO<sub>x</sub>/year)

##### VOC Emission Reductions (1.0 g/bhp-hr → 0.02 lb-VOC/MW-hr)

104,979 MMBtu/year x (0.111 lb-VOC/MMBtu – 0.006 lb-VOC/MMBtu)  
= 11,023 lb-VOC/year (5.5 ton-VOC/year)

#### Multi-Pollutant Cost Effectiveness Thresholds (MCET) for NO<sub>x</sub> and VOC Reductions based on District Standard Emission Reductions

(7.8 ton-NO<sub>x</sub>/year x \$24,500/ton-NO<sub>x</sub>) + (5.5 ton-VOC/year x \$17,500/ton-VOC)  
= **\$287,350/year**

As shown above, the annualized capital cost of this alternate option (\$3,391,017) exceeds the Multi-Pollutant Cost Effectiveness Threshold (MCET) calculated for the NO<sub>x</sub> and VOC emission reductions (\$287,350). Therefore, this option is not cost effective and is being removed from consideration.

#### Options 2 and 3 – Microturbine and IC Engine with NO<sub>x</sub> Emissions ≤ 0.15 g/bhp-hr

The applicant is proposing a NO<sub>x</sub> limit of 0.074 g/bhp-hr. Since this proposed limit is lower than the remaining options, per District BACT Policy APR 1305, Section IX.D.1, a cost effectiveness analysis is not required no further analysis is required.

#### **e. Step 5 - Select BACT**

Pursuant to the above BACT Analysis, BACT for the Digester Gas-fired Engines must be satisfied with the following: NO<sub>x</sub> emissions to 0.15 g/bhp-hr

The applicant has proposed to use an SCR system for the digester gas-fired lean burn IC engine to limit NO<sub>x</sub> emissions to 0.15 g/bhp-hr. Therefore, the BACT requirements are satisfied.

## **2. BACT Analysis for SO<sub>x</sub> Emissions:**

### **a. Step 1 - Identify all control technologies**

The following options were identified to reduce SO<sub>x</sub> emissions from the proposed engine:

- 1) Sulfur Content of fuel gas not exceeding 40 ppmv as H<sub>2</sub>S (Achieved in Practice/Contained in SIP)

There are no options listed in the SJVUAPCD BACT Clearinghouse as alternate basic equipment.

### **b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

### **c. Step 3 - Rank remaining options by control effectiveness**

The control efficiency of each of the options above is estimated and the controls are ranked below based on the control effectiveness.

- 1) Sulfur Content of fuel gas not exceeding 40 ppmv as H<sub>2</sub>S (Achieved in Practice)

### **d. Step 4 - Cost Effectiveness Analysis**

The only option above is achieved practice and has been proposed by the applicant; therefore a cost analysis is not required.

### **e. Step 5 - Select BACT**

Pursuant to the above BACT Analysis, BACT for SO<sub>x</sub> emissions from the proposed engine is fuel gas sulfur content not exceeding 40 ppmv as H<sub>2</sub>S. The applicant has proposed to use addition of iron oxide chemicals to the digester, a biological sulfur removal system, and/or carbon canister scrubbers (or an equivalent sulfur removal system) to reduce the sulfur content of the digester gas combusted in the engines to ≤ 40 ppmv as H<sub>2</sub>S. Therefore, the BACT requirements for SO<sub>x</sub> are satisfied.

### **3. BACT Analysis for PM<sub>10</sub> Emissions:**

#### **a. Step 1 - Identify all control technologies**

Combustion of gaseous fuels generally does not result in significant emissions of particulate matter. Dairy anaerobic digester gas is the planned fuel for the proposed IC engines. The anaerobic digester gas will be composed primarily of methane (approximately 60% molar composition) and CO<sub>2</sub> (approximately 40% molar composition) and is expected to burn in a fairly clean manner. Particulate emissions from combustion of the digester gas are expected to primarily result from the incineration of fuel-born sulfur compounds (mostly H<sub>2</sub>S) resulting in the formation of sulfur-containing particulate. Therefore, scrubbing of the digester gas is the principal means to reduce particulate emissions.

The following control was identified to reduce particulate matter emissions from combustion of the digester gas as fuel in the proposed engines:

- 1) Sulfur Content of fuel  $\leq$  40 ppmv as H<sub>2</sub>S (Achieved in Practice)

#### **b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

#### **c. Step 3 - Rank remaining options by control effectiveness**

- 1) Sulfur Content of fuel gas  $\leq$  40 ppmv as H<sub>2</sub>S (Achieved in Practice)

#### **d. Step 4 - Cost Effectiveness Analysis**

The only option listed above has been identified as achieved in practice. Therefore, the option required and is not subject to a cost analysis.

#### **e. Step 5 - Select BACT**

Pursuant to the above BACT Analysis, BACT for PM<sub>10</sub> emissions from the proposed engine is fuel gas sulfur content not exceeding 40 ppmv as H<sub>2</sub>S. The applicant has proposed to use addition of iron oxide chemicals to the digester, a biological sulfur removal system, and/or carbon canister scrubbers (or an equivalent sulfur removal system) to reduce the sulfur content of the digester gas combusted in the engines to  $\leq$  40 ppmv as H<sub>2</sub>S. Therefore, the BACT requirements for PM<sub>10</sub> are satisfied.

#### **4. BACT Analysis for VOC Emissions:**

##### **a. Step 1 - Identify all control technologies**

The following options were identified to reduce VOC emissions:

- 1) VOC emissions  $\leq$  0.10 g/bhp-hr (lean burn or equivalent and positive crankcase ventilation) (Achieved in Practice)
- 2) Fuel Cell ( $\leq$  0.02 lb/MW-hr) (Alternate Basic Equipment)

##### **b. Step 2 - Eliminate technologically infeasible options**

There are no technologically infeasible options to eliminate from step 1.

##### **c. Step 3 - Rank remaining options by control effectiveness**

- 1) Fuel Cell ( $\leq$  0.02 lb/MW-hr) (Alternate Basic Equipment)
- 2) VOC emissions  $\leq$  0.10 g/bhp-hr (Achieved in Practice)

##### **d. Step 4 - Cost Effectiveness Analysis**

###### Option 1: Fuel Cell ( $\leq$ 0.02 lb/MW-hr VOC as CH<sub>4</sub>) (Alternate Basic Equipment)

The multi-pollutant cost analysis performed above for the NO<sub>x</sub> and VOC emissions demonstrated that the annualized cost of this alternate option exceeds the Multi Pollutant Cost Effectiveness Threshold calculated for the NO<sub>x</sub> and VOC emission reductions achieved by this technology. Therefore, this option is not cost effective and is being removed from consideration.

###### Option 2: VOC emissions $\leq$ 0.10 g/bhp-hr (Achieved in Practice)

This has been identified as achieved in practice and has been proposed by the applicant. Therefore, the option required and is not subject to a cost analysis.

##### **e. Step 5 - Select BACT**

Pursuant to the above BACT Analysis, BACT for VOC emissions from the proposed engines is VOC emissions  $\leq$  0.10 g/bhp-hr. The applicant has proposed IC engines with VOC emissions  $\leq$  0.10 g/bhp-hr. Therefore, the BACT requirements for VOC are satisfied.

**APPENDIX D**  
**HRA/AAQA Summary**



# San Joaquin Valley Air Pollution Control District Risk Management Review

To: John Yoshimura – Permit Services  
 From: Seth Lane – Technical Services  
 Date: June 8, 2017  
 Facility Name: Bar 20 Dairy Biogas LLC  
 Location: 24387 W. Whitesbridge Ave, Kerman  
 Application #(s): C-9169 2-0 & 3-0  
 Project #: C-1170986

---

## A. RMR SUMMARY

RMR Summary						
Units	Prioritization Score	Acute Hazard Index	Chronic Hazard Index	Maximum Individual Cancer Risk	T-BACT Required?	Special Permit Requirements?
Unit 2-0 (Digester)	57	0.21	0.05	4.20E-08	No	Yes
Unit 3-0 (Digester)	57	0.21	0.05	4.20E-08	No	Yes
<b>Project Totals</b>	114	0.42	0.09	8.40E-08		
<b>Facility Totals</b>	>1	0.42	0.09	8.40E-08		

### Proposed Permit Requirements

To ensure that human health risks will not exceed District allowable levels; the following shall be included as requirements for:

#### Unit # 2-0 & 3-0

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction.

## B. RMR REPORT

### I. Project Description

Technical Services received a request on May 5, 2017, to perform an Ambient Air Quality Analysis and a Risk Management Review for a covered anaerobic digester system and two 1,412 bhp digester-fired IC engines. Each engine will be equipped with a selective catalytic reduction (SCR) system for emissions control and will power an electric generator.

## II. Analysis

Technical Services performed a 2-part analysis, the first calculating Toxic emissions for the Dairy Gas Fired internal combustion (4 Stroke Lean Burn) Engine without a catalyst to be operated for a total of 120 hours.

Toxic emissions for this Dairy Gas Fired internal combustion (4 Stroke Lean Burn) Engine were calculated using emission factors from 2000, AP 42, Fifth Edition, Volume I, Chapter 3: Stationary Internal Combustion Sources, Section 2: Natural Gas-Fired Reciprocating Engines and Dairy Biomethane characterization from 2009 report, Pipeline Quality Biomethane: North American Guidance Document for Introduction of Dairy Waste Derived Biomethane Into Existing Natural Gas Networks, and input into the San Joaquin Valley APCD's Hazard Assessment and Reporting Program (SHARP). In accordance with the District's Risk Management Policy for Permitting New and Modified Sources (APR 1905, May 28, 2015), risks from the proposed unit's toxic emissions were prioritized using the procedure in the 1990 CAPCOA Facility Prioritization Guidelines. The prioritization score for this proposed facility was greater than 1.0 (see RMR Summary Table). Therefore, a refined health risk assessment was required. The AERMOD model was used, with the parameters outlined below and meteorological data for 2007-2011 from Mendota to determine the dispersion factors (i.e., the predicted concentration or X divided by the normalized source strength or Q) for a receptor grid. These dispersion factors were input into the SHARP Program, which then used the Air Dispersion Modeling and Risk Tool (ADMRT) of the Hot Spots Analysis and Reporting Program Version 2 (HARP 2) to calculate the chronic and acute hazard indices and the carcinogenic risk for the project.

The following parameters were used for the review:

<b>Analysis Parameters: Unit 2-0 &amp; 3-0 Each</b>			
<b>Source Type</b>	<b>Point</b>	<b>Location Type</b>	<b>Rural</b>
<b>Stack Height (m)</b>	9.14	<b>Closest Receptor (m)</b>	29
<b>Stack Diameter. (m)</b>	0.46	<b>Type of Receptor</b>	Business
<b>Stack Exit Velocity (m/s)</b>	21.84	<b>Max Hours per Year</b>	8500
<b>Stack Exit Temp. (°K)</b>	733	<b>Fuel Type</b>	Dairy Digester Gas
<b>Fuel Usage (120 hrs Commissioning) (MMscf/hr)</b>	0.01	<b>Fuel Usage (120hrs Commissioning) (MMscf/yr)</b>	1.7
<b>NH<sub>3</sub> Commissioning (lbs/hr)</b>	0.15	<b>NH<sub>3</sub> Commissioning (lbs/yr)</b>	19
<b>Fuel Usage Non-Commission (MMscf/hr)</b>	0.01	<b>Fuel Usage Non-Commission (MMscf/yr)</b>	115.3
<b>NH<sub>3</sub> Non-Commission (lbs/hr)</b>	0.15	<b>NH<sub>3</sub> Non-Commission (lbs/yr)</b>	1,345

Technical Services performed modeling for criteria pollutants CO, NO<sub>x</sub>, SO<sub>x</sub>, and PM<sub>10</sub> with the emission rates below:

Unit #	NO <sub>x</sub> (Lbs.)		SO <sub>x</sub> (Lbs.)		CO (Lbs.)		PM <sub>10</sub> (Lbs.)	
	Hr.	Yr.	Hr.	Yr.	Hr.	Yr.	Hr.	Yr.
<b>2-0 &amp; 3-0 (each)</b>	3.11	4,408	0.13	1,091	15.10	19,294	0.31	2,727

The results from the Criteria Pollutant Modeling are as follows:

### Criteria Pollutant Modeling Results\*

	Background Site	1 Hour	3 Hours	8 Hours	24 Hours	Annual
CO	Turlock (2015)	NA <sup>1</sup>	X	NA <sup>1</sup>	X	X
NO <sub>x</sub>	Turlock (2015)	NA <sup>1</sup>	X	X	X	Pass
SO <sub>x</sub>	Fresno – Garland (2015)	NA <sup>1</sup>	NA <sup>1</sup>	X	NA <sup>1</sup>	Pass
PM <sub>10</sub>	Turlock (2015)	X	X	X	NA <sup>1</sup>	Pass <sup>2</sup>
PM <sub>2.5</sub>	Turlock (2015)	X	X	X	NA <sup>1</sup>	Pass <sup>3</sup>

\*Results were taken from the attached PSD spreadsheet.

<sup>1</sup>The project is an intermittent source as defined in APR-1920. In accordance with APR-1920, compliance with short-term (i.e., 1-hour, 3-hour, 8-hour and 24-hour) standards is not required.

<sup>2</sup>The criteria pollutants are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2).

<sup>3</sup>The court has vacated EPA's PM<sub>2.5</sub> SILs. Until such time as new SIL values are approved, the District will use the corresponding PM<sub>10</sub> SILs for both PM<sub>10</sub> and PM<sub>2.5</sub> analyses.

### III. Conclusion

The acute and chronic indices are below 1.0 and the cancer risk factor associated with the project is less than 1.0 in a million. **In accordance with the District's Risk Management Policy, the project is approved without Toxic Best Available Control Technology (T-BACT).**

To ensure that human health risks will not exceed District allowable levels; the permit requirements listed on page 1 of this report must be included for this proposed unit.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

### IV. Attachments

- A. RMR request from the project engineer
- B. Additional information from the applicant/project engineer
- C. Prioritization score w/ toxic emissions summary
- D. Facility Summary
- E. AAQA Report

**APPENDIX E**  
**Quarterly Net Emissions Change (QNEC)**

## Quarterly Net Emissions Change (QNEC)

The Quarterly Net Emissions Change is used to complete the emission profile screen for the District's PAS database. The QNEC shall be calculated as follows:

QNEC = PE2 - PE1, where:

QNEC = Quarterly Net Emissions Change for each emissions unit, lb/qtr.

PE2 = Post Project Potential to Emit for each emissions unit, lb/qtr.

PE1 = Pre-Project Potential to Emit for each emissions unit, lb/qtr.

Using the values in Sections VII.C.2 and VII.C.1 in the evaluation above, quarterly PE2 and quarterly PE1 can be calculated as follows:

$$\begin{aligned} \text{PE2}_{\text{quarterly}} &= \text{PE2}_{\text{annual}} \div 4 \text{ quarters/year} \\ &= 4,408 \text{ lb-NOx/year} \div 4 \text{ qtr/year} \\ &= 1,102.00 \text{ lb-NOx/qtr} \end{aligned}$$

$$\begin{aligned} \text{PE1}_{\text{quarterly}} &= \text{PE1}_{\text{annual}} \div 4 \text{ quarters/year} \\ &= 0 \text{ lb-NOx/year} \div 4 \text{ qtr/year} \\ &= 0 \text{ lb-NOx/qtr} \end{aligned}$$

Quarterly NEC [QNEC] C-9169-1-0			
Pollutant	PE2 (lb/qtr)	PE1 (lb/qtr)	QNEC (lb/qtr)
NO <sub>x</sub>	0	0	0
SO <sub>x</sub>	0	0	0
PM <sub>10</sub>	0	0	0
CO	0	0	0
VOC	0	0	0

Quarterly NEC [QNEC] C-9169-2-0 and '-3-0			
Pollutant	PE2 (lb/qtr)	PE1 (lb/qtr)	QNEC (lb/qtr)
NO <sub>x</sub>	1,102.00	0	1,102.00
SO <sub>x</sub>	272.75	0	272.75
PM <sub>10</sub>	681.75	0	681.75
CO	4823.50	0	4823.50
VOC	766.00	0	766.00