



OCT - 5 2018

Ms. Kristine Boyer
Bear Mountain Limited
34759 Lencioni Avenue
Bakersfield, CA 93308

Re: Notice of Preliminary Decision – Title V Permit Renewal
Facility Number: S-2049
Project Number: S-1173516

Dear Ms. Boyer:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Bear Mountain Limited at 7001 Camino Grande Road in Bakersfield, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,



Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

**SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT**

**Proposed Title V Permit Renewal Evaluation
Bear Mountain Limited
S-2049**

TABLE OF CONTENTS

I.	PROPOSAL	2
II.	FACILITY LOCATION	2
III.	EQUIPMENT LISTING.....	2
IV.	GENERAL PERMIT TEMPLATE USAGE	2
V.	SCOPE OF EPA AND PUBLIC REVIEW.....	3
VI.	FEDERALLY ENFORCEABLE REQUIREMENTS.....	3
VII.	REQUIREMENTS NOT FEDERALLY ENFORCEABLE	4
VIII.	PERMIT REQUIREMENTS.....	5
IX.	PERMIT SHIELD.....	8
X.	CALIFORNIA ENVIRONMENTAL QUALITY ACT	8
XI.	PERMIT CONDITIONS	8
ATTACHMENTS.....		8
A.	DRAFT RENEWED TITLE V OPERATING PERMIT	
B.	PREVIOUS TITLE V OPERATING PERMIT	
C.	DETAILED SUMMARY LIST OF FACILITY PERMITS	

TITLE V PERMIT RENEWAL EVALUATION
Cogeneration

Engineer: David Torii
Date: 9/26/18

Facility Number: S-2049
Facility Name: Bear Mountain Limited
Mailing Address: 34759 Lencioni Avenue
Bakersfield, CA 93308

Contact Name: Kristine Boyer
Phone: 661-387-7828

Responsible Official: Edward Capehart
Title: Plant Manager

Project # : 1173516
Deemed Complete: 10/20/18

I. PROPOSAL

Bear Mountain Limited was issued a Title V permit on 5/1/1998. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and federal rules updated, removed, or added since the previous Title V permit renewal on 11/14/13.

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Bear Mountain Limited is located at 7001 Camino Grande Road, Bakersfield.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment C.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant does not propose to use any model general permit templates.

V. SCOPE OF EPA AND PUBLIC REVIEW

The applicant is not requesting any model general permit templates. Therefore, all federally enforceable conditions in this current Title V permit will be subject to EPA and public review.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions (amended December 18, 2014)
- District Rule 2201, New and Modified Stationary Source Review Rule (amended February 18, 2016)
- 40 CFR Part 60, Subpart GG, Standards of Performance for Stationary Gas Turbines (amended 2/27/14)
- 40 CFR Part 60, Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (amended 2/27/14, 7/7/16)
- 40 CFR Part 60, Subpart JJJJ—Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (amended 2/27/14)
- 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (amended 2/27/2014)
- 40 CFR Part 82, Subpart F, Recycling and Emission Reduction (amended 10/28/14, 4/10/15, 11/18/16, 12/27/17)

B. Rules Removed

There are no applicable rules that were removed since the last Title V renewal.

C. Rules Added

None.

D. Rules Not Updated

- District Rule 1070 Inspections (amended 12/17/92)
- District Rule 1080, Stack Monitoring (amended 12/17/92)
- District Rule 1081, Source Sampling (amended 12/17/92)
- District Rule 1100, Equipment Breakdown (amended 12/17/92)
- District Rule 2010, Permits Required (amended 12/17/92)
- District Rule 2031, Transfer of Permits (amended 12/17/92)
- District Rule 2040, Applications (amended 12/17/92)
- District Rule 2070, Standards for Granting Applications (amended 12/17/92)
- District Rule 2080, Conditional Approval (amended 12/17/92)
- District Rule 2520, Federally Mandated Operating Permits (amended 6/21/01)
- District Rule 4101, Visible Emissions (amended 2/17/05)
- District Rule 4201, Particulate Matter Concentration (amended 12/17/92)

- District Rule 4301, Fuel Burning Equipment (amended 12/17/92)
- District Rule 4663, Organic Solvent Cleaning, Storage, And Disposal (amended 9/20/07)
- District Rule 4703, Stationary Gas Turbines (amended September 20, 2007)
- District Rule 4801, Sulfur Compounds (amended 12/17/92)
- District Rule 4601, Architectural Coatings (amended December 17, 2009)
- District Rule 8011, Fugitive Dust General Requirements (amended August 19, 2004)
- District Rule 8021, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Construction, Demolition, Excavation, and Extraction Activities (amended August 19, 2004)
- District Rule 8031, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Handling and Storage of Bulk Materials (amended August 19, 2004)
- District Rule 8041, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Carryout and Trackout (amended August 19, 2004)
- District Rule 8051, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Open Area (amended August 19, 2004)
- District Rule 8061, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Paved and Unpaved Roads (amended August 19, 2004)
- District Rule 8071, Fugitive Dust Requirements for Control of Fine Particulate Matter (PM10) from Unpaved Vehicle/Equipment Areas (amended September 16, 2004)
- 40 CFR Part 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines (amended 3/20/09)
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos (amended July 20, 2004)
- 40 CFR Part 63 Subpart YYYY—National Emission Standards for Hazardous Air Pollutants for Stationary Combustion Turbines (amended 4/20/06)
- 40 CFR Part 64, Compliance Assurance Monitoring (amended 10/22/97)
- 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners (amended June 25, 2013)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added/Updated

None

B. Rules Not Updated

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit or most recent renewal of the Title V permit.

A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which is specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any effect on current permit requirements and will therefore not be addressed in this evaluation.

B. District Rule 2201 - New and Modified Stationary Source Review Rule (NSR)

District Rule 2201 has been amended since this facility's initial Title V permit was issued. However, the requirements of this rule are only triggered at the time the source undergoes a modification. All applicable requirements from any NSR permit actions have already been incorporated into the current Title V permit.

C. District Rule 2520 - Federally Mandated Operating Permits

No changes to this Rule have occurred since issuance of the previous TV permit; however, greenhouse gas emissions will be addressed under Rule 2520 during this renewal.

Greenhouse Gas Discussion

There are no federally applicable Greenhouse Gas (GHG) requirements for this source. It should be noted that the Mandatory Greenhouse Gas Reporting rule (40 CFR Part 98) is not included in the definition of an applicable requirement within Title V (per 40 CFR 71.2). Therefore, there will be no further discussion of GHG in this evaluation.

D. 40 CFR Part 60, Subpart GG, Standard of Performance for Stationary Gas Turbines

40 CFR Part 60 Subpart GG applies to stationary gas turbines with a heat input greater than 10.7 gigajoules per hour (3.0 MW) that commence construction, modification, or reconstruction after 10/03/77. The facility's turbine is subject to this subpart.

Section 60.335 of this subpart was amended on 2/27/14 by clarifying NOx source testing procedures. No permit revision is necessary as a result of the amendment.

E. 40 CFR 60 Subpart III – Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

§60.4200 – Applicability

This subpart is applicable to owners and operators of stationary compression ignited internal combustion engines that commence construction after July 11, 2005, where the engines are:

- 1) Manufactured after April 1, 2006, if not a fire pump engine.
- 2) Manufactured as a National Fire Protection Association (NFPA) fire pump engine after July 1, 2006.

The compression ignited internal combustion engine at the facility was manufactured before April 1, 2006; therefore, this subpart does not apply.

F. 40 CFR 63 Subpart ZZZZ – National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)

The requirements of 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines, are applicable to owners and operators of a stationary RICE located at a major or area source of HAP emissions. This facility is not a major source of HAP emissions and is therefore, by definition, and area source of HAP emissions. Therefore, the requirements of this subpart are applicable to the engine.

The subject engine was installed before 2006; therefore, as defined by Section 63.65.90(iii), the engine can be classified as existing stationary RICE.

S-2049-2 currently has conditions ensuring compliance with this regulation.

This subpart was amended on 2/27/14. The amendment included revisions to clarify that a heated probe is not necessary when using ASTM D6522 to measure oxygen or carbon dioxide concentrations. The requirement to use Method 1 or 1A for sampling site and sampling point selection in testing gaseous emissions from engines with smaller ducts is deleted, and single- or three-point sampling, depending on duct size, is added.

This amendment does not affect the facility's IC engine. No further discussion is required.

G. 40 CFR Part 82, Subpart F - Stratospheric Ozone

The purpose of 40 CFR Part 82 Subpart F is to reduce emissions of class I and class II refrigerants and their substitutes to the lowest achievable level by maximizing the recapture and recycling of such refrigerants during the service, maintenance, repair, and disposal of appliances and restricting the sale of refrigerants consisting in whole or in part of a class I and class II ODS in accordance with Title VI of the Clean Air Act.

These regulations apply to any person servicing, maintaining, or repairing appliances. This subpart also applies to persons disposing of appliances, including small appliances and motor vehicle air conditioners. In addition, this subpart applies to refrigerant reclaimers, technician certifying programs, appliance owners and operators, manufacturers of appliances, manufacturer of recycling and recovery equipment, approved recycling and recovery equipment testing organizations, persons selling class I or class II refrigerants or offering class I or class II refrigerants for sale, and persons purchasing class I or class II refrigerants.

The amendments to this subpart do not have any effect on the current permit requirements and therefore will not be addressed further in this evaluation.

F. 40 CFR Part 64 - Compliance Assurance Monitoring(CAM)

40 CFR Part 64 requires Compliance Assurance Monitoring for units that meet the following three criteria:

- 1) the unit must have an emission limit for the pollutant;
- 2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
- 3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

Pollutant	Major Source Threshold (lb/year)
NO _x	20,000
SO _x	140,000
PM ₁₀	140,000
CO	200,000
VOC	20,000

S-2049-1: 48 MW Natural Gas-Fired Turbine Engine Cogeneration System

This permit unit is equipped with continuous emission monitors (CEMS) for NO_x and CO, the pollutants for which it is considered a Major Source. Therefore this permit unit is exempt from CAM requirements.

S-2049-2: 208 HP Cummins Model 6BTA Diesel-Fired Emergency IC Engine Powering A Fire Water Pump

This permit unit is not equipped with add on controls, Therefore this permit unit is exempt from CAM requirements

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

A. Requirements Addressed by Model General Permit Templates

The applicant does not propose to use any model general permit templates.

X. CALIFORNIA ENVIRONMENTAL QUALITY ACT

The purpose of the Title V permit renewal is to update the permit to ensure that any changes to regulations since the issuance of the initial Title V permit or most recent renewal of the Title V permit are incorporated as permit requirements.

Per the California Environmental Quality Act (CEQA) Statute §21080.24, and CEQA Guidelines §15281, the issuance, modification, amendment, or renewal of any permit by an air pollution control district or air quality management district pursuant to Title V is exempt from CEQA, unless the issuance, modification, amendment, or renewal authorizes a physical or operational change to a source or facility. There will be no physical or operational change to the source or facility nor will the Title V permit renewal authorize a physical or operational change to the source or facility. Therefore, this project, a Title V permit renewal, is subject to a ministerial action that is exempt from CEQA.

XI. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit.

ATTACHMENTS

- A. Draft Renewed Title V Operating Permit
- B. Previous Title V Operating Permit
- C. Detailed Summary List of Facility Permits

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-2049-0-5

EXPIRATION DATE: 04/30/2018

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: BEAR MOUNTAIN LIMITED
Location: HEAVY OIL CENTRAL, KERN BLUFF
S-2049-0-5 - Sep 26 2018 10:40AM - TORID

9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

22. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Kern County Rule 401 and Kern County Rule 111. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. An owner or operator shall not use organic solvents for cleaning operations that exceed the VOC content limits specified as follows: A) Product cleaning during manufacturing process or surface preparation for adhesive application; 1) general, 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components, 500 g/l (4.2 lb/gal); B) repair and maintenance cleaning, 1) 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components 900 g/l (7.5 lb/gal); C) cleaning of coating or adhesive application equipment, 550 g/l (4.6 lb/gal) [District Rule 4663, 5.1.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. Cleaning activities that use solvents with a VOC content greater than 50 g/l (0.42 lb/gallon) shall be performed by one or more of the following methods: 1) wipe cleaning; 2) application of solvent from hand-held spray bottles from which solvents are dispensed without a propellant-induced force; 3) non-atomized solvent flow method in which the cleaning solvent is collected in a container or a collection system which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container, or; 4) solvent flushing method in which the cleaning solvent is discharged into a container that is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the open air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 4663, 5.2.1] Federally Enforceable Through Title V Permit
44. Solvent shall not be atomized into the open air unless it is vented to a VOC emission control system. This provision shall not apply to the cleaning of nozzle tips of automated spray equipment systems, except for robotic systems, and cleaning with spray bottles or containers described elsewhere in this permit. [District Rule 4663, 5.2.2] Federally Enforceable Through Title V Permit
45. An owner or operator shall not use VOC-containing materials to clean spray equipment used for the application of coatings, adhesives, or ink, unless an enclosed system or equipment that is proven to be equally effective at controlling emissions is used for cleaning. If an enclosed system is used, it must totally enclose spray guns, cups, nozzles, bowls, and other parts during washing, rinsing and draining procedures, and it must be used according to the manufacturer's recommendations and must be closed when not in use. [District Rule 4663, 5.2.3] Federally Enforceable Through Title V Permit
46. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts and thinners shall be stored in closed, non-absorbent and non-leaking containers. [District Rule 4663, 5.3] Federally Enforceable Through Title V Permit
47. In lieu of complying with the requirements in Sections 5.1.2, an owner or operator may comply with this rule by using a VOC emission collection and control system in association with the solvent cleaning operation as provided in District Rule 4663, 5.4.1 and 5.4.2 (Adopted December 30, 2001). [District Rule 4663, 5.4] Federally Enforceable Through Title V Permit
48. An owner or operator shall maintain the records required by District Rule 4663, Sections 6.2.2 through 6.2.5 (Adopted December 20, 2001) at the stationary source for a period of five years. The records shall be made available to the APCO upon request. [District Rules 1070 and 4663, 6.2.1] Federally Enforceable Through Title V Permit
49. The VOC content of solvents and organic materials shall be determined by using United States Environmental Protection Agency (EPA) Test Method 24 or 24A, or South Coast Air Quality Management District (SCAQMD) Method 304 (Determination of Volatile Organic compounds in Various Materials), or by using the manufacturer's product formulation data and the formula for "Grams of VOC per liter of Material" in Section 3.0. [District Rule 4663, 6.3.1.1] Federally Enforceable Through Title V Permit
50. The content of exempt halogenated VOCs shall be determined by using the California Air Resources Board (ARB) Test Method 432 or SCAQMD Test Method 303 (Determination of Exempt Compounds). [District Rule 4663, 6.3.1.2] Federally Enforceable Through Title V Permit
51. The facility shall comply with all applicable requirements regarding preparation and implementation of a Risk Management Plan and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR Part 68] Federally Enforceable Through Title V Permit
52. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
53. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

54. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
55. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
56. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
57. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
58. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
59. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit
60. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
61. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
62. The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
63. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
64. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
65. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
66. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

67. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit
68. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2049-1-12

EXPIRATION DATE: 04/30/2018

SECTION: SW12 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

NOMINALLY RATED 48 MW G.T.E. COGENERATION SYSTEM WITH SCR, INCLUDING STEWART AND STEVENSON GE LM-5000 GAS TURBINE GENERATOR, HEAT RECOVERY STEAM GENERATOR, AND INLET AIR ABSORPTION CHILLER AND HEAT EXCHANGER

PERMIT UNIT REQUIREMENTS

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 9.8 lb per day [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas fired turbine engine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703, 5.1.1] Federally Enforceable Through Title V Permit
4. Gas fired turbine engine shall be equipped with carbon monoxide catalytic oxidizer. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine combustor steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
6. CEM data shall be used in addition to stack testing to determine compliance with NOx and CO concentrations and daily emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system accurate to within +/- 5%. [District Rules 2201 and 4703, 6.2.1 and 40 CFR 60.334 (a)] Federally Enforceable Through Title V Permit
8. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2201 and 4801; 40 CFR 60.333 (a) & (b); 60.332(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
9. Startup is defined as the thermal stabilization period to bring the exhaust gas to normal operating temperature range. Shutdown is defined as the cessation of operation. [District Rule 4703 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
10. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Inlet gas temperature to oxidation catalyst bed shall be maintained within the range recommended by manufacturer except during periods of startup and shutdown as defined herein. The facility shall maintain a record of the recommended temperature range of the manufacturer onsite. [District Rule 2201] Federally Enforceable Through Title V Permit
12. All gas turbine engine exhaust shall flow through catalyst bed. [District Rule 2201] Federally Enforceable Through Title V Permit
13. When oxidation catalyst inlet temperature exceeds 800 degrees F, the VOC emission concentration at turbine exhaust shall not exceed 0.6 ppmv dry at 15% O₂, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 1.04 lb/hr and 25.0 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Emission rate from the gas turbine exhaust shall not exceed the following: PM₁₀: 75.0 lb/day, NO_x (as NO₂): 143.7 lb/day, SO_x (as SO₂): 31.1 lb/day, and CO: 252.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Nitrogen oxides (as NO₂) concentrations from the exhaust stack shall not exceed 3.6 ppmv dry calculated to 15% O₂, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.1 and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
17. Carbon monoxide (CO) concentrations from the exhaust stack shall not exceed 10 ppmv dry calculated to 15% O₂, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.2] Federally Enforceable Through Title V Permit
18. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (amended December 17, 1992). [District Rules 2201, 4703 and 1081] Federally Enforceable Through Title V Permit
19. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
20. Facility shall maintain file copies of all natural gas fuel invoices, including certification and quantity of gas consumed used to determine compliance with the requirements of this permit unit. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within 24 hours prior to a planned shut down of monitoring equipment. [District Rule 2520, 9.6.2; Rule 1080, 9.0 and 10.0 and 40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
22. Startup and shutdown of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time limit of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
23. All permits issued for facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Turbine lube oil vent shall be equipped with one pre-separator, one heat exchanger, and one air/oil separator with drain lines to turbine lube oil reservoir. [District Rule 2201] Federally Enforceable Through Title V Permit
25. All atmospheric lube oil vents from the turbine lube oil reservoir and the generator shall be equipped with a lube oil mist eliminator. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. Gas turbine exhaust shall be equipped with continuously recording NOx emission monitor located prior to catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Gas temperature at SCR catalyst section inlet shall be monitored and recorded by operational temperature indicator. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]
30. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed, in accordance with EPA guidelines. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Facility shall monitor and record exhaust gas temperature at oxidation catalyst inlet. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with VOC emission limits shall be demonstrated by sample collection by independent testing laboratory annually, using EPA Test Method 25, within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collected shall be submitted to the District within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Any lube oil/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested, using EPA Test Method 25, to demonstrate compliance with lube oil/accumulating vent VOC emissions limit. If no visible emissions occur, VOC emissions are assumed to be zero. [District Rule 2201] Federally Enforceable Through Title V Permit
34. The gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
35. All CEM data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.14(h)] Federally Enforceable Through Title V Permit
36. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [District Rule 2201 and 40 CFR 60.486 paragraph (b), (c) and (d)] Federally Enforceable Through Title V Permit
37. Compliance with ammonia slip (ppmv) emission limit shall be demonstrated by sample collection by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collected shall be submitted to the District within 60 days of testing. [District Rule 4102] Federally Enforceable Through Title V Permit
38. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NOx and O2 concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
39. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. The NOx and O2 CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specifications 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and, District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

41. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
44. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NOx concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx or O2 (or both). [40 CFR 60.334(J)(1)(iii)] Federally Enforceable Through Title V Permit
45. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
46. {2264} Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.19] Federally Enforceable Through Title V Permit
47. {2265} Thermal Stabilization Period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
48. {2256} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
49. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If H2S content is less than 0.25 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
50. Performance testing shall be conducted annually to measure NOx and CO emission concentrations using the following test methods: EPA Methods 7E or 20 for NOx emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A, or 20 for Oxygen content of the exhaust gas. The 9-run tests shall be performed at highest physically achievable load of the gas turbine. [40 CFR 60.335(a), (b)(7) and District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3] Federally Enforceable Through Title V Permit
51. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
52. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

53. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 days of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
54. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
55. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
56. Owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2049-2-7

EXPIRATION DATE: 04/30/2018

SECTION: SW12 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

208 BHP CUMMINS MODEL 6BTA DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The IC engine shall be equipped with a turbocharger and with an aftercooler or intercooler. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The IC engine shall be equipped with a positive crankcase ventilation (PCV) system or a crankcase emissions control device of at least 90% control efficiency. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Engine shall be equipped with an rpm indicator. [District Rule 2520, 9.3.3] Federally Enforceable Through Title V Permit
5. Maximum engine speed shall not exceed 1760 rpm (182 bhp). [District NSR Rule] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 4.3, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
7. {2413} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101, 5.1] Federally Enforceable Through Title V Permit
8. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Nitrogen oxide (NO_x as NO₂) emissions shall not exceed 7.1 grams/hp-hr. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District NSR Rule and District Rule 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, 4.3, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4702, 6.2 and 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
22. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4702, 6.2 and 2520, 9.4.2, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

San Joaquin Valley Air Pollution Control District

FACILITY: S-2049-0-4

EXPIRATION DATE: 04/30/2018

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; Kern County Rule 111] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: BEAR MOUNTAIN LIMITED
Location: HEAVY OIL CENTRAL, KERN BLUFF
S-2049-0-4 : Sep 26 2018 10:40AM - TORID

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (2/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and Kern County Rule 401] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Kern County Rule 401 and Kern County Rule 111. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. An owner or operator shall not use organic solvents for cleaning operations that exceed the VOC content limits specified as follows: A) Product cleaning during manufacturing process or surface preparation for adhesive application; 1) general, 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components, 500 g/l (4.2 lb/gal); B) repair and maintenance cleaning, 1) 50 g/l (0.42 lb/gal) and 2) electrical apparatus components and electronic components 900 g/l (7.5 lb/gal); C) cleaning of coating or adhesive application equipment, 550 g/l (4.6 lb/gal) [District Rule 4663, 5.1.2] Federally Enforceable Through Title V Permit
43. Cleaning activities that use solvents with a VOC content greater than 50 g/l (0.42 lb/gallon) shall be performed by one or more of the following methods: 1) wipe cleaning; 2) application of solvent from hand-held spray bottles from which solvents are dispensed without a propellant-induced force; 3) non-atomized solvent flow method in which the cleaning solvent is collected in a container or a collection system which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container, or; 4) solvent flushing method in which the cleaning solvent is discharged into a container that is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the open air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 4663, 5.2.1] Federally Enforceable Through Title V Permit
44. Solvent shall not be atomized into the open air unless it is vented to a VOC emission control system. This provision shall not apply to the cleaning of nozzle tips of automated spray equipment systems, except for robotic systems, and cleaning with spray bottles or containers described elsewhere in this permit. [District Rule 4663, 5.2.2] Federally Enforceable Through Title V Permit
45. An owner or operator shall not use VOC-containing materials to clean spray equipment used for the application of coatings, adhesives, or ink, unless an enclosed system or equipment that is proven to be equally effective at controlling emissions is used for cleaning. If an enclosed system is used, it must totally enclose spray guns, cups, nozzles, bowls, and other parts during washing, rinsing and draining procedures, and it must be used according to the manufacturer's recommendations and must be closed when not in use. [District Rule 4663, 5.2.3] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

46. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts and thinners shall be stored in closed, non-absorbent and non-leaking containers. [District Rule 4663, 5.3] Federally Enforceable Through Title V Permit
47. In lieu of complying with the requirements in Sections 5.1.2, an owner or operator may comply with this rule by using a VOC emission collection and control system in association with the solvent cleaning operation as provided in District Rule 4663, 5.4.1 and 5.4.2 (Adopted December 30, 2001). [District Rule 4663, 5.4] Federally Enforceable Through Title V Permit
48. An owner or operator shall maintain the records required by District Rule 4663, Sections 6.2.2 through 6.2.5 (Adopted December 20, 2001) at the stationary source for a period of five years. The records shall be made available to the APCO upon request. [District Rules 1070 and 4663, 6.2.1] Federally Enforceable Through Title V Permit
49. The VOC content of solvents and organic materials shall be determined by using United States Environmental Protection Agency (EPA) Test Method 24 or 24A, or South Coast Air Quality Management District (SCAQMD) Method 304 (Determination of Volatile Organic compounds in Various Materials), or by using the manufacturer's product formulation data and the formula for "Grams of VOC per liter of Material" in Section 3.0. [District Rule 4663, 6.3.1.1] Federally Enforceable Through Title V Permit
50. The content of exempt halogenated VOCs shall be determined by using the California Air Resources Board (ARB) Test Method 432 or SCAQMD Test Method 303 (Determination of Exempt Compounds). [District Rule 4663, 6.3.1.2] Federally Enforceable Through Title V Permit
51. The facility shall comply with all applicable requirements regarding preparation and implementation of a Risk Management Plan and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR Part 68] Federally Enforceable Through Title V Permit
52. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
53. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
54. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
55. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
56. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
57. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
58. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
59. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

60. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
61. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
62. The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
63. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
64. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
65. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
66. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
67. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit
68. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2049-1-11

EXPIRATION DATE: 04/30/2018

SECTION: SW12 TOWNSHIP: 29S RANGE: 28E

EQUIPMENT DESCRIPTION:

NOMINALLY RATED 48 MW G.T.E. COGENERATION SYSTEM WITH SCR, INCLUDING STEWART AND STEVENSON GE LM-5000 GAS TURBINE GENERATOR, HEAT RECOVERY STEAM GENERATOR, AND INLET AIR ABSORPTION CHILLER AND HEAT EXCHANGER

PERMIT UNIT REQUIREMENTS

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 9.8 lb per day [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas fired turbine engine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703, 5.1.1] Federally Enforceable Through Title V Permit
4. Gas fired turbine engine shall be equipped with carbon monoxide catalytic oxidizer. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Gas turbine engine combustor steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
6. CEM data shall be used in addition to stack testing to determine compliance with NOx and CO concentrations and daily emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system accurate to within +/- 5%. [District Rules 2201 and 4703, 6.2.1 and 40 CFR 60.334 (a)] Federally Enforceable Through Title V Permit
8. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2201 and 4801; 40 CFR 60.333 (a) & (b); 60.332(a) and Kern County Rule 407] Federally Enforceable Through Title V Permit
9. Startup is defined as the thermal stabilization period to bring the exhaust gas to normal operating temperature range. Shutdown is defined as the cessation of operation. [District Rule 4703 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
10. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Inlet gas temperature to oxidation catalyst bed shall be maintained within the range recommended by manufacturer except during periods of startup and shutdown as defined herein. The facility shall maintain a record of the recommended temperature range of the manufacturer onsite. [District Rule 2201] Federally Enforceable Through Title V Permit
12. All gas turbine engine exhaust shall flow through catalyst bed. [District Rule 2201] Federally Enforceable Through Title V Permit
13. When oxidation catalyst inlet temperature exceeds 800 degrees F, the VOC emission concentration at turbine exhaust shall not exceed 0.6 ppmv dry at 15% O₂, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 1.04 lb/hr and 25.0 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Emission rate from the gas turbine exhaust shall not exceed the following: PM₁₀: 75.0 lb/day, NO_x (as NO₂): 143.7 lb/day, SO_x (as SO₂): 31.1 lb/day, and CO: 252.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Nitrogen oxides (as NO₂) concentrations from the exhaust stack shall not exceed 3.6 ppmv dry calculated to 15% O₂, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.1 and 40 CFR Part 60.332(a)] Federally Enforceable Through Title V Permit
17. Carbon monoxide (CO) concentrations from the exhaust stack shall not exceed 10 ppmv dry calculated to 15% O₂, except during periods of startup and shutdown. [District Rules 2201 and 4703, 5.2] Federally Enforceable Through Title V Permit
18. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (amended December 17, 1992). [District Rules 2201, 4703 and 1081] Federally Enforceable Through Title V Permit
19. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
20. Facility shall maintain file copies of all natural gas fuel invoices, including certification and quantity of gas consumed used to determine compliance with the requirements of this permit unit. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within 24 hours prior to a planned shut down of monitoring equipment. [District Rule 2520, 9.6.2; Rule 1080, 9.0 and 10.0 and 40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
22. Startup and shutdown of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time limit of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit
23. All permits issued for facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Turbine lube oil vent shall be equipped with one pre-separator, one heat exchanger, and one air/oil separator with drain lines to turbine lube oil reservoir. [District Rule 2201] Federally Enforceable Through Title V Permit
25. All atmospheric lube oil vents from the turbine lube oil reservoir and the generator shall be equipped with a lube oil mist eliminator. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

26. Gas turbine exhaust shall be equipped with continuously recording NOx emission monitor located prior to catalyst. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Gas temperature at SCR catalyst section inlet shall be monitored and recorded by operational temperature indicator. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]
30. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed, in accordance with EPA guidelines. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Facility shall monitor and record exhaust gas temperature at oxidation catalyst inlet. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Compliance with VOC emission limits shall be demonstrated by sample collection by independent testing laboratory annually, using EPA Test Method 25, within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collected shall be submitted to the District within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Any lube oil/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested, using EPA Test Method 25, to demonstrate compliance with lube oil/accumulating vent VOC emissions limit. If no visible emissions occur, VOC emissions are assumed to be zero. [District Rule 2201] Federally Enforceable Through Title V Permit
34. The gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
35. All CEM data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.14(h)] Federally Enforceable Through Title V Permit
36. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [District Rule 2201 and 40 CFR 60.486 paragraph (b), (c) and (d)] Federally Enforceable Through Title V Permit
37. Compliance with ammonia slip (ppmv) emission limit shall be demonstrated by sample collection by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collected shall be submitted to the District within 60 days of testing. [District Rule 4102] Federally Enforceable Through Title V Permit
38. The owner or operator shall install, certify, maintain, operate and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NOx and O2 concentrations. [40 CFR 60.334(b) and District Rule 4703, 6.2.1] Federally Enforceable Through Title V Permit
39. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2) and District Rule 1080, 6.4] Federally Enforceable Through Title V Permit
40. The NOx and O2 CEMS shall meet the requirements in 40 CFR 60, Appendix F Procedure 1 and Part 60, Appendix B Performance Specifications 2 and 3, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 60.334(b)(1) and, District Rule 1080, 6.3, 6.5, 6.6, & 7.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

41. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [40 CFR 60.7(b) and District Rule 1080, 7.3] Federally Enforceable Through Title V Permit
43. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j), (j)(5) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit
44. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NOx concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOx or O2 (or both). [40 CFR 60.334(J)(1)(iii)] Federally Enforceable Through Title V Permit
45. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
46. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.19] Federally Enforceable Through Title V Permit
47. Thermal Stabilization Period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
48. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
49. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If H2S content is less than 0.25 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
50. Performance testing shall be conducted annually to measure NOx and CO emission concentrations using the following test methods: EPA Methods 7E or 20 for NOx emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A, or 20 for Oxygen content of the exhaust gas. The 9-run tests shall be performed at highest physically achievable load of the gas turbine. [40 CFR 60.335(a), (b)(7) and District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3] Federally Enforceable Through Title V Permit
51. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
52. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

53. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 days of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
54. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
55. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703, 5.1, 6.4] Federally Enforceable Through Title V Permit
56. Owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-2049-2-6

EXPIRATION DATE: 04/30/2018

SECTION: SW12 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:

208 BHP CUMMINS MODEL 6BTA DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIRE WATER PUMP

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District NSR Rule] Federally Enforceable Through Title V Permit
2. The IC engine shall be equipped with a turbocharger and with an aftercooler or intercooler. [District NSR Rule] Federally Enforceable Through Title V Permit
3. The IC engine shall be equipped with a positive crankcase ventilation (PCV) system or a crankcase emissions control device of at least 90% control efficiency. [District NSR Rule] Federally Enforceable Through Title V Permit
4. Engine shall be equipped with an rpm indicator. [District Rule 2520, 9.3.3] Federally Enforceable Through Title V Permit
5. Maximum engine speed shall not exceed 1760 rpm (182 bhp). [District NSR Rule] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 4.3, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
7. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101, 5.1] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
9. Nitrogen oxide (NO_x as NO₂) emissions shall not exceed 7.1 grams/hp-hr. [District NSR Rule] Federally Enforceable Through Title V Permit
10. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District NSR Rule and District Rule 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
11. The permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, 4.3, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, and the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.). For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4702, 6.2 and 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit
19. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
20. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
21. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
22. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4702, 6.2 and 2520, 9.4.2, 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

ATTACHMENT C

Detailed Summary List of Facility Permits

SJVUAPCD
SOUTHERN

Detailed Facility Report
For Facility=2049 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

9/26/18
10:41 am

BEAR MOUNTAIN LIMITED
HEAVY OIL CENTRAL
KERN BLUFF

FAC # S 2049
STATUS: A
TELEPHONE 8053936885

TYPE: TitleV
TOXIC ID: 51620
EXPIRE ON: 04/30/2018
AREA: 83 /
INSP. DATE: 08/19

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-2049-1-11	48 MW G.T.E. COGENERATION SYSTEM	3020-08A G	1	11,715.00	11,715.00	A	NOMINALLY RATED 48 MW G.T.E. COGENERATION SYSTEM WITH SCR, INCLUDING STEWART AND STEVENSON GE LM-5000 GAS TURBINE GENERATOR, HEAT RECOVERY STEAM GENERATOR, AND INLET AIR ABSORPTION CHILLER AND HEAT EXCHANGER
S-2049-2-6	208 bhp IC engine	3020-10 C	1	277.00	277.00	A	208 BHP CUMMINS MODEL 6BTA DIESEL-FIRED EMERGENCY IC ENGINE POWERING A FIRE WATER PUMP

Number of Facilities Reported: 1