



DEC 11 2018

Mr. Adam Rogge
Double C Limited
1034759 Lencioni Ave
Bakersfield, CA 93308

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: S-1119
Project Number: S-1172670

Dear Mr. Rogge:

The District has issued the Final Renewed Title V Permit for Double C Limited (see enclosure). The preliminary decision for this project was made on September 12, 2018. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Facility # S-1119
DOUBLE C LIMITED
34759 LENCIONI AVE STE A
BAKERSFIELD, CA 93308

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Permit to Operate

FACILITY: S-1119

EXPIRATION DATE: 02/28/2023

LEGAL OWNER OR OPERATOR:

DOUBLE C LIMITED

MAILING ADDRESS:

34759 LENCIONI AVE STE A
BAKERSFIELD, CA 93308

FACILITY LOCATION:

HEAVY OIL CENTRAL
KERN FRONT, CA

FACILITY DESCRIPTION:

OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh

Executive Director / APCO

Arnaud Marjollet

Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-1119-0-5

EXPIRATION DATE: 02/28/2023

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; Kern County Rule 111] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; Kern County Rule 111] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: DOUBLE C LIMITED
Location: HEAVY OIL CENTRAL, KERN FRONT, CA
S-1119-0-5 Dec 5 2018 10 01AM - HQSHMAM

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Kern), Rule 111 (Kern), and Rule 202 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Facility shall notify the APCO of a violation of any emission standards indicated by the CEMs within 96 hours of occurrence. The APCO shall be notified within 8 hours after detection of a breakdown in monitoring equipment and 24 hours prior to a planned shut down of monitoring equipment. [District Rules 2520, 9.6.2; 1080, 9.0 and 10.0; and 40 CFR 60.334(c)] Federally Enforceable Through Title V Permit
42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
43. An owner or operator shall not use organic solvents for cleaning operations that exceed the VOC content limits specified as follows: A) Product cleaning during manufacturing process or surface preparation for adhesive application; 1) general, 25 g/l (0.21 lb/gal) and 2) electrical apparatus components and electronic components, 100 g/l (0.84 lb/gal); B) repair and maintenance cleaning, 1) 25 g/l (0.21 lb/gal) and 2) electrical apparatus components and electronic components 100 g/l (0.84 lb/gal); C) cleaning of coating or adhesive application equipment, 25 g/l (0.21 lb/gal). [District Rule 4663] Federally Enforceable Through Title V Permit
44. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall be performed by one or more of the following methods: 1) wipe cleaning; 2) application of solvent from hand-held spray bottles from which solvents are dispensed without a propellant-induced force; 3) non-atomized solvent flow method in which the cleaning solvent is collected in a container or a collection system which is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container, or; 4) solvent flushing method in which the cleaning solvent is discharged into a container that is closed except for solvent collection openings and, if necessary, openings to avoid excessive pressure build-up inside the container. The discharged solvent from the equipment must be collected into containers without atomizing into the open air. The solvent may be flushed through the system by air or hydraulic pressure, or by pumping. [District Rule 4663] Federally Enforceable Through Title V Permit
45. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall not atomize the solvent into the open air unless it is vented to a VOC emission control system. This provision shall not apply to the cleaning of nozzle tips of automated spray equipment systems, except for robotic systems, and cleaning with spray bottles or containers described elsewhere in this permit. [District Rule 4663] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

46. Cleaning activities that use solvents with a VOC content greater than 25 g/l (0.21 lb/gallon) and meeting the applicable VOC content limits of District Rule 4663 Table 1 (amended September 20, 2007) shall not use VOC-containing materials to clean spray equipment used for the application of coatings, adhesives, or ink, unless an enclosed system or equipment that is proven to be equally effective at controlling emissions is used for cleaning. If an enclosed system is used, it must totally enclose spray guns, cups, nozzles, bowls, and other parts during washing, rinsing and draining procedures, and it must be used according to the manufacturer's recommendations and must be closed when not in use. [District Rule 4663] Federally Enforceable Through Title V Permit
47. All fresh or spent solvents, waste solvent cleaning materials such as cloth, paper, etc., coatings, adhesives, catalysts and thinners shall be stored in closed, non-absorbent and non-leaking containers. [District Rule 4663] Federally Enforceable Through Title V Permit
48. In lieu of complying with the requirements in District Rule 4663, Section 5.1, an owner or operator may comply with this rule by using a VOC emission collection and control system in association with the solvent cleaning operation as provided in District Rule 4663, Sections 5.5.4 and 5.5.5 and either Section 5.5.2 or Section 5.5.3, as applicable (amended September 20, 2007). [District Rule 4663] Federally Enforceable Through Title V Permit
49. An owner or operator shall maintain the records required by District Rule 4663, Sections 6.2.2 through 6.2.6 (amended September 20, 2007) at the stationary source for a period of five years. The records shall be made available to the APCO upon request. [District Rules 1070 and 4663] Federally Enforceable Through Title V Permit
50. The VOC content of solvents and organic materials shall be determined by using United States Environmental Protection Agency (EPA) Test Method 24 or 24A, or South Coast Air Quality Management District (SCAQMD) Method 304 (Determination of Volatile Organic compounds in Various Materials), or by using the manufacturer's product formulation data and the formula for "Grams of VOC per liter of Material" in Section 3.0. [District Rule 4663] Federally Enforceable Through Title V Permit
51. The content of exempt halogenated VOCs shall be determined by using the California Air Resources Board (ARB) Test Method 432 or SCAQMD Test Method 303 (Determination of Exempt Compounds). [District Rule 4663] Federally Enforceable Through Title V Permit
52. The facility shall comply with all applicable requirements regarding preparation and implementation of a Risk Management Plan and shall abide by all applicable sections of 40 CFR Part 68. [40 CFR Part 68] Federally Enforceable Through Title V Permit
53. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1119-1-15

EXPIRATION DATE: 02/28/2023

SECTION: 11 TOWNSHIP: 28S RANGE: 27E

EQUIPMENT DESCRIPTION:

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE COGENERATION SYSTEM WITH STEAM INJECTION, OXIDATION CATALYST, AND SELECTIVE CATALYTIC REDUCTION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60, Subpart A] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District Rules 2201 and 4703; 40 CFR 60.334(a)] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a),(b); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h)] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NOx and CO concentrations and daily emission rates. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703 and 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR 60.334(b)2] Federally Enforceable Through Title V Permit
12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District Rules 2201, 4201 and 4703; 40 CFR 60.332(a) and 333(b)(2)] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080; 40 CFR 60.7(c)] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 and S-1326-341 (California Resources Production Corp). [District Rule 2201] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703; 40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District Rules 2201, 1081 and 4703] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. Nitrogen oxides (NO_x) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O₂) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081, 2520, 9.3.2, and 4703; 40 CFR 60.335(b), (c)] Federally Enforceable Through Title V Permit
25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NO_x, CO, and O₂. The continuous NO_x monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rules 2201, 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080 and 4703] Federally Enforceable Through Title V Permit
28. Except for NO_x and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NO_x and CO shall be averaged over a three hour period. [District Rule 4703] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080, and 4703; 40 CFR 60.332(a), (b)] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NO_x and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rules 2201, 2520, 9.4.2 and 4703] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended September 20, 2007); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District Rule 2201] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District Rule 2201] Federally Enforceable Through Title V Permit
36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NOx concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rules 2201 and 4703; 40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NOx and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District Rules 2201, 2520, 9.3.2 and 9.4.2] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a), (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.13(e)(2)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1119-2-15

EXPIRATION DATE: 02/28/2023

SECTION: 11 TOWNSHIP: 28S RANGE: 27E

EQUIPMENT DESCRIPTION:

NOMINALLY RATED 25 MW GENERAL ELECTRIC LM-2500 NATURAL GAS FIRED GAS TURBINE ENGINE COGENERATION SYSTEM WITH STEAM INJECTION, OXIDATION CATALYST, AND SELECTIVE CATALYTIC REDUCTION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Turbine washing operation shall take place only when the turbine is off-line. [District Rule 2201] Federally Enforceable Through Title V Permit
2. VOC emissions from off-line turbine wash operation shall not exceed 5.9 lb per day, averaged over a 15-minute period. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Gas-fired turbine shall be equipped with combustor steam injection and a selective catalytic reduction (SCR) system utilizing ammonia as the reducing agent. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
4. Gas-fired turbine shall be equipped with carbon monoxide (CO) catalytic oxidizer. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
5. The gas turbine steam injection rate shall be maintained at a steam to fuel ratio which results in compliance with emissions limits, except during periods of startup, shutdown, and malfunction as defined in this permit. Only malfunctions as defined in 40 CFR 60 qualify for this exemption. [40 CFR 60, Subpart A] Federally Enforceable Through Title V Permit
6. Gas turbine combustor steam injection system shall be equipped with continuously recording steam and fuel injection rate monitoring system, accurate to within +/- 5%. [District Rules 2201 and 4703, 6.2.1; 40 CFR 60.334(a)] Federally Enforceable Through Title V Permit
7. The gas turbine shall be fired exclusively with PUC regulated or FERC regulated natural gas, with fuel gas sulfur content not to exceed 1 grain S/100 scf. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a),(b); Kern County Rule 407] Federally Enforceable Through Title V Permit
8. All CEMS data required to comply with the conditions in this permit shall be rounded to the same number of significant digits as the specified limits, but not less than two significant digits. [40 CFR 60.13(h)] Federally Enforceable Through Title V Permit
9. CEM data can be used in addition to stack testing to determine compliance with the NO_x and CO concentrations and daily emission rates. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Startup and shutdown and reduced load period of the gas turbine, as defined in this permit, in 40 CFR Subpart A 60.2, and in Rule 4703 shall not exceed a time period of two hours and one hour, respectively, per occurrence. Emission concentrations subsequent to this startup period shall not exceed the limits specified in this permit, except during shutdown. [District Rule 4703; 40 CFR Subpart A 60.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Facility shall maintain on file copies of all natural gas fuel invoices, natural gas bills, gas purchase contracts, supplier certifications, and test results used to determine compliance with the requirements of this permit unit. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rule 2520, 9.3.2 and 40 CFR 60.334(b)2] Federally Enforceable Through Title V Permit
12. Operations during periods of startup and shutdown shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the emission limit shown in this permit during periods of startup and shutdown be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard. This requirement only applies to the subsumed NOx and SO2 emission standards under NSPS subpart GG for Stationary Gas Turbines. [40 CFR 60.8(c)] Federally Enforceable Through Title V Permit
13. All gas turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Total VOC emissions, including those from the gas turbine exhaust and lube oil vents shall not exceed 3.12 lb/hr and 74.84 lb/day, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
15. The emission rate from the gas turbine exhaust shall not exceed the following: PM10: 74.88 lb/day and 3.12 lb/hr, NOx (as NO2): 96.96 lb/day, SOx (as SO2): 17.1 lb/day, and CO: 669.19 lb/day. [District Rules 2201 and 4201; 4703; 40 CFR 60.332(a) and 333(b)(2)] Federally Enforceable Through Title V Permit
16. Operators of CEMS shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; and a negative declaration when no excess emissions occurred. [District Rule 1080; 40 CFR 60.7(c)] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall only affect wells connected to well vent vapor recovery systems S-1326-28 and S-1326-341 (California Resources Production Corp). [District Rule 2201] Federally Enforceable Through Title V Permit
18. All permits issued to facilities S-172, S-1118, S-1119, S-1120 and S-2049 are included in the same heavy oil central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Nitrogen oxides (as NO2) concentration from the gas turbine exhaust stack shall not exceed 4.5 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703; 40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
20. Carbon monoxide (CO) concentration from the gas turbine exhaust stack shall not exceed 51 ppmv dry calculated to 15% O2, except during periods of startup and shutdown. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
21. The total particulate matter (PM) emissions from the gas turbine exhaust shall not exceed 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
22. The circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straighteners, if necessary, to minimize turbulence. The facility shall comply with this and all applicable compliance testing procedures described in District Rule 1081 (Amended December 17, 1992). [District Rules 2201, 1081, and 4703] Federally Enforceable Through Title V Permit
23. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rules 1081 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

24. Nitrogen oxides (NOx) concentrations from each of the gas turbine exhaust shall be determined using EPA Method 7E or 20, and oxygen (O2) concentration shall be determined using EPA Method 3, 3A, or 20. Carbon monoxide (CO) emissions shall be determined using EPA Test Methods 10 or 10B. Source test results will be provided to the district annually. EPA approved alternate test methods may also be used to address the source testing requirement of this permit. [District Rules 1081 and 4703; 40 CFR 60.335(b), (c)] Federally Enforceable Through Title V Permit
25. Unfired heat recovery steam generator turbine exhaust for the unit shall be equipped with continuous emissions monitors (CEM) for NOx, CO, and O2. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR, Part 60, Appendix B, Spec 2, 40 CFR Part 60, Appendix F, 40 CFR Part 51, Appendix P, and 40 CFR Part 60.7(c), 60.7(d) and 60.13 or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rules 2201, 1080, and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
26. The facility shall comply with the applicable requirements for quality assurance testing and maintenance of the CEM equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rules 1080 and 4703; 40 CFR 60] Federally Enforceable Through Title V Permit
27. CEM results shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rules 1080 and 4703] Federally Enforceable Through Title V Permit
28. Except for NOx and CO emission data obtained for compliance demonstration purposes, CEM data shall be averaged in accordance with the requirements specified under 40 CFR Part 60.13. Compliance results for NOx and CO shall be averaged over a three hour period. [District Rule 4703] Federally Enforceable Through Title V Permit
29. Records shall be maintained and shall contain: the occurrence and duration of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any CEM that have been installed pursuant to District Rule 1080; emission measurements, and daily actual local startup and stop time, length and reason for reduced load periods, total hours of operation and daily quantity of fuel used. [District Rules 1080 and 4703; 40 CFR 60.332(a), (b)] Federally Enforceable Through Title V Permit
30. Gas turbine engine shall not be operated unless steam injection system, selective catalytic reduction system, and oxidation catalyst system are operating, except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
31. A written record of the compliance demonstration with NOx and CO daily emissions limits during gas turbine engine startup/shutdown shall be maintained and made available for District inspection for a period of five years. [District Rules 2201, 2520, 9.4.2 and 4703] Federally Enforceable Through Title V Permit
32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1080, sections 4.0, 6.5, 7.2, 7.3, 8.0, 9.0, and 10.0 (Amended December 17, 1992); 1081 (Amended December 16, 1993); 4201 (Amended December 17, 1992); 4703 sections 5.0, 5.1, 5.2, 6.2.1, 6.2.2, 6.2.4, 6.3, and 6.4 (Amended September 20, 2007); 4801 (Amended December 17, 1992); 40 CFR 60.332(a),(b); 60.333(a),(b),(c); 60.334(a),(c); and 60.335(b),(c). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Facility shall keep an accurate record of the location and name of the owner or operator of each oil production operation using steam from this facility and shall make those records available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
34. Gas turbine and generator lube oil atmospheric vents shall be equipped with mist eliminators. [District Rule 2201] Federally Enforceable Through Title V Permit
35. Liquids collected from lube oil system (including atmospheric vent) shall be stored in closed containers such that VOC emissions do not occur. [District Rule 2201] Federally Enforceable Through Title V Permit
36. Ammonia injection rate shall be controlled to maintain ammonia slip to less than 20 ppmv. [District Rule 4102]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. Inlet gas temperature to catalyst bed shall be maintained within range recommended by catalyst manufacturer except during periods of startup and shutdown as defined herein. [District Rule 2201] Federally Enforceable Through Title V Permit
38. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
39. Compliance with PM10 (hourly) emission limit shall be demonstrated by sample collection taken by independent testing laboratory within 60 days upon visible emissions in excess of 5% opacity from turbine exhaust. The District shall be notified prior to any sampling event. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrated compliance with lube oil cooler/accumulating vent VOC hourly emissions limit. Official test results and field data collected shall be submitted within 60 days of testing. [District Rule 2201] Federally Enforceable Through Title V Permit
41. Source testing, for VOC (hourly), NOx concentration and CO concentration shall be conducted annually. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rules 2201 and 4703; 40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
42. Facility shall demonstrate compliance with NOx and CO daily emissions limits by use of CEM data, fuel rate data, and daily hours of operation data. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District Rules 2201, 2520, 9.3.2 and 9.4.2] Federally Enforceable Through Title V Permit
43. Audits of monitors shall be conducted quarterly, except during quarters in which RATA testing is performed in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with the quarterly compliance reports to the District. [District Rule 2201] Federally Enforceable Through Title V Permit
44. Compliance with fuel sulfur limit shall be demonstrated by fuel gas sample analysis by independent testing laboratory taken at time of annual stack gas sampling. Certification of the sulfur content by the gas supplier will be an acceptable alternative for verifying compliance. [District Rules 2520, 9.3.2 and 4801; 40 CFR 60.332(a) and 60.333(a), (b); Kern County Rule 407] Federally Enforceable Through Title V Permit
45. Except during system breakdowns, repairs and maintenance, calibration checks, and zero and span adjustments, the continuous emission monitoring system shall be in continuous operation. NOx emissions in ppmv (corrected to 15% O2) and O2 concentrations must be recorded continuously (except as noted before) and data shall be reduced to 15 minute averages per 40 CFR Part 60.13(e)(2). [40 CFR 60.13(e)(2)] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.