



DEC 12 2018

Mr. David King
Sunrise Power Company
12857 Sunrise Power Road
Fellows, CA 93244

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: S-3746
Project Number: S-1180002

Dear Mr. King:

The District has issued the Final Renewed Title V Permit for Sunrise Power Company (see enclosure). The preliminary decision for this project was made on 10/11/18. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



Facility # S-3746
SUNRISE POWER CO
12857 SUNRISE POWER RD
FELLOWS, CA 93224

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Samir Sheikh

Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95358-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

Permit to Operate

FACILITY: S-3746

EXPIRATION DATE: 06/30/2023

LEGAL OWNER OR OPERATOR:
MAILING ADDRESS:

SUNRISE POWER CO
12857 SUNRISE POWER RD
FELLOWS, CA 93224

FACILITY LOCATION:

12857 SUNRISE POWER RD
FELLOWS, CA 93224

FACILITY DESCRIPTION:

POWER PLANT

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley Air Pollution Control District

FACILITY: S-3746-0-4

EXPIRATION DATE: 06/30/2023

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SUNRISE POWER CO
Location: 12857 SUNRISE POWER RD, FELLOWS, CA 93224
S-3746-0-4 : Dec 4 2019 1:32PM - TORID

10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. On December 31, 2003, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule]

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3746-1-10

EXPIRATION DATE: 06/30/2023

SECTION: SW23 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

160 MW NOMINALLY RATED COMBINED-CYCLE POWER GENERATING SYSTEM #1 CONSISTING OF GENERAL ELECTRIC FRAME 7FA, NATURAL GAS-FIRED COMBUSTION TURBINE GENERATOR WITH DRY LOW-NOX COMBUSTORS, HEAT RECOVERY STEAM GENERATOR WITH DUCT FIRING, SCR, AND OXIDATION CATALYSTS (585 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording fuel gas flowmeter. [District NSR Rule] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NO_x, CO, and O₂. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [40 CFR 60.334(c), District Rules 1080, 2201 and 4703, 40 CFR 64, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
4. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District NSR Rule, and 40 CFR 64] Federally Enforceable Through Title V Permit
5. The facility shall maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
6. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
7. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4, 3.4.1 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, and 40 CFR 64] Federally Enforceable Through Title V Permit
9. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Source Emission Monitoring and Testing. [District Rule 1081] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
12. The owner/operator shall perform a relative accuracy test audit (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
13. Operators of CEM systems installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA (Attn: AIR-5). The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred; And reports on opacity monitors giving the number of three minute periods during which the average opacity exceeded the standard for each hour of operation. The averaged may be obtained by integration over the averaging period or by arithmetically averaging a minimum of four equally spaced instantaneous opacity measurements per minute. Any time exempted shall be considered before determining the excess averages of opacity. [40 CFR 64, District Rule 1080 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
14. An hour of excess emissions shall be defined as any operating hour in which 4-hour rolling average NO_x concentration exceeds applicable emissions limit in §60.332(a)(1), and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO_x, CO or O₂. The 4-hour rolling average is the arithmetic average of the average NO_x concentration measured by the CEMS for a given hour (corrected to 15 percent O₂) and the three unit operating hour average NO_x concentrations immediately preceding that unit operating hour. [40 CFR 64 and 40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit
15. The owner or operator shall submit reports of NO_x excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c) on a semi annual basis. Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction, for any 4-consecutive rolling average that exceeds the NO_x limit under 40 CFR 60.332(a)(1). For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined in 40 CFR 60.334(j). All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.334(j), 40 CFR 60.334 (j)(5) and District Rule 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

16. If the total duration of NOx excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CEMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form in §60.7(d) shall be submitted and the excess emission report described in §60.7(c) need not be submitted unless requested by the EPA or the Air District. [40 CFR 60.334(j), and 40 CFR 60.7(c) and (d)] Federally Enforceable Through Title V Permit
17. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
20. CTG shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.25 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [40 CFR 60.333(b), District NSR Rule, PSD SJ 01-01] Federally Enforceable Through Title V Permit
21. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 0.25 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(1) & (3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Sulfur compound emissions shall not exceed 0.015% by volume at 15% oxygen, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rule 407 (Kern)] Federally Enforceable Through Title V Permit
23. Startup is defined as the period beginning with turbine initial firing. Shutdown is defined by the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 60 minutes for a hot startup, 128 minutes for a warm startup, and 230 minutes for a cold startup, and one hour for a shutdown, per occurrence. [District Rules 2201, 4001 & 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
24. Reduced load period is defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate. Each reduced load period shall not exceed one hour. [District Rule 4703] Federally Enforceable Through Title V Permit
25. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
26. The owner or operator shall submit to the District information correlating the NOx control system operating parameters to the associated measured NOx output. The information must be sufficient to allow the District to determine compliance with the NOx emission limits of this permit when the CEMS is not operating properly. [District Rule 4703] Federally Enforceable Through Title V Permit
27. The HHV and LHV of the fuel combusted shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a) and (b) and District Rule 4703] Federally Enforceable Through Title V Permit
28. An owner or operator of any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703] Federally Enforceable Through Title V Permit
29. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines (S-3746-1 and -2) heat recovery steam generator exhausts shall not exceed any of the following: NOx (as NO₂) - 700 lb and CO - 1,580 lb, in any one hour. If any CTG is in either startup or shutdown mode during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Emission rates from each CTG, except during startup and/or shutdown, shall not exceed any of the following: PM₁₀ - 17.8 lb/hr, SO_x (as SO₂) - 1.55 lb/hr, NO_x (as NO₂) - 15.96 lb/hr and 2.0 ppmvd @ 15% O₂, VOC - 5.51 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 19.22 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x (as NO₂) ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmvd and lb/hr limits are three-hour rolling averages. If a CTG is in either startup or shutdown mode during any portion of a clock hour, that unit will not be subject to the aforementioned limits during that clock hour. [40 CFR 60.332(a)(1), District Rules 2201, 4001, 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
32. Emission rates from each CTG shall not exceed any of the following: PM₁₀ - 461.2 lb/day, SO_x (as SO₂) - 37.2 lb/day, NO_x (as NO₂) - 1,170.9 lb/day, VOC - 220.6 lb/day, and CO - 2,443.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Emission rates from both CTGs (S-3746-1 and -2) shall not exceed any of the following: PM₁₀ - 922.3 lb/day, SO_x (as SO₂) - 74.4 lb/day, NO_x (as NO₂) - 2,341.8 lb/day, VOC - 441.2 lb/day, and CO - 4,886.8 lb/day. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
34. Annual emissions from both CTGs calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 269,651 lb/year, SO_x (as SO₂) - 24,259 lb/year, NO_x (as NO₂) - 311,337 lb/year, VOC - 87,674 lb/year, and CO - 507,978 lb/year. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
35. Each one-hour period in a one-hour rolling average will commence on the hour. Each one-hour period in a three-hour rolling average will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
36. Daily emissions will be compiled for a twenty-four period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions will commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions will be compiled from the twelve most recent calendar months. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
37. Ammonia slip limit shall be measured using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = $((a-(b \times c / 1,000,000)) \times 1,000,000 / b) \times d$, where a = ammonia injection rate (lb/hr)/17 (lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29 (lb/lb. mol)), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rule 4102] Federally Enforceable Through Title V Permit
38. Short term emission limits (lb/hr and ppmv @ 15% O₂) shall be measured annually by District witnessed in-situ sampling of exhaust gases by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rules 1081 and 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
39. Startup NO_x, CO, and VOC mass emission limits shall be measured for one of the CTGs (S-3746-1, or -2) at least every seven years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. The District and the EPA must be notified 30 days prior to any source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
41. The following test methods shall be used PM10: EPA method 5 (front half and back half) or 201A, NOx: EPA Method 7E or 20, CO: EPA method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246 or ASTM D6228. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) & (c), District Rules 1081, 4001, 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
42. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703] Federally Enforceable Through Title V Permit
43. The permittee shall maintain hourly records of NOx, CO, and ammonia emission concentrations (ppmv @ 15% O2), and hourly, daily, and twelve month rolling average records of NOx and CO emissions. [District NSR Rule] Federally Enforceable Through Title V Permit
44. The permittee shall maintain records of SOx lb/hr, lb/day, and lb/twelve month rolling average emission. SOx emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District NSR Rule] Federally Enforceable Through Title V Permit
45. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
46. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b), 40 CFR 60.8(d), District Rules 1080 and 2201, 40 CFR 64 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
47. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
48. The owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local startup and stop time, length and reason for reduced load periods, total hours of operation, the type and quantity of fuel used, and duration of each start-up and each shutdown time period. [District Rule 4703] Federally Enforceable Through Title V Permit
49. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
50. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75. [40 CFR Part 75] Federally Enforceable Through Title V Permit
51. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

52. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR Part 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR Part 73] Federally Enforceable Through Title V Permit
53. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR Part 77] Federally Enforceable Through Title V Permit
54. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR Part 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR Part 72, 40 CFR Part 75] Federally Enforceable Through Title V Permit
55. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR Part 72] Federally Enforceable Through Title V Permit
56. An allowance shall not be deducted in order to comply with the requirements under 40 CFR Part 73, prior to the calendar year for which the allowance was allocated. [40 CFR Part 73] Federally Enforceable Through Title V Permit
57. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR Part 72.7 and Part 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR Part 72] Federally Enforceable Through Title V Permit
58. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR Part 72] Federally Enforceable Through Title V Permit
59. The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR Part 72] Federally Enforceable Through Title V Permit
60. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit
61. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit
62. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR Part 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR Part 72] Federally Enforceable Through Title V Permit
63. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR Part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR Part 72, 40 CFR Part 75] Federally Enforceable Through Title V Permit
64. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 75 Subpart I. [40 CFR Part 75] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

65. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rule 407 (Kern) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
66. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a)(1) and (b), 60.333 (a) and (b), 60.334 (c), h(1), h(3) and (j), and 60.335 (a), (b)(3), and (c); District Rule 4703 (as amended 09/20/07), Sections 5.1.3, 5.2, 5.3, 6.1, 6.3.1, 6.3.3, 6.4.1, 6.4.2, 6.4.3, and 6.4.5 as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
67. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3746-2-10

EXPIRATION DATE: 06/30/2023

SECTION: SW23 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

160 MW NOMINALLY RATED COMBINED-CYCLE POWER GENERATING SYSTEM #2 CONSISTING OF GENERAL ELECTRIC FRAME 7FA, NATURAL GAS-FIRED COMBUSTION TURBINE GENERATOR WITH DRY LOW-NOX COMBUSTORS, HEAT RECOVERY STEAM GENERATOR WITH DUCT FIRING, SCR, AND OXIDATION CATALYSTS (585 MW TOTAL PLANT NOMINAL RATING)

PERMIT UNIT REQUIREMENTS

1. Combustion turbine generator (CTG) and electrical generator lube oil vents shall be equipped with mist eliminators to maintain visible emissions from lube oil vents no greater than 5% opacity, except for three minutes in any hour. [District NSR Rule] Federally Enforceable Through Title V Permit
2. CTG shall be equipped with continuously recording fuel gas flowmeter. [District NSR Rule] Federally Enforceable Through Title V Permit
3. CTG exhaust after the SCR unit shall be equipped with continuously recording emissions monitors dedicated to this unit for NO_x, CO, and O₂. Continuous emissions monitors shall meet the requirements of 40 CFR Part 60, Appendices B and F, and 40 CFR Part 75, and shall be capable of monitoring emissions during startups and shutdowns as well as normal operating conditions. If relative accuracy of CEM(s) cannot be demonstrated during startup conditions, CEM results during startup and shutdown events shall be replaced with startup emission rates obtained from source testing to determine compliance with emission limits. [40 CFR 60.334(c), District Rules 1080, 2201 and 4703, 40 CFR 64, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
4. CTG shall be equipped with a continuously recording emission monitor preceding the SCR module measuring NO_x concentration for the purposes of calculating ammonia slip. Permittee shall check, record, and quantify the calibration drift (CD) at two concentration values at least once daily (approximately 24 hours). The calibration shall be adjusted whenever the daily zero or high-level CD exceeds 5%. If either the zero or high-level CD exceeds 5% for five consecutive daily periods, the analyzer shall be deemed out-of-control. If either the zero or high-level CD exceeds 10% during any CD check, analyzer shall be deemed out-of-control. If the analyzer is out-of-control, the permittee shall take appropriate corrective action and then repeat the CD check. [District NSR Rule, and 40 CFR 64] Federally Enforceable Through Title V Permit
5. The facility shall maintain equipment, facilities, and systems compatible with the District's CEM data polling software system and shall make CEM data available to the District's automated polling system on a daily basis. [District Rule 1080] Federally Enforceable Through Title V Permit
6. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080] Federally Enforceable Through Title V Permit
7. The owner or operator shall be required to conform to the compliance testing and sampling procedures described in District Rule 1081 (as amended 12/16/93). [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

8. CEM cycling times shall be those specified in 40 CFR, Part 51, Appendix P, Sections 3.4, 3.4.1 and 3.4.2, or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, and 40 CFR 64] Federally Enforceable Through Title V Permit
9. The exhaust stack shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and shall be equipped with safe permanent provisions to sample stack gases with a portable NO_x, CO, and O₂ analyzer during District inspections. The sampling ports shall be located in accordance with the CARB regulation titled California Air Resources Board Air Monitoring Quality Assurance Volume VI, Standard Operating Procedures for Stationary Source Emission Monitoring and Testing. [District Rule 1081] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring shall be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [District Rule 1080] Federally Enforceable Through Title V Permit
11. Audits of continuous emission monitors shall be conducted quarterly, except during quarters in which relative accuracy and total accuracy testing is performed, in accordance with EPA guidelines. The District shall be notified prior to completion of the audits. Audit reports shall be submitted along with quarterly compliance reports to the District. [District Rule 1080] Federally Enforceable Through Title V Permit
12. The owner/operator shall perform a relative accuracy test audit (RATA) as specified by 40 CFR Part 60, Appendix F, 5.11, at least once every four calendar quarters. The permittee shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F. [District Rule 1080] Federally Enforceable Through Title V Permit
13. Operators of CEM systems installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO and EPA (Attn: AIR-5). The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred; And reports on opacity monitors giving the number of three minute periods during which the average opacity exceeded the standard for each hour of operation. The averaged may be obtained by integration over the averaging period or by arithmetically averaging a minimum of four equally spaced instantaneous opacity measurements per minute. Any time exempted shall be considered before determining the excess averages of opacity. [40 CFR 64, District Rule 1080 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
14. An hour of excess emissions shall be defined as any operating hour in which 4-hour rolling average NO_x concentration exceeds applicable emissions limit in §60.332(a)(1), and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO_x, CO or O₂. The 4-hour rolling average is the arithmetic average of the average NO_x concentration measured by the CEMS for a given hour (corrected to 15 percent O₂) and the three unit operating hour average NO_x concentrations immediately preceding that unit operating hour. [40 CFR 64 and 40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit
15. The owner or operator shall submit reports of NO_x excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c) on a semi annual basis. Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction, for any 4-consecutive rolling average that exceeds the NO_x limit under 40 CFR 60.332(a)(1). For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined in 40 CFR 60.334(j). All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each six-month period. [40 CFR 60.334(j), 40 CFR 60.334 (j)(5) and District Rule 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

16. If the total duration of NO_x excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CEMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form in §60.7(d) shall be submitted and the excess emission report described in §60.7(c) need not be submitted unless requested by the EPA or the Air District. [40 CFR 60.334(j), and 40 CFR 60.7(c) and (d)] Federally Enforceable Through Title V Permit
17. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator. [District NSR Rule] Federally Enforceable Through Title V Permit
18. Permittee shall monitor and record exhaust gas temperature at selective catalytic reduction and oxidation catalyst inlets. [District NSR Rule] Federally Enforceable Through Title V Permit
19. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
20. CTG shall be fired exclusively on natural gas, consisting primarily of methane and ethane, with a sulfur content no greater than 0.25 grains of sulfur compounds (as S) per 100 dry scf of natural gas. [40 CFR 60.333(b), District NSR Rule, PSD SJ 01-01] Federally Enforceable Through Title V Permit
21. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If sulfur content is less than 0.25 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [40 CFR 60.334(h)(1) & (3) and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Sulfur compound emissions shall not exceed 0.015% by volume at 15% oxygen, on a dry basis averaged over 15 consecutive minutes. [40 CFR 60.333(a); County Rule 407 (Kern)] Federally Enforceable Through Title V Permit
23. Startup is defined as the period beginning with turbine initial firing. Shutdown is defined by the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 60 minutes for a hot startup, 128 minutes for a warm startup, and 230 minutes for a cold startup, and one hour for a shutdown, per occurrence. [District Rules 2201, 4001 & 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
24. Reduced load period is defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate. Each reduced load period shall not exceed one hour. [District Rule 4703] Federally Enforceable Through Title V Permit
25. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703] Federally Enforceable Through Title V Permit
26. The owner or operator shall submit to the District information correlating the NO_x control system operating parameters to the associated measured NO_x output. The information must be sufficient to allow the District to determine compliance with the NO_x emission limits of this permit when the CEMS is not operating properly. [District Rule 4703] Federally Enforceable Through Title V Permit
27. The HHV and LHV of the fuel combusted shall be determined using ASTM D3588, ASTM 1826, or ASTM 1945. [40 CFR 60.332(a) and (b) and District Rule 4703] Federally Enforceable Through Title V Permit
28. An owner or operator of any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner both on and off. [40 CFR 60.335(b)(3) and District Rule 4703] Federally Enforceable Through Title V Permit
29. Ammonia shall be injected when the selective catalytic reduction system catalyst temperature exceeds 500 degrees F. Permittee shall monitor and record catalyst temperature during periods of startup. [District NSR Rule] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. During startup or shutdown of any gas turbine engine(s), combined emissions from both gas turbine engines (S-3746-1 and -2) heat recovery steam generator exhausts shall not exceed any of the following: NOx (as NO₂) - 700 lb and CO - 1,580 lb, in any one hour. If any CTG is in either startup or shutdown mode during any portion of a clock hour, the facility will be subject to the aforementioned limits during that clock hour. [District NSR Rule] Federally Enforceable Through Title V Permit
31. Emission rates from each CTG, except during startup and/or shutdown, shall not exceed any of the following: PM₁₀ - 17.8 lb/hr, SO_x (as SO₂) - 1.55 lb/hr, NO_x (as NO₂) - 15.96 lb/hr and 2.0 ppmvd @ 15% O₂, VOC - 5.51 lb/hr and 2.0 ppmvd @ 15% O₂, CO - 19.22 lb/hr and 4 ppmvd @ 15% O₂, ammonia - 10 ppmvd @ 15% O₂. NO_x (as NO₂) ppmv and lb/hr limits are a one-hour rolling average. Ammonia emission limit is a twenty-four hour rolling average. All other ppmvd and lb/hr limits are three-hour rolling averages. If a CTG is in either startup or shutdown mode during any portion of a clock hour, that unit will not be subject to the aforementioned limits during that clock hour. [40 CFR 60.332(a)(1), District Rules 2201, 4001, 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
32. Emission rates from each CTG shall not exceed any of the following: PM₁₀ - 461.2 lb/day, SO_x (as SO₂) - 37.2 lb/day, NO_x (as NO₂) - 1,170.9 lb/day, VOC - 220.6 lb/day, and CO - 2,443.4 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Emission rates from both CTGs (S-3746-1 and -2) shall not exceed any of the following: PM₁₀ - 922.3 lb/day, SO_x (as SO₂) - 74.4 lb/day, NO_x (as NO₂) - 2,341.8 lb/day, VOC - 441.2 lb/day, and CO - 4,886.8 lb/day. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
34. Annual emissions from both CTGs calculated on a twelve consecutive month rolling basis shall not exceed any of the following: PM₁₀ - 269,651 lb/year, SO_x (as SO₂) - 24,259 lb/year, NO_x (as NO₂) - 311,337 lb/year, VOC - 87,674 lb/year, and CO - 507,978 lb/year. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
35. Each one-hour period in a one-hour rolling average will commence on the hour. Each one-hour period in a three-hour rolling average will commence on the hour. The three-hour average will be compiled from the three most recent one-hour periods. Each one-hour period in a twenty-four-hour average for ammonia slip will commence on the hour. The twenty-four-hour average will be calculated starting and ending at twelve-midnight. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
36. Daily emissions will be compiled for a twenty-four period starting and ending at twelve-midnight. Each calendar month in a twelve-consecutive-month rolling emissions will commence at the beginning of the first day of the month. The twelve-consecutive-month rolling emissions total to determine compliance with annual emissions will be compiled from the twelve most recent calendar months. [District NSR Rule and PSD SJ 01-01] Federally Enforceable Through Title V Permit
37. Ammonia slip limit shall be measured using the following calculation procedure: ammonia slip ppmv @ 15% O₂ = $((a-(b \times c / 1,000,000)) \times 1,000,000 / b) \times d$, where a = ammonia injection rate (lb/hr)/17 (lb/lb. mol), b = dry exhaust gas flow rate (lb/hr)/(29 (lb/lb. mol)), c = change in measured NO_x concentration ppmv at 15% O₂ across catalyst, and d = correction factor. The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip. Alternatively, permittee may utilize a continuous in-stack ammonia monitor, acceptable to the District, to monitor compliance. At least 60 days prior to using a NH₃ CEM, the permittee must submit a monitoring plan for District review and approval. [District Rule 4102] Federally Enforceable Through Title V Permit
38. Short term emission limits (lb/hr and ppmv @ 15% O₂) shall be measured annually by District witnessed in-situ sampling of exhaust gases by a qualified independent source test firm at full load conditions as follows - NO_x: ppmvd @ 15% O₂ and lb/hr, CO: ppmvd @ 15% O₂ and lb/hr, VOC: ppmvd @ 15% O₂ and lb/hr, PM₁₀: lb/hr, and ammonia: ppmvd @ 15% O₂. Sample collection to demonstrate compliance with ammonia emission limit shall be based on three consecutive test runs of thirty minutes each. [District Rules 1081 and 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
39. Startup NO_x, CO, and VOC mass emission limits shall be measured for one of the CTGs (S-3746-1, or -2) at least every seven years by District witnessed in situ sampling of exhaust gases by a qualified independent source test firm. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. The District and the EPA must be notified 30 days prior to any source test, and a source test plan must be submitted for approval 15 days prior to testing. Official test results and field data collected by source tests required by conditions on this permit shall be submitted to the District within 60 days of testing. [District Rule 1081 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
41. The following test methods shall be used PM10: EPA method 5 (front half and back half) or 201A, NOx: EPA Method 7E or 20, CO: EPA method 10 or 10B, O2: EPA Method 3, 3A, or 20, VOC: EPA method 18 or 25, ammonia: BAAQMD ST-1B, and fuel gas sulfur content: ASTM D3246 or ASTM D6228. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) & (c), District Rules 1081, 4001, 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
42. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with either EPA Method 7E or EPA Method 20 for NOx, EPA Test Methods 10 or 10B for CO, or EPA Methods 3, 3A, or 20 for O2, or, if continuous emission monitors are used, all applicable requirements of CFR 60.13. [40 CFR 60.13 and District Rule 4703] Federally Enforceable Through Title V Permit
43. The permittee shall maintain hourly records of NOx, CO, and ammonia emission concentrations (ppmv @ 15% O2), and hourly, daily, and twelve month rolling average records of NOx and CO emissions. [District NSR Rule] Federally Enforceable Through Title V Permit
44. The permittee shall maintain records of SOx lb/hr, lb/day, and lb/twelve month rolling average emission. SOx emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations. [District NSR Rule] Federally Enforceable Through Title V Permit
45. The owner or operator shall, upon written notice from the APCO, provide a summary of the data obtained from the CEM systems. This summary of data shall be in the form and the manner prescribed by the APCO. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
46. The owner or operator shall maintain records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, any periods during which a continuous monitoring system or monitoring device is inoperative, maintenance of any CEM system that has been installed pursuant to District Rule 1080 (as amended 12/17/92), and emission measurements. [40 CFR 60.7(b), 40 CFR 60.8(d), District Rules 1080 and 2201, 40 CFR 64 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
47. APCO or an authorized representative shall be allowed to inspect, as he or she determines to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0 and PSD SJ 01-01] Federally Enforceable Through Title V Permit
48. The owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local startup and stop time, length and reason for reduced load periods, total hours of operation, the type and quantity of fuel used, and duration of each start-up and each shutdown time period. [District Rule 4703] Federally Enforceable Through Title V Permit
49. All records required to be maintained by this permit shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 4703, and PSD SJ 01-01] Federally Enforceable Through Title V Permit
50. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75. [40 CFR Part 75] Federally Enforceable Through Title V Permit
51. The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR Part 75] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

52. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR Part 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR Part 73] Federally Enforceable Through Title V Permit
53. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR Part 77] Federally Enforceable Through Title V Permit
54. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR Part 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR Part 72, 40 CFR Part 75] Federally Enforceable Through Title V Permit
55. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR Part 72] Federally Enforceable Through Title V Permit
56. An allowance shall not be deducted in order to comply with the requirements under 40 CFR Part 73, prior to the calendar year for which the allowance was allocated. [40 CFR Part 73] Federally Enforceable Through Title V Permit
57. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR Part 72.7 and Part 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR Part 72] Federally Enforceable Through Title V Permit
58. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR Part 72] Federally Enforceable Through Title V Permit
59. The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR Part 72] Federally Enforceable Through Title V Permit
60. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit
61. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR Part 77. [40 CFR Part 77] Federally Enforceable Through Title V Permit
62. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR Part 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superceded because of the submission of a new certificate of representation changing the designated representative. [40 CFR Part 72] Federally Enforceable Through Title V Permit
63. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR Part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR Part 72, 40 CFR Part 75] Federally Enforceable Through Title V Permit
64. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 75 Subpart I. [40 CFR Part 75] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

65. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rule 407 (Kern) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
66. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a)(1) and (b), 60.333 (a) and (b), 60.334 (c), h(1), h(3) and (j), and 60.335 (a), (b)(3), and (c); District Rule 4703 (as amended 09/20/07), Sections 5.1.3, 5.2, 5.3, 6.1, 6.3.1, 6.3.3, 6.4.1, 6.4.2, 6.4.3, and 6.4.5 as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
67. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b), 60.8, 60.8(d), 60.13, and 60.13(b); District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 7.0, 7.1, 7.2, 7.3, 8.0, 9.0, 10.0, and 11.0; and 1081 (as amended 12/16/93) as of the date of permit issuance. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3746-3-4

EXPIRATION DATE: 06/30/2023

SECTION: SW23 **TOWNSHIP:** 31S **RANGE:** 22E

EQUIPMENT DESCRIPTION:

137,000 GPM COOLING TOWER WITH HIGH EFFICIENCY DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012] Federally Enforceable Through Title V Permit
3. Drift eliminator drift rate shall not exceed 0.0006%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. PM10 emission rate shall not exceed 15.78 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
5. Compliance with the PM10 daily emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{circulating water recirculation rate} * \text{total dissolved solids concentration in the blowdown water} * \text{design drift rate} * \text{correction factor}$. [District NSR Rule] Federally Enforceable Through Title V Permit
6. Compliance with PM10 emission limit shall be determined quarterly by circulating water sample analysis performed by an independent laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
7. The operator shall maintain records of all circulating water tests performed. Records shall be maintained for at least 5 years and shall be made available to the District upon request. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-3746-4-3

EXPIRATION DATE: 06/30/2023

EQUIPMENT DESCRIPTION:

TRANSPORTABLE TIER-3 CERTIFIED DIESEL-FIRED IC ENGINE UP TO 532 HP POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Permittee shall provide written notification to the District within 48 hours of operating unit under this permit (if unit is located onsite longer than 24 hours). Such notification shall include the date the unit was brought onsite, the manufacturer, model number, maximum rating, and emissions information that documents that the unit meets the emission limits and requirements specified in the permit. [District Rule 1070] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. The engine shall not operate unless permit units S-3746-1 and S-3746-2 are shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
5. This nonroad transportable engine shall not be operated at one location for more than 12 consecutive months and shall meet all the requirements of a nonroad transportable engine, per CFR Title 40 Part 89. [CCR, Title 17 and District Rule 4701] Federally Enforceable Through Title V Permit
6. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
7. Any engine utilized by this permit shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
8. Permittee shall monitor the operational characteristics of the engine as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
9. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO-approved alternative. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
10. Operation of IC engine shall not exceed 200 hours/yr without prior District approval through issuance of an Authority to Construct. [District Rules 2201, 4102, and 4702] Federally Enforceable Through Title V Permit
11. NOx emissions (referenced as NO2) shall not exceed 2.3 g/bhp-hr. [District Rule 2201 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit
12. VOC emissions (referenced as methane) shall not exceed 0.16 g/bhp-hr. [District Rule 2201 and 40 CFR Part 60 Subpart III] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. CO emissions shall not exceed 0.6 g/bhp-hr. [District Rule 2201 and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
14. The PM10 emissions rate from the engine shall not exceed 0.12 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
15. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801; and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
16. Any engine utilized by this permit shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
17. The operator shall maintain records of the cumulative hours of operation on a 12 month rolling average, type of fuel used and the purpose for operating the engine. These records shall be updated at least monthly. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.