



**JAN 15 2019**

Mr. David Bryson  
Rainbow Farms  
PO Box 910  
Turlock, CA 95381

**Re: Notice of Final Action - Title V Permit Renewal**  
**Facility Number: N-5526**  
**Project Number: N-1172382**

Dear Mr. Bryson:

The District has issued the Final Renewed Title V Permit for Rainbow Farms (see enclosure). The preliminary decision for this project was made on November 7, 2018. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,

Arnaud Marjollet  
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email  
cc: Gerardo C. Rios, EPA (w/enclosure) via email

**Samir Sheikh**  
Executive Director/Air Pollution Control Officer

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585



Facility # N-5526  
RAINBOW FARMS  
PO BOX 910  
TURLOCK, CA 95381

## Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.\* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

\*Failure to comply with the permit unit requirements may result in enforcement action.

**Samir Sheikh**  
Executive Director/Air Pollution Control Officer

Northern Region  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: 661-392-5500 FAX: 661-392-5585

# Permit to Operate

**FACILITY:** N-5526

**EXPIRATION DATE:** 12/31/2022

**LEGAL OWNER OR OPERATOR:**  
**MAILING ADDRESS:**

RAINBOW FARMS  
PO BOX 910  
TURLOCK, CA 95381

**FACILITY LOCATION:**

1220 HALL RD  
DENAIR, CA 95316

**FACILITY DESCRIPTION:**

CHICKEN EGGS

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

**Samir Sheikh**  
Executive Director / APCO

**Arnaud Marjollet**  
Director of Permit Services

# San Joaquin Valley Air Pollution Control District

FACILITY: N-5526-0-2

EXPIRATION DATE: 12/31/2022

## FACILITY-WIDE REQUIREMENTS

---

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.



10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
24. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The owner or operator shall implement the applicable conservation management practices (CMP) selected in the approved CMP plan pursuant to Section 6.2 of District Rule 4550 (8/19/04). The owner or operator shall submit a CMP application to the APCO prepared pursuant to Section 6.1 of District Rule 4550 (8/19/04) within 90 days for an agricultural operation site or an agricultural parcel that is acquired or becomes subject to District Rule 4550 and within 60 days of any operational, administrative, or other modification that necessitates revision of the CMP Plan. The owner or operator shall maintain a copy of each CMP application, CMP plan, and any supporting information necessary to confirm the implementation of the CMPs for a minimum of five (5) years. [District Rule 4550] Federally Enforceable Through Title V Permit
43. This permit does not authorize the violation of any conditions established for this facility in the Conditional Use Permit (CUP), Special Use Permit (SUP), Site Approval, Site Plan Review (SPR), or other approval documents issued by a local, state, or federal agency. [Public Resources Code 21000-21177: California Environmental Quality Act]
44. On August 31, 2013, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin September 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-1-5

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

LAYING HEN RANCH INCLUDING 1,786,000 LAYERS CONSISTING OF 23 MECHANICALLY VENTILATED LAYER HOUSES INCLUDING ELECTRIC FANS TOTALING 624 HP

## PERMIT UNIT REQUIREMENTS

---

1. Permittee shall implement and maintain all the mitigation measures contained in this permit no later than December 25, 2013 [District Rule 4570] Federally Enforceable Through Title V Permit
2. Mitigation measures that are currently being implemented as required by Phase I of Rule 4570 should continue to be implemented until the mitigation measures required under this permit are implemented. [District Rule 4570] Federally Enforceable Through Title V Permit
3. If a licensed veterinarian or a certified nutritionist determines that any VOC mitigation measure will be required to be suspended as a detriment to animal health or necessary for the animal to molt, the owners/operators must notify the District in writing within forty-eight (48) hours of the determination including the duration and the specific health condition requiring the mitigation measure to be suspended. If the situation is expected to exist longer than a thirty-day (30) period, the owner/operator shall submit a new emission mitigation plan designating a mitigation measure to be implemented in lieu of the suspended mitigation measure. [District Rule 4570] Federally Enforceable Through Title V Permit
4. Permittee shall feed animals additives such as amylase, xylanase, and protease, designed to maximize digestive efficiency. [District Rule 4570] Federally Enforceable Through Title V Permit
5. Permittee shall maintain records that demonstrate animals are fed feed additives such as amylase, xylanase, and protease. Records such as feed company guaranteed analyses (feed tags), ration sheets, or feed purchase records may be used to meet this. [District Rule 4570] Federally Enforceable Through Title V Permit
6. Permittee shall use drinkers that do not drip continuously. [District Rule 4570] Federally Enforceable Through Title V Permit
7. Permittee shall inspect water pipes and drinkers and repair leaks daily. [District Rule 4570] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records indicating that water pipes and drinkers are inspected daily and that any leaks are repaired. [District Rule 4570] Federally Enforceable Through Title V Permit
9. Permittee shall maintain a record of the number of animals of each species and production group at the facility and shall maintain quarterly records of any changes to this information. [District Rule 4570] Federally Enforceable Through Title V Permit
10. Permittee shall keep and maintain all records for a minimum of five (5) years and shall make records available to the APCO and EPA upon request. [District Rule 4570] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-2-4

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

SOLID MANURE HANDLING SYSTEM CONSISTING OF OPEN MANURE STOCK PILES WITH SOLID MANURE APPLICATION TO LAND, OFFSITE HAULING, AND ON-SITE COMPOSTING

## PERMIT UNIT REQUIREMENTS

---

1. Permittee shall implement and maintain all the mitigation measures contained in this permit no later than December 25, 2013. [District Rule 4570] Federally Enforceable Through Title V Permit
2. Mitigation measures that are currently being implemented as required by Phase I of Rule 4570 should continue to be implemented until the mitigation measures required under this permit are implemented. [District Rule 4570] Federally Enforceable Through Title V Permit
3. If a licensed veterinarian or a certified nutritionist determines that any VOC mitigation measure will be required to be suspended as a detriment to animal health or necessary for the animal to molt, the owners/operators must notify the District in writing within forty-eight (48) hours of the determination including the duration and the specific health condition requiring the mitigation measure to be suspended. If the situation is expected to exist longer than a thirty-day (30) period, the owner/operator shall submit a new emission mitigation plan designating a mitigation measure to be implemented in lieu of the suspended mitigation measure. [District Rule 4570] Federally Enforceable Through Title V Permit
4. Within seventy two (72) hours of removal of solid manure from housing, permittee shall either 1) remove all litter/manure from the facility, or 2) cover litter/manure outside the housing with a weatherproof covering from October through May, except for times when wind events remove the covering, not to exceed twenty-four (24) hours per event. [District Rule 4570] Federally Enforceable Through Title V Permit
5. Permittee shall keep records of dates when litter/manure is removed from the facility; manure hauling invoices may be used to meet this requirement, or permittee shall maintain records to demonstrate that litter/manure piles outside the pens are covered with a weatherproof covering from October through May. [District Rule 4570] Federally Enforceable Through Title V Permit
6. If weatherproof coverings are used, permittee shall maintain records, such as manufacturer warranties or other documentation, demonstrating that the weatherproof covering over dry manure are installed, used, and maintained in accordance with manufacturer recommendations and applicable standards listed in NRCS Field Office Technical Guide Code 313 or 367, or any other applicable standard approved by the APCO, ARB, and EPA. [District Rule 4570] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-4-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

234 BHP CATERPILLAR MODEL 3306D1 (S/N: 85Z11102) DIESEL-FIRED EMERGENCY STANDBY IC ENGINE  
POWERING AN ELECTRICAL GENERATOR (PEPPER)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-6-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

147 BHP DEUTZ MODEL 1013FC (S/N: 00410072) DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (CORTEZ)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-7-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

314 BHP CATERPILLAR MODEL 3306DI DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (HALL)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-9-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

450 BHP GENERAL MOTORS MODEL W-LS-TT (S/N: 500-600) DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (SHASTA)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-10-2

EXPIRATION DATE: 12/31/2022

## EQUIPMENT DESCRIPTION:

450 BHP DETROIT MODEL 12V71 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (SIERRA)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.



11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-12-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

450 BHP DAEWOO MODEL P180LE(G) (S/N: 401438EASOC) DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (VEGAS)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-13-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

300 BHP GENERAL MOTORS MODEL 500-600 (S/N: 514769) DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR (YOSEMITE)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-14-2

EXPIRATION DATE: 12/31/2022

## EQUIPMENT DESCRIPTION:

AGRICULTURAL GASOLINE DISPENSING OPERATION WITH ONE 1,000 GALLON ABOVEGROUND STORAGE TANK SERVED BY TWO-POINT PHASE I VAPOR RECOVERY SYSTEM (G-70-142-B), AND 1 FUELING POINT WITH 1 PHASE II EXEMPT GASOLINE DISPENSING NOZZLE

## PERMIT UNIT REQUIREMENTS

---

1. The Phase I vapor recovery system shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Order specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rule 4621] Federally Enforceable Through Title V Permit
2. The storage container(s) shall be installed, maintained, and operated such that they are leak-free. [District Rule 4621] Federally Enforceable Through Title V Permit
3. The Phase I vapor recovery systems and gasoline dispensing equipment shall be maintained without leaks as determined in accordance with the test method specified in this permit. [District Rule 4621] Federally Enforceable Through Title V Permit
4. A leak is defined as the dripping of VOC-containing liquid at a rate of more than three (3) drops per minute, or the detection of any gaseous or vapor emissions with a concentration of total organic compound greater than 10,000 ppmv, as methane, above background when measured in accordance with EPA Test Method 21. [District Rule 4621] Federally Enforceable Through Title V Permit
5. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo container, which attest to the vapor integrity of the container. [District Rule 4621] Federally Enforceable Through Title V Permit
6. The permittee shall conduct periodic maintenance inspections based on the greatest monthly throughput of gasoline dispensed by the facility in the previous year as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rule 4621] Federally Enforceable Through Title V Permit
7. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621] Federally Enforceable Through Title V Permit
8. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rule 4621] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

9. The permittee shall perform and pass a Static Leak Test for Aboveground Tanks using ARB TP-201.3B or TP-206.3 at least once every 36 months. [District Rule 4621] Federally Enforceable Through Title V Permit
10. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621] Federally Enforceable Through Title V Permit
11. A person performing installation of, or maintenance on, a certified Phase I vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rule 4621] Federally Enforceable Through Title V Permit
12. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rule 4621] Federally Enforceable Through Title V Permit
13. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rule 4621]
14. Total gasoline throughput for the facility shall not exceed either of the following: 10,000 gallons in any consecutive 30-day period or 24,000 gallons per calendar year. If throughput exceeds stated limits, the permittee shall submit a complete application for an Authority to Construct (ATC) to the District within 30 days of the loss of exemption and install and test a certified Phase II vapor recovery system within six (6) months from the date the ATC is issued. [District Rule 4622] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly and annual gasoline throughput records. The records should allow the gasoline throughput for any 30-day period to be continuously determined. These records shall be maintained on the premises as long as exempt status is claimed. [District Rules 4621 and 4622] Federally Enforceable Through Title V Permit
16. All records required by this permit shall be retained on-site for a period of at least five years and shall be made available for District inspection upon request. [District Rule 4621] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-19-2

EXPIRATION DATE: 12/31/2022

## EQUIPMENT DESCRIPTION:

490 BHP DETROIT DIESEL MODEL 606MK35 SPECB34450 DIESEL-FIRED EMERGENCY STANDBY IC ENGINE  
POWERING AN ELECTRICAL GENERATOR

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4701] Federally Enforceable Through Title V Permit
3. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight shall be consumed by the engine. [District Rule 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 40 CFR §63.6625 (f)] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
6. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per year. [District Rule 4702] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
9. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
10. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's oil and filter shall be changed every 500 hours of operation or annually, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's air filter shall be inspected every 1,000 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The engine's hoses and belts shall be inspected every 500 hours of operation or annually, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-20-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

0.4 MMBTU/HR CHORE-TIME MODEL A600 DIESEL-FIRED POULTRY INCINERATOR WITH 0.09 MMBTU/HR AFTERBURNER

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 2000 ppmv as SO<sub>2</sub>. [District Rule 4801] Federally Enforceable Through Title V Permit
3. The primary combustion chamber incinerator shall not be operated unless the secondary chamber (afterburner) is operating. [District Rule 4302] Federally Enforceable Through Title V Permit
4. Emission rates from this unit shall not exceed any of the following limits: 0.000883 lb-NO<sub>x</sub>/lb-poultry carcasses; 0.0016 lb-SO<sub>x</sub>/lb-poultry carcasses; 0.0062 lb-CO/lb-poultry carcasses; 0.0013 lb-PM<sub>10</sub>/lb-poultry carcasses; and 0.0002 lb-VOC/lb-poultry carcasses. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The maximum poultry incinerator charging rate shall not exceed 600 lb-poultry carcasses per day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Daily records of weight of poultry carcasses incinerated in each incinerator shall be maintained, retained on-site for a period of at least five years and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-21-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

0.4 MMBTU/HR CHORE-TIME MODEL A600 DIESEL-FIRED POULTRY INCINERATOR WITH 0.09 MMBTU/HR AFTERBURNER

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 2000 ppmv as SO<sub>2</sub>. [District Rule 4801] Federally Enforceable Through Title V Permit
3. The primary combustion chamber incinerator shall not be operated unless the secondary chamber (afterburner) is operating. [District Rule 4302] Federally Enforceable Through Title V Permit
4. Emission rates from this unit shall not exceed any of the following limits: 0.000883 lb-NO<sub>x</sub>/lb-poultry carcasses; 0.0016 lb-SO<sub>x</sub>/lb-poultry carcasses; 0.0062 lb-CO/lb-poultry carcasses; 0.0013 lb-PM<sub>10</sub>/lb-poultry carcasses; and 0.0002 lb-VOC/lb-poultry carcasses. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The maximum poultry incinerator charging rate shall not exceed 600 lb-poultry carcasses per day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Daily records of weight of poultry carcasses incinerated in each incinerator shall be maintained, retained on-site for a period of at least five years and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-22-2

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

871 BHP DAEWOO MODEL P222LE TIER 1 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE  
POWERING AN ELECTRICAL GENERATOR (FORMERLY N-5526-5-0)

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. Emissions from this IC engine shall not exceed any of the following limits: 6.12 g-NOx/bhp-hr, 0.70 g-CO/bhp-hr, or 0.03 g-VOC/bhp-hr. [District Rule 2201 and 17 CCR 93115] Federally Enforceable Through Title V Permit
8. Emissions from this IC engine shall not exceed 0.07 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, and 17 CCR 93115] Federally Enforceable Through Title V Permit
9. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
10. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
12. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-23-2

EXPIRATION DATE: 12/31/2022

**EQUIPMENT DESCRIPTION:**

ORGANIC WASTE MATERIAL RECEIVING, STORAGE, AND MIXING OPERATION

## PERMIT UNIT REQUIREMENTS

---

1. All material for processing shall be maintained adequately moist to prevent visible emissions in excess of 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. The combined quantity of animal manure, poultry litter and agricultural waste received and/or generated shall not exceed 19,062 wet tons (28,600 cubic yards) in any 12-month rolling period. [District Rule 2010] Federally Enforceable Through Title V Permit
3. The permittee shall test the carbon to nitrogen ratio of the composting material when it is prepared for active composting using TMECC Method 05.02A (Carbon to Nitrogen Ratio). Testing shall be done each day that materials are mixed and test samples shall be representative of the initial composition of the active compost pile. [District Rule 4565] Federally Enforceable Through Title V Permit
4. If the tested parameters of the mitigation measure are found to be outside the applicable limits the permittee shall take corrective action, within 24 hours of discovery, to bring the pile characteristics to within the specified limits. [District Rule 4565] Federally Enforceable Through Title V Permit
5. The permittee shall maintain a record indicating a record indicating the date and the tested carbon to nitrogen ratio of the composting material prepared and mixed for active composting use. [District Rule 4565] Federally Enforceable Through Title V Permit
6. The permittee shall record on a daily basis the quantity of organic waste material received that would be used in the compost/co-compost operation. [District Rule 4565] Federally Enforceable Through Title V Permit
7. The permittee shall maintain a cumulative annual log and the log shall include the following: (a) Total quantity and type of each organic waste material received and/or generated onsite (in wet tons); (b) Total quantity and type of each organic waste material mixed for composting (in wet tons). The records shall be updated at least monthly. [District Rule 1070] Federally Enforceable Through Title V Permit
8. All bulk material transport vehicles shall limit the Visible Dust Emissions to 20% opacity by either limiting vehicular speed, maintaining sufficient freeboard on the load, applying water to the top of the load or covering the load with a tarp or other suitable cover. [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
9. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 or Rule 8011. [District Rule 8041] Federally Enforceable Through Title V Permit
10. Any open area having 3.0 acres, or more, of disturbed surface area that has remained undeveloped, unoccupied, unused or vacant for more than seven days shall comply with the requirements of District Rule 8051 (Open Areas), unless specifically exempted under Section 4.0 [District Rule 8051] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

11. Any new or existing public or private paved or unpaved road, road construction project, or road modification project shall implement the control measures and design criteria of, and comply with the requirements of District Rule 8061 (Paved and Unpaved Roads), unless specifically exempted under Section 4.0 of Rule 8061. [District Rule 8061] Federally Enforceable Through Title V Permit
12. Water, gravel, roadmix or chemical/organic dust stabilizers/suppressants, vegetative materials, or other District approved control measure shall be applied to unpaved vehicle travel areas as required to limit Visible Dust Emissions to 20% opacity and comply with the requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
13. On each day that 50 or more Vehicle Daily Trips or 25 or more Vehicle Daily Trips with 3 axles or more will occur on an unpaved vehicle/equipment traffic area, the permittee shall apply water, gravel, road mix or chemical/organic dust stabilizers/suppressants, vegetative materials or other District approved control measure as required to limit Visible Dust Emissions to 20% opacity and comply with requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
14. Whenever any portion of the site becomes inactive, the permittee shall restrict access and periodically stabilize any disturbed surface to comply with the conditions for a stabilized surface as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a minimum of five years and shall be made available for District, ARB or EPA inspection upon request. [District Rules 1070 and 4565] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-24-2

EXPIRATION DATE: 12/31/2022

**EQUIPMENT DESCRIPTION:**

OPEN WINDROW ACTIVE AND CURING PHASE CO-COMPOSTING OPERATION

## PERMIT UNIT REQUIREMENTS

---

1. All material for processing shall be maintained adequately moist to prevent visible emissions in excess of 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. The permittee shall test the oxygen concentration of each active compost pile and each curing compost pile at least once per week using TMECC Method 05.08-C (In-Situ Oxygen Refresh Rate). [District Rule 4565] Federally Enforceable Through Title V Permit
3. The permittee shall test the moisture content of each active compost pile and each curing compost pile at least once per week using TMECC Method 03.09-C (Total Solids and Moisture at 70 +/- 5 degrees Centigrade). [District Rule 4565] Federally Enforceable Through Title V Permit
4. If the tested oxygen concentration and moisture content are found to be outside the applicable limits the permittee shall take corrective action, within 24 hours of discovery, to bring the pile characteristics to within the specified limits. [District Rule 4565] Federally Enforceable Through Title V Permit
5. The permittee shall maintain a record indicating indicating the date and the tested oxygen concentration of each active compost pile and each curing compost pile. [District Rule 4565] Federally Enforceable Through Title V Permit
6. The permittee shall maintain a record indicating indicating the date and the tested moisture content of each active compost pile and each curing compost pile. [District Rule 4565] Federally Enforceable Through Title V Permit
7. A daily record shall be maintained and shall include the following: (a) Total quantity of active phase composting piles utilized onsite (in wet tons); (b) Total quantity of curing phase composting piles utilized onsite (in wet tons). [District Rules 1070 and 4565] Federally Enforceable Through Title V Permit
8. A cumulative 12-month rolling period record log shall be maintained and shall include the following: (a) Total quantity and type of each organic waste material received and/or generated onsite (in wet tons); (b) Total quantity and type of each organic waste material mixed for composting (in wet tons). The records shall be updated at least monthly. [District Rule 1070] Federally Enforceable Through Title V Permit
9. The permittee shall maintain annual records indicating the quantity of biosolids, animal manure and poultry litter received, generated and composted on site, in tons per year. [District Rule 4565] Federally Enforceable Through Title V Permit
10. All bulk material transport vehicles shall limit Visible Dust Emissions to 20% opacity by either limiting vehicular speed, maintaining sufficient freeboard on the load, applying water to the top of the load or covering the load with a tarp or other suitable cover. [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
11. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 or Rule 8011. [District Rule 8041] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Any open area having 3.0 acres, or more, of disturbed surface area that has remained undeveloped, unoccupied, unused or vacant for more than seven days shall comply with the requirements of District Rule 8051 (Open Areas), unless specifically exempted under Section 4.0 [District Rule 8051] Federally Enforceable Through Title V Permit
13. Any new or existing public or private paved or unpaved road, road construction project, or road modification project shall implement the control measures and design criteria of, and comply with the requirements of District Rule 8061 (Paved and Unpaved Roads), unless specifically exempted under Section 4.0 of Rule 8061. [District Rule 8061] Federally Enforceable Through Title V Permit
14. Water, gravel, roadmix or chemical/organic dust stabilizers/suppressants, vegetative materials, or other District approved control measure shall be applied to unpaved vehicle travel areas as required to limit Visible Dust Emissions to 20% opacity and comply with the requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
15. On each day that 50 or more Vehicle Daily Trips or 25 or more Vehicle Daily Trips with 3 axles or more will occur on an unpaved vehicle/equipment traffic area, the permittee shall apply water, gravel, road mix or chemical/organic dust stabilizers/suppressants, vegetative materials or other District approved control measure as required to limit Visible Dust Emissions to 20% opacity and comply with requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
16. Whenever any portion of the site becomes inactive, the permittee shall restrict access and periodically stabilize any disturbed surface to comply with the conditions for a stabilized surface as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
17. All records shall be maintained and retained on-site for a minimum of five years and shall be made available for District, ARB or EPA inspection upon request. [District Rules 1070 and 4565] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-25-2

EXPIRATION DATE: 12/31/2022

## EQUIPMENT DESCRIPTION:

FINISHED COMPOST STORAGE AND LOADOUT OPERATION

## PERMIT UNIT REQUIREMENTS

---

1. All material for processing shall be maintained adequately moist to prevent visible emissions in excess of 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
2. All bulk material transport vehicles shall limit Visible Dust Emissions to 20% opacity by either limiting vehicular speed, maintaining sufficient freeboard on the load, applying water to the top of the load or covering the load with a tarp or other suitable cover. [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
3. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 or Rule 8011. [District Rule 8041] Federally Enforceable Through Title V Permit
4. Any open area having 3.0 acres, or more, of disturbed surface area that has remained undeveloped, unoccupied, unused or vacant for more than seven days shall comply with the requirements of District Rule 8051 (Open Areas), unless specifically exempted under Section 4.0 [District Rule 8051] Federally Enforceable Through Title V Permit
5. Any new or existing public or private paved or unpaved road, road construction project, or road modification project shall be implement the control measures and design criteria of, and comply with the requirements of District Rule 8061 (Paved and Unpaved Roads), unless specifically exempted under Section 4.0 of Rule 8061. [District Rule 8061] Federally Enforceable Through Title V Permit
6. Water, gravel, roadmix or chemical/organic dust stabilizers/suppressants, vegetative materials, or other District approved control measure shall be applied to unpaved vehicle travel areas as required to limit Visible Dust Emissions to 20% opacity and comply with the requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
7. On each day that 50 or more Vehicle Daily Trips or 25 or more Vehicle Daily Trips with 3 axles or more will occur on an unpaved vehicle/equipment traffic area, the permittee shall apply water, gravel, road mix or chemical/organic dust stabilizers/suppressants, vegetative materials or other District approved control measure as required to limit Visible Dust Emissions to 20% opacity and comply with requirements for a stabilized unpaved road as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
8. Whenever any portion of the site becomes inactive, the permittee shall restrict access and periodically stabilize any disturbed surface to comply with the conditions for a stabilized surface as defined in District Rule 8011. [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
9. All records shall be maintained and retained on-site for a minimum of five years and shall be made available for District, ARB or EPA inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.



# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-26-2

EXPIRATION DATE: 12/31/2022

**EQUIPMENT DESCRIPTION:**

157 BHP PERKINS MODEL 1104D-E44TAG2 TIER 3 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE  
POWERING AN ELECTRIC GENERATOR

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. This engine shall only be used for the growing of crops or raising of fowl or animals. [District Rule 4702] Federally Enforceable Through Title V Permit
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201, 4801, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
6. Emissions from this IC engine shall not exceed any of the following limits: 2.39 g-NOx/bhp-hr, 1.34 g-CO/bhp-hr, or 0.37 g-VOC/bhp-hr. [District Rule 2201, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. Emissions from this IC engine shall not exceed 0.15 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115, and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
8. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
10. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
11. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

12. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
13. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 17 CCR 93115 and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702 and 17 CCR 93115] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** N-5526-27-1

**EXPIRATION DATE:** 12/31/2022

**EQUIPMENT DESCRIPTION:**

SHENANDOAH A-850 POULTRY INCINERATOR #1 WITH A 0.42 MMBTU/HR DIESEL-FIRED MAIN BURNER AND A 0.07 MMBTU/HR DIESEL-FIRED AFTERBURNER

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 2000 ppmv as SO<sub>2</sub>. [District Rule 4801] Federally Enforceable Through Title V Permit
3. The primary combustion chamber incinerator shall not be operated unless the secondary chamber (afterburner) is operating. [District Rule 4302] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing no more than 0.0015% sulfur by weight is to be used. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Operation of the incinerator shall not exceed 9 hours in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The quantity of poultry incinerated shall not exceed 850 pounds in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. NO<sub>x</sub> emissions shall not exceed 0.217 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. SO<sub>x</sub> emissions shall not exceed 0.184 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CO emissions shall not exceed 1.53 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM<sub>10</sub> emissions shall not exceed 0.0019 pounds per pound of poultry incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit
11. VOC emissions shall not exceed 0.0002 pounds per pound of poultry incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The permittee shall keep a daily record of the number of hours operated. [District Rule 2201] Federally Enforceable Through Title V Permit
13. The permittee shall keep a daily record of the quantity of poultry incinerated, in pounds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. All records shall be maintained and retained on-site for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 2201 and 4302] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-28-1

EXPIRATION DATE: 12/31/2022

**EQUIPMENT DESCRIPTION:**

SHENANDOAH A-850 POULTRY INCINERATOR #2 WITH A 0.42 MMBTU/HR DIESEL-FIRED MAIN BURNER AND A 0.07 MMBTU/HR DIESEL-FIRED AFTERBURNER

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
2. Sulfur compound emissions shall not exceed 2000 ppmv as SO<sub>2</sub>. [District Rule 4801] Federally Enforceable Through Title V Permit
3. The primary combustion chamber incinerator shall not be operated unless the secondary chamber (afterburner) is operating. [District Rule 4302] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing no more than 0.0015% sulfur by weight is to be used. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Operation of the incinerator shall not exceed 9 hours in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. The quantity of poultry incinerated shall not exceed 850 pounds in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. NO<sub>x</sub> emissions shall not exceed 0.217 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. SO<sub>x</sub> emissions shall not exceed 0.184 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CO emissions shall not exceed 1.53 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM<sub>10</sub> emissions shall not exceed 0.0019 pounds per pound of poultry incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit
11. VOC emissions shall not exceed 0.0002 pounds per pound of poultry incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The permittee shall keep a daily record of the number of hours operated. [District Rule 2201] Federally Enforceable Through Title V Permit
13. The permittee shall keep a daily record of the quantity of poultry incinerated, in pounds. [District Rule 2201] Federally Enforceable Through Title V Permit
14. All records shall be maintained and retained on-site for a minimum of five years, and shall be made available for District inspection upon request. [District Rules 2201 and 4302] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-5526-29-2

EXPIRATION DATE: 12/31/2022

## EQUIPMENT DESCRIPTION:

389 BHP (INTERMITTENT) IVECO/FPT INDUSTRIAL S.P.A. MODEL F2CE9685A-E TIER 3 CERTIFIED DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRIC GENERATOR

## PERMIT UNIT REQUIREMENTS

---

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201]
2. This IC engine shall only be used for the growing and harvesting of crops or the raising of fowl or animals for the primary purpose of making a profit, providing a livelihood, or conducting agricultural research or instruction by an educational institution. [District Rule 4701 and 17 CCR 93115]
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (a flapper type is acceptable), roof overhang, or any other obstruction. [District Rule 4102]
4. This engine shall be equipped with a non-resettable hour meter with a minimum display capability of 9,999 hours, unless the District determines that a non-resettable hour meter with a different minimum display capability is appropriate in consideration of the historical use of the engine and the owner or operator's compliance history. [District Rule 4702, 17 CCR 93115, and 40 CFR Part 60 Subpart III]
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115, and 40 CFR Part 60 Subpart III]
6. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702 and 40 CFR Part 60 Subpart III]
7. Emissions from this IC engine shall not exceed any of the following limits: 2.47 g-NO<sub>x</sub>/bhp-hr, 0.4 g-CO/bhp-hr, or 0.13 g-VOC/bhp-hr. [District Rule 2201, 17 CCR 93115, and 40 CFR Part 60 Subpart III]
8. Emissions from this IC engine shall not exceed 0.10 g-PM<sub>10</sub>/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102, 17 CCR 93115, and 40 CFR Part 60 Subpart III]
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702]
10. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations or to supply power while maintenance is performed or repairs are made to the primary power supply. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rules 2201 and 4702, and 40 CFR Part 60 Subpart III]
11. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702]
12. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702 and 17 CCR 93115]
14. The permittee shall maintain monthly records of the type of fuel purchased. [District Rule 4702 and 17 CCR 93115]
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702, and 17 CCR 93115]
16. This permit does not authorize the violation of any conditions established for this facility in the Conditional Use Permit (CUP), Special Use Permit (SUP), Site Approval, Site Plan Review (SPR), or other approval documents issued by a local, state, or federal agency. [Public Resources Code 21000-21177: California Environmental Quality Act]

These terms and conditions are part of the Facility-wide Permit to Operate.