

**AVISO DE UNA DECISIÓN FINAL
PARA LA OTORGACIÓN DE UNA AUTORIDAD PARA CONSTRUIR Y
MODIFICACIÓN SIGNIFICATIVA DE UN PERMISO MANDATORIO FEDERAL
PARA OPERAR**

POR EL PRESENTE SE NOTIFICA que el Distrito para el Control de la Contaminación del Aire del Valle de San Joaquín ha tomado la decisión final para otorgar una Autoridad para Construir a Fresno/Clovis Regional WWTP en 5607 W Jensen Ave, Fresno, California. El proyecto incluye la instalación de una nueva llamarada John Zink cerrada bajo la unidad del permiso C-535-45 para operar en conjunto con la llamarada existente listada bajo la unidad del permiso C-535-9. También ha presentado una solicitud de ATC para la modificación de un aparato de combustión de 7.46 MMBtu/hora existente en el sistema de acondicionamiento de gas (permitido bajo C-535-26) para aclarar la descripción del equipo para permitir la combustión de gas digestor crudo no tratado

El Distrito no recibió comentarios durante la decisión preliminar en este proyecto.

El análisis del Distrito para el Proyecto # C-1170082, está disponible para la inspección del público en http://www.valleyair.org/notices/public_notices_idx.htm, el DISTRITO PARA EL CONTROL DE LA CONTAMINACIÓN DEL AIRE DEL VALLE DE SAN JOAQUÍN, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, y en cualquiera de las oficinas del Distrito. Para más información en Español, por favor comuníquese con el Distrito al (559) 230-6000.

**NOTICE OF FINAL DECISION
FOR THE ISSUANCE OF AUTHORITY TO CONSTRUCT AND
SIGNIFICANT MODIFICATION OF FEDERALLY
MANDATED OPERATING PERMIT**

NOTICE IS HEREBY GIVEN that the San Joaquin Valley Air Pollution Control District has made its final decision to issue Authorities to Construct to Fresno/Clovis Regional WWTP at 5607 W Jensen Ave, Fresno, California. the installation of a new enclosed John Zink flare under permit unit C-535-45 to operate in conjunction with existing flare listed under permit unit C-535-9 at the facility. Additionally combined with project C-1170082 ATC application is submitted under project # C-1170245 for the modification of an existing 7.46 MMBtu/hr combustion device in the gas conditioning system permitted under C-535-26 to clarify the equipment description so it will read how the system is allowed to combust waste gas and raw untreated digester gas