



NOV 14 2019

Mr. Bill Davidson
TRC Operating Company
PO Box 227
Taft CA, 93268

Re: Proposed ATC / Certificate of Conformity (Significant Mod)
Facility Number: S-3088
Project Number: S-1193387

Dear Mr. Davidson:

Enclosed for your review is the District's analysis of an application for Authority to Construct for the facility identified above. You requested that a Certificate of Conformity with the procedural requirements of 40 CFR Part 70 be issued with this project. The application is for a process heater.

The notice of preliminary decision for this project has been posted on the District's website (www.valleyair.org). After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the Authority to Construct with a Certificate of Conformity. Please submit your comments within the 30-day public comment period, as specified in the enclosed public notice. Prior to operating with modifications authorized by the Authority to Construct, the facility must submit an application to modify the Title V permit as an administrative amendment, in accordance with District Rule 2520, Section 11.5.

If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Thank you for your cooperation in this matter.

Sincerely,



Arnaud Marjolle
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

Authority to Construct Application Review

Facility Name: TRC Operating Company
Mailing Address: PO Box 227
Taft CA, 93268
Contact Person: Bill Davidson
Telephone: 661-616-8680
Application #(s): S-3088-31-0
Project #: 1193387
Deemed Complete:

Date: 11/14/19
Engineer: David Torii
Lead Engineer: Rich Karrs

I. Proposal

TRC Operating Company (TRC) has requested an Authority to Construct (ATC) permit for the installation of a 8.2 MMBtu/hr process heater.

TRC has received their Title V Permit. This modification can be classified as a Title V significant modification pursuant to Rule 2520, and can be processed with a Certificate of Conformity (COC). Since the facility has specifically requested that this project be processed in that manner, the 45-day EPA comment period will be satisfied prior to the issuance of the Authority to Construct. TRC must apply to administratively amend their Title V permit.

II. Applicable Rules

Rule 2201 New and Modified Stationary Source Review Rule (8/15/19)
Rule 2410 Prevention of Significant Deterioration (6/16/11)
Rule 2520 Federally Mandated Operating Permits (8/15/19)
Rule 4001 New Source Performance Standards (4/14/99)
Rule 4101 Visible Emissions (2/17/05)
Rule 4102 Nuisance (12/17/92)
Rule 4201 Particulate Matter Concentration (12/17/92)
Rule 4301 Fuel Burning Equipment (12/17/92)
Rule 4305 Boilers, Steam Generators, and Process Heaters – Phase 2 (8/21/03)
Rule 4306 Boilers, Steam Generators, and Process Heaters – Phase 3 (10/16/08)
Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr (10/16/08)
Rule 4801 Sulfur Compounds (12/17/92)
CH&SC 41700 Health Risk Assessment
CH&SC 42301.6 School Notice
Public Resources Code 21000-21177: California Environmental Quality Act (CEQA)
California Code of Regulations, Title 14, Division 6, Chapter 3, Sections 15000-15387: CEQA Guidelines

III. Project Location

The equipment will operate at various locations within the Midway Sunset Oil Field, within the Section 22, Township 32S, Range 23E in TRC's Heavy Oil Western stationary source. The equipment will not be located within 1,000 feet of the outer boundary of a K-12 school. Therefore, the public notification requirement of California Health and Safety Code 42301.6 is not applicable to this project.

IV. Process Description

The unit will be used to heat an oil-based product that will be pumped into an oil well via enclosed piping in order to heat the surrounding formation water to create steam to lower the viscosity of crude oil which will facilitate the crude oil's production. The temperature of the unit will be relatively high in order to maintain the fluid temperature in the well. This is a new untested technology that is being used for steaming in lieu of a traditional steam generator.

V. Equipment Listing

S-3088-31-0: PORTABLE 8.2 MMBTU/HR NORTH AMERICAN HEATING MODEL MTHG-804 NATURAL GAS FIRED HEATER WITH AN INDUSTRIAL COMBUSTION MTHG-84 LOW NOX BURNER

VI. Emission Control Technology Evaluation

Low-NO_x burners reduce NO_x formation by producing lower flame temperatures (and longer flames) than conventional burners. Conventional burners thoroughly mix all the fuel and air in a single stage just prior to combustion, whereas low-NO_x burners delay the mixing of fuel and air by introducing the fuel (or sometimes the air) in multiple stages. Generally, in the first combustion stage, the air-fuel mixture is fuel rich. In a fuel rich environment, all the oxygen will be consumed in reactions with the fuel, leaving no excess oxygen available to react with nitrogen to produce thermal NO_x. In the secondary and tertiary stages, the combustion zone is maintained in a fuel-lean environment. The excess air in these stages helps to reduce the flame temperature so that the reaction between the excess oxygen with nitrogen is minimized.

VII. General Calculations

A. Assumptions

- The maximum operating schedule is 8760 hours per year
- The unit is fired solely on PUC-quality natural gas
- Natural Gas Heating Value: 1,000 Btu/scf (District Practice)
- F-Factor for Natural Gas: 8,578 dscf/MMBtu corrected to 60°F (40 CFR 60, Appendix B)

B. Emission Factors

Pollutant	Post-Project Emission Factors (EF2) (lb/MMBtu)		Source
NO _x	0.011	9 ppmvd NO _x (@ 3%O ₂)	Proposed and Rule 4320
SO _x	0.00285		District Policy APR 1720
PM ₁₀	0.0076		Proposed and AP-42 (07/98) Table 1.4-2
CO	0.0370	50 ppmvd CO (@ 3%O ₂)	Proposed
VOC	0.0055	13 ppmvd VOC (@ 3% O ₂)	Proposed and AP-42 (07/98) Table 1.4-2

1. Pre-Project Potential to Emit (PE1)

Since this is a new emissions unit, PE1 = 0 for all pollutants.

2. Post-Project Potential to Emit (PE2)

The potential to emit for the heater is calculated as follows, and summarized in the table below:

$$\begin{aligned}
 PE2_{NO_x} &= (0.011 \text{ lb/MMBtu}) * (8.2 \text{ MMBtu/hr}) * (24 \text{ hr/day}) \\
 &= 2.2 \text{ lb NO}_x/\text{day} \\
 &= (0.011 \text{ lb/MMBtu}) * (8.2 \text{ MMBtu/hr}) * (24 \text{ hr/day}) * (365 \text{ day/year}) \\
 &= 790 \text{ lb NO}_x/\text{year}
 \end{aligned}$$

PE2		
Pollutant	Daily Emissions (lb/day)	Annual Emissions (lb/year)
NO _x	2.2	790
SO _x	0.6	205
PM ₁₀	1.5	546
CO	7.3	2,658
VOC	1.1	395

3. Pre-Project Stationary Source Potential to Emit (SSPE1)

Pursuant to District Rule 2201, the SSPE1 is the Potential to Emit (PE) from all units with valid Authorities to Construct (ATC) or Permits to Operate (PTO) at the Stationary Source and the quantity of Emission Reduction Credits (ERC) which have been banked since September 19, 1991 for Actual Emissions Reductions (AER) that have occurred at the source, and which have not been used on-site.

SSPE1 (lb/year)							
Permit #			NO _x	SO _x	PM ₁₀	CO	VOC
S	2622	1	3,979	624	1,678	16,717	1,205
S	2622	5					56,940*
S	2622	11	2,286	381	1,016	4,573	762
S	2622	17	9,855	1,560	4,161	19,163	1,643
S	2622	18	19,710	8,213	8,213	19,163	1,643
S	2622	19	19,710	7,884	7,884	20,235	1,752
S	2622	20	19,710	7,884	7,884	20,235	1,752
S	3088	7	9,308	119,903	20,258	41,446	3,011
S	3088	8	8,560	75,774	1,007	46,576	7,931*
S	3088	9	0	0	0	0	0
S	3088	10	0	0	0	0	0
S	3088	11	0	0	0	0	0
S	3088	12	0	0	0	0	0
S	3088	13	0	0	0	0	0
S	3088	14	0	0	0	0	0
S	3088	15	0	0	0	0	0
S	3088	16	0	0	0	0	0
S	3088	20	9,308	0	4,161	19,163	3,011
S	3088	21	0	0	0	0	0
S	3088	24	9,308	0	31,755	19,163	3,011
SSPE1			107,755	221,599	86,339	209,717	82,661
SSPE1**			107,755	221,599	86,339	209,717	17,790

*fugitive emissions

**without fugitive emissions

4. Post-Project Stationary Source Potential to Emit (SSPE2)

Pursuant to District Rule 2201, the SSPE2 is the PE from all units with valid ATCs or PTOs at the Stationary Source and the quantity of ERCs which have been banked since September 19, 1991 for AER that have occurred at the source, and which have not been used on-site.

SSPE2 (lb/year)							
Permit #			NO _x	SO _x	PM ₁₀	CO	VOC
S	2622	1	3,979	624	1,678	16,717	1,205
S	2622	5					56,940*
S	2622	11	2,286	381	1,016	4,573	762
S	2622	17	9,855	1,560	4,161	19,163	1,643
S	2622	18	19,710	8,213	8,213	19,163	1,643
S	2622	19	19,710	7,884	7,884	20,235	1,752
S	2622	20	19,710	7,884	7,884	20,235	1,752
S	3088	7	9,308	119,903	20,258	41,446	3,011
S	3088	8	8,560	75,774	1,007	46,576	7,931*
S	3088	9	0	0	0	0	0
S	3088	10	0	0	0	0	0
S	3088	11	0	0	0	0	0
S	3088	12	0	0	0	0	0
S	3088	13	0	0	0	0	0
S	3088	14	0	0	0	0	0
S	3088	15	0	0	0	0	0
S	3088	16	0	0	0	0	0
S	3088	20	9,308	0	4,161	19,163	3,011
S	3088	21	0	0	0	0	0
S	3088	24	9,308	0	31,755	19,163	3,011
S	3088	31-0	790	205	546	2,658	395
SSPE2			108,545	221,804	86,885	212,375	83,056
SSPE2**			108,545	221,804	86,885	212,375	18,185

*fugitive emissions

**without fugitive emissions

5. Major Source Determination

Rule 2201 Major Source Determination:

Pursuant to District Rule 2201, a Major Source is a stationary source with a SSPE2 equal to or exceeding one or more of the following threshold values. For the purposes of determining major source status the following shall not be included:

- any ERCs associated with the stationary source
- Emissions from non-road IC engines (i.e. IC engines at a particular site at the facility for less than 12 months)
- Fugitive emissions, except for the specific source categories specified in 40 CFR 51.165

Rule 2201 Major Source Determination (lb/year)						
	NO _x	SO _x	PM ₁₀	PM _{2.5}	CO	VOC
SSPE1	107,755	221,599	86,339	86,339	209,717	17,790
SSPE2	108,545	221,804	86,885	86,885	212,375	18,185
Major Source Threshold	20,000	140,000	140,000	140,000	200,000	20,000
Major Source?	y	y	n	n	y	n

Note: PM2.5 assumed to be equal to PM10

This source is an existing Major Source for NO_x, SO_x, and CO emissions and will remain so. No change in other pollutants are proposed or expected as a result of this project.

Rule 2410 Major Source Determination:

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(iii). Therefore the PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination (tons/year)						
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀
Estimated Facility PE before Project Increase	54	41	111	105	43	43
PSD Major Source Thresholds	250	250	250	250	250	250
PSD Major Source?	No	No	No	No	No	No

As shown above, the facility is not an existing PSD major source for any regulated NSR pollutant expected to be emitted at this facility.

6. Baseline Emissions (BE)

The BE calculation (in lb/year) is performed pollutant-by-pollutant for each unit within the project to calculate the QNEC, and if applicable, to determine the amount of offsets required.

Since this is a new emissions unit, BE = PE1 = 0 for all pollutants.

7. SB 288 Major Modification

SB 288 Major Modification is defined in 40 CFR Part 51.165 as "any physical change in or change in the method of operation of a major stationary source that would result in a significant net emissions increase of any pollutant subject to regulation under the Act."

Since this facility is a major source for NO_x, SO_x and CO the project's PE2 is compared to the SB 288 Major Modification Thresholds in the following table in order to determine if the SB 288 Major Modification calculation is required.

SB 288 Major Modification Thresholds			
Pollutant	Project PE2 (lb/year)	Threshold (lb/year)	SB 288 Major Modification Calculation Required?
NO _x	733	50,000	N
SO _x	205	80,000	N

Since none of the SB 288 Major Modification Thresholds are surpassed with this project, this project does not constitute an SB 288 Major Modification.

8. Federal Major Modification

District Rule 2201 states that a Federal Major Modification is the same as a "Major Modification" as defined in 40 CFR 51.165 and part D of Title I of the CAA.

The determination of Federal Major Modification is based on a two-step test. For the first step, only the emission *increases* are counted. Emission decreases may not cancel out the increases for this determination.

Step 1

For new emissions units, the increase in emissions is equal to the PE2 for each new unit included in this project.

The project's combined total emission increases compared to the Federal Major Modification Thresholds in the following table.

Federal Major Modification Thresholds for Emission Increases			
Pollutant	Total Emissions Increases (lb/yr)	Thresholds (lb/yr)	Federal Major Modification?
NO _x	790	0	Y
SO _x	205	80,000	N

Since there is an increase in NO_x emissions, this project constitutes a Federal Major Modification. Federal Offset quantities are calculated below.

Federal Offset Quantities:

The Federal offset quantity is only calculated only for the pollutants for which the project is a Federal Major Modification. The Federal offset quantity is the sum of the annual emission changes for all new and modified emission units in a project calculated as the potential to emit after the modification (PE2) minus the actual emissions (AE) during the baseline period for each emission unit multiplied by the applicable federal offset ratio. There are no special calculations performed for units covered by an SLC.

NOx		Federal Offset Ratio	1.5
Permit No.	Actual Emissions (lb/year)	Potential Emissions (lb/year)	Emissions Change (lb/yr)
S-3088-31-0	0	790	790
Net Emission Change (lb/year):			790
Federal Offset Quantity: (NEC * 1.5)			1185

9. Rule 2410 – Prevention of Significant Deterioration (PSD) Applicability Determination

I. Project Emissions Increase - New Major Source Determination

The post-project potentials to emit from all new and modified units are compared to the PSD major source thresholds to determine if the project constitutes a new major source subject to PSD requirements.

The facility or the equipment evaluated under this project is not listed as one of the categories specified in 40 CFR 52.21 (b)(1)(i). The PSD Major Source threshold is 250 tpy for any regulated NSR pollutant.

PSD Major Source Determination: Potential to Emit (tons/year)						
	NO ₂	VOC	SO ₂	CO	PM	PM ₁₀
Total PE from New and Modified Units	0	0	0	1	0	0
PSD Major Source threshold	250	250	250	250	250	250
New PSD Major Source?	n	n	n	n	n	n

As shown in the table above, the potential to emit for the project, by itself, does not exceed any PSD major source threshold. Therefore Rule 2410 is not applicable and no further analysis is required.

10. Quarterly Net Emissions Change (QNEC)

The QNEC is calculated solely to establish emissions that are used to complete the District's PAS emissions profile screen. Detailed QNEC calculations are included in Appendix A.

VIII. Compliance Determination

Rule 2201 New and Modified Stationary Source Review Rule

A. Best Available Control Technology (BACT)

1. BACT Applicability

Pursuant to District Rule 2201, Section 4.1, BACT requirements are triggered on a pollutant-by-pollutant basis and on an emissions unit-by-emissions unit basis. Unless specifically exempted by Rule 2201, BACT shall be required for the following actions*:

- a. Any new emissions unit with a potential to emit exceeding two pounds per day,
- b. The relocation from one Stationary Source to another of an existing emissions unit with a potential to emit exceeding two pounds per day,
- c. Modifications to an existing emissions unit with a valid Permit to Operate resulting in an Adjusted Increase in Permitted Emissions (AIPE) exceeding two pounds per day, and/or
- d. Any new or modified emissions unit, in a stationary source project, which results in an SB 288 Major Modification or a Federal Major Modification, as defined by the rule.

*Except for CO emissions from a new or modified emissions unit at a Stationary Source with an SSPE2 of less than 200,000 pounds per year of CO.

a. New emissions units – PE > 2 lb/day

As seen in Section VII.C.2 above, the applicant is proposing to install a new heater with a PE greater than 2 lb/day for NO_x, and CO. BACT is triggered for NO_x and CO since the PEs are greater than 2 lb/day.

b. Relocation of emissions units – PE > 2 lb/day

As discussed in Section I above, there are no emissions units being relocated from one stationary source to another; therefore BACT is not triggered.

c. Modification of emissions units – AIPE > 2 lb/day

As discussed in Section I above, there are no modified emissions units associated with this project. Therefore BACT is not triggered.

d. SB 288/Federal Major Modification

As discussed in Sections VII.C.7 and VII.C.8 above, this project constitutes a Federal Major Modification for NO_x emissions. Therefore BACT is triggered for NO_x.

2. BACT Guideline

Please note that BACT Guideline 1.1.1 Boiler: < or = 20.0 MMBtu/hr, Natural Gas or Propane Fired has been rescinded; therefore, a project-specific BACT determination will be performed.

3. Top-Down BACT Analysis

Pursuant to the project-specific BACT determination (see Appendix B), BACT has been satisfied with the following:

NO_x: 9 ppmvd @ 3% O₂
CO: 50 ppmvd @ 3% O₂

B. Offsets**1. Offset Applicability**

Pursuant to District Rule 2201, Section 4.5, offset requirements shall be triggered on a pollutant by pollutant basis and shall be required if the SSPE2 equals or exceeds the offset threshold levels in Table 4-1 of Rule 2201.

The SSPE2 is compared to the offset thresholds in the following table.

Offset Determination (lb/year)					
	NO _x	SO _x	PM ₁₀	CO	VOC
SSPE2	112,467	222,428	88,563	229,092	83,056
Offset Thresholds	20,000	54,750	29,200	200,000	20,000
Offsets triggered?	y	y	y	y	y

2. Quantity of Offsets Required

As seen above, the SSPE2 is greater than the offset thresholds for all pollutants. Therefore offset calculations will be required for this project.

The quantity of offsets in pounds per year is calculated as follows for sources with an SSPE1 greater than the offset threshold levels before implementing the project being evaluated.

Offsets Required (lb/year) = $(\sum[PE2 - BE] + ICCE) \times DOR$, for all new or modified emissions units in the project,

Where,

PE2 = Post-Project Potential to Emit, (lb/year)

BE = Baseline Emissions, (lb/year)

ICCE = Increase in Cargo Carrier Emissions, (lb/year)

DOR = Distance Offset Ratio, determined pursuant to Section 4.8

The facility is proposing to install a new emissions unit; therefore BE = 0. Also, there is only one emissions unit associated with this project and there are no increases in cargo carrier emissions; therefore offsets can be determined as follows:

Offsets Required (lb/year) = $([PE2 - BE] + ICCE) \times DOR$

NO_x:

PE2 (NO_x) = 790 lb/year

BE (NO_x) = 0 lb/year

ICCE = 0 lb/year

The project is a Federal Major Modification and therefore the correct offset ratio for NO_x is 1.5:1.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= ([790 - 0] + 0) \times 1.5 \\ &= 790 \times 1.5 \\ &= 1,185 \text{ lb NO}_x\text{/year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (1,185 \text{ lb NO}_x\text{/year}) \div (4 \text{ quarters/year}) \\ &= 296.25 \text{ lb/qtr} \end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X \div 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>Total</u>
296	296	296	297	1185

Per section 4.13.8 of Rule 2201, AER for NO_x that occurred from April through November may be used to offset increases in NO_x during any period of the year.

The applicant has stated that the facility plans to use ERC certificates S-5117-2 and C-1489-2 to offset the increases in NO_x emissions associated with this project. The above certificate has available quarterly NO_x credits as follows:

ERC #	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter	
S-5117-2	215	321	321	0	857
C-1489-2	107	0	0	322	857
Total:					1,714

As seen above, the facility has sufficient credits to fully offset the quarterly NO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender NO_x emission reduction credits for the following quantity of emissions: 1st quarter – 296 lb, 2nd quarter – 296 lb, 3rd quarter – 296 lb, and 4th quarter – 297 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Numbers S-5117-2 and C-1489-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

SO_x:

PE2 (NO_x) = 205 lb/year
 BE (NO_x) = 0 lb/year
 ICCE = 0 lb/year

The approved distance offset ratio is 1:1.5 because the emission reduction originated greater than 15 miles for the proposed unit.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= ([205 - 0] + 0) \times 1.5 \\ &= 205 \times 1.5 \\ &= 308 \text{ lb SO}_x\text{/year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (308 \text{ lb SO}_x\text{/year}) \div (4 \text{ quarters/year}) \\ &= 77.0 \text{ lb/qtr} \end{aligned}$$

Therefore the appropriate quarterly emissions to be offset are as follows:

<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
77	77	77	77

The applicant has stated that the facility plans to use ERC certificate N-1513-5 to offset the increases in SO_x emissions associated with this project. The above certificate has available quarterly SO_x credits as follows:

ERC #	1 st Quarter	2 nd Quarter	3 rd Quarter	4 th Quarter
N-1513-5	83	83	83	84

As seen above, the facility has sufficient credits to fully offset the quarterly SO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender SO_x emission reduction credits for the following quantity of emissions: 1st quarter – 77 lb, 2nd quarter – 77 lb, 3rd quarter – 77 lb, and 4th quarter – 77 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Numbers N-1513-5 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

PM10:

PE2 (PM10) = 546 lb/year
 BE (PM10) = 0 lb/year
 ICCE = 0 lb/year

The approved distance offset ratio is 1:1.5 because the emission reduction originated greater than 15 miles for the proposed unit.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= ([546 - 0] + 0) \times 1.5 \\ &= 546 \times 1.5 \\ &= 819.0 \text{ lb PM10/year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (819 \text{ lb PM10/year}) \div (4 \text{ quarters/year}) \\ &= 204.75 \text{ lb/qtr} \end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X + 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>Total Annual</u>
204	205	205	205	819

Pursuant to section 4.13.7 of Rule 2201, AER for PM that occurred from October through March, inclusive, may be used to offset increases in PM during any period of the year.

The applicant has stated that the facility plans to use ERC certificate N-1489-4 to offset the increases in PM10 emissions associated with this project. The above certificate has available quarterly PM10 credits as follows:

<u>ERC #</u>	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>Total</u>
C-1489-4	444	0	0	445	889

As seen above, the facility has sufficient credits to fully offset the quarterly SO_x emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter – 204 lb, 2nd quarter – 205 lb, 3rd quarter – 205 lb, and 4th quarter – 205 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]
- ERC Certificate Numbers C-1489-4 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

VOC:

PE2 (NO_x) = 395 lb/year
 BE (NO_x) = 0 lb/year
 ICCE = 0 lb/year

The approved distance offset ratio is 1:1.5 because the emission reduction originated greater than 15 miles for the proposed unit.

$$\begin{aligned} \text{Offsets Required (lb/year)} &= ([395 - 0] + 0) \times 1.5 \\ &= 395 \times 1.5 \\ &= 593 \text{ lb NO}_x\text{/year} \end{aligned}$$

Calculating the appropriate quarterly emissions to be offset is as follows:

$$\begin{aligned} \text{Quarterly offsets required (lb/qtr)} &= (593 \text{ lb VOC/year}) \div (4 \text{ quarters/year}) \\ &= 148.25 \text{ lb/qtr} \end{aligned}$$

As shown in the calculation above, the quarterly amount of offsets required for this project, when evenly distributed to each quarter, results in fractional pounds of offsets being required each quarter. Since offsets are required to be withdrawn as whole pounds, the quarterly amounts of offsets need to be adjusted to ensure the quarterly values sum to the total annual amount of offsets required.

To adjust the quarterly amount of offsets required, the fractional amount of offsets required in each quarter will be summed and redistributed to each quarter based on the number of days in each quarter. The redistribution is based on the Quarter 1 having the fewest days and the Quarters 3 and 4 having the most days. The redistribution method is summarized in the following table:

Redistribution of Required Quarterly Offsets (where X is the annual amount of offsets, and $X + 4 = Y.z$)				
Value of z	Quarter 1	Quarter 2	Quarter 3	Quarter 4
.0	Y	Y	Y	Y
.25	Y	Y	Y	Y+1
.5	Y	Y	Y+1	Y+1
.75	Y	Y+1	Y+1	Y+1

Therefore the appropriate quarterly emissions to be offset are as follows:

<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>Total</u>
148	148	148	149	593

The applicant has stated that the facility plans to use ERC certificate S-5119-1 to offset the increases in VOC emissions associated with this project. The above certificate has available quarterly VOC credits as follows:

	<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>
ERC #S-5119-1	161	161	161	160

As seen above, the facility has sufficient credits to fully offset the quarterly VOC emissions increases associated with this project.

Proposed Rule 2201 (offset) Conditions:

- {GC# 4447 - edited} Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter – 148 lb, 2nd quarter – 148 lb, 3rd quarter – 148 lb, and 4th quarter – 149 lb. These amounts include the applicable offset ratio specified in Rule

2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201]

- ERC Certificate Numbers S-5119-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201]

Note that the above ERC certificates proposed for surrender are owned by Future Energy, LLC (FEL). The proposed project is a joint venture between TRC and FEL. Therefore, the offsets will be provided by FEL ERCs.

3. ERC Withdrawal Calculations

The applicant must identify the ERC Certificate(s) to be used to offset the emissions increases for the project. See **Appendix C** for detailed ERC Withdrawal Calculations.

C. Public Notification

1. Applicability

Pursuant to District Rule 2201, Section 5.4, public noticing is required for:

- a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications,
- b. Any new emissions unit with a Potential to Emit greater than 100 pounds during any one day for any one pollutant,
- c. Any project which results in the offset thresholds being surpassed,
- d. Any project with an SSIPE of greater than 20,000 lb/year for any pollutant, and/or
- e. Any project which results in a Title V significant permit modification

a. New Major Sources, Federal Major Modifications, and SB 288 Major Modifications

New Major Sources are new facilities, which are also Major Sources. Since this is not a new facility, public noticing is not required for this project for New Major Source purposes.

As demonstrated in Sections VII.C.7 and VII.C.8, this project is a Federal Major Modification. Therefore, public noticing for Federal Major Modification purposes is required.

b. PE > 100 lb/day

Applications which include a new emissions unit with a PE greater than 100 pounds during any one day for any pollutant will trigger public noticing requirements. As seen in Section VII.C.2 above, this project does not include a new emissions unit which has daily emissions greater than 100 lb/day for any pollutant, therefore public noticing for PE > 100 lb/day purposes is not required.

c. Offset Threshold

Public notification is required if the pre-project Stationary Source Potential to Emit (SSPE1) is increased to a level exceeding the offset threshold levels. The following table compares the SSPE1 with the SSPE2 in order to determine if any offset thresholds have been surpassed with this project.

Offset Thresholds				
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	Offset Threshold	Public Notice Required?
NO _x	112,467	112,467	20,000 lb/year	N
SO _x	222,428	222,428	54,750 lb/year	N
PM ₁₀	88,563	88,563	29,200 lb/year	N
CO	229,092	229,092	200,000 lb/year	N
VOC	83,056	83,056	20,000 lb/year	N

As detailed above, there were no thresholds surpassed with this project; therefore public noticing is not required for offset purposes.

d. SSIPE > 20,000 lb/year

Public notification is required for any permitting action that results in a SSIPE of more than 20,000 lb/year of any affected pollutant. According to District policy, the SSIPE = SSPE2 – SSPE1. The SSIPE is compared to the SSIPE Public Notice thresholds in the following table.

SSIPE Public Notice Thresholds					
Pollutant	SSPE1 (lb/year)	SSPE2 (lb/year)	SSIPE (lb/year)	SSIPE Public Notice Threshold	Public Notice Required?
NO _x	112,467	112,467	733	20,000 lb/year	N
SO _x	222,428	222,428	205	20,000 lb/year	N
PM ₁₀	88,563	88,563	546	20,000 lb/year	N
CO	229,092	229,092	2,658	20,000 lb/year	N
VOC	83,056	83,056	395	20,000 lb/year	N

As demonstrated above, the SSIPEs for all pollutants were less than 20,000 lb/year; therefore public noticing for SSIPE purposes is not required.

e. Title V Significant Permit Modification

As shown in the Discussion of Rule 2520 below, this project constitutes a Title V significant modification. Therefore, public noticing for Title V significant modifications is required for this project.

2. Public Notice Action

As discussed above, public noticing is required for constituting a Title V significant modification. Therefore, public notice documents will be submitted to the California Air Resources Board (CARB) and a public notice will be electronically published on the District's website prior to the issuance of the ATC for this equipment.

D. Daily Emission Limits (DELs)

DELs and other enforceable conditions are required by Rule 2201 to restrict a unit's maximum daily emissions, to a level at or below the emissions associated with the maximum design capacity. The DEL must be contained in the latest ATC and contained in or enforced by the latest PTO and enforceable, in a practicable manner, on a daily basis. DELs are also required to enforce the applicability of BACT.

Proposed Rule 2201 (DEL) Conditions:

The unit shall only be fired on PUC-quality natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201 and 4320] Y

Emission rates shall not exceed: NO_x (as NO_x): 9 ppmvd @ 3% O₂ or 0.011 lb-NO_x/MMBtu; PM₁₀: 0.0076 lb/MMBtu; CO: 50 ppmvd @ 3% O₂ or 0.037 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rule 2201, 4305, 4306, and 4320] Y

E. Compliance Assurance

1. Source Testing

Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rule 2201, 4305, 4306, and 4320]

Source testing to measure combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320]

2. Monitoring

As required by District Rule 4305, Boilers, Steam Generators and Process Heaters, Phase 2, District Rule 4306, Boilers, Steam Generators and Process Heaters, Phase 3, and District Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr, this unit is subject to monitoring requirements. Monitoring requirements, in accordance with District Rules 4305, 4306, and 4320 will be discussed in Section VIII, District Rule 4320 of this evaluation.

3. Recordkeeping

Recordkeeping is required to demonstrate compliance with the offset, public notification and daily emission limit requirements of Rule 2201. The following condition(s) are listed on the permit to operate:

Records of sulfur content (gr S/100 scf) of combusted gas shall be maintained. [District Rules 1070, 2201, and 4320] Y

Permittee shall maintain accurate records of valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts used to satisfy the fuel sulfur content analysis of fuel combusted in process heater, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2201 and 4320] N

All monitoring data, support information and records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320]

4. Reporting

No reporting is required to demonstrate compliance with Rule 2201.

F. Ambient Air Quality Analysis (AAQA)

Section 4.14 of District Rule 2201 requires that an AAQA be conducted for the purpose of determining whether a new or modified Stationary Source will cause or make worse a violation of an air quality standard. The District's Technical Services Division conducted the required analysis. Refer to **Appendix D** of this document for the AAQA summary sheet.

The proposed location is in an attainment area for NO_x, CO, and SO_x. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for NO_x, CO, or SO_x.

The proposed location is in a non-attainment area for the state's PM₁₀ as well as federal and state PM_{2.5} thresholds. As shown by the AAQA summary sheet the proposed equipment will not cause a violation of an air quality standard for PM₁₀ and PM_{2.5}.

G. Compliance Certification

Section 4.15.2 of this Rule requires the owner of a new Major Source or a source undergoing a Federal Major Modification to demonstrate to the satisfaction of the District that all other Major Sources owned by such person and operating in California are in compliance or are on a schedule for compliance with all applicable emission limitations and standards. As discussed in Section VIII above, this facility is a new major source and this project does constitute a Federal Major Modification, therefore this requirement is applicable. Corporation TRC's compliance certification is included in Appendix E.

H. Alternate Siting Analysis

The current project occurs at an existing facility. The applicant proposes to install a heater. Since the project will provide heat to be used at the same location, the existing site will result in the least possible impact from the project. Alternative sites would involve the relocation

and/or construction of various support structures on a much greater scale, and would therefore result in a much greater impact.

Rule 2410 Prevention of Significant Deterioration

As shown in Section VII.C.9 above, this project does not result in a new PSD major source or PS major modification. No further discussion is required.

Rule 2520 Federally Mandated Operating Permits

This facility is subject to this Rule, and has received their Title V Operating Permit. A significant permit modification is defined as a "permit amendment that does not qualify as a minor permit modification or administrative amendment."

Minor permit modifications are not Title I modifications as defined in this rule. This project triggers a Federal Major Modification, as a result, the proposed project constitutes a Significant Modification to the Title V Permit.

Rule 4001 New Source Performance Standards (NSPS)

This rule incorporates NSPS from Part 60, Chapter 1, Title 40, Code of Federal Regulations (CFR); and applies to all new sources of air pollution and modifications of existing sources of air pollution listed in 40 CFR Part 60. However, no subparts of 40 CFR Part 60 apply to heaters.

Rule 4101 Visible Emissions

Per Section 5.0, no person shall discharge into the atmosphere emissions of any air contaminant aggregating more than 3 minutes in any hour which is as dark as or darker than Ringelmann 1 (or 20% opacity). As the unit is fired solely on natural gas, visible emissions are not expected to exceed Ringelmann 1 or 20% opacity. The following condition will be listed on the permit to ensure compliance:

No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]

Rule 4102 Nuisance

Rule 4102 prohibits discharge of air contaminants which could cause injury, detriment, nuisance or annoyance to the public. Public nuisance conditions are not expected as a result of these operations, provided the equipment is well maintained. Therefore, compliance with this rule is expected.

California Health & Safety Code 41700 (Health Risk Assessment)

Discuss whether a Health Risk Assessment is required and/or the results of the HRA, including any special conditions to consider when issuing the ATC(s).

District Policy APR 1905 – *Risk Management Policy for Permitting New and Modified Sources* specifies that for an increase in emissions associated with a proposed new source or modification, the District perform an analysis to determine the possible impact to the nearest resident or worksite.

An HRA is not required for a project with a total facility prioritization score of less than or equal to one. According to the Technical Services Memo for this project (**Appendix D**), the total facility prioritization score including this project was less than or equal to one. Therefore, no further analysis is required to determine the impact from this project and compliance with the District's Risk Management Policy is expected.

Discussion of T-BACT

BACT for toxic emission control (T-BACT) is required if the cancer risk exceeds one in one million. As demonstrated above, T-BACT is not required for this project because the HRA indicates that the risk is not above the District's thresholds for triggering T-BACT requirements; therefore, compliance with the District's Risk Management Policy is expected.

Rule 4201 Particulate Matter Concentration

Section 3.1 prohibits discharge of dust, fumes, or total particulate matter into the atmosphere from any single source operation in excess of 0.1 grain per dry standard cubic foot.

F-Factor for NG: 8,578 dscf/MMBtu at 60 °F
 PM10 Emission Factor: 0.0076 lb-PM10/MMBtu
 Percentage of PM as PM10 in Exhaust: 100%
 Exhaust Oxygen (O₂) Concentration: 3%
 Excess Air Correction to F Factor = 20.9/(20.9 - 3) = 1.17

$$GL = \left(\frac{0.007 \text{ lb-PM}}{\text{MMBtu}} \right) * \left(\frac{7,000 \text{ grain}}{\text{lb-PM}} \right) / \left(\frac{8,578 \text{ ft}^3}{\text{MMBtu}} * 1.17 \right)$$

GL = 0.005 grain/dscf < 0.1 grain/dscf

Therefore, compliance with District Rule 4201 requirements is expected. Additionally, particulate matter emissions from the steam generator is already limited by Rule 2201 to a value less than or equal to the rule limit of 0.1 grain per cubic foot of gas at dry standard conditions.

Rule 4301 Fuel Burning Equipment

This rule specifies maximum emission rates in lb/hr for SO₂, NO₂, and combustion contaminants (defined as total PM in Rule 1020). This rule also limits combustion contaminants to ≤ 0.1 gr/scf. According to AP 42 (Table 1.4-2, footnote c), all PM emissions from natural gas combustion are less than 1 μm in diameter.

District Rule 4301 Limits (lb/hr)			
	Pollutant		
	NO₂	Total PM	SO₂
S-3088-31-0	0.011 x 8.2 = 0.09	0.0076 x 8.2 = 0.06	0.00285 x 8.2 = 0.02
Rule Limit (lb/hr)	140	10	200

The above table indicates compliance with the maximum lb/hr emissions in this rule;

Rule 4305 Boilers, Steam Generators and Process Heaters – Phase II

This unit is natural gas-fired with a maximum heat input of 8.2 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4305, the unit is subject to District Rule 4305, *Boilers, Steam Generators and Process Heaters – Phase 2*.

In addition, the unit is also subject to District Rule 4306, *Boilers, Steam Generators and Process Heaters – Phase 3*.

Since the emissions limits of District Rule 4306 and all other requirements are equivalent or more stringent than District Rule 4305 requirements, compliance with District Rule 4306 requirements will satisfy the requirements of District Rule 4305.

Rule 4306 Boilers, Steam Generators and Process Heaters – Phase III

This unit is natural gas-fired with a maximum heat input of 8.2 MMBtu/hr. Pursuant to Section 2.0 of District Rule 4306, the unit is subject to District Rule 4306.

In addition, the unit is also subject to *District Rule 4320, Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5 MMBtu/hr*.

Since the emissions limits of District Rule 4320 and all other requirements are equivalent or more stringent than District Rule 4306 requirements, compliance with District Rule 4320 requirements will satisfy the requirements of District Rule 4306.

Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters Greater than 5.0 MMBtu/hr

Section 5.2 NOx and CO Emission Limits

The 8.2 MMBtu/hr heater is subject to the following NOx limits in Table 2, as shown below.

The applicant has proposed to meet the standard schedule NOx emission limit.

Rule 4320 Emissions Limits				
Category	Operated on gaseous fuel		Operated on liquid fuel	
	NO_x Limit	CO Limit	NO_x Limit	CO Limit
A. Units with a total rated heat input > 5.0 MMBtu/hr to < 20.0 MMBtu/hr, except for Categories C through G units	a) Standard Schedule 9 ppmv or 0.011 lb/MMBtu; or	400 ppmv	40 ppmv or 0.052 lb/MMBtu	400 ppmv
	b) Enhanced Schedule 6 ppmv or 0.007 lb/MMBtu			

The proposed NO_x emission factor is 9 ppmvd @ 3% O₂ (0.011 lb/MMBtu), and the proposed CO emission factor is 50 ppmvd @ 3% O₂ (0.074 lb/MMBtu).

Therefore, compliance with Section 5.2 of District Rule 4320 is expected.

A permit condition listing the emissions limit will be listed on permit as shown in the DEL section above.

Section 5.4 Particulate Matter Control Requirements

Section 5.4 of the rule requires one of four options for control of particulate matter: 1) combustion of PUC-quality natural gas, commercial propane, butane, or liquefied petroleum gas, or a combination of such gases, 2) limit fuel sulfur content to no more than five (5) grains of total sulfur per one hundred (100) standard cubic, 3) install and properly operate an emission control system that reduces SO₂ emissions by at least 95% by weight; or limit exhaust SO₂ to less than or equal to 9 ppmv corrected to 3.0% O₂ or 4) refinery units, which require modification of refinery equipment to reduce sulfur emissions, shall be in compliance with the applicable requirement in Section 5.4.1 no later than July 1, 2013.

The heater will only combust natural gas containing no more than 1.0 gr S/100 scf.

Section 5.6, Startup and Shutdown Provisions

Applicable emissions limits are not required during startup and shutdown provided The duration of each start-up or each shutdown shall not exceed two hours, the emission control system shall be in operation and emissions shall be minimized insofar as technologically feasible during start-up or shutdown or operator has submitted an application for a Permit to Operate condition to allow more than two hours for each start-up or each shutdown provided the operator meets all of the conditions specified in Sections 5.6.3.1 through 5.6.3.3.

Startup and shutdown conditions have not been proposed.

Section 5.7, Monitoring Provisions

Section 5.7 requires either use of a APCO approved Continuous Emissions Monitoring System (CEMS) for NO_x, CO, and oxygen, or implementation of an APCO-approved Alternate Monitoring System.

In order to satisfy the requirements of District Rule 4320, the applicant has proposed to use pre-approved alternate monitoring scheme A (pursuant to District Policy SSP-1105), which requires that monitoring of NO_x, CO, and O₂ exhaust concentrations shall be conducted at least once per month (in which a source test is not performed) using a portable analyzer. The following conditions will be incorporated into the permit in order to ensure compliance with the requirements of the proposed alternate monitoring plan:

{4063} The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320]

{4064} If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions

concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306, and 4320]

{4065} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320]

{4066} The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320]

5.7.6 Monitoring SO_x Emissions

Section 5.7.6.1 Operators complying with Sections 5.4.1.1 or 5.4.1.2 shall provide an annual fuel analysis to the District unless a more frequent sampling and reporting period is included in the Permit To Operate. Sulfur analysis shall be performed in accordance with the test methods in Section 6.2.

Section 5.7.6.2 Operators complying with Section 5.4.1.3 by installing and operating a control device with 95% SO_x reduction shall propose the key system operating parameters and frequency of the monitoring and recording. The monitoring option proposed shall be submitted for approval by the APCO.

Section 5.7.6.3 Operators complying with Section 5.4.1.3 shall perform an annual source test unless a more frequent sampling and reporting period is included in the Permit To Operate. Source tests shall be performed in accordance with the test methods in Section 6.2.

The unit shall only be fired on PUC-quality natural gas with a maximum sulfur content of 1.0 gr-S/100scf. [District Rules 2201 and 4320] Y

Permittee shall maintain accurate records of valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts used to satisfy the fuel sulfur content analysis of fuel combusted in process heater, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2201 and 4320] N

Section 5.8 Compliance Determination

Section 5.8.1 requires that the operator of any unit have the option of complying with either the applicable heat input (lb/MMBtu), emission limits or the concentration (ppmv) emission limits

specified in Section 5.2. The emission limits selected to demonstrate compliance shall be specified in the source test proposal pursuant to Rule 1081 (Source Sampling). Therefore, the following condition will be retained or listed on the permit as follows:

The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] N

Section 5.8.2 requires that all emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0. Therefore, the following permit condition will be listed on the permits as follows:

{2972} All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320]

Section 5.8.4 requires that for emissions monitoring pursuant to Sections 5.7.1 and 6.3.1 using a portable NO_x analyzer as part of an APCO approved Alternate Emissions Monitoring System, emission readings shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five (5) readings evenly spaced out over the 15-consecutive-minute period. Therefore, the following previously listed permit condition will be on the permits as follows:

{2937} All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320]

Section 5.8.5 requires that for emissions source testing performed pursuant to Section 6.3.1 for the purpose of determining compliance with an applicable standard or numerical limitation of this rule, the arithmetic average of three (3) 30-consecutive-minute test runs shall apply. If two (2) of three (3) runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. Therefore, the following permit condition will be listed on the permit as follows:

{2980} For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320]

Section 6.1 Recordkeeping

Section 6.1 requires that the records required by Sections 6.1.1 through 6.1.5 shall be maintained for five calendar years and shall be made available to the APCO and EPA upon request. Failure to maintain records or information contained in the records that demonstrate noncompliance with the applicable requirements of this rule shall constitute a violation of this rule. Therefore, the following permit condition will be listed on the permit as follows:

All monitoring data, support information and records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] N

Section 6.2, Test Methods

Section 6.2 identifies test methods to be used when determining compliance with the rule. The following conditions will be listed on the permits:

{109} Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081]

The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities – EPA Method 2; Stack gas moisture content – EPA Method 4; SO_x – EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content – EPA Method 11 or 15; and fuel hhv (MMBtu) –ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 4305, 4306 and 4320]

Section 6.3, Compliance Testing

Section 6.3.1 requires that each unit subject to the requirements in Section 5.2 shall be source tested at least once every 12 months, except if two consecutive annual source tests demonstrate compliance, source testing may be performed every 36 months. If such a source test demonstrates non-compliance, source testing shall revert to every 12 months. The following conditions will be included in the permit:

A source test to demonstrate compliance with NO_x and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320]

Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320]

{110} The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]

Sections 6.3.2.1 through 6.3.2.7 address the requirements of group testing which is not proposed in this project. Therefore these sections are not applicable.

Conclusion

Conditions will be incorporated into the permit in order to ensure compliance with each section of this rule, see attached draft permits. Therefore, compliance with District Rule 4320 requirements is expected.

District Rule 4801 Sulfur Compounds

A person shall not discharge into the atmosphere sulfur compounds, which would exist as a liquid or gas at standard conditions, exceeding in concentration at the point of discharge: 0.2 % by volume calculated as SO₂, on a dry basis averaged over 15 consecutive minutes.

Using the ideal gas equation and the emission factors presented in Section VII, the sulfur compound emissions are calculated as follows:

EPA F-Factor for Natural Gas: 8,710 dscf/MMBtu at 68 °F, equivalent to

$$\text{Corrected } F - \text{factor} = \left(\frac{8,710 \text{ dscf}}{\text{MMBtu}} \right) \times \left(\frac{60^\circ F + 459.6}{68^\circ F + 459.6} \right) = 8,578 \frac{\text{dscf}}{\text{MMBtu}} \text{ at } 60^\circ F$$

$$(1.0 \text{ gr-S/scf})(\text{lb}/7000 \text{ gr})(1000 \text{ scf/MMBtu})(\text{MMBtu}/8578 \text{ dscf})(\text{lb-mole}/64 \text{ lb})(10.76 \text{ psi-sc}/\text{lb-mole-}^\circ\text{R}) \\ (520 \text{ }^\circ\text{R}/14.7 \text{ psi})(1,000,000 \text{ parts/MM}) = 99 \text{ ppmv}$$

$$99 \text{ ppmv} < 2,000 \text{ ppmv (or 0.2\%)}$$

Therefore, compliance with District Rule 4801 requirements is expected.

California Health & Safety Code 42301.6 (School Notice)

The District has verified that this site is not located within 1,000 feet of a school. Therefore, pursuant to California Health and Safety Code 42301.6, a school notice is not required.

California Environmental Quality Act (CEQA)

CEQA SECTION 1: OIL AND GAS ACTIVITIES

CEQA requires each public agency to adopt objectives, criteria, and specific procedures consistent with CEQA Statutes and the CEQA Guidelines for administering its responsibilities under CEQA, including the orderly evaluation of projects and preparation of environmental documents. The District adopted its *Environmental Review Guidelines* (ERG) in 2001. The basic purposes of CEQA are to:

- Inform governmental decision-makers and the public about the potential, significant environmental effects of proposed activities;
- Identify the ways that environmental damage can be avoided or significantly reduced;

- Prevent significant, avoidable damage to the environment by requiring changes in projects through the use of alternatives or mitigation measures when the governmental agency finds the changes to be feasible; and
- Disclose to the public the reasons why a governmental agency approved the project in the manner the agency chose if significant environmental effects are involved.

Greenhouse Gas (GHG) Significance Determination

Oil and gas operations in Kern County must comply with the *Kern County Zoning Ordinance – 2015 (C) Focused on Oil and Gas Local Permitting*. In 2015, Kern County revised the Kern County Zoning Ordinance Focused on Oil and Gas Activities (Kern Oil and Gas Zoning Ordinance) in regards to future oil and gas exploration, and drilling and production of hydrocarbon resource projects occurring within Kern County.

Kern County served as lead agency for the revision to their ordinance under the California Environmental Quality Act (CEQA), and prepared an Environmental Impact Report (EIR) that was certified on November 9, 2015. The EIR evaluated and disclosed to the public the environmental impacts associated with the growth of oil and gas exploration in Kern County, and determined that such growth will result in significant GHG impacts in the San Joaquin Valley. As such, the EIR included mitigation measures for GHG.

The District is a Responsible Agency for the project because of its discretionary approval power over the project via its Permits Rule (Rule 2010) and New Source Review Rule (Rule 2201), (CEQA Guidelines §15381). As a Responsible Agency, the District is limited to mitigating or avoiding impacts for which it has statutory authority. The District does not have statutory authority for regulating GHGs. The District has determined that the applicant is responsible for implementing GHG mitigation measures imposed in the EIR by the Kern County for the Kern County Zoning Ordinance.

District CEQA Findings

The proposed project is located in Kern County and is thus subject to the Kern County Zoning Ordinance – 2015 (C) Focused on Oil and Gas Local Permitting. The Kern County Zoning Ordinance was developed by the Kern County Planning Agency as a comprehensive set of goals, objectives, policies, and standards to guide development, expansion, and operation of oil and gas exploration within Kern County.

In 2015, Kern County revised their *Kern County Zoning Ordinance* in regards to exploration, drilling and production of hydrocarbon resources projects. Kern County, as the lead agency, is the agency that will enforce the mitigation measures identified the EIR, including the mitigation requirements of the Oil and Gas ERA. As a responsible agency the District complies with CEQA by considering the EIR prepared by the Lead Agency, and by reaching its own conclusion on whether and how to approve the project involved (CCR §15096). The District has reviewed the EIR prepared by Kern County, the Lead Agency for the project, and finds it to be adequate. The District also prepared a full findings document. The full findings document, *California Environmental Quality Act (CEQA) Statement of Findings for the Kern County Zoning Ordinance EIR* contains the details of the District's findings regarding the Project. The District's implementation of the Kern Zoning Ordinance and its EIR applies to ATC applications received for any new/modified equipment used in oil/gas production in Kern County, including new wells. The full findings applies to the Project and the Project's related activity equipment(s) is covered under the Kern Zoning Ordinance. To reduce project related impacts on air

quality, the District evaluates emission controls for the project such as Best Available Control Technology (BACT) under District Rule 2201 (New and Modified Stationary Source Review). In addition, the District is requiring the applicant to surrender emission reduction credits (ERC) for stationary source emissions above the offset threshold.

Thus, the District concludes that through a combination of project design elements, permit conditions, and the Oil and Gas ERA, the project will be fully mitigated to result in no net increase in emissions. Pursuant to CCR §15096, prior to project approval and issuance of ATCs the District prepared findings.

IX. Recommendation

Compliance with all applicable rules and regulations is expected. Pending a successful NSR Public Noticing period, issue the ATC subject to the permit conditions on the attached draft ATC in **Appendix F**.

X. Billing Information

Annual Permit Fees			
Permit Number	Fee Schedule	Fee Description	Annual Fee
S-3088-31-0	3020-02 G	8.2 MMBtu/hr	\$980

Appendixes

- A: Quarterly Net Emissions Change
- B: BACT Analysis
- C: ERC Withdrawal Calculations
- D: HRA Summary and AAQA
- E: Compliance Certification
- F: Draft ATC

APPENDIX A
Quarterly Net Emissions Change (QNEC)

Quarterly Net Emissions Change (QNEC)

The Quarterly Net Emissions Change is used to complete the emission profile screen for the District's PAS database. The QNEC shall be calculated as follows:

$QNEC = PE2 - PE1$, where:

QNEC = Quarterly Net Emissions Change for each emissions unit, lb/qtr.

PE2 = Post Project Potential to Emit for each emissions unit, lb/qtr.

PE1 = Pre-Project Potential to Emit for each emissions unit, lb/qtr.

Using the values in Sections VII.C.2 and VII.C.6 in the evaluation above, quarterly PE2 and quarterly PE1 can be calculated as follows:

$PE2_{quarterly} = PE2_{annual} \div 4 \text{ quarters/year}$

$PE1_{quarterly} = PE1_{annual} \div 4 \text{ quarters/year}$

Quarterly NEC [QNEC]					
	PE2 (lb/yr)	PE2 (lb/qtr)	PE1 (lb/yr)	PE1 (lb/qtr)	QNEC (lb/qtr)
NO _x	790	198	0	0	198
SO _x	205	51	0	0	51
PM ₁₀	546	137	0	0	137
CO	2,658	665	0	0	665
VOC	395	99	0	0	99

APPENDIX B
BACT Analysis

Project-Specific BACT Determination for Heater

The BACT guideline for the proposed unit's class and category of source has been rescinded. Therefore, a project-specific BACT determination will be performed.

NO_x

Step 1 - Identify all control technologies

District Rule 4320 includes a compliance option that limits units greater than 5 MMBtu/hr and less than 20 MMBtu/hr to 9 ppm @ 3% O₂. This emission limit is determined to be achieved in practice control technology for this BACT analysis.

Note that no source tests results were found for a process heater with similar operating requirements as the proposed experimental unit that will heat an oil-based product (thermo-fluid) to relatively high temperatures.

District Rule 4320 contains an enhanced schedule option that allows applicants additional time to meet the requirements of the rule. The enhanced schedule NO_x emission limit requirement is 6 ppmv @ 3% O₂. Since this is an enhanced option in the rule, it is determined to be technologically feasible control technology for the BACT analysis.

The following are possible control technologies:

1. 9 ppmvd @ 3% O₂ – Achieved in Practice.
2. 6 ppmvd @ 3% O₂ – Technologically Feasible

Step 2 - Eliminate Technologically Infeasible Options

The burner manufacturer does not have a 6 ppmvd NO_x burner that can heat the unit's thermo-fluid to the temperature required to generate down-hole steam from the surrounding formation water.

Therefore, control technology #2 is eliminated.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

1. 9 ppmvd @ 3% O₂ - Achieved in Practice.

Step 4 - Cost Effectiveness Analysis

The only remaining control option has been proposed; therefore a cost effective analysis is not required.

Step 5 - Select BACT

A NO_x limit of 9 ppmvd @ 3% O₂

CO

Step 1 - Identify all control technologies

District Rule 4320 CO emissions to 400 ppmv @ 3% O₂. This emission limit is determined to be achieved in practice control technology for this BACT analysis.

The following are possible control technologies:

- 400 ppmvd @ 3% O₂ – Achieved in Practice.

Step 2 - Eliminate Technologically Infeasible Options

Achieved in Practice requirements cannot be eliminated.

Step 3 - Rank Remaining Control Technologies by Control Effectiveness

- 400 ppmvd @ 3% O₂ – Achieved in Practice.

Step 4 - Cost Effectiveness Analysis

The Achieved in Practice has been proposed; therefore a cost effective analysis is not required.

Step 5 - Select BACT

CO limit of 50 ppmvd @ 3% O₂

APPENDIX C
ERC Withdrawal Calculations

NO _x	1 st Quarter (lb)	2 nd Quarter (lb)	3 rd Quarter (lb)	4 th Quarter (lb)
ERC S-5117-2	215	321	321	0
ERC C-1489-2	107	0	0	322
Offsets Required (Includes distance offset ratio)	296	296	296	297
Amount Remaining	47	46	46	47
Credits reissued under ERC S-YYYY-2 and C-YYYY-2	47	46	46	47

SO _x	1 st Quarter (lb)	2 nd Quarter (lb)	3 rd Quarter (lb)	4 th Quarter (lb)
ERC N-1513-5	83	83	83	84
Offsets Required (Includes distance offset ratio)	77	77	77	77
Amount Remaining	6	6	6	7
Credits reissued under ERC N-YYYY-5	6	6	6	7

PM ₁₀	1 st Quarter (lb)	2 nd Quarter (lb)	3 rd Quarter (lb)	4 th Quarter (lb)
ERC C-1489-4	444	0	0	445
Offsets Required (Includes distance offset ratio)	204	205	205	205
Amount Remaining	36			35
Credits reissued under ERC C-YYYY-4	36			35

VOC	1 st Quarter (lb)	2 nd Quarter (lb)	3 rd Quarter (lb)	4 th Quarter (lb)
ERC S-5119-1	161	161	161	160
Offsets Required (Includes distance offset ratio)	148	148	148	149
Amount Remaining	13	13	13	12
Credits reissued under ERC S-YYYY-1	13	13	13	12

APPENDIX D
HRA Summary and AAQA

San Joaquin Valley Air Pollution Control District Risk Management Review and Ambient Air Quality Analysis

To: David Torii – Permit Services
 From: Kyle J Melching – Technical Services
 Date: September 19, 2019
 Facility Name: TRC CYPRESS GROUP LLC
 Location: HEAVY OIL WESTERN STATIONARY SOURCE,
 Application #(s): S-3088-31-0
 Project #: S-1193387

Summary

RMR

Units	Prioritization Score	Acute Hazard Index	Chronic Hazard Index	Maximum Individual Cancer Risk	T-BACT Required	Special Permit Requirements
31	0.00	N/A ¹	N/A ¹	N/A ¹	No	No
Project Totals	0.00	N/A ¹	N/A ¹	N/A ¹		
Facility Totals	0.05	0.00	0.00	0.00		

Notes:

- The project passed with a prioritization score less than 1; therefore, no further analysis was required.

AAQA

Pollutant	Air Quality Standard (State/Federal)				
	1 Hour	3 Hours	8 Hours	24 Hours	Annual
CO	Pass		Pass		
NO _x	Pass				Pass
SO _x	Pass	Pass		Pass	Pass
PM10				Pass	Pass
PM2.5				Pass	Pass

Notes:

- Results were taken from the attached AAQA Report.
- The criteria pollutants are below EPA's level of significance as found in 40 CFR Part 51.165 (b)(2) unless otherwise noted below.
- Modeled PM10 concentrations were below the District SIL for non-fugitive sources of 5 µg/m³ for the 24-hour average concentration and 1 µg/m³ for the annual concentration.
- Modeled PM2.5 concentrations were below the District SIL for non-fugitive sources of 1.2 µg/m³ for the 24-hour average concentration and 0.2 µg/m³ for the annual concentration.

Unit # 31-0

1. The unit must operate at least 200 meters from the property boundary

Project Description

Technical Services received a request on September 12, 2019 to perform a Risk Management Review (RMR) and Ambient Air Quality Analysis (AAQA) for the following:

- Unit -31-0: PORTABLE 8.2 MMBTU/HR NORTH AMERICAN HEATING MODEL MTHG-804 NATURAL GAS FIRED HEATER WITH AN INDUSTRIAL COMBUSTION MTHG-84 LOW NOX BURNER

RMR Report**Analysis**

The District performed an analysis pursuant to the District's Risk Management Policy for Permitting New and Modified Sources (APR 1905, May 28, 2015) to determine the possible cancer and non-cancer health impact to the nearest resident or worksite. This policy requires that an assessment be performed on a unit by unit basis, project basis, and on a facility-wide basis. If a preliminary prioritization analysis demonstrates that:

- A unit's prioritization score is less than the District's significance threshold and;
- The project's prioritization score is less than the District's significance threshold and;
- The facility's total prioritization score is less than the District's significance threshold

Then, generally no further analysis is required.

The District's significant prioritization score threshold is defined as being equal to or greater than 1.0. If a preliminary analysis demonstrates that either the unit(s) or the project's or the facility's total prioritization score is greater than the District threshold, a screening or a refined assessment is required

If a refined assessment is greater than one in a million but less than 20 in one million for carcinogenic impacts (Cancer Risk) and less than 1.0 for the Acute and Chronic hazard indices (Non-Carcinogenic) on a unit by unit basis, project basis and on a facility-wide basis the proposed application is considered less than significant. For unit's that exceed a cancer risk of 1 in one million, Toxic Best Available Control Technology (TBACT) must be implemented.

Toxic emissions for this project were calculated using the following methods:

- Toxic emissions for the Petroleum Boiler(s) or Process Heater(s) fueled by (Natural gas, Natural Gas and Refinery Gas, Refinery Gas, or Oil) were calculated using emission factors from December 2009 Emission Estimation Protocol for Petroleum Refineries by the American Petroleum Institute and Western States Petroleum Association.

These emissions were input into the San Joaquin Valley APCD's Hazard Assessment and Reporting Program (SHARP). In accordance with the District's Risk Management Policy, risks from the proposed unit's toxic emissions were prioritized using the procedure in the 2016 CAPCOA Facility Prioritization Guidelines. The prioritization score for this proposed unit was less than 1.0 (see RMR Summary Table). Therefore, no further analysis was necessary.

The following parameters were used for the review:

Source Process Rates						
Unit ID	Process ID	Process Material	Process Units	Hourly Process Rate	Annual Process Rate	Receptor Distance (m)
31	1	Natural Gas	mmscf	0.0082	71.83	450

AAQA Report

The District modeled the impact of the proposed project on the National Ambient Air Quality Standard (NAAQS) and/or California Ambient Air Quality Standard (CAAQS) in accordance with District Policy APR-1925 (Policy for District Rule 2201 AAQA Modeling) and EPA's Guideline for Air Quality Modeling (Appendix W of 40 CFR Part 51). The District uses a progressive three level approach to perform AAQAs. The first level (Level 1) uses a very conservative approach. If this analysis indicates a likely exceedance of an AAQS or Significant Impact Level (SIL), the analysis proceeds to the second level (Level 2) which implements a more refined approach. For the 1-hour NO₂ standard, there is also a third level that can be implemented if the Level 2 analysis indicates a likely exceedance of an AAQS or SIL.

The modeling analyses predicts the maximum air quality impacts using the appropriate emissions for each standard's averaging period. Required model inputs for a refined AAQA include background ambient air quality data, land characteristics, meteorological inputs, a receptor grid, and source parameters including emissions. These inputs are described in the sections that follow.

Ambient air concentrations of criteria pollutants are recorded at monitoring stations throughout the San Joaquin Valley. Monitoring stations may not measure all necessary pollutants, so background data may need to be collected from multiple sources. The following stations were used for this evaluation:

Monitoring Stations				
Pollutant	Station Name	County	City	Measurement Year
CO	Bakersfield-Muni	Kern	Bakersfield	2016
NOx	Bakersfield-Muni	Kern	Bakersfield	2016
PM10	Bakersfield-California Avenue	Kern	Bakersfield	2016
PM2.5	Bakersfield-California Avenue	Kern	Bakersfield	2016
SOx	Fresno - Garland	Fresno	Fresno	2016

Technical Services performed modeling for directly emitted criteria pollutants with the emission rates below:

Emission Rates (lbs/hour)						
Unit ID	Process	NOx	SOx	CO	PM10	PM2.5
31	1	0.08	0.03	0.30	0.06	0.06

Emission Rates (lbs/year)						
Unit ID	Process	NOx	SOx	CO	PM10	PM2.5
31	1	718	205	2,663	546	546

The AERMOD model was used to determine if emissions from the project would cause or contribute to an exceedance of any state of federal air quality standard. The parameters outlined below and meteorological data for 2004-2008 from Fellows (rural dispersion coefficient selected) were used for the analysis:

The following parameters were used for the review:

Point Source Parameters						
Unit ID	Unit Description	Release Height (m)	Temp. (°K)	Exit Velocity (m/sec)	Stack Diameter (m)	Vertical/Horizontal/Capped
31	NG Process Heater	2.44	450	3.00	0.61	Capped

Conclusion

RMR

The cumulative prioritization score for the facility, including this project, is less than 1.0. **In accordance with the District's Risk Management Policy, the project is approved without Toxic Best Available Control Technology (T-BACT).**

To ensure that human health risks will not exceed District allowable levels; the permit requirements listed on page 1 of this report must be included for this proposed unit.

These conclusions are based on the data provided by the applicant and the project engineer. Therefore, this analysis is valid only as long as the proposed data and parameters do not change.

AAQA

The emissions from the proposed equipment will not cause or contribute significantly to a violation of the State and National AAQS.

APPENDIX E
Compliance Certification


August 28, 2019

Mr. Leonard Scandura
Permit Services Manager
San Joaquin Valley Unified
Air Pollution Control District
34946 Flyover Ct.
Bakersfield, CA 93308

**Subject: Federal Major Modification Statewide Compliance Certification
S-3088 ATC Application – 8.2 MMbtu/Hr Heater**

Dear Mr. Scandura:

I hereby certify that all major Stationary Sources owned or operated by such person (or by any entity controlling, controlled by, or under common control with such person) in California, which are subject to emission limitations, are in compliance or on a schedule for compliance with all applicable emission limitations and standards.



Signature



Title

APPENDIX F
Draft ATC

San Joaquin Valley
Air Pollution Control District

AUTHORITY TO CONSTRUCT

ISSUANCE DATE: DRAFT
DRAFT

PERMIT NO: S-3088-31-0

LEGAL OWNER OR OPERATOR: TRC CYPRESS GROUP LLC
MAILING ADDRESS: PO BOX 227
TAFT, CA 93268

LOCATION: HEAVY OIL WESTERN STATIONARY SOURCE
CA

SECTION: 22 TOWNSHIP: 32S RANGE: 23E

EQUIPMENT DESCRIPTION:

PORTABLE 8.2 MMBTU/HR NORTH AMERICAN HEATING MODEL MTHG-804 NATURAL GAS FIRED HEATER WITH AN INDUSTRIAL COMBUSTION MTHG-84 LOW NOX BURNER

CONDITIONS

1. {1830} This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. {1831} Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Prior to operating equipment under this Authority to Construct, permittee shall surrender NOX emission reduction credits for the following quantity of emissions: 1st quarter - 296 lb, 2nd quarter - 296 lb, 3rd quarter - 296 lb, and 4th quarter - 297 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
4. ERC Certificate Numbers S-5117-2 and C-1489-2 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Arnaud Marjollet, Director of Permit Services

S-3088-31-0 Nov 14 2019 6:34AM -- TORRD Joint Inspection NOT Required

5. Prior to operating equipment under this Authority to Construct, permittee shall surrender SOX emission reduction credits for the following quantity of emissions: 1st quarter - 77 lb, 2nd quarter - 77 lb, 3rd quarter - 77 lb, and 4th quarter - 77 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
6. ERC Certificate Numbers N-1513-5 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Prior to operating equipment under this Authority to Construct, permittee shall surrender PM10 emission reduction credits for the following quantity of emissions: 1st quarter - 204 lb, 2nd quarter - 205 lb, 3rd quarter - 205 lb, and 4th quarter - 205 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
8. ERC Certificate Numbers C-1489-4 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Prior to operating equipment under this Authority to Construct, permittee shall surrender VOC emission reduction credits for the following quantity of emissions: 1st quarter - 148 lb, 2nd quarter - 148 lb, 3rd quarter - 148 lb, and 4th quarter - 149 lb. These amounts include the applicable offset ratio specified in Rule 2201 Section 4.8 (as amended 2/18/16) for the ERC specified below. [District Rule 2201] Federally Enforceable Through Title V Permit
10. ERC Certificate Numbers S-5119-1 (or a certificate split from this certificate) shall be used to supply the required offsets, unless a revised offsetting proposal is received and approved by the District, upon which this Authority to Construct shall be reissued, administratively specifying the new offsetting proposal. Original public noticing requirements, if any, shall be duplicated prior to reissuance of this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
11. This unit shall only operate in section 22, T32S, R23E. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
13. Particulate matter emissions shall not exceed 0.1 grain/dscf at operating conditions, nor 0.1 grain/dscf calculated to 12% CO₂, nor 10 lb/hr. [District Rules 4201, 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
14. The unit shall only be fired on PUC-quality natural gas with a maximum sulfur content of 1.0 gr S/100scf. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
15. Emission rates shall not exceed: NO_x (as NO_x): 9 ppmvd @ 3% O₂ or 0.011 lb-NO_x/MMBtu; PM₁₀: 0.0076 lb/MMBtu; CO: 50 ppmvd @ 3% O₂ or 0.037 lb-CO/MMBtu; or VOC: 0.0055 lb/MMBtu. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. Source testing to measure NO_x and CO emissions from this unit shall be conducted within 60 days of initial start-up. [District Rule 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing to measure combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

DRAFT

CONDITIONS CONTINUE ON NEXT PAGE

18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, NO_x (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; Stack gas oxygen (O₂) - EPA Method 3 or 3A or ARB Method 100; stack gas velocities - EPA Method 2; Stack gas moisture content - EPA Method 4; SO_x - EPA Method 6C or 8 or ARB Method 100; fuel gas sulfur as H₂S content - EPA Method 11 or 15; and fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2201, 4305, 4306, 4320] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. If the NO_x or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the applicable emission limit, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. All NO_x, CO, and O₂ emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NO_x, CO, and O₂ analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NO_x, CO and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the PTO, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081 and 4320] Federally Enforceable Through Title V Permit
30. Fuel sulfur content shall be determined using EPA Method 11, Method 15, ASTM method D3246 or or double GC for H₂S and mercaptans for sulfur content of gas. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
31. Records of sulfur content (gr S/100 scf) of combusted gas shall be maintained. [District Rules 1070, 2201, and 4320] Federally Enforceable Through Title V Permit
32. Permittee shall maintain accurate records of valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts used to satisfy the fuel sulfur content analysis of fuel combusted in process heater, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
33. All monitoring data, support information and records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT