

Potential Amendments to District Rule 4352 (Solid Fuel Fired Boilers, Steam Generators, and Process Heaters)


September 30, 2021

San Joaquin Valley Air Pollution Control District

webcast@valleyair.org

Valley's Air Quality Challenges


- Valley's challenges in meeting federal air quality standards unmatched due to unique geography, meteorology, and topography
- Valley designated as “Extreme” non-attainment of the 8-hour Ozone NAAQS; “Serious” non-attainment of federal standards for fine particulate matter (PM_{2.5})
 - Substantial emission reductions needed to achieve federal standards – need to go beyond already strict control limits
- Combustion is a significant source of NO_x emissions, primary precursor to ozone and PM_{2.5} formation
 - Comprehensive strategy in *2018 PM_{2.5} Plan* includes commitment to reduce emissions from mobile sources and a number of stationary source categories, including solid fuel fired boilers, steam generators, & process heaters



Health Benefits of Reducing Emissions in the Valley

- Exposure to PM_{2.5} and Ozone linked to a variety of health issues, including (but not limited to):
 - Asthma, chronic bronchitis, irregular heartbeat, and respiratory/cardiovascular hospitalizations
- District implements control measures to lower direct and precursor emissions throughout the Valley
 - NO_x emissions are key precursor to formation of ammonium nitrate, which is large portion of total PM_{2.5} during winter
 - NO_x is also chemical precursor to formation of Ozone
- Proposed rule amendment will support goal of attaining health-based federal ambient air quality standards for both PM_{2.5} and Ozone, and help to protect public health

Effects on health



Rule 4352 Overview

- Rule 4352 applies to any boiler, steam generator, or process heater fired on solid fuel
 - **Boilers** are external combustion equipment used to produce hot water or steam
 - **Process heaters** are combustion equipment that transfer heat from combustion gases to liquid or gas process streams
 - **Steam generators** are external combustion equipment that convert water to steam



Image credit: Prime Boiler Services Ltd.

Where do Solid Fuel Fired Boilers, Steam Generators, and Process Heaters Operate?


- Solid fuel fired boilers, steam generators, and process heaters are primarily used for power generation
- Units subject to Rule 4352 may be fired on a variety of solid fuels:
 - Municipal solid waste
 - Biomass
 - Coal
 - Petroleum coke
- Units currently operating in the Valley are fired on municipal solid waste or biomass




Image credit: Covanta Holding Corporation

NOx from Solid Fuel Fired Boilers, Process Heaters and Steam Generators in the Valley

All NOx Sources in the Valley
(Mobile, Stationary, & Area Sources)



NOx Emissions from Stationary Sources



■ Other NOx Sources ■ Solid Fuel Fired Boilers

■ Other Stationary Sources ■ Solid Fuel Fired Boilers

Current Rule 4352 Requirements

- District Rule 4352 adopted September 14, 1994, and amended in 1996, 2006, and 2011
- Rule requirements approved as meeting Most Stringent Measures (MSM) by U.S. EPA in July, 2020
- Rule 4352 establishes specific NO_x and CO limits for categories of solid fuel fired boiler/steam generator/process heater units
 - Municipal Solid Waste (165 ppmv NO_x at 12% CO₂, 400 ppmv CO at 3% O₂)
 - Biomass (90 ppmv NO_x at 3% O₂, 400 ppmv CO at 3% O₂)
 - NO_x and CO emission limits are based on a block 24-hour average
 - Monitoring and recordkeeping requirements
- NO_x from solid fuel fired boilers controlled by up to ~75% through current rule requirements

Current Controls In Use on Valley Solid Fuel Fired Boilers

Particulate Matter Control Technologies

- Electrostatic Precipitators (ESP)
 - Removes particulates from a gas stream by using electrical energy to charge particles either positively or negatively and attracted to collector plates
- Baghouses
 - Removes particulates from a gas stream by using fabric filters to collect and separate particles from industrial exhaust streams






Image credit:
Babcock & Wilcox,
2016

Current Controls In Use on Valley Solid Fuel Fired Boilers (cont'd)

NOx Control Technologies

- Selective Non-Catalytic Reduction (SNCR) Systems
 - Reduces NOx emissions through injection of ammonia type reagent into furnace/exhaust stream
- Selective Catalytic Reduction (SCR) Systems
 - Targeted to reduce NOx emissions through injection of ammonia type reagent into furnace in the presence of a catalyst



SOx Control Technologies

- Dry Sorbent Injection Systems
 - Powdered alkaline sorbent, such as hydrated lime, is injected into exhaust duct and reacts with acid gases to reduce SOx
- Wet Scrubber Systems
 - Wet solution containing a reagent, chemical reactions reduce emissions of SOx






Image credit:
Babcock & Wilcox,
2016

Evaluation of Additional Emission Reduction Opportunities

- Per *2018 PM_{2.5} Plan*, District pursuing the following potential opportunities to reduce NO_x emissions for municipal waste-fired units to the extent that additional NO_x controls are technologically and economically feasible:
 - Lowering NO_x limit for units fired on Municipal Solid Waste from 165 ppmv @ 12% CO₂ to 110 ppmv @ 12% CO₂ over 24-hr period and 90 ppmv @ 12% CO₂ over annual period
 - Evaluating feasibility of even lower NO_x limits
- District also evaluating feasibility of lower NO_x emission limits for other solid fuel fired units

Control Technologies Under Evaluation

- Selective Non-Catalytic Reduction
- Selective Catalytic Reduction
- Gore De-NO_x Filter Bags
- Covanta LN™
- Combination of controls




Cost Assessment of Further Control Technology

- Sources for cost assessments
 - Actual costs provided by facilities, engineering estimates, and control technology vendors & manufacturers
 - Various sources for the cost of electricity, fuel, and replacement parts
 - Cost factors from EPA's Office of Air Quality Planning and Standards
- Staff held virtual meetings with facilities, vendors, manufacturers, and other stakeholders to gather cost figures

Selective Catalytic Reduction

- Selective Catalytic Reduction (SCR)
 - Reduces NO_x emissions through injection of ammonia type reagent
 - Total Capital Cost: \$10M - \$34M
 - Operation & Maintenance Cost: \$1.7M - \$2M annually



Gore De-NOx Filtration System

- Gore De-NOx Filtration System
 - Reduces NOx emissions through use of filter bags with ammonia catalyst
 - Total Capital Cost: \$5.5M - \$7.8M
 - Operation & Maintenance Cost: \$900K - \$6.6M annually




Image credit: W. L. Gore & Associates, Inc.

Covanta LN™

- Covanta LN™
 - Proprietary staged combustion air system for municipal waste combustors
 - Achieves further NO_x control
 - Total Capital Cost: ~\$5.5M
 - Operation & Maintenance Cost: ~\$190K





Image credit: Covanta Holding Corporation

Cost-Effectiveness (CE) Analysis

- Cost-Effectiveness is cost (capital and annual) over emission reductions for the life of the equipment (\$/ton)
- Two major cost elements
 - Capital Costs (Equipment, Infrastructure, Engineering, Installation, Tax, Freight)
 - Annual Costs (Operation & Maintenance)
- Emission reductions based on current emission levels (baseline) to proposed emission limit



Proposed Amendments to Rule 4352: Requirements for Municipal Solid Waste Facilities

- Proposing to lower existing NO_x limits
 - Current NO_x limit 165 ppm with SNCR as current control technology
 - Proposed lower NO_x limit: 90 ppmv
- Proposing to establish PM₁₀ emission limits within Rule 4352
 - Permit limits at 0.053 lbs/MMBtu
 - Considering limit of 0.04 lbs/MMBtu with baghouse as control system
- Proposing to establish SO_x emission limits within Rule 4352
 - Permit limits at 0.09 lbs/MMBtu
 - Considering limit of 0.05 lbs/MMBtu with dry sorbent injection system as control
- Full compliance proposed to be required by January 1, 2024

Proposed Amendments to Rule 4352: Further Requirements for Biomass Facilities

- Proposing to lower existing NO_x limits
 - Current NO_x rule limits for Biomass: 90 ppmv NO_x
 - Proposed lower NO_x limit: 65 ppmv NO_x
- Current PM₁₀ limits for Biomass facilities established on facility permits
 - Considering establishing new PM₁₀ limits within Rule 4352, under evaluation
- Current SO_x limits for Biomass facilities established on facility permits
 - Considering establishing new SO_x limits within Rule 4352, under evaluation





Image credit: Jumo, 2021

Next Steps

- Requesting comment on rule concepts by October 14, 2021
 - Draft rule to be published in coming weeks, with associated comment period
- Continued analysis of costs, cost-effectiveness of various controls, and feasibility of control requirements
- Socioeconomic Impact Analysis underway by third-party consultant to evaluate economic impacts of proposed amendments
 - Characterization of the Valley's economic climate
 - Evaluation of economic impacts
 - Socioeconomic Impact Analysis report
 - Results of analysis will be included with proposed rule packages
- Ongoing public engagement process

Public Engagement Process for Rule 4352 Amendment



Public Participation and Comment Invited throughout Process

Contact

Contact: Ross Badertscher

Mail: San Joaquin Valley APCD
1990 E. Gettysburg Ave
Fresno, CA 93726

Phone: (559) 230-5812

Fax: (559) 230-6064

Email: ross.badertscher@valleyair.org

Listserv: [http://lists.valleyair.org/mailman/listinfo/
boilers_and_heaters](http://lists.valleyair.org/mailman/listinfo/boilers_and_heaters)

Comments/Questions

webcast@valleyair.org