

**San Joaquin Valley
Unified Air Pollution Control District**

Best Performance Standard (BPS) x.x.xx

Class	Gasoline Dispensing Facilities (GDFs)
Category	GDFs with Underground Storage Tanks (USTs) and Phase II EVR Vapor Recovery System
Best Performance Standard	ARB-certified non-combustion based Phase II vapor recovery systems
Percentage Reduction in GHG Emissions Relative to Baseline Emissions	Greater than 75%

District Project Number	C-1100389
Prepared by	Sajjad Ahmad (Air Quality Engineer)
Reviewed by	Jim Swaney, P.E. (Permit Services Manager), Arnaud Marjollet (Permit Services Manager), Sheraz Gill (Supervising Air Quality Engineer), Daniel Barber, Ph.D. (Supervising Air Quality Specialist)
Approved by	Dave Warner (Director of Permit Services)

Initial Public Notice Date	March 4, 2010
Final Public Notice Date	April 8, 2010
Determination Effective Date	