

**San Joaquin Valley Air Pollution Control District
SOUTHERN REGION HEARING BOARD MEETING**

Meeting held via Zoom Webinar

ACTION SUMMARY MINUTES

Wednesday, April 14, 2021

1. Call Meeting to Order

The Chair, John Stovall called the meeting to order at 10:02 a.m.

2. Roll Call

John Stovall – Attorney	Present
Nancy Dunn– Public	Present
Chang Na– Medical	Present
Blaine Neptune– Engineer	Present

Staff Present via Zoom:

Southern Region (Bakersfield): Dave Born; Senior Air Quality Inspector

Central Region (Fresno): Jessi Fierro, Assistant District Counsel; Chris Kalashian, Air Quality Specialist II; Patrick Houlihan, Senior Air Quality Specialist II; Clay Bishop, Supervising Air Quality Specialist; See Thao, Operations & Support Supervisor; Ariana Orozco; Operations & Support Supervisor

3. Approval of Consent Calendar (Items 9-11)

These items are routine in nature and are usually approved by a single vote. Prior to action by the Hearing Board, the public will be given the opportunity to comment on any consent item.

9. Approve Minutes of Thursday, March 11, 2021

10. Emergency Variance Report

11. Next Scheduled Meeting

The next scheduled meeting is on May 12, 2021. The meeting will be held via Zoom Webinar.

Public Comments: None

Moved:	Dr. Na
Seconded:	Dunn
Ayes:	Dunn, Stovall, Dr. Na, Neptune
Nays:	None

Motion unanimously carried to approve Consent Calendar Items 9-11

4. Public Hearing

The Vice Chair, John Stovall swore in all those present to testify for all matters.

<u>Docket No.</u>	<u>Type</u>	<u>Company Name</u>
A. S-21-10S	Short	Sunrise Power Company LLC 12857 Sunrise Power Road Fellows, CA 93224

Petitioner: George Piantka and Scott Seipel

Mr. Kalashian presented the staff report.

Sunrise Power Company, LLC has requested a short variance from the applicable requirements of District Rules 1080, 2070, 2201, 2520, 4001, and 4703, in addition to the applicable conditions of the subject permits. The requested variance would be effective for a 21 day non-consecutive day period to occur sometime between May 19, 2021, and August 16, 2021, inclusive. If granted, the variance would allow continued operation of the subject cogeneration turbine units without an operational CEMS while new components and software are installed and the CEMS is re-certified.

Public Comment: None

Moved: Dr. Na
Seconded: Dunn
Ayes: Dunn, Stovall, Dr. Na, Neptune
Nays: None

Motion unanimously carried to approve Docket No. S-21-10S

5. Public Comments: None

6. Hearing Board Member Comments: None

7. New Business: None

8. Adjournment: The Chair adjourned the meeting at 10:30 am.