

**NOTICE OF FINAL ACTION
FOR THE ISSUANCE OF
AUTHORITY TO CONSTRUCT PERMITS**

NOTICE IS HEREBY GIVEN that the Air Pollution Control Officer has issued the Authority to Construct permits to Mercy Hospital for the installation of a 10.206 MMBtu/hr natural gas-fired boiler equipped with a Cleaver-Brooks ultra-low NOx burner that will provide heated water to the building and the installation of a 2,218 horsepower Tier 2 certified diesel-fired emergency standby internal combustion (IC) engine to provide emergency power in the event of an electrical outage, at 400 Old River Road, Bakersfield, CA 93311.

No comments were received following the District's preliminary decision on this project.

The application review for Project # S-1213068 is available for public inspection at http://www.valleyair.org/notices/public_notices_idx.htm, the SAN JOAQUIN VALLEY UNIFIED AIR POLLUTION CONTROL DISTRICT, 1990 EAST GETTYSBURG AVENUE, FRESNO, CA 93726, and at any other District office. For additional information, please contact the District at (559) 230-6000.